

SOMERSET THERAPEUTICS LIMITED

Ampoule Washing Area

${\bf Excursion Test Report}$

Date Time	ems_svp1_amp_trh_03_rh	ems_svp1_amp_trh_03_temp	ems_svp1_amp_dp_15_dp
Excursion Low Limit	5	6	3
Excursion High Limit	82	82	82
08-06-2022 16:00:00	70.6	19.1	83
08-06-2022 18:30:00	71.9	19.1	84
09-06-2022 21:30:00	59.3	23.8	88
09-06-2022 22:00:00	58.4	23.1	86
09-06-2022 22:30:00	60.2	22.1	85
09-06-2022 23:00:00	62.7	21.4	87
09-06-2022 23:30:00	64.8	20.7	86
10-06-2022 00:00:00	68.8	20.4	84
10-06-2022 08:30:00	69.0	19.4	83
10-06-2022 14:00:00	68.1	18.9	83
11-06-2022 04:00:00	69.6	18.8	83
11-06-2022 05:00:00	69.7	18.8	83
11-06-2022 05:30:00	69.7	18.8	83
11-06-2022 06:00:00	69.0	18.7	83
11-06-2022 10:00:00	70.1	18.9	83

End Of Report: From 08-06-2022 12:00:24 To 11-06-2022 12:00:24

ACTIVITY	NAME	SIGNATURE AND DATE
REVIEWED BY USER		
REVIEWED BY QA		