

# SOMERSET THERAPEUTICS LIMITED

### DATA REPORT - SVP1 AND AMPOULE LINE EMS

### WASHING AND STERILIZATION AREA

Date Time	Temperature	RH	Diffrential Pressure	Diffrential Pressure	Diffrential Pressure
DD-MM-YYYY HH:MM:SS	Washing and Sterilization Area (NMT 30°C)	Washing and Sterilization Area (NMT 80%)	Washing and Sterilization Area w.r.t Unit Preparation Room (NLT 6 Pa)	Washing and Sterilization Area w.r.t Ampoule Decartoning Room (NLT 12 Pa)	Washing and Sterilization Area w.r.t Injectable main corridor (NLT 12 Pa)
12-07-2022 13:40:00	18.3	80	47	22	43
12-07-2022 13:41:00	18.3	80.2	46	22	45
12-07-2022 13:42:00	18.3	80.4	47	24	47
12-07-2022 13:43:00	18.3	80.5	47	21	45
12-07-2022 13:44:00	18.3	80.5	47	22	43
12-07-2022 13:45:00	18.4	80.6	43	21	44
12-07-2022 13:46:00	18.4	80.7	46	23	45
12-07-2022 13:47:00	18.4	80.8	46	23	43
12-07-2022 13:48:00	18.4	80.8	47	23	47
12-07-2022 13:49:00	18.4	80.7	46	23	47
12-07-2022 13:50:00	18.4	80.6	47	23	45
12-07-2022 13:51:00	18.5	80.4	47	23	46
12-07-2022 13:52:00	18.4	80.4	47	23	47
12-07-2022 13:53:00	18.5	80.4	47	22	45
12-07-2022 13:54:00	18.5	80.3	47	24	48
12-07-2022 13:55:00	18.5	80.3	47	23	46
12-07-2022 13:56:00	18.5	80.3	47	24	46
12-07-2022 13:57:00	18.5	80.3	47	23	47
12-07-2022 13:58:00	18.5	80.4	48	23	47
12-07-2022 13:59:00	18.5	80.4	48	21	43
12-07-2022 14:00:00	18.5	80.4	47	23	46
12-07-2022 14:01:00	18.6	80.3	47	23	45
12-07-2022 14:02:00	18.6	80.2	46	23	45
12-07-2022 14:03:00	18.5	80.1	47	24	46

ACTIVITY	NAME	SIGNATURE AND DATE
REVIEWED BY USER		
REVIEWED BY QA		



# SOMERSET THERAPEUTICS LIMITED

### DATA REPORT - SVP1 AND AMPOULE LINE EMS

### WASHING AND STERILIZATION AREA

	Date Time	Temperature	RH	Diffrential Pressure	Diffrential Pressure	Diffrential Pressure
	DD-MM-YYYY HH:MM:SS	Washing and Sterilization Area (NMT 30°C)	Washing and Sterilization Area (NMT 80%)	Washing and Sterilization Area w.r.t Unit Preparation Room (NLT 6 Pa)	Washing and Sterilization Area w.r.t Ampoule Decartoning Room (NLT 12 Pa)	Washing and Sterilization Area w.r.t Injectable main corridor (NLT 12 Pa)
	12-07-2022 14:04:00	18.5	80.1	46	23	45
L	12-07-2022 14:05:00	18.5	80.1	47	23	47
	12-07-2022 14:06:00	18.5	80.1	48	23	46
	12-07-2022 14:07:00	18.5	80	47	23	46
	12-07-2022 14:08:00	18.5	80	47	23	47
	12-07-2022 14:09:00	18.5	80	47	23	46
	12-07-2022 14:10:00	18.5	80	46	23	45
	12-07-2022 14:11:00	18.5	80.1	47	21	45
	12-07-2022 14:12:00	18.5	80.1	47	22	45
	12-07-2022 14:13:00	18.5	80.1	45	19	42
	12-07-2022 14:14:00	18.5	79.9	47	23	40
	12-07-2022 14:15:00	18.5	79.7	46	22	41
	12-07-2022 14:16:00	18.5	79.5	46	22	43
	12-07-2022 14:17:00	18.5	79.5	46	22	44
	12-07-2022 14:18:00	18.5	79.4	46	21	39
	12-07-2022 14:19:00	18.5	79.2	46	19	38
	12-07-2022 14:20:00	18.5	79.1	46	21	44
	12-07-2022 14:21:00	18.5	79	46	22	44
	12-07-2022 14:22:00	18.5	78.9	47	22	45
Ī	12-07-2022 14:23:00	18.5	78.8	47	22	45
Ī	12-07-2022 14:24:00	18.5	78.7	47	22	43
	12-07-2022 14:25:00	18.5	78.7	47	20	44
	12-07-2022 14:26:00	18.5	78.6	47	22	41
	12-07-2022 14:27:00	18.4	78.6	46	22	43

ACTIVITY	NAME	SIGNATURE AND DATE
REVIEWED BY USER		
REVIEWED BY QA		



## SOMERSET THERAPEUTICS LIMITED

#### DATA REPORT - SVP1 AND AMPOULE LINE EMS

#### WASHING AND STERILIZATION AREA

Date Time	Temperature	RH	Diffrential Pressure	Diffrential Pressure	Diffrential Pressure
DD-MM-YYYY HH:MM:SS	Washing and Sterilization Area (NMT 30°C)	Washing and Sterilization Area (NMT 80%)	Washing and Sterilization Area w.r.t Unit Preparation Room (NLT 6 Pa)	Washing and Sterilization Area w.r.t Ampoule Decartoning Room (NLT 12 Pa)	Washing and Sterilization Area w.r.t Injectable main corridor (NLT 12 Pa)
12-07-2022 14:28:00	18.4	78.6	48	22	44
12-07-2022 14:29:00	18.4	78.6	47	23	46
12-07-2022 14:30:00	18.4	78.7	47	23	47
Min Value	18.3	78.6	43	19	38
Max Value	18.6	80.8	48	24	48

End Of Report: From 12-07-2022 13:40:32 To 12-07-2022 14:30:32

ACTIVITY	NAME	SIGNATURE AND DATE
REVIEWED BY USER		
REVIEWED BY QA		