



Environmental Monitoring System

DATA REPORT

TS LOADING & UNLOADING-SPARE ROOM

Date Time	TS LOADING ROOM	TS UNLOADING ROOM	QUARENTINE ROOM	MEDIA FILLED UNIT IN INCUBATION	MATERIAL TO EXIT	MATERIAL TO EXIT wrt CORRIDOR	DECORTNING ROOM	DECORTNING ROOM wrt CORRIDOR
Date Time	°C TEMP	°C TEMP	°C TEMP	°C TEMP	°C TEMP	DP Pa	°C TEMP	DP Pa
Alarm Low Limit	17.00	17.00	17.00	10.00	22.00	6	22.00	0
Set Value								
Alarm High Limit	45.00	30.00	40.00	36.00	25.00	15	25.00	0
04-11-2021 00:00	23.39	19.64	22.71	25.18	24.81	0	23.78	-9006
04-11-2021 00:01	23.39	19.64	22.71	25.17	24.82	3	23.78	-9006
04-11-2021 00:02	23.40	19.65	22.70	25.19	24.81	3	23.79	-9006
04-11-2021 00:03	23.39	19.63	22.68	25.17	24.82	0	23.78	-9006
04-11-2021 00:04	23.39	19.64	22.67	25.17	24.83	3	23.78	-9006
04-11-2021 00:05	23.40	19.65	22.64	25.17	24.83	3	23.78	-9006
04-11-2021 00:06	23.41	19.64	22.64	25.16	24.82	3	23.78	-9006
04-11-2021 00:07	23.38	19.65	22.63	25.15	24.81	4	23.78	-9006
04-11-2021 00:08	23.39	19.64	22.62	25.15	24.81	3	23.77	-9006
04-11-2021 00:09	23.39	19.63	22.62	25.12	24.82	0	23.77	-9006
04-11-2021 00:10	23.38	19.64	22.61	25.12	24.81	3	23.78	-9006
04-11-2021 00:11	23.40	19.63	22.61	25.12	24.82	4	23.77	-9006
04-11-2021 00:12	23.40	19.64	22.61	25.13	24.81	4	23.78	-9006
04-11-2021 00:13	23.40	19.64	22.60	25.14	24.82	3	23.77	-9006
04-11-2021 00:14	23.40	19.63	22.59	25.15	24.80	3	23.77	-9006
04-11-2021 00:15	23.41	19.62	22.59	25.16	24.82	3	23.77	-9006
04-11-2021 00:16	23.40	19.62	22.58	25.13	24.82	0	23.76	-9006
04-11-2021 00:17	23.41	19.62	22.59	25.12	24.81	3	23.77	-9006
04-11-2021 00:18	23.40	19.63	22.60	25.13	24.80	4	23.77	-9006
04-11-2021 00:19	23.41	19.63	22.58	25.14	24.81	4	23.76	-9006
04-11-2021 00:20	23.39	19.65	22.59	25.14	24.80	3	23.76	-9006
04-11-2021 00:21	23.40	19.63	22.62	25.15	24.81	4	23.77	-9006
04-11-2021 00:22	23.42	19.62	22.59	25.13	24.80	3	23.77	-9006
04-11-2021 00:23	23.39	19.64	22.59	25.13	24.80	4	23.77	-9006
04-11-2021 00:24	23.39	19.64	22.59	25.14	24.80	4	23.77	-9006



Environmental Monitoring System

DATA REPORT

TS LOADING & UNLOADING-SPARE ROOM

Date Time	TS LOADING ROOM	TS UNLOADING ROOM	QUARENTINE ROOM	MEDIA FILLED UNIT IN INCUBATION	MATERIAL TO EXIT	MATERIAL TO EXIT wrt CORRIDOR	DECORTNING ROOM	DECORTNING ROOM wrt CORRIDOR
Date Time	°C TEMP	°C TEMP	°C TEMP	°C TEMP	°C TEMP	DP Pa	°C TEMP	DP Pa
04-11-2021 00:25	23.39	19.63	22.57	25.14	24.78	4	23.76	-9006
04-11-2021 00:26	23.40	19.64	22.57	25.14	24.80	4	23.76	-9006
04-11-2021 00:27	23.38	19.64	22.57	25.12	24.80	3	23.76	-9006
04-11-2021 00:28	23.37	19.63	22.57	25.09	24.80	3	23.76	-9006
04-11-2021 00:29	23.39	19.62	22.58	25.11	24.80	3	23.75	-9006
04-11-2021 00:30	23.38	19.62	22.58	25.13	24.79	3	23.75	-9006
04-11-2021 00:31	23.39	19.64	22.58	25.13	24.81	0	23.76	-9006
04-11-2021 00:32	23.38	19.63	22.58	25.13	24.79	3	23.74	-9006
04-11-2021 00:33	23.37	19.63	22.58	25.11	24.77	4	23.74	-9006
04-11-2021 00:34	23.38	19.64	22.57	25.10	24.77	3	23.75	-9006
04-11-2021 00:35	23.39	19.63	22.57	25.09	24.78	3	23.75	-9006
04-11-2021 00:36	23.38	19.62	22.57	25.12	24.77	3	23.74	-9006
04-11-2021 00:37	23.39	19.63	22.55	25.12	24.76	3	23.75	-9006
04-11-2021 00:38	23.36	19.62	22.56	25.12	24.76	0	23.75	-9006
04-11-2021 00:39	23.36	19.61	22.55	25.12	24.76	3	23.74	-9006
04-11-2021 00:40	23.37	19.62	22.55	25.13	24.77	0	23.74	-9006
04-11-2021 00:41	23.36	19.63	22.56	25.11	24.76	3	23.74	-9006
04-11-2021 00:42	23.36	19.62	22.56	25.08	24.77	3	23.73	-9006
04-11-2021 00:43	23.36	19.61	22.57	25.10	24.76	3	23.74	-9006
04-11-2021 00:44	23.36	19.61	22.56	25.09	24.79	3	23.74	-9006
04-11-2021 00:45	23.36	19.61	22.55	25.07	24.78	3	23.72	-9006
04-11-2021 00:46	23.37	19.60	22.55	25.05	24.77	4	23.74	-9006
04-11-2021 00:47	23.38	19.63	22.54	25.07	24.77	3	23.74	-9006
04-11-2021 00:48	23.37	19.63	22.54	25.06	24.78	0	23.73	-9006
04-11-2021 00:49	23.39	19.63	22.54	25.07	24.80	4	23.74	-9006
04-11-2021 00:50	23.39	19.61	22.53	25.06	24.79	3	23.73	-9006
04-11-2021 00:51	23.38	19.62	22.53	25.06	24.79	3	23.72	-9006
04-11-2021 00:52	23.38	19.61	22.53	25.05	24.77	3	23.72	-9006



Environmental Monitoring System

DATA REPORT

TS LOADING & UNLOADING-SPARE ROOM

Date Time	TS LOADING ROOM	TS UNLOADING ROOM	QUARENTINE ROOM	MEDIA FILLED UNIT IN INCUBATION	MATERIAL TO EXIT	MATERIAL TO EXIT wrt CORRIDOR	DECORTNING ROOM	DECORTNING ROOM wrt CORRIDOR
Date Time	°C TEMP	°C TEMP	°C TEMP	°C TEMP	°C TEMP	DP Pa	°C TEMP	DP Pa
04-11-2021 00:53	23.36	19.62	22.52	25.04	24.77	4	23.73	-9006
04-11-2021 00:54	23.36	19.61	22.52	25.06	24.77	3	23.73	-9006
04-11-2021 00:55	23.36	19.61	22.51	25.06	24.77	3	23.72	-9006
04-11-2021 00:56	23.36	19.62	22.53	25.05	24.78	3	23.72	-9006
04-11-2021 00:57	23.36	19.62	22.51	25.06	24.77	4	23.72	-9006
04-11-2021 00:58	23.38	19.61	22.51	25.06	24.78	3	23.72	-9006
04-11-2021 00:59	23.37	19.60	22.50	25.06	24.78	3	23.72	-9006
04-11-2021 01:00	23.37	19.61	22.49	25.05	24.78	3	23.72	-9006
04-11-2021 01:01	23.36	19.62	22.49	25.07	24.79	3	23.72	-9006
04-11-2021 01:02	23.34	19.62	22.49	25.07	24.78	0	23.72	-9006
04-11-2021 01:03	23.35	19.61	22.50	25.06	24.78	3	23.72	-9006
04-11-2021 01:04	23.32	19.61	22.49	25.07	24.79	0	23.72	-9006
04-11-2021 01:05	23.34	19.61	22.49	25.08	24.79	3	23.71	-9006
04-11-2021 01:06	23.33	19.62	22.49	25.07	24.79	3	23.70	-9006
04-11-2021 01:07	23.33	19.62	22.49	25.06	24.79	3	23.71	-9006
04-11-2021 01:08	23.32	19.63	22.50	25.05	24.80	4	23.71	-9006
04-11-2021 01:09	23.33	19.62	22.49	25.05	24.80	3	23.71	-9006
04-11-2021 01:10	23.34	19.62	22.50	25.04	24.80	4	23.71	-9006
04-11-2021 01:11	23.33	19.62	22.50	25.05	24.79	3	23.70	-9006
04-11-2021 01:12	23.33	19.60	22.50	25.04	24.79	0	23.71	-9006
04-11-2021 01:13	23.33	19.60	22.50	25.05	24.79	4	23.70	-9006
04-11-2021 01:14	23.33	19.60	22.50	25.06	24.80	3	23.70	-9006
04-11-2021 01:15	23.32	19.60	22.51	25.07	24.80	3	23.71	-9006
04-11-2021 01:16	23.30	19.60	22.50	25.05	24.80	4	23.71	-9006
04-11-2021 01:17	23.32	19.61	22.52	25.06	24.80	3	23.70	-9006
04-11-2021 01:18	23.30	19.61	22.52	25.06	24.81	0	23.69	-9006
04-11-2021 01:19	23.30	19.61	22.52	25.04	24.80	3	23.70	-9006
04-11-2021 01:20	23.29	19.61	22.52	25.05	24.81	0	23.69	-9006



Environmental Monitoring System

DATA REPORT

TS LOADING & UNLOADING-SPARE ROOM

Date Time	TS LOADING ROOM	TS UNLOADING ROOM	QUARENTINE ROOM	MEDIA FILLED UNIT IN INCUBATION	MATERIAL TO EXIT	MATERIAL TO EXIT wrt CORRIDOR	DECORTNING ROOM	DECORTNING ROOM wrt CORRIDOR
Date Time	°C TEMP	°C TEMP	°C TEMP	°C TEMP	°C TEMP	DP Pa	°C TEMP	DP Pa
04-11-2021 01:21	23.28	19.60	22.52	25.04	24.80	0	23.70	-9006
04-11-2021 01:22	23.29	19.59	22.51	25.04	24.81	3	23.69	-9006
04-11-2021 01:23	23.29	19.60	22.52	25.02	24.79	4	23.69	-9006
04-11-2021 01:24	23.30	19.58	22.52	25.03	24.79	4	23.70	-9006
04-11-2021 01:25	23.28	19.57	22.51	25.05	24.79	4	23.69	-9006
04-11-2021 01:26	23.29	19.56	22.53	25.04	24.78	3	23.69	-9006
04-11-2021 01:27	23.28	19.54	22.53	25.04	24.79	3	23.67	-9006
04-11-2021 01:28	23.29	19.54	22.52	25.02	24.78	0	23.68	-9006
04-11-2021 01:29	23.28	19.54	22.51	25.02	24.79	3	23.69	-9006
04-11-2021 01:30	23.28	19.54	22.51	25.02	24.78	3	23.68	-9006
04-11-2021 01:31	23.28	19.53	22.50	25.03	24.78	3	23.68	-9006
04-11-2021 01:32	23.27	19.53	22.49	25.04	24.77	0	23.67	-9006
04-11-2021 01:33	23.25	19.52	22.49	25.05	24.76	4	23.69	-9006
04-11-2021 01:34	23.26	19.51	22.48	25.05	24.78	3	23.68	-9006
04-11-2021 01:35	23.29	19.50	22.48	25.04	24.77	3	23.68	-9006
04-11-2021 01:36	23.25	19.51	22.47	25.04	24.78	4	23.66	-9006
04-11-2021 01:37	23.25	19.49	22.47	25.02	24.78	0	23.68	-9006
04-11-2021 01:38	23.25	19.50	22.47	25.02	24.78	3	23.67	-9006
04-11-2021 01:39	23.26	19.49	22.48	25.01	24.76	3	23.67	-9006
04-11-2021 01:40	23.24	19.49	22.47	25.01	24.76	0	23.67	-9006
04-11-2021 01:41	23.28	19.47	22.46	25.02	24.76	3	23.66	-9006
04-11-2021 01:42	23.25	19.47	22.46	25.00	24.77	3	23.67	-9006
04-11-2021 01:43	23.24	19.47	22.46	25.00	24.76	3	23.67	-9006
04-11-2021 01:44	23.23	19.46	22.48	25.01	24.76	0	23.67	-9006
04-11-2021 01:45	23.24	19.46	22.45	25.00	24.76	3	23.67	-9006
04-11-2021 01:46	23.23	19.46	22.46	24.99	24.75	3	23.67	-9006
04-11-2021 01:47	23.24	19.47	22.45	25.01	24.76	3	23.67	-9006
04-11-2021 01:48	23.23	19.46	22.47	24.99	24.75	3	23.67	-9006



Environmental Monitoring System

DATA REPORT

TS LOADING & UNLOADING-SPARE ROOM

Date Time	TS LOADING ROOM	TS UNLOADING ROOM	QUARENTINE ROOM	MEDIA FILLED UNIT IN INCUBATION	MATERIAL TO EXIT	MATERIAL TO EXIT wrt CORRIDOR	DECORTNING ROOM	DECORTNING ROOM wrt CORRIDOR
Date Time	°C TEMP	°C TEMP	°C TEMP	°C TEMP	°C TEMP	DP Pa	°C TEMP	DP Pa
04-11-2021 01:49	23.24	19.45	22.45	25.00	24.75	3	23.66	-9006
04-11-2021 01:50	23.23	19.44	22.45	24.99	24.76	3	23.67	-9006
04-11-2021 01:51	23.23	19.43	22.44	24.99	24.75	3	23.66	-9006
04-11-2021 01:52	23.21	19.43	22.44	25.01	24.76	3	23.66	-9006
04-11-2021 01:53	23.22	19.43	22.44	24.99	24.75	4	23.67	-9006
04-11-2021 01:54	23.21	19.43	22.45	25.00	24.76	0	23.66	-9006
04-11-2021 01:55	23.20	19.43	22.46	24.98	24.76	3	23.66	-9006
04-11-2021 01:56	23.20	19.42	22.46	24.98	24.77	4	23.66	-9006
04-11-2021 01:57	23.20	19.41	22.45	24.97	24.76	3	23.65	-9006
04-11-2021 01:58	23.21	19.41	22.45	24.99	24.77	4	23.66	-9006
04-11-2021 01:59	23.22	19.40	22.44	24.99	24.76	3	23.65	-9006
04-11-2021 02:00	23.22	19.40	22.44	25.01	24.77	4	23.66	-9006
04-11-2021 02:01	23.21	19.40	22.44	25.01	24.76	0	23.65	-9006
04-11-2021 02:02	23.21	19.40	22.46	25.02	24.77	3	23.65	-9006
04-11-2021 02:03	23.21	19.40	22.46	25.02	24.77	4	23.65	-9006
04-11-2021 02:04	23.20	19.40	22.49	25.02	24.76	0	23.65	-9006
04-11-2021 02:05	23.21	19.40	22.49	25.00	24.77	3	23.65	-9006
04-11-2021 02:06	23.21	19.39	22.50	25.03	24.77	3	23.66	-9006
04-11-2021 02:07	23.20	19.37	22.51	25.01	24.77	4	23.66	-9006
04-11-2021 02:08	23.20	19.39	22.51	25.02	24.77	3	23.65	-9006
04-11-2021 02:09	23.21	19.39	22.50	25.01	24.76	3	23.65	-9006
04-11-2021 02:10	23.20	19.39	22.52	24.99	24.77	4	23.65	-9006
04-11-2021 02:11	23.20	19.40	22.51	24.98	24.79	4	23.65	-9006
04-11-2021 02:12	23.20	19.38	22.52	25.02	24.78	4	23.65	-9006
04-11-2021 02:13	23.19	19.38	22.54	25.04	24.77	4	23.64	-9006
04-11-2021 02:14	23.19	19.37	22.54	25.03	24.77	4	23.65	-9006
04-11-2021 02:15	23.19	19.37	22.55	25.03	24.77	3	23.64	-9006
04-11-2021 02:16	23.19	19.37	22.54	25.02	24.77	3	23.64	-9006



Environmental Monitoring System

DATA REPORT

TS LOADING & UNLOADING-SPARE ROOM

Date Time	TS LOADING ROOM	TS UNLOADING ROOM	QUARENTINE ROOM	MEDIA FILLED UNIT IN INCUBATION	MATERIAL TO EXIT	MATERIAL TO EXIT wrt CORRIDOR	DECORTNING ROOM	DECORTNING ROOM wrt CORRIDOR
Date Time	°C TEMP	°C TEMP	°C TEMP	°C TEMP	°C TEMP	DP Pa	°C TEMP	DP Pa
04-11-2021 02:17	23.18	19.37	22.55	25.04	24.78	3	23.65	-9006
04-11-2021 02:18	23.19	19.37	22.55	25.04	24.77	4	23.64	-9006
04-11-2021 02:19	23.20	19.37	22.55	25.03	24.78	4	23.64	-9006
04-11-2021 02:20	23.18	19.36	22.55	25.04	24.78	3	23.64	-9006
04-11-2021 02:21	23.21	19.35	22.55	25.04	24.77	3	23.64	-9006
04-11-2021 02:22	23.18	19.34	22.55	25.02	24.77	4	23.65	-9006
04-11-2021 02:23	23.19	19.35	22.55	25.03	24.78	3	23.64	-9006
04-11-2021 02:24	23.20	19.35	22.54	25.03	24.79	3	23.63	-9006
04-11-2021 02:25	23.18	19.34	22.55	25.04	24.80	4	23.63	-9006
04-11-2021 02:26	23.20	19.34	22.55	25.03	24.79	4	23.63	-9006
04-11-2021 02:27	23.20	19.33	22.55	25.02	24.79	3	23.63	-9006
04-11-2021 02:28	23.19	19.33	22.54	25.00	24.78	3	23.63	-9006
04-11-2021 02:29	23.20	19.33	22.55	25.01	24.79	4	23.62	-9006
04-11-2021 02:30	23.20	19.33	22.54	25.02	24.79	4	23.61	-9006
04-11-2021 02:31	23.19	19.33	22.55	25.00	24.80	4	23.62	-9006
04-11-2021 02:32	23.18	19.32	22.55	25.01	24.80	3	23.63	-9006
04-11-2021 02:33	23.20	19.32	22.56	25.03	24.80	4	23.63	-9006
04-11-2021 02:34	23.18	19.33	22.57	25.03	24.80	4	23.62	-9006
04-11-2021 02:35	23.19	19.33	22.57	25.01	24.81	4	23.62	-9006
04-11-2021 02:36	23.19	19.33	22.58	24.99	24.80	3	23.62	-9006
04-11-2021 02:37	23.19	19.32	22.56	25.01	24.80	4	23.63	-9006
04-11-2021 02:38	23.19	19.31	22.56	25.00	24.80	3	23.62	-9006
04-11-2021 02:39	23.18	19.32	22.56	24.99	24.82	3	23.62	-9006
04-11-2021 02:40	23.18	19.31	22.56	24.98	24.82	3	23.61	-9006
04-11-2021 02:41	23.16	19.32	22.57	24.98	24.80	3	23.62	-9006
04-11-2021 02:42	23.16	19.32	22.56	25.00	24.81	3	23.60	-9006
04-11-2021 02:43	23.18	19.32	22.56	24.99	24.80	4	23.61	-9006
04-11-2021 02:44	23.17	19.31	22.57	24.99	24.82	0	23.62	-9006



Environmental Monitoring System

DATA REPORT

TS LOADING & UNLOADING-SPARE ROOM

Date Time	TS LOADING ROOM	TS UNLOADING ROOM	QUARENTINE ROOM	MEDIA FILLED UNIT IN INCUBATION	MATERIAL TO EXIT	MATERIAL TO EXIT wrt CORRIDOR	DECORTNING ROOM	DECORTNING ROOM wrt CORRIDOR
Date Time	°C TEMP	°C TEMP	°C TEMP	°C TEMP	°C TEMP	DP Pa	°C TEMP	DP Pa
04-11-2021 02:45	23.17	19.30	22.57	25.00	24.80	4	23.61	-9006
04-11-2021 02:46	23.17	19.31	22.57	25.00	24.81	3	23.62	-9006
04-11-2021 02:47	23.17	19.31	22.58	24.99	24.81	4	23.61	-9006
04-11-2021 02:48	23.17	19.31	22.57	24.98	24.82	4	23.61	-9006
04-11-2021 02:49	23.17	19.31	22.57	24.99	24.80	4	23.61	-9006
04-11-2021 02:50	23.18	19.31	22.56	24.99	24.82	4	23.61	-9006
04-11-2021 02:51	23.16	19.31	22.57	24.99	24.82	4	23.61	-9006
04-11-2021 02:52	23.17	19.30	22.57	24.98	24.83	4	23.60	-9006
04-11-2021 02:53	23.15	19.31	22.58	24.99	24.82	3	23.61	-9006
04-11-2021 02:54	23.16	19.30	22.57	24.99	24.82	3	23.61	-9006
04-11-2021 02:55	23.17	19.31	22.58	25.00	24.83	3	23.61	-9006
04-11-2021 02:56	23.18	19.31	22.58	24.98	24.82	4	23.60	-9006
04-11-2021 02:57	23.17	19.32	22.58	24.98	24.84	0	23.60	-9006
04-11-2021 02:58	23.18	19.31	22.58	24.99	24.82	4	23.60	-9006
04-11-2021 02:59	23.18	19.30	22.57	24.99	24.83	4	23.59	-9006
04-11-2021 03:00	23.18	19.30	22.58	24.99	24.83	4	23.58	-9006
04-11-2021 03:01	23.18	19.30	22.58	25.00	24.82	4	23.58	-9006
04-11-2021 03:02	23.17	19.30	22.58	25.01	24.83	3	23.59	-9006
04-11-2021 03:03	23.17	19.29	22.58	24.99	24.84	4	23.59	-9006
04-11-2021 03:04	23.18	19.29	22.57	24.99	24.84	4	23.59	-9006
04-11-2021 03:05	23.17	19.29	22.57	24.99	24.84	4	23.59	-9006
04-11-2021 03:06	23.18	19.30	22.57	25.01	24.83	3	23.58	-9006
04-11-2021 03:07	23.17	19.29	22.57	25.00	24.82	4	23.59	-9006
04-11-2021 03:08	23.16	19.30	22.56	25.00	24.83	3	23.59	-9006
04-11-2021 03:09	23.18	19.29	22.57	25.01	24.82	4	23.59	-9006
04-11-2021 03:10	23.18	19.29	22.57	24.98	24.86	4	23.59	-9006
04-11-2021 03:11	23.16	19.30	22.57	24.97	24.84	4	23.59	-9006
04-11-2021 03:12	23.18	19.30	22.57	24.97	24.83	4	23.59	-9006



Environmental Monitoring System

DATA REPORT

TS LOADING & UNLOADING-SPARE ROOM

Date Time	TS LOADING ROOM	TS UNLOADING ROOM	QUARENTINE ROOM	MEDIA FILLED UNIT IN INCUBATION	MATERIAL TO EXIT	MATERIAL TO EXIT wrt CORRIDOR	DECORTNING ROOM	DECORTNING ROOM wrt CORRIDOR
Date Time	°C TEMP	°C TEMP	°C TEMP	°C TEMP	°C TEMP	DP Pa	°C TEMP	DP Pa
04-11-2021 03:13	23.17	19.29	22.58	24.97	24.83	3	23.59	-9006
04-11-2021 03:14	23.16	19.29	22.58	24.99	24.83	3	23.58	-9006
04-11-2021 03:15	23.16	19.28	22.57	24.98	24.83	3	23.59	-9006
04-11-2021 03:16	23.17	19.29	22.58	24.99	24.83	3	23.58	-9006
04-11-2021 03:17	23.16	19.29	22.57	24.99	24.83	3	23.59	-9006
04-11-2021 03:18	23.17	19.29	22.58	24.99	24.83	4	23.58	-9006
04-11-2021 03:19	23.16	19.29	22.57	25.01	24.85	3	23.57	-9006
04-11-2021 03:20	23.16	19.29	22.57	24.99	24.85	3	23.58	-9006
04-11-2021 03:21	23.15	19.29	22.57	24.99	24.85	4	23.57	-9006
04-11-2021 03:22	23.16	19.29	22.57	24.97	24.85	4	23.57	-9006
04-11-2021 03:23	23.16	19.29	22.58	24.98	24.85	0	23.57	-9006
04-11-2021 03:24	23.16	19.28	22.58	24.98	24.86	0	23.57	-9006
04-11-2021 03:25	23.15	19.27	22.59	24.97	24.85	0	23.57	-9006
04-11-2021 03:26	23.16	19.28	22.59	24.95	24.85	3	23.57	-9006
04-11-2021 03:27	23.17	19.28	22.58	24.96	24.84	3	23.57	-9006
04-11-2021 03:28	23.15	19.27	22.58	24.98	24.85	3	23.57	-9006
04-11-2021 03:29	23.17	19.27	22.58	24.97	24.85	3	23.57	-9006
04-11-2021 03:30	23.17	19.26	22.59	24.99	24.85	3	23.57	-9006
04-11-2021 03:31	23.17	19.26	22.60	24.99	24.85	3	23.57	-9006
04-11-2021 03:32	23.16	19.27	22.59	25.00	24.86	3	23.57	-9006
04-11-2021 03:33	23.16	19.27	22.60	24.99	24.86	3	23.57	-9006
04-11-2021 03:34	23.15	19.26	22.60	24.99	24.85	3	23.57	-9006
04-11-2021 03:35	23.14	19.27	22.59	24.97	24.84	4	23.57	-9006
04-11-2021 03:36	23.13	19.27	22.58	24.96	24.84	3	23.55	-9006
04-11-2021 03:37	23.15	19.26	22.59	24.94	24.84	4	23.56	-9006
04-11-2021 03:38	23.14	19.27	22.59	24.94	24.85	3	23.57	-9006
04-11-2021 03:39	23.16	19.26	22.59	24.96	24.86	4	23.56	-9006
04-11-2021 03:40	23.14	19.27	22.59	24.96	24.87	3	23.56	-9006



Environmental Monitoring System

DATA REPORT

TS LOADING & UNLOADING-SPARE ROOM

Date Time	TS LOADING ROOM	TS UNLOADING ROOM	QUARENTINE ROOM	MEDIA FILLED UNIT IN INCUBATION	MATERIAL TO EXIT	MATERIAL TO EXIT wrt CORRIDOR	DECORTNING ROOM	DECORTNING ROOM wrt CORRIDOR
Date Time	°C TEMP	°C TEMP	°C TEMP	°C TEMP	°C TEMP	DP Pa	°C TEMP	DP Pa
04-11-2021 03:41	23.14	19.27	22.59	24.96	24.86	4	23.56	-9006
04-11-2021 03:42	23.15	19.26	22.60	24.95	24.87	3	23.55	-9006
04-11-2021 03:43	23.14	19.26	22.59	24.94	24.86	3	23.57	-9006
04-11-2021 03:44	23.14	19.27	22.59	24.97	24.87	3	23.56	-9006
04-11-2021 03:45	23.14	19.25	22.59	24.96	24.86	4	23.56	-9006
04-11-2021 03:46	23.14	19.27	22.60	24.96	24.86	4	23.56	-9006
04-11-2021 03:47	23.16	19.26	22.59	24.96	24.86	4	23.55	-9006
04-11-2021 03:48	23.15	19.26	22.59	24.95	24.87	4	23.55	-9006
04-11-2021 03:49	23.15	19.25	22.60	24.93	24.86	3	23.54	-9006
04-11-2021 03:50	23.14	19.26	22.59	24.94	24.86	0	23.55	-9006
04-11-2021 03:51	23.12	19.26	22.60	24.95	24.86	4	23.55	-9006
04-11-2021 03:52	23.13	19.26	22.60	24.96	24.87	4	23.55	-9006
04-11-2021 03:53	23.13	19.25	22.60	24.96	24.87	4	23.56	-9006
04-11-2021 03:54	23.14	19.24	22.61	24.97	24.86	0	23.55	-9006
04-11-2021 03:55	23.13	19.25	22.61	24.95	24.86	3	23.54	-9006
04-11-2021 03:56	23.14	19.25	22.60	24.95	24.87	0	23.54	-9006
04-11-2021 03:57	23.14	19.25	22.59	24.95	24.88	4	23.55	-9006
04-11-2021 03:58	23.14	19.25	22.60	24.94	24.87	3	23.54	-9006
04-11-2021 03:59	23.14	19.26	22.59	24.94	24.87	4	23.54	-9006
04-11-2021 04:00	23.13	19.26	22.59	24.95	24.88	4	23.54	-9006
04-11-2021 04:01	23.13	19.26	22.58	24.96	24.87	3	23.53	-9006
04-11-2021 04:02	23.13	19.24	22.59	24.96	24.87	3	23.54	-9006
04-11-2021 04:03	23.14	19.25	22.59	24.94	24.87	3	23.53	-9006
04-11-2021 04:04	23.14	19.24	22.59	24.94	24.88	3	23.54	-9006
04-11-2021 04:05	23.13	19.25	22.60	24.93	24.87	3	23.54	-9006
04-11-2021 04:06	23.14	19.25	22.59	24.94	24.88	3	23.54	-9006
04-11-2021 04:07	23.13	19.24	22.59	24.93	24.88	3	23.54	-9006
04-11-2021 04:08	23.13	19.25	22.59	24.93	24.88	3	23.53	-9006



Environmental Monitoring System

DATA REPORT

TS LOADING & UNLOADING-SPARE ROOM

Date Time	TS LOADING ROOM	TS UNLOADING ROOM	QUARENTINE ROOM	MEDIA FILLED UNIT IN INCUBATION	MATERIAL TO EXIT	MATERIAL TO EXIT wrt CORRIDOR	DECORTNING ROOM	DECORTNING ROOM wrt CORRIDOR
Date Time	°C TEMP	°C TEMP	°C TEMP	°C TEMP	°C TEMP	DP Pa	°C TEMP	DP Pa
04-11-2021 04:09	23.16	19.26	22.60	24.91	24.87	3	23.54	-9006
04-11-2021 04:10	23.16	19.25	22.60	24.91	24.88	3	23.54	-9006
04-11-2021 04:11	23.14	19.25	22.59	24.93	24.89	3	23.55	-9006
04-11-2021 04:12	23.15	19.25	22.59	24.94	24.89	4	23.53	-9006
04-11-2021 04:13	23.13	19.26	22.58	24.93	24.89	4	23.54	-9006
04-11-2021 04:14	23.14	19.27	22.59	24.92	24.88	3	23.53	-9006
04-11-2021 04:15	23.12	19.26	22.58	24.92	24.88	3	23.53	-9006
04-11-2021 04:16	23.14	19.26	22.57	24.92	24.89	3	23.53	-9006
04-11-2021 04:17	23.15	19.26	22.59	24.91	24.90	3	23.53	-9006
04-11-2021 04:18	23.13	19.26	22.58	24.92	24.90	3	23.53	-9006
04-11-2021 04:19	23.14	19.25	22.58	24.92	24.89	3	23.53	-9006
04-11-2021 04:20	23.13	19.25	22.57	24.93	24.91	3	23.52	-9006
04-11-2021 04:21	23.16	19.25	22.57	24.89	24.90	0	23.52	-9006
04-11-2021 04:22	23.16	19.24	22.57	24.90	24.90	0	23.52	-9006
04-11-2021 04:23	23.15	19.24	22.58	24.89	24.90	3	23.51	-9006
04-11-2021 04:24	23.14	19.24	22.58	24.89	24.91	4	23.52	-9006
04-11-2021 04:25	23.16	19.26	22.57	24.88	24.92	3	23.52	-9006
04-11-2021 04:26	23.14	19.25	22.57	24.88	24.91	3	23.52	-9006
04-11-2021 04:27	23.15	19.25	22.57	24.88	24.91	3	23.52	-9006
04-11-2021 04:28	23.16	19.26	22.58	24.87	24.91	3	23.53	-9006
04-11-2021 04:29	23.14	19.25	22.56	24.89	24.91	3	23.53	-9006
04-11-2021 04:30	23.14	19.25	22.55	24.88	24.92	0	23.52	-9006
04-11-2021 04:31	23.15	19.25	22.53	24.86	24.92	3	23.53	-9006
04-11-2021 04:32	23.14	19.25	22.53	24.88	24.93	3	23.52	-9006
04-11-2021 04:33	23.14	19.23	22.54	24.86	24.93	3	23.52	-9006
04-11-2021 04:34	23.14	19.24	22.54	24.89	24.93	3	23.52	-9006
04-11-2021 04:35	23.11	19.23	22.54	24.87	24.93	3	23.52	-9006
04-11-2021 04:36	23.12	19.23	22.53	24.87	24.92	0	23.51	-9006



Environmental Monitoring System

DATA REPORT

TS LOADING & UNLOADING-SPARE ROOM

Date Time	TS LOADING ROOM	TS UNLOADING ROOM	QUARENTINE ROOM	MEDIA FILLED UNIT IN INCUBATION	MATERIAL TO EXIT	MATERIAL TO EXIT wrt CORRIDOR	DECORTNING ROOM	DECORTNING ROOM wrt CORRIDOR
Date Time	°C TEMP	°C TEMP	°C TEMP	°C TEMP	°C TEMP	DP Pa	°C TEMP	DP Pa
04-11-2021 04:37	23.14	19.23	22.54	24.86	24.92	3	23.50	-9006
04-11-2021 04:38	23.12	19.22	22.55	24.84	24.92	4	23.50	-9006
04-11-2021 04:39	23.13	19.22	22.54	24.84	24.94	3	23.52	-9006
04-11-2021 04:40	23.11	19.23	22.54	24.83	24.95	3	23.51	-9006
04-11-2021 04:41	23.11	19.24	22.54	24.85	24.94	4	23.51	-9006
04-11-2021 04:42	23.12	19.23	22.54	24.86	24.95	3	23.52	-9006
04-11-2021 04:43	23.12	19.24	22.53	24.85	24.95	9	23.51	-9006
04-11-2021 04:44	23.14	19.22	22.53	24.84	24.97	0	23.51	-9006
04-11-2021 04:45	23.10	19.23	22.52	24.84	24.96	4	23.50	-9006
04-11-2021 04:46	23.10	19.23	22.53	24.84	24.96	4	23.50	-9006
04-11-2021 04:47	23.13	19.23	22.54	24.46	23.78	3	23.51	-9006
04-11-2021 04:48	23.14	19.24	22.53	23.67	23.74	4	23.50	-9006
04-11-2021 04:49	23.14	19.22	22.54	23.67	23.99	3	23.50	-9006
04-11-2021 04:50	23.12	19.24	22.54	23.84	24.08	3	23.51	-9006
04-11-2021 04:51	23.11	19.24	22.54	23.95	24.13	3	23.50	-9006
04-11-2021 04:52	23.12	19.23	22.53	24.02	24.17	3	23.50	-9006
04-11-2021 04:53	23.12	19.22	22.54	24.08	24.21	3	23.50	-9006
04-11-2021 04:54	23.11	19.23	22.53	24.14	24.25	4	23.50	-9006
04-11-2021 04:55	23.11	19.24	22.53	24.19	24.28	4	23.49	-9006
04-11-2021 04:56	23.12	19.24	22.52	24.24	24.33	3	23.50	-9006
04-11-2021 04:57	23.11	19.23	22.52	24.29	24.37	3	23.49	-9006
04-11-2021 04:58	23.10	19.23	22.51	24.34	24.41	4	23.50	-9006
04-11-2021 04:59	23.11	19.23	22.51	24.37	24.44	4	23.50	-9006
04-11-2021 05:00	23.11	19.22	22.51	24.40	24.46	3	23.49	-9006
04-11-2021 05:01	23.10	19.25	22.51	24.45	24.51	4	23.48	-9006
04-11-2021 05:02	23.10	19.23	22.51	24.49	24.52	4	23.49	-9006
04-11-2021 05:03	23.10	19.23	22.51	24.52	24.54	3	23.49	-9006
04-11-2021 05:04	23.11	19.22	22.50	24.54	24.57	0	23.49	-9006



Environmental Monitoring System

DATA REPORT

TS LOADING & UNLOADING-SPARE ROOM

Date Time	TS LOADING ROOM	TS UNLOADING ROOM	QUARENTINE ROOM	MEDIA FILLED UNIT IN INCUBATION	MATERIAL TO EXIT	MATERIAL TO EXIT wrt CORRIDOR	DECORTNING ROOM	DECORTNING ROOM wrt CORRIDOR
Date Time	°C TEMP	°C TEMP	°C TEMP	°C TEMP	°C TEMP	DP Pa	°C TEMP	DP Pa
04-11-2021 05:05	23.10	19.23	22.51	24.55	24.59	3	23.49	-9006
04-11-2021 05:06	23.09	19.22	22.51	24.57	24.59	4	23.48	-9006
04-11-2021 05:07	23.09	19.23	22.50	24.59	24.61	4	23.49	-9006
04-11-2021 05:08	23.11	19.23	22.51	24.61	24.61	3	23.49	-9006
04-11-2021 05:09	23.08	19.23	22.51	24.62	24.63	3	23.48	-9006
04-11-2021 05:10	23.09	19.24	22.50	24.63	24.65	0	23.48	-9006
04-11-2021 05:11	23.08	19.24	22.50	24.64	24.65	5	23.48	-9006
04-11-2021 05:12	23.10	19.23	22.50	24.66	24.66	4	23.48	-9006
04-11-2021 05:13	23.10	19.23	22.50	24.68	24.67	3	23.48	-9006
04-11-2021 05:14	23.09	19.22	22.50	24.65	24.68	4	23.47	-9006
04-11-2021 05:15	23.08	19.24	22.49	24.66	24.68	3	23.47	-9006
04-11-2021 05:16	23.08	19.22	22.49	24.68	24.69	4	23.48	-9006
04-11-2021 05:17	23.10	19.23	22.49	24.70	24.70	3	23.48	-9006
04-11-2021 05:18	23.11	19.22	22.49	24.70	24.71	3	23.48	-9006
04-11-2021 05:19	23.09	19.23	22.48	24.72	24.71	3	23.48	-9006
04-11-2021 05:20	23.08	19.22	22.48	24.72	24.72	3	23.47	-9006
04-11-2021 05:21	23.10	19.22	22.47	24.71	24.73	4	23.48	-9006
04-11-2021 05:22	23.09	19.22	22.48	24.72	24.72	4	23.47	-9006
04-11-2021 05:23	23.09	19.22	22.47	24.71	24.73	4	23.47	-9006
04-11-2021 05:24	23.08	19.22	22.47	24.73	24.73	3	23.47	-9006
04-11-2021 05:25	23.11	19.22	22.47	24.72	24.72	3	23.47	-9006
04-11-2021 05:26	23.09	19.21	22.47	24.74	24.71	3	23.47	-9006
04-11-2021 05:27	23.09	19.21	22.48	24.73	24.74	3	23.46	-9006
04-11-2021 05:28	23.08	19.21	22.47	24.73	24.74	3	23.47	-9006
04-11-2021 05:29	23.07	19.22	22.47	24.75	24.74	3	23.46	-9006
04-11-2021 05:30	23.06	19.22	22.48	24.75	24.74	3	23.46	-9006
04-11-2021 05:31	23.05	19.23	22.48	24.75	24.75	4	23.46	-9006
04-11-2021 05:32	23.06	19.24	22.48	24.74	24.75	3	23.46	-9006



Environmental Monitoring System

DATA REPORT

TS LOADING & UNLOADING-SPARE ROOM

Date Time	TS LOADING ROOM	TS UNLOADING ROOM	QUARENTINE ROOM	MEDIA FILLED UNIT IN INCUBATION	MATERIAL TO EXIT	MATERIAL TO EXIT wrt CORRIDOR	DECORTNING ROOM	DECORTNING ROOM wrt CORRIDOR
Date Time	°C TEMP	°C TEMP	°C TEMP	°C TEMP	°C TEMP	DP Pa	°C TEMP	DP Pa
04-11-2021 05:33	23.05	19.22	22.47	24.73	24.76	4	23.46	-9006
04-11-2021 05:34	23.07	19.21	22.48	24.73	24.76	3	23.47	-9006
04-11-2021 05:35	23.11	19.22	22.47	24.74	24.76	4	23.46	-9006
04-11-2021 05:36	23.09	19.22	22.48	24.74	24.77	3	23.45	-9006
04-11-2021 05:37	23.10	19.20	22.48	24.75	24.78	3	23.46	-9006
04-11-2021 05:38	23.09	19.20	22.46	24.75	24.78	4	23.45	-9006
04-11-2021 05:39	23.10	19.22	22.47	24.75	24.79	4	23.45	-9006
04-11-2021 05:40	23.12	19.21	22.48	24.74	24.79	4	23.45	-9006
04-11-2021 05:41	23.12	19.22	22.46	24.74	24.79	4	23.45	-9006
04-11-2021 05:42	23.09	19.22	22.46	24.74	24.79	0	23.45	-9006
04-11-2021 05:43	23.11	19.19	22.46	24.72	24.79	4	23.45	-9006
04-11-2021 05:44	23.14	19.20	22.47	24.74	24.80	3	23.45	-9006
04-11-2021 05:45	23.13	19.21	22.47	24.74	24.80	4	23.44	-9006
04-11-2021 05:46	23.13	19.21	22.47	24.73	24.81	3	23.45	-9006
04-11-2021 05:47	23.12	19.20	22.45	24.73	24.80	4	23.45	-9006
04-11-2021 05:48	23.12	19.20	22.49	24.74	24.80	3	23.45	-9006
04-11-2021 05:49	23.14	19.19	22.48	24.76	24.80	4	23.44	-9006
04-11-2021 05:50	23.15	19.19	22.47	24.76	24.80	3	23.45	-9006
04-11-2021 05:51	23.14	19.20	22.47	24.75	24.80	3	23.44	-9006
04-11-2021 05:52	23.14	19.19	22.48	24.74	24.79	3	23.45	-9006
04-11-2021 05:53	23.14	19.19	22.48	24.75	24.80	4	23.43	-9006
04-11-2021 05:54	23.13	19.19	22.48	24.74	24.81	4	23.42	-9006
04-11-2021 05:55	23.15	19.20	22.48	24.74	24.81	3	23.43	-9006
04-11-2021 05:56	23.15	19.19	22.47	24.77	24.80	4	23.44	-9006
04-11-2021 05:57	23.15	19.20	22.47	24.78	24.80	4	23.44	-9006
04-11-2021 05:58	23.14	19.18	22.48	24.78	24.83	4	23.44	-9006
04-11-2021 05:59	23.15	19.20	22.48	24.79	24.82	4	23.44	-9006
04-11-2021 06:00	23.14	19.21	22.49	24.78	24.81	4	23.43	-9006



Environmental Monitoring System

DATA REPORT

TS LOADING & UNLOADING-SPARE ROOM

Date Time	TS LOADING ROOM	TS UNLOADING ROOM	QUARENTINE ROOM	MEDIA FILLED UNIT IN INCUBATION	MATERIAL TO EXIT	MATERIAL TO EXIT wrt CORRIDOR	DECORTNING ROOM	DECORTNING ROOM wrt CORRIDOR
Date Time	°C TEMP	°C TEMP	°C TEMP	°C TEMP	°C TEMP	DP Pa	°C TEMP	DP Pa
04-11-2021 06:01	23.14	19.21	22.49	24.78	24.81	4	23.43	-9006
04-11-2021 06:02	23.15	19.20	22.48	24.81	24.81	4	23.43	-9006
04-11-2021 06:03	23.14	19.21	22.49	24.80	24.82	3	23.43	-9006
04-11-2021 06:04	23.13	19.21	22.49	24.79	24.83	4	23.43	-9006
04-11-2021 06:05	23.14	19.21	22.48	24.78	24.81	4	23.43	-9006
04-11-2021 06:06	23.13	19.22	22.50	24.78	24.82	4	23.43	-9006
04-11-2021 06:07	23.13	19.20	22.48	24.79	24.83	3	23.43	-9006
04-11-2021 06:08	23.13	19.20	22.48	24.82	24.83	4	23.43	-9006
04-11-2021 06:09	23.15	19.21	22.49	24.79	24.84	3	23.43	-9006
04-11-2021 06:10	23.11	19.19	22.49	24.79	24.83	4	23.42	-9006
04-11-2021 06:11	23.11	19.22	22.50	24.78	24.83	0	23.42	-9006
04-11-2021 06:12	23.12	19.20	22.50	24.76	24.83	4	23.42	-9006
04-11-2021 06:13	23.12	19.21	22.50	24.80	24.84	3	23.41	-9006
04-11-2021 06:14	23.11	19.20	22.48	24.81	24.84	3	23.41	-9006
04-11-2021 06:15	23.13	19.20	22.49	24.80	24.83	3	23.41	-9006
04-11-2021 06:16	23.12	19.21	22.49	24.81	24.83	4	23.42	-9006
04-11-2021 06:17	23.10	19.19	22.48	24.79	24.84	4	23.41	-9006
04-11-2021 06:18	23.11	19.21	22.48	24.80	24.84	4	23.41	-9006
04-11-2021 06:19	23.11	19.20	22.49	24.81	24.84	3	23.41	-9006
04-11-2021 06:20	23.12	19.20	22.49	24.82	24.83	4	23.42	-9006
04-11-2021 06:21	23.13	19.20	22.48	24.83	24.84	3	23.41	-9006
04-11-2021 06:22	23.12	19.21	22.50	24.81	24.84	4	23.41	-9006
04-11-2021 06:23	23.12	19.21	22.51	24.83	24.84	4	23.41	-9006
04-11-2021 06:24	23.10	19.20	22.51	24.82	24.84	3	23.41	-9006
04-11-2021 06:25	23.11	19.21	22.50	24.82	24.84	4	23.41	-9006
04-11-2021 06:26	23.09	19.21	22.52	24.82	24.86	4	23.41	-9006
04-11-2021 06:27	23.10	19.21	22.51	24.80	24.85	3	23.41	-9006
04-11-2021 06:28	23.11	19.20	22.52	24.81	24.85	4	23.40	-9006



Environmental Monitoring System

DATA REPORT

TS LOADING & UNLOADING-SPARE ROOM

Date Time	TS LOADING ROOM	TS UNLOADING ROOM	QUARENTINE ROOM	MEDIA FILLED UNIT IN INCUBATION	MATERIAL TO EXIT	MATERIAL TO EXIT wrt CORRIDOR	DECORTNING ROOM	DECORTNING ROOM wrt CORRIDOR
Date Time	°C TEMP	°C TEMP	°C TEMP	°C TEMP	°C TEMP	DP Pa	°C TEMP	DP Pa
04-11-2021 06:29	23.12	19.19	22.52	24.82	24.85	4	23.39	-9006
04-11-2021 06:30	23.11	19.19	22.53	24.81	24.86	0	23.40	-9006
04-11-2021 06:31	23.11	19.19	22.52	24.80	24.84	4	23.39	-9006
04-11-2021 06:32	23.11	19.19	22.51	24.82	24.84	4	23.40	-9006
04-11-2021 06:33	23.12	19.20	22.52	24.79	24.85	3	23.40	-9006
04-11-2021 06:34	23.12	19.20	22.50	24.80	24.84	4	23.39	-9006
04-11-2021 06:35	23.12	19.21	22.51	24.81	24.85	3	23.40	-9006
04-11-2021 06:36	23.10	19.19	22.52	24.81	24.84	4	23.40	-9006
04-11-2021 06:37	23.10	19.19	22.51	24.82	24.84	4	23.41	-9006
04-11-2021 06:38	23.12	19.20	22.53	24.80	24.85	4	23.40	-9006
04-11-2021 06:39	23.11	19.21	22.52	24.80	24.86	4	23.40	-9006
04-11-2021 06:40	23.11	19.20	22.53	24.81	24.86	4	23.39	-9006
04-11-2021 06:41	23.12	19.20	22.52	24.80	24.87	4	23.40	-9006
04-11-2021 06:42	23.13	19.19	22.52	24.78	24.86	3	23.39	-9006
04-11-2021 06:43	23.10	19.20	22.52	24.80	24.85	4	23.39	-9006
04-11-2021 06:44	23.11	19.21	22.52	24.79	24.84	4	23.39	-9006
04-11-2021 06:45	23.12	19.20	22.53	24.79	24.85	4	23.39	-9006
04-11-2021 06:46	23.13	19.21	22.53	24.83	24.86	4	23.40	-9006
04-11-2021 06:47	23.13	19.20	22.53	24.80	24.85	3	23.40	-9006
04-11-2021 06:48	23.13	19.20	22.53	24.82	24.86	4	23.39	-9006
04-11-2021 06:49	23.12	19.20	22.52	24.80	24.85	4	23.39	-9006
04-11-2021 06:50	23.13	19.20	22.52	24.81	24.86	4	23.39	-9006
04-11-2021 06:51	23.13	19.20	22.51	24.80	24.85	3	23.39	-9006
04-11-2021 06:52	23.14	19.19	22.52	24.82	24.85	3	23.39	-9006
04-11-2021 06:53	23.13	19.19	22.51	24.81	24.87	4	23.40	-9006
04-11-2021 06:54	23.13	19.20	22.51	24.81	24.86	4	23.39	-9006
04-11-2021 06:55	23.14	19.21	22.52	24.82	24.86	4	23.39	-9006
04-11-2021 06:56	23.13	19.21	22.52	24.82	24.87	4	23.39	-9006



Environmental Monitoring System

DATA REPORT

TS LOADING & UNLOADING-SPARE ROOM

Date Time	TS LOADING ROOM	TS UNLOADING ROOM	QUARENTINE ROOM	MEDIA FILLED UNIT IN INCUBATION	MATERIAL TO EXIT	MATERIAL TO EXIT wrt CORRIDOR	DECORTNING ROOM	DECORTNING ROOM wrt CORRIDOR
Date Time	°C TEMP	°C TEMP	°C TEMP	°C TEMP	°C TEMP	DP Pa	°C TEMP	DP Pa
04-11-2021 06:57	23.13	19.20	22.51	24.83	24.87	4	23.38	-9006
04-11-2021 06:58	23.13	19.20	22.51	24.81	24.86	3	23.38	-9006
04-11-2021 06:59	23.15	19.19	22.54	24.81	24.85	4	23.39	-9006
04-11-2021 07:00	23.13	19.20	22.53	24.81	24.86	3	23.38	-9006
04-11-2021 07:01	23.14	19.19	22.52	24.80	24.86	4	23.38	-9006
04-11-2021 07:02	23.14	19.19	22.51	24.82	24.87	4	23.38	-9006
04-11-2021 07:03	23.14	19.19	22.50	24.81	24.85	4	23.38	-9006
04-11-2021 07:04	23.14	19.19	22.51	24.81	24.85	3	23.38	-9006
04-11-2021 07:05	23.13	19.18	22.50	24.82	24.85	4	23.38	-9006
04-11-2021 07:06	23.14	19.19	22.51	24.81	24.86	3	23.38	-9006
04-11-2021 07:07	23.13	19.20	22.52	24.81	24.86	4	23.36	-9006
04-11-2021 07:08	23.14	19.21	22.53	24.82	24.85	4	23.38	-9006
04-11-2021 07:09	23.15	19.21	22.53	24.82	24.85	4	23.37	-9006
04-11-2021 07:10	23.15	19.19	22.52	24.83	24.87	3	23.36	-9006
04-11-2021 07:11	23.15	19.20	22.53	24.83	24.87	3	23.37	-9006
04-11-2021 07:12	23.15	19.20	22.50	24.82	24.87	3	23.37	-9006
04-11-2021 07:13	23.15	19.19	22.51	24.84	24.85	4	23.37	-9006
04-11-2021 07:14	23.14	19.20	22.51	24.84	24.87	4	23.37	-9006
04-11-2021 07:15	23.15	19.21	22.51	24.84	24.86	4	23.37	-9006
04-11-2021 07:16	23.15	19.20	22.49	24.85	24.86	4	23.37	-9006
04-11-2021 07:17	23.16	19.21	22.51	24.85	24.86	4	23.38	-9006
04-11-2021 07:18	23.16	19.20	22.51	24.83	24.87	4	23.36	-9006
04-11-2021 07:19	23.17	19.20	22.52	24.85	24.87	4	23.38	-9006
04-11-2021 07:20	23.16	19.20	22.52	24.83	24.86	3	23.37	-9006
04-11-2021 07:21	23.16	19.21	22.52	24.83	24.87	4	23.37	-9006
04-11-2021 07:22	23.17	19.21	22.52	24.82	24.85	4	23.36	-9006
04-11-2021 07:23	23.16	19.20	22.51	24.83	24.86	4	23.37	-9006
04-11-2021 07:24	23.15	19.21	22.52	24.83	24.85	3	23.36	-9006



Environmental Monitoring System

DATA REPORT

TS LOADING & UNLOADING-SPARE ROOM

Date Time	TS LOADING ROOM	TS UNLOADING ROOM	QUARENTINE ROOM	MEDIA FILLED UNIT IN INCUBATION	MATERIAL TO EXIT	MATERIAL TO EXIT wrt CORRIDOR	DECORTNING ROOM	DECORTNING ROOM wrt CORRIDOR
Date Time	°C TEMP	°C TEMP	°C TEMP	°C TEMP	°C TEMP	DP Pa	°C TEMP	DP Pa
04-11-2021 07:25	23.17	19.22	22.50	24.82	24.87	4	23.35	-9006
04-11-2021 07:26	23.17	19.22	22.52	24.82	24.85	4	23.36	-9006
04-11-2021 07:27	23.17	19.23	22.53	24.85	24.85	4	23.36	-9006
04-11-2021 07:28	23.17	19.23	22.53	24.85	24.86	4	23.36	-9006
04-11-2021 07:29	23.17	19.22	22.54	24.83	24.87	3	23.36	-9006
04-11-2021 07:30	23.18	19.22	22.53	24.83	24.86	4	23.36	-9006
04-11-2021 07:31	23.19	19.22	22.53	24.83	24.87	4	23.36	-9006
04-11-2021 07:32	23.20	19.23	22.53	24.82	24.88	4	23.36	-9006
04-11-2021 07:33	23.20	19.23	22.55	24.82	24.87	3	23.36	-9006
04-11-2021 07:34	23.19	19.23	22.54	24.82	24.87	4	23.36	-9006
04-11-2021 07:35	23.20	19.24	22.55	24.83	24.88	4	23.36	-9006
04-11-2021 07:36	23.19	19.24	22.54	24.82	24.87	4	23.35	-9006
04-11-2021 07:37	23.21	19.26	22.57	24.84	24.88	4	23.36	-9006
04-11-2021 07:38	23.21	19.25	22.55	24.85	24.89	3	23.36	-9006
04-11-2021 07:39	23.22	19.25	22.55	24.83	24.87	4	23.35	-9006
04-11-2021 07:40	23.24	19.25	22.56	24.82	24.89	3	23.36	-9006
04-11-2021 07:41	23.25	19.25	22.56	24.83	24.90	3	23.36	-9006
04-11-2021 07:42	23.24	19.26	22.57	24.83	24.88	4	23.36	-9006
04-11-2021 07:43	23.24	19.26	22.58	24.83	24.88	4	23.36	-9006
04-11-2021 07:44	23.26	19.26	22.57	24.83	24.88	4	23.36	-9006
04-11-2021 07:45	23.26	19.26	22.57	24.85	24.89	4	23.36	-9006
04-11-2021 07:46	23.26	19.27	22.57	24.83	24.89	4	23.37	-9006
04-11-2021 07:47	23.27	19.27	22.57	24.84	24.88	4	23.37	-9006
04-11-2021 07:48	23.28	19.28	22.57	24.83	24.88	4	23.35	-9006
04-11-2021 07:49	23.30	19.28	22.58	24.82	24.88	4	23.35	-9006
04-11-2021 07:50	23.31	19.27	22.57	24.82	24.89	3	23.36	-9006
04-11-2021 07:51	23.32	19.28	22.57	24.82	24.89	4	23.35	-9006
04-11-2021 07:52	23.32	19.28	22.58	24.82	24.89	4	23.36	-9006



Environmental Monitoring System

DATA REPORT

TS LOADING & UNLOADING-SPARE ROOM

Date Time	TS LOADING ROOM	TS UNLOADING ROOM	QUARENTINE ROOM	MEDIA FILLED UNIT IN INCUBATION	MATERIAL TO EXIT	MATERIAL TO EXIT wrt CORRIDOR	DECORTNING ROOM	DECORTNING ROOM wrt CORRIDOR
Date Time	°C TEMP	°C TEMP	°C TEMP	°C TEMP	°C TEMP	DP Pa	°C TEMP	DP Pa
04-11-2021 07:53	23.32	19.28	22.57	24.82	24.88	4	23.37	-9006
04-11-2021 07:54	23.34	19.30	22.59	24.86	24.88	4	23.35	-9006
04-11-2021 07:55	23.36	19.30	22.58	24.85	24.88	4	23.34	-9006
04-11-2021 07:56	23.36	19.31	22.59	24.86	24.89	4	23.37	-9006
04-11-2021 07:57	23.38	19.32	22.60	24.87	24.88	4	23.37	-9006
04-11-2021 07:58	23.39	19.32	22.60	24.86	24.89	4	23.36	-9006
04-11-2021 07:59	23.41	19.32	22.60	24.88	24.89	4	23.37	-9006
04-11-2021 08:00	23.41	19.32	22.61	24.87	24.90	3	23.37	-9006
04-11-2021 08:01	23.42	19.33	22.60	24.87	24.89	3	23.36	-9006
04-11-2021 08:02	23.42	19.32	22.60	24.87	24.89	4	23.37	-9006
04-11-2021 08:03	23.42	19.33	22.60	24.88	24.89	4	23.37	-9006
04-11-2021 08:04	23.45	19.34	22.62	24.90	24.89	4	23.37	-9006
04-11-2021 08:05	23.46	19.33	22.62	24.91	24.90	4	23.37	-9006
04-11-2021 08:06	23.47	19.34	22.63	24.91	24.87	4	23.38	-9006
04-11-2021 08:07	23.47	19.34	22.64	24.89	24.88	4	23.39	-9006
04-11-2021 08:08	23.48	19.35	22.64	24.89	24.88	3	23.39	-9006
04-11-2021 08:09	23.48	19.36	22.65	24.88	24.87	4	23.37	-9006
04-11-2021 08:10	23.48	19.36	22.65	24.88	24.88	4	23.38	-9006
04-11-2021 08:11	23.50	19.36	22.64	24.89	24.87	3	23.38	-9006
04-11-2021 08:12	23.50	19.36	22.66	24.91	24.88	4	23.38	-9006
04-11-2021 08:13	23.51	19.37	22.65	24.92	24.87	4	23.38	-9006
04-11-2021 08:14	23.50	19.37	22.64	24.91	24.87	3	23.38	-9006
04-11-2021 08:15	23.51	19.37	22.66	24.92	24.86	4	23.38	-9006
04-11-2021 08:16	23.52	19.39	22.66	24.93	24.86	4	23.38	-9006
04-11-2021 08:17	23.51	19.40	22.66	24.93	24.86	3	23.38	-9006
04-11-2021 08:18	23.52	19.41	22.66	24.94	24.85	4	23.38	-9006
04-11-2021 08:19	23.51	19.40	22.66	24.94	24.84	4	23.38	-9006
04-11-2021 08:20	23.53	19.40	22.67	24.93	24.83	3	23.38	-9006



Environmental Monitoring System

DATA REPORT

TS LOADING & UNLOADING-SPARE ROOM

Date Time	TS LOADING ROOM	TS UNLOADING ROOM	QUARENTINE ROOM	MEDIA FILLED UNIT IN INCUBATION	MATERIAL TO EXIT	MATERIAL TO EXIT wrt CORRIDOR	DECORTNING ROOM	DECORTNING ROOM wrt CORRIDOR
Date Time	°C TEMP	°C TEMP	°C TEMP	°C TEMP	°C TEMP	DP Pa	°C TEMP	DP Pa
04-11-2021 08:21	23.53	19.42	22.67	24.93	24.85	3	23.39	-9006
04-11-2021 08:22	23.53	19.41	22.67	24.95	24.84	4	23.37	-9006
04-11-2021 08:23	23.54	19.42	22.68	24.94	24.83	4	23.39	-9006
04-11-2021 08:24	23.55	19.42	22.68	24.94	24.82	4	23.39	-9006
04-11-2021 08:25	23.54	19.43	22.67	24.94	24.83	4	23.39	-9006
04-11-2021 08:26	23.54	19.42	22.68	24.94	24.83	4	23.39	-9006
04-11-2021 08:27	23.54	19.43	22.69	24.95	24.82	4	23.39	-9006
04-11-2021 08:28	23.54	19.44	22.68	24.94	24.80	4	23.39	-9006
04-11-2021 08:29	23.55	19.45	22.70	24.93	24.80	3	23.39	-9006
04-11-2021 08:30	23.57	19.45	22.69	24.94	24.80	3	23.39	-9006
04-11-2021 08:31	23.57	19.45	22.70	24.94	24.81	3	23.40	-9006
04-11-2021 08:32	23.56	19.46	22.69	24.93	24.80	4	23.39	-9006
04-11-2021 08:33	23.56	19.46	22.69	24.93	24.80	3	23.40	-9006
04-11-2021 08:34	23.58	19.47	22.70	24.95	24.79	4	23.40	-9006
04-11-2021 08:35	23.57	19.45	22.71	24.96	24.79	3	23.40	-9006
04-11-2021 08:36	23.57	19.46	22.72	24.95	24.81	3	23.40	-9006
04-11-2021 08:37	23.56	19.46	22.71	24.95	24.80	4	23.39	-9006
04-11-2021 08:38	23.55	19.46	22.71	24.95	24.79	3	23.40	-9006
04-11-2021 08:39	23.56	19.46	22.71	24.96	24.80	4	23.38	-9006
04-11-2021 08:40	23.56	19.45	22.71	24.96	24.79	4	23.40	-9006
04-11-2021 08:41	23.57	19.46	22.71	24.96	24.80	4	23.40	-9006
04-11-2021 08:42	23.58	19.46	22.71	24.96	24.80	4	23.41	-9006
04-11-2021 08:43	23.58	19.45	22.72	24.96	24.79	4	23.41	-9006
04-11-2021 08:44	23.59	19.47	22.71	24.96	24.80	4	23.41	-9006
04-11-2021 08:45	23.59	19.47	22.72	24.97	24.79	4	23.41	-9006
04-11-2021 08:46	23.58	19.47	22.72	24.98	24.79	3	23.42	-9006
04-11-2021 08:47	23.58	19.48	22.73	24.98	24.79	4	23.41	-9006
04-11-2021 08:48	23.59	19.48	22.73	24.98	24.79	3	23.41	-9006



Environmental Monitoring System

DATA REPORT

TS LOADING & UNLOADING-SPARE ROOM

Date Time	TS LOADING ROOM	TS UNLOADING ROOM	QUARENTINE ROOM	MEDIA FILLED UNIT IN INCUBATION	MATERIAL TO EXIT	MATERIAL TO EXIT wrt CORRIDOR	DECORTNING ROOM	DECORTNING ROOM wrt CORRIDOR
Date Time	°C TEMP	°C TEMP	°C TEMP	°C TEMP	°C TEMP	DP Pa	°C TEMP	DP Pa
04-11-2021 08:49	23.58	19.48	22.73	24.99	24.79	4	23.41	-9006
04-11-2021 08:50	23.60	19.49	22.72	25.00	24.78	4	23.41	-9006
04-11-2021 08:51	23.59	19.49	22.72	24.99	24.77	3	23.42	-9006
04-11-2021 08:52	23.60	19.49	22.72	24.98	24.78	4	23.41	-9006
04-11-2021 08:53	23.59	19.49	22.73	24.98	24.79	4	23.40	-9006
04-11-2021 08:54	23.58	19.49	22.73	25.00	24.79	4	23.42	-9006
04-11-2021 08:55	23.58	19.48	22.74	25.01	24.80	4	23.43	-9006
04-11-2021 08:56	23.59	19.48	22.75	25.01	24.79	4	23.42	-9006
04-11-2021 08:57	23.58	19.49	22.74	25.02	24.79	4	23.43	-9006
04-11-2021 08:58	23.59	19.49	22.75	25.02	24.79	4	23.43	-9006
04-11-2021 08:59	23.59	19.49	22.75	25.01	24.79	3	23.43	-9006
04-11-2021 09:00	23.60	19.50	22.74	25.00	24.78	4	23.44	-9006
04-11-2021 09:01	23.60	19.50	22.74	25.01	24.77	4	23.44	-9006
04-11-2021 09:02	23.60	19.50	22.74	25.02	24.77	4	23.44	-9006
04-11-2021 09:03	23.60	19.51	22.73	25.02	24.77	4	23.43	-9006
04-11-2021 09:04	23.61	19.51	22.75	25.03	24.78	4	23.43	-9006
04-11-2021 09:05	23.61	19.50	22.75	25.03	24.77	4	23.43	-9006
04-11-2021 09:06	23.62	19.50	22.75	25.03	24.76	4	23.44	-9006
04-11-2021 09:07	23.62	19.51	22.76	25.02	24.78	4	23.44	-9006
04-11-2021 09:08	23.61	19.50	22.73	25.01	24.78	4	23.44	-9006
04-11-2021 09:09	23.63	19.50	22.74	25.01	24.77	4	23.44	-9006
04-11-2021 09:10	23.63	19.50	22.73	25.00	24.76	4	23.44	-9006
04-11-2021 09:11	23.63	19.52	22.72	25.01	24.78	3	23.45	-9006
04-11-2021 09:12	23.63	19.51	22.72	25.01	24.78	4	23.44	-9006
04-11-2021 09:13	23.62	19.49	22.72	25.00	24.77	3	23.45	-9006
04-11-2021 09:14	23.64	19.51	22.71	25.01	24.78	3	23.44	-9006
04-11-2021 09:15	23.63	19.52	22.72	25.02	24.78	4	23.44	-9006
04-11-2021 09:16	23.63	19.52	22.72	25.02	24.77	4	23.45	-9006



Environmental Monitoring System

DATA REPORT

TS LOADING & UNLOADING-SPARE ROOM

Date Time	TS LOADING ROOM	TS UNLOADING ROOM	QUARENTINE ROOM	MEDIA FILLED UNIT IN INCUBATION	MATERIAL TO EXIT	MATERIAL TO EXIT wrt CORRIDOR	DECORTNING ROOM	DECORTNING ROOM wrt CORRIDOR
Date Time	°C TEMP	°C TEMP	°C TEMP	°C TEMP	°C TEMP	DP Pa	°C TEMP	DP Pa
04-11-2021 09:17	23.62	19.50	22.72	25.02	24.78	4	23.45	-9006
04-11-2021 09:18	23.62	19.51	22.71	25.01	24.78	3	23.44	-9006
04-11-2021 09:19	23.64	19.52	22.72	25.01	24.77	4	23.45	-9006
04-11-2021 09:20	23.64	19.53	22.72	25.03	24.79	4	23.46	-9006
04-11-2021 09:21	23.64	19.52	22.72	25.02	24.78	4	23.46	-9006
04-11-2021 09:22	23.65	19.53	22.73	25.02	24.79	4	23.46	-9006
04-11-2021 09:23	23.64	19.53	22.72	25.03	24.78	4	23.46	-9006
04-11-2021 09:24	23.65	19.54	22.72	25.02	24.78	3	23.46	-9006
04-11-2021 09:25	23.64	19.54	22.72	25.02	24.76	4	23.47	-9006
04-11-2021 09:26	23.65	19.55	22.72	25.02	24.80	4	23.49	-9006
04-11-2021 09:27	23.65	19.56	22.71	25.04	24.78	3	23.48	-9006
04-11-2021 09:28	23.65	19.54	22.72	25.05	24.78	4	23.48	-9006
04-11-2021 09:29	23.65	19.53	22.72	25.04	24.77	4	23.49	-9006
04-11-2021 09:30	23.65	19.55	22.72	25.04	24.77	4	23.48	-9006
04-11-2021 09:31	23.64	19.55	22.73	25.05	24.76	4	23.50	-9006
04-11-2021 09:32	23.66	19.54	22.74	25.04	24.76	4	23.49	-9006
04-11-2021 09:33	23.66	19.55	22.73	25.05	24.77	4	23.49	-9006
04-11-2021 09:34	23.66	19.56	22.73	25.05	24.76	4	23.50	-9006
04-11-2021 09:35	23.67	19.56	22.73	25.05	24.76	4	23.49	-9006
04-11-2021 09:36	23.67	19.55	22.73	25.05	24.76	4	23.49	-9006
04-11-2021 09:37	23.67	19.55	22.73	25.04	24.75	4	23.49	-9006
04-11-2021 09:38	23.68	19.55	22.74	25.04	24.75	3	23.49	-9006
04-11-2021 09:39	23.68	19.56	22.73	25.07	24.77	3	23.49	-9006
04-11-2021 09:40	23.67	19.55	22.74	25.06	24.76	3	23.50	-9006
04-11-2021 09:41	23.67	19.56	22.74	25.05	24.76	4	23.50	-9006
04-11-2021 09:42	23.68	19.56	22.74	25.05	24.75	4	23.50	-9006
04-11-2021 09:43	23.69	19.56	22.74	25.04	24.75	3	23.50	-9006
04-11-2021 09:44	23.69	19.56	22.74	25.05	24.75	4	23.51	-9006



Environmental Monitoring System

DATA REPORT

TS LOADING & UNLOADING-SPARE ROOM

Date Time	TS LOADING ROOM	TS UNLOADING ROOM	QUARENTINE ROOM	MEDIA FILLED UNIT IN INCUBATION	MATERIAL TO EXIT	MATERIAL TO EXIT wrt CORRIDOR	DECORTNING ROOM	DECORTNING ROOM wrt CORRIDOR
Date Time	°C TEMP	°C TEMP	°C TEMP	°C TEMP	°C TEMP	DP Pa	°C TEMP	DP Pa
04-11-2021 09:45	23.70	19.57	22.74	25.04	24.73	3	23.51	-9006
04-11-2021 09:46	23.69	19.58	22.74	25.05	24.74	4	23.51	-9006
04-11-2021 09:47	23.70	19.57	22.75	25.07	24.74	4	23.51	-9006
04-11-2021 09:48	23.71	19.59	22.76	25.06	24.75	4	23.51	-9006
04-11-2021 09:49	23.71	19.58	22.77	25.07	24.75	3	23.51	-9006
04-11-2021 09:50	23.71	19.59	22.76	25.08	24.75	4	23.51	-9006
04-11-2021 09:51	23.70	19.59	22.77	25.07	24.74	3	23.52	-9006
04-11-2021 09:52	23.71	19.59	22.78	25.07	24.74	4	23.51	-9006
04-11-2021 09:53	23.72	19.59	22.78	25.08	24.76	4	23.53	-9006
04-11-2021 09:54	23.73	19.59	22.79	25.09	24.74	4	23.53	-9006
04-11-2021 09:55	23.73	19.60	22.78	25.10	24.75	3	23.53	-9006
04-11-2021 09:56	23.74	19.60	22.78	25.11	24.74	3	23.53	-9006
04-11-2021 09:57	23.73	19.61	22.79	25.11	24.75	4	23.53	-9006
04-11-2021 09:58	23.76	19.62	22.79	25.11	24.74	3	23.54	-9006
04-11-2021 09:59	23.74	19.61	22.79	25.11	24.75	4	23.54	-9006
04-11-2021 10:00	23.76	19.62	22.80	25.11	24.74	4	23.55	-9006
04-11-2021 10:01	23.77	19.62	22.80	25.11	24.74	3	23.54	-9006
04-11-2021 10:02	23.77	19.63	22.80	25.10	24.75	3	23.55	-9006
04-11-2021 10:03	23.77	19.63	22.80	25.09	24.77	4	23.55	-9006
04-11-2021 10:04	23.78	19.63	22.81	25.09	24.75	4	23.56	-9006
04-11-2021 10:05	23.78	19.63	22.82	25.09	24.76	3	23.56	-9006
04-11-2021 10:06	23.79	19.63	22.81	25.10	24.76	4	23.56	-9006
04-11-2021 10:07	23.80	19.64	22.82	25.10	24.76	3	23.56	-9006
04-11-2021 10:08	23.79	19.64	22.82	25.09	24.75	4	23.57	-9006
04-11-2021 10:09	23.79	19.65	22.83	25.10	24.76	4	23.55	-9006
04-11-2021 10:10	23.80	19.64	22.83	25.13	24.75	4	23.56	-9006
04-11-2021 10:11	23.82	19.64	22.82	25.12	24.75	4	23.56	-9006
04-11-2021 10:12	23.80	19.65	22.83	25.10	24.76	4	23.58	-9006



Environmental Monitoring System

DATA REPORT

TS LOADING & UNLOADING-SPARE ROOM

Date Time	TS LOADING ROOM	TS UNLOADING ROOM	QUARENTINE ROOM	MEDIA FILLED UNIT IN INCUBATION	MATERIAL TO EXIT	MATERIAL TO EXIT wrt CORRIDOR	DECORTNING ROOM	DECORTNING ROOM wrt CORRIDOR
Date Time	°C TEMP	°C TEMP	°C TEMP	°C TEMP	°C TEMP	DP Pa	°C TEMP	DP Pa
04-11-2021 10:13	23.82	19.65	22.83	25.11	24.77	4	23.58	-9006
04-11-2021 10:14	23.84	19.66	22.84	25.12	24.76	4	23.57	-9006
04-11-2021 10:15	23.83	19.66	22.85	25.14	24.76	4	23.57	-9006
04-11-2021 10:16	23.85	19.65	22.86	25.13	24.76	3	23.57	-9006
04-11-2021 10:17	23.83	19.65	22.86	25.14	24.76	4	23.58	-9006
04-11-2021 10:18	23.84	19.66	22.86	25.13	24.77	4	23.59	-9006
04-11-2021 10:19	23.83	19.66	22.86	25.15	24.77	4	23.60	-9006
04-11-2021 10:20	23.82	19.67	22.86	25.12	24.75	4	23.59	-9006
04-11-2021 10:21	23.83	19.65	22.85	25.13	24.76	3	23.59	-9006
04-11-2021 10:22	23.80	19.65	22.85	25.13	24.77	4	23.59	-9006
04-11-2021 10:23	23.80	19.65	22.84	25.13	24.76	3	23.59	-9006
04-11-2021 10:24	23.78	19.65	22.84	25.13	24.75	3	23.60	-9006
04-11-2021 10:25	23.76	19.66	22.83	25.13	24.75	3	23.60	-9006
04-11-2021 10:26	23.74	19.65	22.83	25.13	24.77	4	23.60	-9006
04-11-2021 10:27	23.73	19.64	22.82	25.13	24.77	4	23.60	-9006
04-11-2021 10:28	23.70	19.64	22.83	25.12	24.75	4	23.59	-9006
04-11-2021 10:29	23.69	19.63	22.81	25.12	24.77	3	23.60	-9006
04-11-2021 10:30	23.68	19.62	22.80	25.13	24.77	4	23.61	-9006
04-11-2021 10:31	23.65	19.60	22.79	25.13	24.78	4	23.61	-9006
04-11-2021 10:32	23.61	19.60	22.77	25.12	24.76	4	23.60	-9006
04-11-2021 10:33	23.59	19.60	22.75	25.11	24.78	4	23.60	-9006
04-11-2021 10:34	23.57	19.60	22.76	25.11	24.79	4	23.60	-9006
04-11-2021 10:35	23.56	19.59	22.75	25.14	24.78	3	23.61	-9006
04-11-2021 10:36	23.55	19.58	22.74	25.12	24.77	4	23.60	-9006
04-11-2021 10:37	23.52	19.57	22.72	25.14	24.78	4	23.60	-9006
04-11-2021 10:38	23.50	19.57	22.72	25.12	24.78	3	23.60	-9006
04-11-2021 10:39	23.48	19.56	22.71	25.12	24.78	4	23.59	-9006
04-11-2021 10:40	23.47	19.56	22.70	25.12	24.78	4	23.60	-9006



Environmental Monitoring System

DATA REPORT

TS LOADING & UNLOADING-SPARE ROOM

Date Time	TS LOADING ROOM	TS UNLOADING ROOM	QUARENTINE ROOM	MEDIA FILLED UNIT IN INCUBATION	MATERIAL TO EXIT	MATERIAL TO EXIT wrt CORRIDOR	DECORTNING ROOM	DECORTNING ROOM wrt CORRIDOR
Date Time	°C TEMP	°C TEMP	°C TEMP	°C TEMP	°C TEMP	DP Pa	°C TEMP	DP Pa
04-11-2021 10:41	23.47	19.60	22.69	25.13	24.77	4	23.59	-9006
04-11-2021 10:42	23.45	19.59	22.68	25.11	24.79	3	23.59	-9006
04-11-2021 10:43	23.44	19.57	22.68	25.11	24.79	3	23.58	-9006
04-11-2021 10:44	23.42	19.54	22.69	25.13	24.78	3	23.58	-9006
04-11-2021 10:45	23.41	19.54	22.68	25.13	24.79	3	23.59	-9006
04-11-2021 10:46	23.39	19.53	22.68	25.14	24.79	3	23.60	-9006
04-11-2021 10:47	23.39	19.52	22.67	25.13	24.79	4	23.60	-9006
04-11-2021 10:48	23.38	19.52	22.65	25.12	24.79	4	23.59	-9006
04-11-2021 10:49	23.36	19.51	22.64	25.12	24.78	4	23.59	-9006
04-11-2021 10:50	23.36	19.51	22.64	25.12	24.78	4	23.60	-9006
04-11-2021 10:51	23.34	19.50	22.63	25.13	24.78	4	23.59	-9006
04-11-2021 10:52	23.34	19.47	22.61	25.12	24.78	4	23.60	-9006
04-11-2021 10:53	23.35	19.48	22.60	25.12	24.77	3	23.59	-9006
04-11-2021 10:54	23.33	19.47	22.61	25.14	24.75	4	23.59	-9006
04-11-2021 10:55	23.33	19.47	22.60	25.13	24.77	4	23.59	-9006
04-11-2021 10:56	23.30	19.46	22.59	25.11	24.77	4	23.59	-9006
04-11-2021 10:57	23.28	19.46	22.57	25.10	24.77	4	23.59	-9006
04-11-2021 10:58	23.28	19.44	22.57	25.11	24.78	4	23.59	-9006
04-11-2021 10:59	23.29	19.45	22.57	25.10	24.77	4	23.59	-9006
04-11-2021 11:00	23.27	19.44	22.56	25.10	24.76	4	23.59	-9006
04-11-2021 11:01	23.28	19.43	22.56	25.09	24.75	4	23.59	-9006
04-11-2021 11:02	23.26	19.43	22.57	25.10	24.77	3	23.58	-9006
04-11-2021 11:03	23.26	19.42	22.55	25.09	24.75	4	23.58	-9006
04-11-2021 11:04	23.24	19.42	22.54	25.10	24.76	3	23.59	-9006
04-11-2021 11:05	23.24	19.40	22.53	25.11	24.75	0	23.58	-9006
04-11-2021 11:06	23.23	19.41	22.52	25.10	24.74	3	23.58	-9006
04-11-2021 11:07	23.23	19.40	22.51	25.10	24.74	4	23.58	-9006
04-11-2021 11:08	23.23	19.40	22.51	25.10	24.75	4	23.59	-9006



Environmental Monitoring System

DATA REPORT

TS LOADING & UNLOADING-SPARE ROOM

Date Time	TS LOADING ROOM	TS UNLOADING ROOM	QUARENTINE ROOM	MEDIA FILLED UNIT IN INCUBATION	MATERIAL TO EXIT	MATERIAL TO EXIT wrt CORRIDOR	DECORTNING ROOM	DECORTNING ROOM wrt CORRIDOR
Date Time	°C TEMP	°C TEMP	°C TEMP	°C TEMP	°C TEMP	DP Pa	°C TEMP	DP Pa
04-11-2021 11:09	23.22	19.39	22.52	25.11	24.75	3	23.58	-9006
04-11-2021 11:10	23.22	19.39	22.53	25.10	24.74	4	23.59	-9006
04-11-2021 11:11	23.21	19.38	22.54	25.08	24.75	4	23.56	-9006
04-11-2021 11:12	23.20	19.38	22.52	25.08	24.75	4	23.58	-9006
04-11-2021 11:13	23.21	19.39	22.52	25.07	24.74	4	23.57	-9006
04-11-2021 11:14	23.22	19.39	22.52	25.07	24.73	3	23.58	-9006
04-11-2021 11:15	23.19	19.38	22.53	25.06	24.72	4	23.58	-9006
04-11-2021 11:16	23.18	19.38	22.53	25.05	24.73	4	23.56	-9006
04-11-2021 11:17	23.18	19.37	22.52	25.05	24.75	3	23.59	-9006
04-11-2021 11:18	23.20	19.36	22.52	25.05	24.73	4	23.58	-9006
04-11-2021 11:19	23.18	19.37	22.52	25.06	24.74	4	23.57	-9006
04-11-2021 11:20	23.17	19.35	22.52	25.07	24.73	4	23.58	-9006
04-11-2021 11:21	23.18	19.35	22.51	25.04	24.73	4	23.58	-9006
04-11-2021 11:22	23.17	19.34	22.51	25.05	24.74	4	23.58	-9006
04-11-2021 11:23	23.18	19.34	22.51	25.05	24.74	3	23.58	-9006
04-11-2021 11:24	23.17	19.34	22.52	25.03	24.74	4	23.58	-9006
04-11-2021 11:25	23.16	19.34	22.52	25.03	24.74	4	23.59	-9006
04-11-2021 11:26	23.17	19.33	22.52	25.04	24.74	3	23.57	-9006
04-11-2021 11:27	23.16	19.33	22.51	25.03	24.73	4	23.58	-9006
04-11-2021 11:28	23.16	19.33	22.52	25.02	24.74	4	23.59	-9006
04-11-2021 11:29	23.16	19.34	22.52	25.03	24.75	4	23.59	-9006
04-11-2021 11:30	23.15	19.33	22.52	25.02	24.74	4	23.58	-9006
04-11-2021 11:31	23.15	19.34	22.52	25.00	24.75	3	23.59	-9006
04-11-2021 11:32	23.16	19.33	22.51	24.99	24.73	4	23.58	-9006
04-11-2021 11:33	23.16	19.33	22.50	25.00	24.73	3	23.58	-9006
04-11-2021 11:34	23.16	19.34	22.51	24.99	24.73	4	23.59	-9006
04-11-2021 11:35	23.16	19.34	22.50	24.98	24.73	4	23.59	-9006
04-11-2021 11:36	23.16	19.33	22.50	24.97	24.73	3	23.59	-9006



Environmental Monitoring System

DATA REPORT

TS LOADING & UNLOADING-SPARE ROOM

Date Time	TS LOADING ROOM	TS UNLOADING ROOM	QUARENTINE ROOM	MEDIA FILLED UNIT IN INCUBATION	MATERIAL TO EXIT	MATERIAL TO EXIT wrt CORRIDOR	DECORTNING ROOM	DECORTNING ROOM wrt CORRIDOR
Date Time	°C TEMP	°C TEMP	°C TEMP	°C TEMP	°C TEMP	DP Pa	°C TEMP	DP Pa
04-11-2021 11:37	23.18	19.33	22.50	24.98	24.73	4	23.59	-9006
04-11-2021 11:38	23.16	19.32	22.50	24.97	24.75	4	23.59	-9006
04-11-2021 11:39	23.17	19.32	22.51	24.97	24.74	4	23.59	-9006
04-11-2021 11:40	23.16	19.31	22.51	24.95	24.74	3	23.59	-9006
04-11-2021 11:41	23.15	19.31	22.50	24.95	24.73	4	23.61	-9006
04-11-2021 11:42	23.15	19.31	22.51	24.97	24.74	4	23.60	-9006
04-11-2021 11:43	23.17	19.30	22.51	24.96	24.75	4	23.60	-9006
04-11-2021 11:44	23.16	19.31	22.50	24.95	24.74	3	23.60	-9006
04-11-2021 11:45	23.16	19.32	22.50	24.94	24.74	3	23.60	-9006
04-11-2021 11:46	23.17	19.32	22.51	24.96	24.74	3	23.60	-9006
04-11-2021 11:47	23.17	19.31	22.52	24.94	24.73	4	23.60	-9006
04-11-2021 11:48	23.17	19.31	22.51	24.95	24.74	4	23.59	-9006
04-11-2021 11:49	23.17	19.30	22.51	24.97	24.75	4	23.59	-9006
04-11-2021 11:50	23.18	19.31	22.51	24.97	24.73	3	23.60	-9006
04-11-2021 11:51	23.17	19.31	22.51	24.98	24.73	4	23.59	-9006
04-11-2021 11:52	23.17	19.32	22.51	24.98	24.73	4	23.59	-9006
04-11-2021 11:53	23.17	19.30	22.50	24.99	24.74	4	23.60	-9006
04-11-2021 11:54	23.15	19.31	22.50	24.97	24.72	4	23.61	-9006
04-11-2021 11:55	23.15	19.31	22.49	24.95	24.73	4	23.59	-9006
04-11-2021 11:56	23.16	19.31	22.49	24.95	24.72	3	23.61	-9006
04-11-2021 11:57	23.17	19.30	22.50	24.93	24.71	3	23.60	-9006
04-11-2021 11:58	23.18	19.29	22.49	24.95	24.71	4	23.61	-9006
04-11-2021 11:59	23.17	19.29	22.50	24.94	24.70	4	23.61	-9006
04-11-2021 12:00	23.18	19.28	22.50	24.95	24.71	4	23.61	-9006
04-11-2021 12:01	23.18	19.28	22.50	24.95	24.70	3	23.61	-9006
04-11-2021 12:02	23.17	19.28	22.49	24.96	24.70	3	23.62	-9006
04-11-2021 12:03	23.16	19.29	22.50	24.94	24.70	3	23.62	-9006
04-11-2021 12:04	23.17	19.29	22.50	24.94	24.72	4	23.63	-9006



Environmental Monitoring System

DATA REPORT

TS LOADING & UNLOADING-SPARE ROOM

Date Time	TS LOADING ROOM	TS UNLOADING ROOM	QUARENTINE ROOM	MEDIA FILLED UNIT IN INCUBATION	MATERIAL TO EXIT	MATERIAL TO EXIT wrt CORRIDOR	DECORTNING ROOM	DECORTNING ROOM wrt CORRIDOR
Date Time	°C TEMP	°C TEMP	°C TEMP	°C TEMP	°C TEMP	DP Pa	°C TEMP	DP Pa
04-11-2021 12:05	23.16	19.29	22.49	24.93	24.70	3	23.63	-9006
04-11-2021 12:06	23.16	19.29	22.51	24.94	24.70	4	23.63	-9006
04-11-2021 12:07	23.17	19.29	22.50	24.95	24.70	3	23.63	-9006
04-11-2021 12:08	23.17	19.28	22.49	24.95	24.70	3	23.64	-9006
04-11-2021 12:09	23.17	19.29	22.48	24.93	24.70	4	23.62	-9006
04-11-2021 12:10	23.18	19.28	22.49	24.93	24.71	3	23.63	-9006
04-11-2021 12:11	23.17	19.28	22.48	24.94	24.70	4	23.64	-9006
04-11-2021 12:12	23.17	19.28	22.48	24.93	24.71	3	23.63	-9006
04-11-2021 12:13	23.17	19.28	22.47	24.91	24.69	4	23.64	-9006
04-11-2021 12:14	23.17	19.29	22.47	24.95	24.72	4	23.64	-9006
04-11-2021 12:15	23.17	19.28	22.46	24.93	24.71	4	23.65	-9006
04-11-2021 12:16	23.17	19.29	22.46	24.93	24.71	3	23.64	-9006
04-11-2021 12:17	23.17	19.28	22.47	24.92	24.70	4	23.65	-9006
04-11-2021 12:18	23.17	19.28	22.47	24.91	24.72	4	23.66	-9006
04-11-2021 12:19	23.17	19.28	22.47	24.89	24.72	4	23.66	-9006
04-11-2021 12:20	23.15	19.27	22.48	24.88	24.72	4	23.66	-9006
04-11-2021 12:21	23.16	19.28	22.47	24.89	24.72	3	23.66	-9006
04-11-2021 12:22	23.15	19.28	22.47	24.90	24.71	3	23.66	-9006
04-11-2021 12:23	23.14	19.28	22.47	24.91	24.72	3	23.67	-9006
04-11-2021 12:24	23.15	19.27	22.47	24.90	24.72	4	23.67	-9006
04-11-2021 12:25	23.16	19.27	22.46	24.89	24.72	4	23.67	-9006
04-11-2021 12:26	23.17	19.26	22.45	24.88	24.72	3	23.67	-9006
04-11-2021 12:27	23.16	19.27	22.46	24.87	24.73	3	23.67	-9006
04-11-2021 12:28	23.15	19.27	22.46	24.87	24.72	4	23.67	-9006
04-11-2021 12:29	23.16	19.27	22.44	24.87	24.72	4	23.66	-9006
04-11-2021 12:30	23.16	19.27	22.46	24.88	24.73	4	23.68	-9006
04-11-2021 12:31	23.17	19.26	22.48	24.88	24.73	3	23.70	-9006
04-11-2021 12:32	23.15	19.27	22.47	24.87	24.73	3	23.69	-9006



Environmental Monitoring System

DATA REPORT

TS LOADING & UNLOADING-SPARE ROOM

Date Time	TS LOADING ROOM	TS UNLOADING ROOM	QUARENTINE ROOM	MEDIA FILLED UNIT IN INCUBATION	MATERIAL TO EXIT	MATERIAL TO EXIT wrt CORRIDOR	DECORTNING ROOM	DECORTNING ROOM wrt CORRIDOR
Date Time	°C TEMP	°C TEMP	°C TEMP	°C TEMP	°C TEMP	DP Pa	°C TEMP	DP Pa
04-11-2021 12:33	23.15	19.27	22.47	24.86	24.72	4	23.70	-9006
04-11-2021 12:34	23.14	19.27	22.47	24.86	24.73	4	23.70	-9006
04-11-2021 12:35	23.16	19.26	22.48	24.86	24.75	3	23.70	-9006
04-11-2021 12:36	23.16	19.26	22.47	24.87	24.75	4	23.70	-9006
04-11-2021 12:37	23.16	19.26	22.47	24.86	24.75	3	23.70	-9006
04-11-2021 12:38	23.15	19.27	22.48	24.86	24.74	3	23.71	-9006
04-11-2021 12:39	23.15	19.26	22.49	24.87	24.75	3	23.70	-9006
04-11-2021 12:40	23.16	19.27	22.49	24.88	24.74	4	23.70	-9006
04-11-2021 12:41	23.16	19.26	22.47	24.86	24.76	3	23.70	-9006
04-11-2021 12:42	23.16	19.27	22.46	24.86	24.75	4	23.70	-9006
04-11-2021 12:43	23.17	19.26	22.47	24.86	24.74	4	23.72	-9006
04-11-2021 12:44	23.17	19.27	22.47	24.85	24.75	4	23.71	-9006
04-11-2021 12:45	23.17	19.27	22.47	24.85	24.75	3	23.71	-9006
04-11-2021 12:46	23.18	19.26	22.47	24.87	24.75	3	23.71	-9006
04-11-2021 12:47	23.18	19.27	22.47	24.86	24.74	3	23.71	-9006
04-11-2021 12:48	23.20	19.27	22.47	24.86	24.75	3	23.71	-9006
04-11-2021 12:49	23.17	19.27	22.47	24.89	24.75	3	23.73	-9006
04-11-2021 12:50	23.17	19.27	22.47	24.89	24.74	3	23.72	-9006
04-11-2021 12:51	23.18	19.28	22.47	24.88	24.76	3	23.72	-9006
04-11-2021 12:52	23.16	19.27	22.48	24.86	24.75	4	23.73	-9006
04-11-2021 12:53	23.18	19.27	22.47	24.86	24.74	4	23.72	-9006
04-11-2021 12:54	23.17	19.26	22.47	24.86	24.74	4	23.75	-9006
04-11-2021 12:55	23.17	19.27	22.47	24.86	24.73	4	23.74	-9006
04-11-2021 12:56	23.18	19.26	22.48	24.88	24.74	3	23.74	-9006
04-11-2021 12:57	23.19	19.26	22.48	24.89	24.73	3	23.74	-9006
04-11-2021 12:58	23.19	19.25	22.49	24.87	24.74	4	23.75	-9006
04-11-2021 12:59	23.19	19.25	22.48	24.86	24.73	4	23.74	-9006
04-11-2021 13:00	23.20	19.25	22.50	24.88	24.73	3	23.76	-9006



Environmental Monitoring System

DATA REPORT

TS LOADING & UNLOADING-SPARE ROOM

Date Time	TS LOADING ROOM	TS UNLOADING ROOM	QUARENTINE ROOM	MEDIA FILLED UNIT IN INCUBATION	MATERIAL TO EXIT	MATERIAL TO EXIT wrt CORRIDOR	DECORTNING ROOM	DECORTNING ROOM wrt CORRIDOR
Date Time	°C TEMP	°C TEMP	°C TEMP	°C TEMP	°C TEMP	DP Pa	°C TEMP	DP Pa
04-11-2021 13:01	23.20	19.26	22.48	24.87	24.73	3	23.75	-9006
04-11-2021 13:02	23.20	19.26	22.48	24.87	24.71	3	23.76	-9006
04-11-2021 13:03	23.21	19.26	22.49	24.87	24.70	4	23.76	-9006
04-11-2021 13:04	23.20	19.26	22.48	24.87	24.72	4	23.76	-9006
04-11-2021 13:05	23.21	19.25	22.49	24.86	24.69	4	23.77	-9006
04-11-2021 13:06	23.19	19.25	22.49	24.85	24.70	0	23.77	-9006
04-11-2021 13:07	23.20	19.26	22.49	24.85	24.69	4	23.78	-9006
04-11-2021 13:08	23.20	19.27	22.48	24.87	24.69	3	23.77	-9006
04-11-2021 13:09	23.20	19.27	22.49	24.86	24.70	0	23.78	-9006
04-11-2021 13:10	23.19	19.26	22.49	24.85	24.69	4	23.77	-9006
04-11-2021 13:11	23.19	19.25	22.49	24.85	24.68	3	23.78	-9006
04-11-2021 13:12	23.18	19.25	22.51	24.87	24.67	3	23.78	-9006
04-11-2021 13:13	23.19	19.25	22.50	24.89	24.69	3	23.78	-9006
04-11-2021 13:14	23.21	19.27	22.50	24.88	24.69	4	23.78	-9006
04-11-2021 13:15	23.20	19.28	22.50	24.89	24.69	4	23.78	-9006
04-11-2021 13:16	23.21	19.27	22.50	24.89	24.70	4	23.79	-9006
04-11-2021 13:17	23.23	19.27	22.52	24.88	24.70	3	23.79	-9006
04-11-2021 13:18	23.22	19.27	22.51	24.90	24.69	4	23.80	-9006
04-11-2021 13:19	23.23	19.27	22.51	24.88	24.69	4	23.80	-9006
04-11-2021 13:20	23.23	19.27	22.52	24.89	24.69	4	23.79	-9006
04-11-2021 13:21	23.23	19.27	22.53	24.91	24.70	4	23.81	-9006
04-11-2021 13:22	23.23	19.28	22.51	24.89	24.70	3	23.81	-9006
04-11-2021 13:23	23.22	19.26	22.51	24.90	24.72	4	23.81	-9006
04-11-2021 13:24	23.23	19.28	22.52	24.91	24.72	3	23.81	-9006
04-11-2021 13:25	23.22	19.27	22.52	24.90	24.72	4	23.81	-9006
04-11-2021 13:26	23.23	19.27	22.53	24.89	24.72	3	23.82	-9006
04-11-2021 13:27	23.24	19.27	22.53	24.89	24.72	4	23.82	-9006
04-11-2021 13:28	23.25	19.27	22.53	24.90	24.72	3	23.83	-9006



Environmental Monitoring System

DATA REPORT

TS LOADING & UNLOADING-SPARE ROOM

Date Time	TS LOADING ROOM	TS UNLOADING ROOM	QUARENTINE ROOM	MEDIA FILLED UNIT IN INCUBATION	MATERIAL TO EXIT	MATERIAL TO EXIT wrt CORRIDOR	DECORTNING ROOM	DECORTNING ROOM wrt CORRIDOR
Date Time	°C TEMP	°C TEMP	°C TEMP	°C TEMP	°C TEMP	DP Pa	°C TEMP	DP Pa
04-11-2021 13:29	23.23	19.27	22.54	24.93	24.73	3	23.83	-9006
04-11-2021 13:30	23.24	19.28	22.53	24.91	24.72	4	23.83	-9006
04-11-2021 13:31	23.24	19.28	22.53	24.92	24.72	4	23.83	-9006
04-11-2021 13:32	23.24	19.29	22.53	24.92	24.74	3	23.84	-9006
04-11-2021 13:33	23.26	19.29	22.53	24.91	24.74	4	23.84	-9006
04-11-2021 13:34	23.26	19.29	22.53	24.93	24.73	3	23.84	-9006
04-11-2021 13:35	23.26	19.30	22.52	24.91	24.75	3	23.85	-9006
04-11-2021 13:36	23.26	19.29	22.53	24.91	24.75	3	23.86	-9006
04-11-2021 13:37	23.27	19.29	22.54	24.91	24.75	4	23.86	-9006
04-11-2021 13:38	23.30	19.30	22.54	24.91	24.76	3	23.86	-9006
04-11-2021 13:39	23.30	19.30	22.54	24.92	24.75	4	23.86	-9006
04-11-2021 13:40	23.31	19.30	22.56	24.92	24.76	3	23.87	-9006
04-11-2021 13:41	23.31	19.31	22.55	24.93	24.76	3	23.87	-9006
04-11-2021 13:42	23.32	19.30	22.54	24.92	24.77	4	23.87	-9006
04-11-2021 13:43	23.33	19.30	22.54	24.91	24.78	4	23.88	-9006
04-11-2021 13:44	23.33	19.31	22.56	24.91	24.78	4	23.88	-9006
04-11-2021 13:45	23.34	19.32	22.56	24.91	24.78	3	23.88	-9006
04-11-2021 13:46	23.35	19.31	22.55	24.92	24.77	4	23.89	-9006
04-11-2021 13:47	23.33	19.32	22.56	24.92	24.77	4	23.90	-9006
04-11-2021 13:48	23.34	19.32	22.55	24.92	24.78	3	23.90	-9006
04-11-2021 13:49	23.34	19.32	22.57	24.93	24.78	3	23.91	-9006
04-11-2021 13:50	23.35	19.32	22.56	24.93	24.78	4	23.92	-9006
04-11-2021 13:51	23.37	19.32	22.56	24.94	24.78	4	23.92	-9006
04-11-2021 13:52	23.37	19.33	22.56	24.94	24.77	4	23.92	-9006
04-11-2021 13:53	23.38	19.33	22.56	24.94	24.78	3	23.93	-9006
04-11-2021 13:54	23.36	19.34	22.56	24.94	24.75	4	23.93	-9006
04-11-2021 13:55	23.37	19.34	22.56	24.96	24.76	3	23.94	-9006
04-11-2021 13:56	23.37	19.35	22.57	24.96	24.75	4	23.93	-9006



Environmental Monitoring System

DATA REPORT

TS LOADING & UNLOADING-SPARE ROOM

Date Time	TS LOADING ROOM	TS UNLOADING ROOM	QUARENTINE ROOM	MEDIA FILLED UNIT IN INCUBATION	MATERIAL TO EXIT	MATERIAL TO EXIT wrt CORRIDOR	DECORTNING ROOM	DECORTNING ROOM wrt CORRIDOR
Date Time	°C TEMP	°C TEMP	°C TEMP	°C TEMP	°C TEMP	DP Pa	°C TEMP	DP Pa
04-11-2021 13:57	23.39	19.34	22.56	24.95	24.76	3	23.94	-9006
04-11-2021 13:58	23.38	19.35	22.58	24.96	24.77	4	23.95	-9006
04-11-2021 13:59	23.38	19.35	22.59	24.98	24.75	4	23.95	-9006
04-11-2021 14:00	23.38	19.35	22.59	24.97	24.76	4	23.94	-9006
04-11-2021 14:01	23.38	19.35	22.60	24.96	24.76	3	23.95	-9006
04-11-2021 14:02	23.39	19.35	22.60	24.97	24.75	3	23.96	-9006
04-11-2021 14:03	23.38	19.35	22.61	24.98	24.75	4	23.96	-9006
04-11-2021 14:04	23.38	19.35	22.61	24.97	24.74	3	23.96	-9006
04-11-2021 14:05	23.37	19.36	22.61	24.98	24.74	3	23.97	-9006
04-11-2021 14:06	23.38	19.35	22.60	24.97	24.73	4	23.98	-9006
04-11-2021 14:07	23.38	19.37	22.60	24.97	24.73	4	23.98	-9006
04-11-2021 14:08	23.38	19.36	22.60	24.97	24.73	3	23.98	-9006
04-11-2021 14:09	23.36	19.36	22.61	24.97	24.73	4	23.99	-9006
04-11-2021 14:10	23.36	19.37	22.61	24.96	24.73	4	23.98	-9006
04-11-2021 14:11	23.32	19.35	22.60	24.97	24.72	4	23.99	-9006
04-11-2021 14:12	23.33	19.35	22.60	24.96	24.72	4	24.00	-9006
04-11-2021 14:13	23.32	19.36	22.60	24.96	24.72	4	24.00	-9006
04-11-2021 14:14	23.33	19.35	22.59	24.97	24.71	4	24.01	-9006
04-11-2021 14:15	23.33	19.36	22.59	24.99	24.71	4	24.01	-9006
04-11-2021 14:16	23.32	19.36	22.59	24.98	24.71	3	24.01	-9006
04-11-2021 14:17	23.31	19.37	22.60	24.98	24.70	3	24.02	-9006
04-11-2021 14:18	23.32	19.36	22.60	25.00	24.71	4	24.01	-9006
04-11-2021 14:19	23.32	19.36	22.60	25.02	24.71	4	24.02	-9006
04-11-2021 14:20	23.31	19.35	22.59	24.99	24.71	4	24.03	-9006
04-11-2021 14:21	23.31	19.36	22.59	24.98	24.71	4	24.02	-9006
04-11-2021 14:22	23.31	19.36	22.59	24.97	24.70	4	24.03	-9006
04-11-2021 14:23	23.31	19.35	22.58	24.98	24.71	4	24.03	-9006
04-11-2021 14:24	23.31	19.35	22.58	24.98	24.71	3	24.04	-9006



Environmental Monitoring System

DATA REPORT

TS LOADING & UNLOADING-SPARE ROOM

Date Time	TS LOADING ROOM	TS UNLOADING ROOM	QUARENTINE ROOM	MEDIA FILLED UNIT IN INCUBATION	MATERIAL TO EXIT	MATERIAL TO EXIT wrt CORRIDOR	DECORTNING ROOM	DECORTNING ROOM wrt CORRIDOR
Date Time	°C TEMP	°C TEMP	°C TEMP	°C TEMP	°C TEMP	DP Pa	°C TEMP	DP Pa
04-11-2021 14:25	23.30	19.35	22.59	24.99	24.71	4	24.03	-9006
04-11-2021 14:26	23.30	19.35	22.58	24.98	24.71	3	24.03	-9006
04-11-2021 14:27	23.28	19.34	22.57	24.99	24.71	4	24.04	-9006
04-11-2021 14:28	23.28	19.33	22.58	24.98	24.70	3	24.04	-9006
04-11-2021 14:29	23.27	19.34	22.58	24.98	24.70	4	24.04	-9006
04-11-2021 14:30	23.25	19.34	22.57	24.99	24.72	3	24.05	-9006
04-11-2021 14:31	23.26	19.34	22.57	24.98	24.71	3	24.05	-9006
04-11-2021 14:32	23.25	19.33	22.57	25.00	24.73	3	24.06	-9006
04-11-2021 14:33	23.24	19.33	22.57	25.00	24.72	3	24.06	-9006
04-11-2021 14:34	23.23	19.33	22.56	25.00	24.73	4	24.06	-9006
04-11-2021 14:35	23.22	19.33	22.56	25.01	24.72	3	24.06	-9006
04-11-2021 14:36	23.22	19.31	22.58	25.01	24.72	3	24.06	-9006
04-11-2021 14:37	23.22	19.31	22.57	25.01	24.73	3	24.07	-9006
04-11-2021 14:38	23.20	19.31	22.56	25.00	24.72	4	24.07	-9006
04-11-2021 14:39	23.20	19.32	22.56	25.01	24.72	3	24.08	-9006
04-11-2021 14:40	23.21	19.31	22.56	25.02	24.73	4	24.08	-9006
04-11-2021 14:41	23.20	19.33	22.56	25.01	24.74	0	24.08	-9006
04-11-2021 14:42	23.18	19.33	22.55	25.03	24.73	3	24.08	-9006
04-11-2021 14:43	23.18	19.32	22.55	25.02	24.72	3	24.08	-9006
04-11-2021 14:44	23.19	19.32	22.55	25.02	24.73	4	24.09	-9006
04-11-2021 14:45	23.18	19.30	22.55	25.02	24.72	3	24.08	-9006
04-11-2021 14:46	23.17	19.31	22.54	25.01	24.74	3	24.09	-9006
04-11-2021 14:47	23.17	19.31	22.55	25.02	24.74	3	24.09	-9006
04-11-2021 14:48	23.18	19.32	22.54	25.01	24.74	4	24.09	-9006
04-11-2021 14:49	23.18	19.32	22.56	25.01	24.74	0	24.10	-9006
04-11-2021 14:50	23.18	19.32	22.57	25.00	24.74	4	24.10	-9006
04-11-2021 14:51	23.19	19.32	22.56	25.01	24.74	4	24.09	-9006
04-11-2021 14:52	23.19	19.31	22.56	25.02	24.73	4	24.10	-9006



Environmental Monitoring System

DATA REPORT

TS LOADING & UNLOADING-SPARE ROOM

Date Time	TS LOADING ROOM	TS UNLOADING ROOM	QUARENTINE ROOM	MEDIA FILLED UNIT IN INCUBATION	MATERIAL TO EXIT	MATERIAL TO EXIT wrt CORRIDOR	DECORTNING ROOM	DECORTNING ROOM wrt CORRIDOR
Date Time	°C TEMP	°C TEMP	°C TEMP	°C TEMP	°C TEMP	DP Pa	°C TEMP	DP Pa
04-11-2021 14:53	23.19	19.31	22.56	25.03	24.73	4	24.10	-9006
04-11-2021 14:54	23.19	19.31	22.57	25.03	24.74	4	24.11	-9006
04-11-2021 14:55	23.20	19.30	22.58	25.02	24.73	3	24.09	-9006
04-11-2021 14:56	23.18	19.31	22.57	25.01	24.73	3	24.10	-9006
04-11-2021 14:57	23.18	19.30	22.57	25.03	24.73	4	24.11	-9006
04-11-2021 14:58	23.19	19.32	22.57	25.02	24.75	3	24.11	-9006
04-11-2021 14:59	23.20	19.32	22.58	25.02	24.74	4	24.12	-9006
04-11-2021 15:00	23.22	19.31	22.58	25.02	24.74	3	24.11	-9006
04-11-2021 15:01	23.20	19.31	22.59	25.05	24.73	3	24.11	-9006
04-11-2021 15:02	23.20	19.30	22.60	25.03	24.73	3	24.12	-9006
04-11-2021 15:03	23.19	19.29	22.59	25.02	24.74	4	24.12	-9006
04-11-2021 15:04	23.18	19.29	22.59	25.03	24.74	3	24.12	-9006
04-11-2021 15:05	23.20	19.29	22.59	25.01	24.74	3	24.13	-9006
04-11-2021 15:06	23.20	19.29	22.59	25.03	24.74	4	24.12	-9006
04-11-2021 15:07	23.18	19.29	22.57	25.03	24.75	3	24.13	-9006
04-11-2021 15:08	23.18	19.29	22.58	25.04	24.74	4	24.13	-9006
04-11-2021 15:09	23.17	19.30	22.57	25.03	24.75	3	24.13	-9006
04-11-2021 15:10	23.18	19.31	22.57	25.03	24.75	4	24.13	-9006
04-11-2021 15:11	23.17	19.30	22.56	25.01	24.74	3	24.14	-9006
04-11-2021 15:12	23.15	19.29	22.56	25.01	24.74	4	24.14	-9006
04-11-2021 15:13	23.15	19.30	22.56	25.02	24.73	4	24.14	-9006
04-11-2021 15:14	23.12	19.28	22.56	25.01	24.72	4	24.14	-9006
04-11-2021 15:15	23.15	19.29	22.56	25.02	24.72	4	24.14	-9006
04-11-2021 15:16	23.13	19.28	22.55	25.02	24.73	3	24.14	-9006
04-11-2021 15:17	23.15	19.29	22.56	25.02	24.72	4	24.15	-9006
04-11-2021 15:18	23.14	19.29	22.55	25.03	24.72	4	24.15	-9006
04-11-2021 15:19	23.13	19.29	22.55	25.00	24.71	4	24.15	-9006
04-11-2021 15:20	23.14	19.28	22.55	25.01	24.71	3	24.15	-9006



Environmental Monitoring System

DATA REPORT

TS LOADING & UNLOADING-SPARE ROOM

Date Time	TS LOADING ROOM	TS UNLOADING ROOM	QUARENTINE ROOM	MEDIA FILLED UNIT IN INCUBATION	MATERIAL TO EXIT	MATERIAL TO EXIT wrt CORRIDOR	DECORTNING ROOM	DECORTNING ROOM wrt CORRIDOR
Date Time	°C TEMP	°C TEMP	°C TEMP	°C TEMP	°C TEMP	DP Pa	°C TEMP	DP Pa
04-11-2021 15:21	23.14	19.28	22.55	25.02	24.71	4	24.15	-9006
04-11-2021 15:22	23.11	19.27	22.55	25.02	24.71	4	24.15	-9006
04-11-2021 15:23	23.12	19.28	22.55	25.01	24.70	4	24.16	-9006
04-11-2021 15:24	23.12	19.28	22.55	25.03	24.71	4	24.16	-9006
04-11-2021 15:25	23.13	19.29	22.55	25.04	24.71	3	24.16	-9006
04-11-2021 15:26	23.12	19.27	22.54	25.03	24.73	3	24.16	-9006
04-11-2021 15:27	23.11	19.27	22.54	25.01	24.71	3	24.16	-9006
04-11-2021 15:28	23.10	19.27	22.54	25.02	24.71	4	24.17	-9006
04-11-2021 15:29	23.10	19.27	22.54	25.02	24.71	4	24.17	-9006
04-11-2021 15:30	23.10	19.28	22.55	25.03	24.70	3	24.18	-9006
04-11-2021 15:31	23.10	19.27	22.53	25.03	24.70	4	24.17	-9006
04-11-2021 15:32	23.09	19.29	22.53	25.02	24.70	3	24.17	-9006
04-11-2021 15:33	23.10	19.28	22.53	25.01	24.70	3	24.18	-9006
04-11-2021 15:34	23.09	19.28	22.52	25.01	24.70	3	24.18	-9006
04-11-2021 15:35	23.08	19.26	22.53	25.00	24.72	3	24.18	-9006
04-11-2021 15:36	23.08	19.27	22.53	25.01	24.71	3	24.17	-9006
04-11-2021 15:37	23.07	19.25	22.52	25.01	24.72	4	24.18	-9006
04-11-2021 15:38	23.07	19.26	22.50	25.02	24.73	4	24.18	-9006
04-11-2021 15:39	23.05	19.25	22.51	25.02	24.71	4	24.18	-9006
04-11-2021 15:40	23.05	19.26	22.51	25.02	24.70	4	24.18	-9006
04-11-2021 15:41	23.06	19.26	22.50	25.02	24.71	4	24.18	-9006
04-11-2021 15:42	23.06	19.24	22.50	25.02	24.72	3	24.18	-9006
04-11-2021 15:43	23.04	19.25	22.49	25.02	24.74	3	24.18	-9006
04-11-2021 15:44	23.04	19.26	22.50	25.01	24.73	4	24.19	-9006
04-11-2021 15:45	23.04	19.25	22.51	25.00	24.72	4	24.18	-9006
04-11-2021 15:46	23.04	19.25	22.50	25.01	24.73	4	24.19	-9006
04-11-2021 15:47	23.05	19.23	22.50	25.01	24.73	4	24.19	-9006
04-11-2021 15:48	23.04	19.24	22.49	25.00	24.73	4	24.20	-9006



Environmental Monitoring System

DATA REPORT

TS LOADING & UNLOADING-SPARE ROOM

Date Time	TS LOADING ROOM	TS UNLOADING ROOM	QUARENTINE ROOM	MEDIA FILLED UNIT IN INCUBATION	MATERIAL TO EXIT	MATERIAL TO EXIT wrt CORRIDOR	DECORTNING ROOM	DECORTNING ROOM wrt CORRIDOR
Date Time	°C TEMP	°C TEMP	°C TEMP	°C TEMP	°C TEMP	DP Pa	°C TEMP	DP Pa
04-11-2021 15:49	23.02	19.23	22.50	25.01	24.73	3	24.19	-9006
04-11-2021 15:50	23.02	19.23	22.48	25.01	24.73	4	24.19	-9006
04-11-2021 15:51	23.02	19.25	22.49	25.01	24.74	4	24.19	-9006
04-11-2021 15:52	23.02	19.24	22.50	25.01	24.74	3	24.19	-9006
04-11-2021 15:53	23.01	19.24	22.49	25.02	24.74	3	24.19	-9006
04-11-2021 15:54	23.01	19.24	22.48	25.01	24.75	4	24.20	-9006
04-11-2021 15:55	23.01	19.23	22.48	25.01	24.76	3	24.20	-9006
04-11-2021 15:56	23.00	19.22	22.47	25.01	24.74	4	24.20	-9006
04-11-2021 15:57	23.02	19.22	22.49	25.01	24.75	4	24.19	-9006
04-11-2021 15:58	23.01	19.22	22.49	25.03	24.74	4	24.21	-9006
04-11-2021 15:59	23.01	19.22	22.49	25.03	24.75	4	24.20	-9006
04-11-2021 16:00	23.02	19.20	22.48	25.03	24.76	4	24.20	-9006
04-11-2021 16:01	23.00	19.20	22.46	25.02	24.76	3	24.21	-9006
04-11-2021 16:02	23.00	19.20	22.47	25.00	24.75	4	24.21	-9006
04-11-2021 16:03	23.00	19.20	22.48	24.99	24.74	4	24.21	-9006
04-11-2021 16:04	22.98	19.20	22.48	25.00	24.74	3	24.21	-9006
04-11-2021 16:05	22.98	19.20	22.48	25.00	24.76	4	24.21	-9006
04-11-2021 16:06	22.96	19.18	22.47	25.00	24.75	3	24.21	-9006
04-11-2021 16:07	22.98	19.20	22.47	25.01	24.76	4	24.21	-9006
04-11-2021 16:08	22.97	19.18	22.47	25.01	24.75	4	24.22	-9006
04-11-2021 16:09	22.97	19.17	22.47	25.00	24.75	4	24.19	-9006
04-11-2021 16:10	22.95	19.17	22.47	25.00	24.75	4	24.20	-9006
04-11-2021 16:11	22.95	19.16	22.46	25.00	24.76	3	24.20	-9006
04-11-2021 16:12	22.93	19.17	22.45	25.01	24.76	3	24.21	-9006
04-11-2021 16:13	22.93	19.18	22.46	25.01	24.76	4	24.21	-9006
04-11-2021 16:14	22.94	19.19	22.45	25.02	24.75	3	24.20	-9006
04-11-2021 16:15	22.92	19.18	22.45	25.00	24.77	4	24.20	-9006
04-11-2021 16:16	22.91	19.16	22.44	24.99	24.76	4	24.22	-9006



Environmental Monitoring System

DATA REPORT

TS LOADING & UNLOADING-SPARE ROOM

Date Time	TS LOADING ROOM	TS UNLOADING ROOM	QUARENTINE ROOM	MEDIA FILLED UNIT IN INCUBATION	MATERIAL TO EXIT	MATERIAL TO EXIT wrt CORRIDOR	DECORTNING ROOM	DECORTNING ROOM wrt CORRIDOR
Date Time	°C TEMP	°C TEMP	°C TEMP	°C TEMP	°C TEMP	DP Pa	°C TEMP	DP Pa
04-11-2021 16:17	22.91	19.15	22.44	25.00	24.77	4	24.21	-9006
04-11-2021 16:18	22.91	19.17	22.44	25.00	24.78	4	24.21	-9006
04-11-2021 16:19	22.91	19.17	22.45	24.99	24.80	4	24.21	-9006
04-11-2021 16:20	22.91	19.16	22.45	25.00	24.79	3	24.21	-9006
04-11-2021 16:21	22.90	19.15	22.44	25.00	24.80	4	24.22	-9006
04-11-2021 16:22	22.90	19.15	22.45	25.00	24.79	4	24.22	-9006
04-11-2021 16:23	22.90	19.14	22.43	25.00	24.79	4	24.22	-9006
04-11-2021 16:24	22.90	19.14	22.43	25.00	24.80	4	24.22	-9006
04-11-2021 16:25	22.90	19.13	22.43	25.01	24.79	4	24.22	-9006
04-11-2021 16:26	22.89	19.14	22.42	25.01	24.80	4	24.22	-9006
04-11-2021 16:27	22.89	19.14	22.42	25.01	24.79	4	24.22	-9006
04-11-2021 16:28	22.88	19.13	22.41	25.00	24.80	3	24.22	-9006
04-11-2021 16:29	22.87	19.13	22.42	25.00	24.79	4	24.22	-9006
04-11-2021 16:30	22.88	19.12	22.41	24.98	24.81	4	24.21	-9006
04-11-2021 16:31	22.86	19.13	22.41	24.99	24.80	3	24.22	-9006
04-11-2021 16:32	22.87	19.12	22.39	24.99	24.81	3	24.22	-9006
04-11-2021 16:33	22.86	19.13	22.39	25.00	24.80	4	24.22	-9006
04-11-2021 16:34	22.85	19.13	22.39	24.99	24.82	3	24.23	-9006
04-11-2021 16:35	22.85	19.11	22.40	24.97	24.81	4	24.22	-9006
04-11-2021 16:36	22.85	19.12	22.40	24.99	24.80	4	24.22	-9006
04-11-2021 16:37	22.84	19.12	22.40	25.00	24.79	4	24.22	-9006
04-11-2021 16:38	22.83	19.11	22.40	24.98	24.80	4	24.23	-9006
04-11-2021 16:39	22.83	19.11	22.40	24.98	24.82	3	24.22	-9006
04-11-2021 16:40	22.83	19.11	22.39	24.99	24.80	3	24.22	-9006
04-11-2021 16:41	22.84	19.10	22.39	24.98	24.81	4	24.23	-9006
04-11-2021 16:42	22.83	19.08	22.38	24.97	24.82	4	24.24	-9006
04-11-2021 16:43	22.82	19.10	22.38	24.98	24.81	4	24.23	-9006
04-11-2021 16:44	22.82	19.09	22.40	24.98	24.82	4	24.23	-9006



Environmental Monitoring System

DATA REPORT

TS LOADING & UNLOADING-SPARE ROOM

Date Time	TS LOADING ROOM	TS UNLOADING ROOM	QUARENTINE ROOM	MEDIA FILLED UNIT IN INCUBATION	MATERIAL TO EXIT	MATERIAL TO EXIT wrt CORRIDOR	DECORTNING ROOM	DECORTNING ROOM wrt CORRIDOR
Date Time	°C TEMP	°C TEMP	°C TEMP	°C TEMP	°C TEMP	DP Pa	°C TEMP	DP Pa
04-11-2021 16:45	22.81	19.10	22.39	24.97	24.81	4	24.24	-9006
04-11-2021 16:46	22.80	19.09	22.38	24.98	24.81	4	24.24	-9006
04-11-2021 16:47	22.80	19.09	22.38	24.98	24.82	4	24.23	-9006
04-11-2021 16:48	22.80	19.08	22.38	24.98	24.80	4	24.23	-9006
04-11-2021 16:49	22.80	19.09	22.36	24.97	24.80	4	24.24	-9006
04-11-2021 16:50	22.80	19.07	22.36	24.98	24.80	3	24.24	-9006
04-11-2021 16:51	22.79	19.07	22.35	24.97	24.80	4	24.23	-9006
04-11-2021 16:52	22.77	19.09	22.35	24.97	24.80	3	24.23	-9006
04-11-2021 16:53	22.78	19.07	22.35	24.96	24.78	3	24.22	-9006
04-11-2021 16:54	22.78	19.06	22.35	24.97	24.78	3	24.23	-9006
04-11-2021 16:55	22.78	19.07	22.36	24.97	24.77	3	24.23	-9006
04-11-2021 16:56	22.76	19.06	22.36	24.96	24.78	3	24.23	-9006
04-11-2021 16:57	22.76	19.05	22.34	24.96	24.78	4	24.22	-9006
04-11-2021 16:58	22.75	19.05	22.35	24.96	24.79	4	24.22	-9006
04-11-2021 16:59	22.75	19.06	22.35	24.96	24.78	3	24.22	-9006
04-11-2021 17:00	22.73	19.06	22.34	24.96	24.78	4	24.23	-9006
04-11-2021 17:01	22.73	19.05	22.33	24.96	24.77	4	24.22	-9006
04-11-2021 17:02	22.73	19.04	22.33	24.96	24.76	4	24.23	-9006
04-11-2021 17:03	22.74	19.03	22.33	24.97	24.76	4	24.22	-9006
04-11-2021 17:04	22.73	19.04	22.34	24.97	24.76	4	24.22	-9006
04-11-2021 17:05	22.74	19.04	22.32	24.97	24.77	4	24.22	-9006
04-11-2021 17:06	22.73	19.03	22.31	24.95	24.76	4	24.23	-9006
04-11-2021 17:07	22.73	19.03	22.32	24.95	24.77	4	24.23	-9006
04-11-2021 17:08	22.72	19.02	22.31	24.95	24.76	3	24.21	-9006
04-11-2021 17:09	22.74	19.01	22.30	24.97	24.78	4	24.22	-9006
04-11-2021 17:10	22.71	19.02	22.31	24.96	24.76	3	24.22	-9006
04-11-2021 17:11	22.71	19.03	22.31	24.95	24.77	4	24.23	-9006
04-11-2021 17:12	22.70	19.02	22.30	24.95	24.78	4	24.23	-9006



Environmental Monitoring System

DATA REPORT

TS LOADING & UNLOADING-SPARE ROOM

Date Time	TS LOADING ROOM	TS UNLOADING ROOM	QUARENTINE ROOM	MEDIA FILLED UNIT IN INCUBATION	MATERIAL TO EXIT	MATERIAL TO EXIT wrt CORRIDOR	DECORTNING ROOM	DECORTNING ROOM wrt CORRIDOR
Date Time	°C TEMP	°C TEMP	°C TEMP	°C TEMP	°C TEMP	DP Pa	°C TEMP	DP Pa
04-11-2021 17:13	22.70	19.01	22.31	24.96	24.77	3	24.22	-9006
04-11-2021 17:14	22.70	19.01	22.30	24.96	24.78	4	24.22	-9006
04-11-2021 17:15	22.70	19.01	22.30	24.96	24.77	3	24.23	-9006
04-11-2021 17:16	22.69	19.02	22.30	24.96	24.77	4	24.23	-9006
04-11-2021 17:17	22.70	19.00	22.29	24.95	24.78	4	24.22	-9006
04-11-2021 17:18	22.69	19.02	22.29	24.95	24.78	3	24.22	-9006
04-11-2021 17:19	22.69	19.01	22.30	24.95	24.78	4	24.23	-9006
04-11-2021 17:20	22.68	19.01	22.30	24.96	24.78	4	24.22	-9006
04-11-2021 17:21	22.67	18.99	22.31	24.95	24.78	3	24.23	-9006
04-11-2021 17:22	22.67	19.00	22.29	24.92	24.77	4	24.23	-9006
04-11-2021 17:23	22.66	19.00	22.29	24.94	24.79	4	24.22	-9006
04-11-2021 17:24	22.65	18.99	22.29	24.95	24.79	3	24.23	-9006
04-11-2021 17:25	22.66	19.00	22.30	24.95	24.79	3	24.22	-9006
04-11-2021 17:26	22.66	18.98	22.27	24.95	24.78	4	24.22	-9006
04-11-2021 17:27	22.66	18.97	22.29	24.93	24.77	4	24.21	-9006
04-11-2021 17:28	22.65	18.98	22.28	24.94	24.79	3	24.22	-9006
04-11-2021 17:29	22.65	18.99	22.28	24.94	24.79	4	24.22	-9006
04-11-2021 17:30	22.65	19.00	22.27	24.95	24.77	4	24.22	-9006
04-11-2021 17:31	22.67	18.98	22.27	24.94	24.77	3	24.23	-9006
04-11-2021 17:32	22.66	18.98	22.26	24.95	24.78	3	24.22	-9006
04-11-2021 17:33	22.66	18.97	22.26	24.96	24.78	4	24.23	-9006
04-11-2021 17:34	22.65	18.96	22.26	24.95	24.78	3	24.23	-9006
04-11-2021 17:35	22.64	18.97	22.26	24.95	24.79	4	24.23	-9006
04-11-2021 17:36	22.64	18.95	22.26	24.95	24.79	4	24.24	-9006
04-11-2021 17:37	22.64	18.96	22.23	24.94	24.79	3	24.22	-9006
04-11-2021 17:38	22.64	18.95	22.26	24.94	24.79	4	24.23	-9006
04-11-2021 17:39	22.63	18.95	22.25	24.94	24.79	4	24.22	-9006
04-11-2021 17:40	22.63	18.95	22.25	24.94	24.79	3	24.23	-9006



Environmental Monitoring System

DATA REPORT

TS LOADING & UNLOADING-SPARE ROOM

Date Time	TS LOADING ROOM	TS UNLOADING ROOM	QUARENTINE ROOM	MEDIA FILLED UNIT IN INCUBATION	MATERIAL TO EXIT	MATERIAL TO EXIT wrt CORRIDOR	DECORTNING ROOM	DECORTNING ROOM wrt CORRIDOR
Date Time	°C TEMP	°C TEMP	°C TEMP	°C TEMP	°C TEMP	DP Pa	°C TEMP	DP Pa
04-11-2021 17:41	22.62	18.95	22.25	24.93	24.79	4	24.22	-9006
04-11-2021 17:42	22.62	18.95	22.23	24.91	24.78	3	24.22	-9006
04-11-2021 17:43	22.62	18.96	22.25	24.92	24.79	4	24.23	-9006
04-11-2021 17:44	22.60	18.95	22.24	24.92	24.80	4	24.22	-9006
04-11-2021 17:45	22.60	18.96	22.22	24.93	24.79	4	24.22	-9006
04-11-2021 17:46	22.61	18.96	22.24	24.93	24.79	3	24.22	-9006
04-11-2021 17:47	22.62	18.96	22.25	24.94	24.80	3	24.22	-9006
04-11-2021 17:48	22.61	18.95	22.25	24.94	24.81	4	24.22	-9006
04-11-2021 17:49	22.61	18.93	22.24	24.94	24.80	4	24.22	-9006
04-11-2021 17:50	22.59	18.93	22.23	24.93	24.81	3	24.22	-9006
04-11-2021 17:51	22.60	18.93	22.23	24.92	24.80	4	24.22	-9006
04-11-2021 17:52	22.60	18.92	22.23	24.93	24.82	4	24.22	-9006
04-11-2021 17:53	22.59	18.93	22.21	24.91	24.81	4	24.22	-9006
04-11-2021 17:54	22.59	18.92	22.22	24.93	24.80	3	24.22	-9006
04-11-2021 17:55	22.58	18.92	22.21	24.91	24.80	3	24.21	-9006
04-11-2021 17:56	22.56	18.90	22.21	24.92	24.80	4	24.22	-9006
04-11-2021 17:57	22.58	18.91	22.21	24.92	24.80	4	24.21	-9006
04-11-2021 17:58	22.55	18.90	22.20	24.92	24.81	3	24.22	-9006
04-11-2021 17:59	22.56	18.91	22.20	24.91	24.80	3	24.22	-9006
04-11-2021 18:00	22.55	18.90	22.20	24.91	24.82	4	24.21	-9006
04-11-2021 18:01	22.53	18.90	22.20	24.90	24.82	4	24.22	-9006
04-11-2021 18:02	22.54	18.89	22.20	24.91	24.82	3	24.22	-9006
04-11-2021 18:03	22.53	18.88	22.19	24.91	24.82	3	24.21	-9006
04-11-2021 18:04	22.53	18.89	22.19	24.91	24.85	4	24.21	-9006
04-11-2021 18:05	22.55	18.89	22.20	24.91	24.83	4	24.22	-9006
04-11-2021 18:06	22.56	18.90	22.19	24.91	24.84	3	24.20	-9006
04-11-2021 18:07	22.57	18.90	22.21	24.90	24.83	4	24.21	-9006
04-11-2021 18:08	22.58	18.90	22.20	24.89	24.83	4	24.21	-9006



Environmental Monitoring System

DATA REPORT

TS LOADING & UNLOADING-SPARE ROOM

Date Time	TS LOADING ROOM	TS UNLOADING ROOM	QUARENTINE ROOM	MEDIA FILLED UNIT IN INCUBATION	MATERIAL TO EXIT	MATERIAL TO EXIT wrt CORRIDOR	DECORTNING ROOM	DECORTNING ROOM wrt CORRIDOR
Date Time	°C TEMP	°C TEMP	°C TEMP	°C TEMP	°C TEMP	DP Pa	°C TEMP	DP Pa
04-11-2021 18:09	22.60	18.90	22.20	24.90	24.82	4	24.22	-9006
04-11-2021 18:10	22.63	18.90	22.20	24.89	24.84	3	24.21	-9006
04-11-2021 18:11	22.63	18.91	22.22	24.87	24.83	4	24.21	-9006
04-11-2021 18:12	22.65	18.91	22.23	24.87	24.83	4	24.21	-9006
04-11-2021 18:13	22.67	18.91	22.23	24.87	24.83	3	24.20	-9006
04-11-2021 18:14	22.69	18.92	22.24	24.87	24.83	3	24.21	-9006
04-11-2021 18:15	22.69	18.93	22.25	24.86	24.84	4	24.21	-9006
04-11-2021 18:16	22.70	18.95	22.27	24.86	24.83	4	24.21	-9006
04-11-2021 18:17	22.71	18.94	22.28	24.86	24.84	4	24.22	-9006
04-11-2021 18:18	22.72	18.96	22.28	24.88	24.84	4	24.22	-9006
04-11-2021 18:19	22.74	18.96	22.28	24.89	24.84	4	24.22	-9006
04-11-2021 18:20	22.75	18.96	22.30	24.90	24.84	4	24.22	-9006
04-11-2021 18:21	22.77	18.98	22.31	24.90	24.83	4	24.21	-9006
04-11-2021 18:22	22.78	18.99	22.32	24.89	24.83	4	24.23	-9006
04-11-2021 18:23	22.80	18.99	22.33	24.87	24.82	3	24.22	-9006
04-11-2021 18:24	22.81	19.00	22.35	24.87	24.84	4	24.22	-9006
04-11-2021 18:25	22.82	19.02	22.36	24.86	24.85	4	24.23	-9006
04-11-2021 18:26	22.82	19.03	22.36	24.86	24.85	4	24.23	-9006
04-11-2021 18:27	22.83	19.03	22.37	24.85	24.85	3	24.24	-9006
04-11-2021 18:28	22.83	19.04	22.39	24.86	24.85	0	24.24	-9006
04-11-2021 18:29	22.84	19.04	22.40	24.85	24.84	4	24.24	-9006
04-11-2021 18:30	22.84	19.07	22.40	24.85	24.85	0	24.25	-9006
04-11-2021 18:31	22.84	19.07	22.42	24.86	24.86	4	24.24	-9006
04-11-2021 18:32	22.85	19.08	22.42	24.88	24.84	4	24.24	-9006
04-11-2021 18:33	22.86	19.09	22.43	24.88	24.85	3	24.25	-9006
04-11-2021 18:34	22.86	19.09	22.44	24.87	24.85	3	24.25	-9006
04-11-2021 18:35	22.86	19.09	22.45	24.87	24.84	4	24.26	-9006
04-11-2021 18:36	22.87	19.10	22.45	24.87	24.83	3	24.25	-9006



Environmental Monitoring System

DATA REPORT

TS LOADING & UNLOADING-SPARE ROOM

Date Time	TS LOADING ROOM	TS UNLOADING ROOM	QUARENTINE ROOM	MEDIA FILLED UNIT IN INCUBATION	MATERIAL TO EXIT	MATERIAL TO EXIT wrt CORRIDOR	DECORTNING ROOM	DECORTNING ROOM wrt CORRIDOR
Date Time	°C TEMP	°C TEMP	°C TEMP	°C TEMP	°C TEMP	DP Pa	°C TEMP	DP Pa
04-11-2021 18:37	22.87	19.11	22.47	24.86	24.83	4	24.27	-9006
04-11-2021 18:38	22.88	19.12	22.47	24.87	24.83	4	24.27	-9006
04-11-2021 18:39	22.89	19.13	22.48	24.87	24.83	4	24.27	-9006
04-11-2021 18:40	22.89	19.14	22.49	24.88	24.82	4	24.27	-9006
04-11-2021 18:41	22.90	19.14	22.50	24.87	24.82	4	24.28	-9006
04-11-2021 18:42	22.90	19.15	22.50	24.88	24.81	4	24.27	-9006
04-11-2021 18:43	22.90	19.15	22.51	24.89	24.81	4	24.28	-9006
04-11-2021 18:44	22.91	19.17	22.52	24.89	24.80	3	24.29	-9006
04-11-2021 18:45	22.91	19.16	22.53	24.88	24.80	3	24.29	-9006
04-11-2021 18:46	22.91	19.16	22.54	24.89	24.80	4	24.29	-9006
04-11-2021 18:47	22.91	19.18	22.54	24.92	24.79	4	24.29	-9006
04-11-2021 18:48	22.91	19.18	22.54	24.92	24.78	3	24.30	-9006
04-11-2021 18:49	22.91	19.20	22.55	24.91	24.79	3	24.30	-9006
04-11-2021 18:50	22.91	19.20	22.56	24.90	24.78	4	24.31	-9006
04-11-2021 18:51	22.92	19.21	22.56	24.92	24.77	4	24.31	-9006
04-11-2021 18:52	22.93	19.21	22.57	24.90	24.79	4	24.30	-9006
04-11-2021 18:53	22.92	19.21	22.58	24.91	24.79	3	24.31	-9006
04-11-2021 18:54	22.93	19.21	22.58	24.91	24.78	3	24.31	-9006
04-11-2021 18:55	22.93	19.22	22.58	24.91	24.77	4	24.32	-9006
04-11-2021 18:56	22.94	19.22	22.59	24.91	24.78	4	24.31	-9006
04-11-2021 18:57	22.94	19.22	22.60	24.91	24.78	3	24.32	-9006
04-11-2021 18:58	22.95	19.23	22.60	24.92	24.78	4	24.32	-9006
04-11-2021 18:59	22.95	19.24	22.61	24.95	24.77	3	24.32	-9006
04-11-2021 19:00	22.94	19.25	22.61	24.95	24.77	3	24.33	-9006
04-11-2021 19:01	22.95	19.25	22.62	24.93	24.79	4	24.35	-9006
04-11-2021 19:02	22.94	19.25	22.63	24.95	24.79	3	24.32	-9006
04-11-2021 19:03	22.94	19.26	22.63	24.93	24.79	4	24.33	-9006
04-11-2021 19:04	22.95	19.26	22.63	24.94	24.79	4	24.33	-9006



Environmental Monitoring System

DATA REPORT

TS LOADING & UNLOADING-SPARE ROOM

Date Time	TS LOADING ROOM	TS UNLOADING ROOM	QUARENTINE ROOM	MEDIA FILLED UNIT IN INCUBATION	MATERIAL TO EXIT	MATERIAL TO EXIT wrt CORRIDOR	DECORTNING ROOM	DECORTNING ROOM wrt CORRIDOR
Date Time	°C TEMP	°C TEMP	°C TEMP	°C TEMP	°C TEMP	DP Pa	°C TEMP	DP Pa
04-11-2021 19:05	22.95	19.27	22.64	24.95	24.77	3	24.35	-9006
04-11-2021 19:06	22.95	19.26	22.64	24.94	24.79	3	24.34	-9006
04-11-2021 19:07	22.95	19.26	22.65	24.94	24.78	4	24.35	-9006
04-11-2021 19:08	22.95	19.27	22.65	24.96	24.79	4	24.34	-9006
04-11-2021 19:09	22.96	19.28	22.66	24.96	24.78	4	24.35	-9006
04-11-2021 19:10	22.96	19.28	22.67	24.95	24.79	3	24.35	-9006
04-11-2021 19:11	22.95	19.29	22.66	24.95	24.79	4	24.34	-9006
04-11-2021 19:12	22.96	19.30	22.68	24.97	24.78	3	24.36	-9006
04-11-2021 19:13	22.95	19.29	22.68	24.98	24.78	4	24.35	-9006
04-11-2021 19:14	22.96	19.29	22.68	25.00	24.78	3	24.36	-9006
04-11-2021 19:15	22.96	19.30	22.69	25.00	24.80	4	24.36	-9006
04-11-2021 19:16	22.95	19.30	22.69	25.00	24.79	4	24.37	-9006
04-11-2021 19:17	22.96	19.30	22.69	25.00	24.80	3	24.37	-9006
04-11-2021 19:18	22.96	19.30	22.70	25.00	24.80	3	24.37	-9006
04-11-2021 19:19	22.96	19.30	22.69	25.00	24.80	3	24.37	-9006
04-11-2021 19:20	22.95	19.31	22.70	24.98	24.79	3	24.37	-9006
04-11-2021 19:21	22.96	19.30	22.70	24.99	24.79	3	24.37	-9006
04-11-2021 19:22	22.95	19.30	22.70	25.00	24.78	3	24.38	-9006
04-11-2021 19:23	22.96	19.31	22.70	24.99	24.79	4	24.38	-9006
04-11-2021 19:24	22.96	19.31	22.70	24.99	24.79	0	24.38	-9006
04-11-2021 19:25	22.95	19.31	22.71	25.01	24.80	4	24.38	-9006
04-11-2021 19:26	22.96	19.31	22.73	25.03	24.81	3	24.39	-9006
04-11-2021 19:27	22.95	19.30	22.74	25.05	24.79	3	24.39	-9006
04-11-2021 19:28	22.96	19.31	22.72	25.03	24.79	3	24.39	-9006
04-11-2021 19:29	22.96	19.32	22.73	25.02	24.81	3	24.39	-9006
04-11-2021 19:30	22.96	19.32	22.74	25.02	24.81	3	24.39	-9006
04-11-2021 19:31	22.96	19.31	22.76	25.03	24.81	4	24.39	-9006
04-11-2021 19:32	22.95	19.31	22.75	25.02	24.81	3	24.39	-9006



Environmental Monitoring System

DATA REPORT

TS LOADING & UNLOADING-SPARE ROOM

Date Time	TS LOADING ROOM	TS UNLOADING ROOM	QUARENTINE ROOM	MEDIA FILLED UNIT IN INCUBATION	MATERIAL TO EXIT	MATERIAL TO EXIT wrt CORRIDOR	DECORTNING ROOM	DECORTNING ROOM wrt CORRIDOR
Date Time	°C TEMP	°C TEMP	°C TEMP	°C TEMP	°C TEMP	DP Pa	°C TEMP	DP Pa
04-11-2021 19:33	22.96	19.32	22.75	25.01	24.82	4	24.39	-9006
04-11-2021 19:34	22.95	19.32	22.76	25.01	24.82	4	24.40	-9006
04-11-2021 19:35	22.96	19.32	22.77	25.01	24.82	4	24.40	-9006
04-11-2021 19:36	22.96	19.31	22.77	25.02	24.83	4	24.41	-9006
04-11-2021 19:37	22.96	19.32	22.76	25.05	24.82	3	24.40	-9006
04-11-2021 19:38	22.96	19.33	22.77	25.05	24.83	0	24.41	-9006
04-11-2021 19:39	22.96	19.32	22.77	25.06	24.82	3	24.40	-9006
04-11-2021 19:40	22.97	19.32	22.77	25.05	24.83	3	24.40	-9006
04-11-2021 19:41	22.96	19.32	22.79	25.05	24.83	4	24.40	-9006
04-11-2021 19:42	22.96	19.32	22.78	25.05	24.83	3	24.41	-9006
04-11-2021 19:43	22.96	19.32	22.78	25.04	24.84	3	24.40	-9006
04-11-2021 19:44	22.96	19.33	22.79	25.05	24.84	3	24.41	-9006
04-11-2021 19:45	22.97	19.33	22.78	25.05	24.84	3	24.41	-9006
04-11-2021 19:46	22.96	19.33	22.80	25.04	24.84	4	24.41	-9006
04-11-2021 19:47	22.96	19.33	22.80	25.04	24.84	3	24.41	-9006
04-11-2021 19:48	22.97	19.33	22.80	25.04	24.84	3	24.41	-9006
04-11-2021 19:49	22.97	19.33	22.80	25.04	24.84	3	24.41	-9006
04-11-2021 19:50	22.95	19.33	22.82	25.04	24.85	3	24.41	-9006
04-11-2021 19:51	22.95	19.33	22.81	25.04	24.86	4	24.41	-9006
04-11-2021 19:52	22.94	19.32	22.81	25.03	24.85	3	24.41	-9006
04-11-2021 19:53	22.95	19.33	22.81	25.03	24.85	4	24.42	-9006
04-11-2021 19:54	22.95	19.33	22.81	25.03	24.85	3	24.42	-9006
04-11-2021 19:55	22.95	19.33	22.82	25.04	24.85	3	24.42	-9006
04-11-2021 19:56	22.96	19.33	22.83	25.07	24.86	3	24.42	-9006
04-11-2021 19:57	22.95	19.33	22.81	25.07	24.87	4	24.42	-9006
04-11-2021 19:58	22.95	19.33	22.81	25.07	24.86	3	24.41	-9006
04-11-2021 19:59	22.95	19.33	22.82	25.06	24.86	4	24.41	-9006
04-11-2021 20:00	22.95	19.33	22.84	25.05	24.85	3	24.41	-9006



Environmental Monitoring System

DATA REPORT

TS LOADING & UNLOADING-SPARE ROOM

Date Time	TS LOADING ROOM	TS UNLOADING ROOM	QUARENTINE ROOM	MEDIA FILLED UNIT IN INCUBATION	MATERIAL TO EXIT	MATERIAL TO EXIT wrt CORRIDOR	DECORTNING ROOM	DECORTNING ROOM wrt CORRIDOR
Date Time	°C TEMP	°C TEMP	°C TEMP	°C TEMP	°C TEMP	DP Pa	°C TEMP	DP Pa
04-11-2021 20:01	22.95	19.33	22.83	25.06	24.85	4	24.42	-9006
04-11-2021 20:02	22.96	19.32	22.83	25.06	24.86	3	24.41	-9006
04-11-2021 20:03	22.94	19.32	22.83	25.05	24.87	4	24.41	-9006
04-11-2021 20:04	22.94	19.32	22.83	25.05	24.86	4	24.42	-9006
04-11-2021 20:05	22.94	19.31	22.83	25.04	24.85	4	24.42	-9006
04-11-2021 20:06	22.94	19.31	22.83	25.03	24.86	3	24.42	-9006
04-11-2021 20:07	22.94	19.31	22.82	25.04	24.86	4	24.42	-9006
04-11-2021 20:08	22.94	19.31	22.83	25.03	24.86	4	24.43	-9006
04-11-2021 20:09	22.94	19.31	22.83	25.03	24.87	3	24.44	-9006
04-11-2021 20:10	22.94	19.31	22.83	25.02	24.86	3	24.43	-9006
04-11-2021 20:11	22.94	19.31	22.83	25.02	24.87	3	24.42	-9006
04-11-2021 20:12	22.95	19.31	22.85	25.04	24.87	4	24.42	-9006
04-11-2021 20:13	22.95	19.31	22.84	25.04	24.87	4	24.42	-9006
04-11-2021 20:14	22.94	19.32	22.83	25.04	24.87	4	24.43	-9006
04-11-2021 20:15	22.95	19.31	22.84	25.04	24.86	4	24.43	-9006
04-11-2021 20:16	22.94	19.30	22.85	25.07	24.88	4	24.42	-9006
04-11-2021 20:17	22.94	19.31	22.85	25.07	24.87	4	24.42	-9006
04-11-2021 20:18	22.94	19.30	22.85	25.06	24.87	3	24.42	-9006
04-11-2021 20:19	22.94	19.30	22.84	25.06	24.86	3	24.43	-9006
04-11-2021 20:20	22.94	19.30	22.85	25.09	24.86	4	24.42	-9006
04-11-2021 20:21	22.94	19.30	22.85	25.08	24.87	4	24.42	-9006
04-11-2021 20:22	22.94	19.30	22.85	25.06	24.87	4	24.40	-9006
04-11-2021 20:23	22.94	19.30	22.85	25.05	24.87	4	24.43	-9006
04-11-2021 20:24	22.93	19.31	22.86	25.07	24.86	4	24.42	-9006
04-11-2021 20:25	22.94	19.31	22.85	25.07	24.86	4	24.42	-9006
04-11-2021 20:26	22.94	19.30	22.84	25.05	24.85	4	24.42	-9006
04-11-2021 20:27	22.94	19.31	22.85	25.05	24.85	3	24.42	-9006
04-11-2021 20:28	22.95	19.31	22.84	25.04	24.85	3	24.42	-9006



Environmental Monitoring System

DATA REPORT

TS LOADING & UNLOADING-SPARE ROOM

Date Time	TS LOADING ROOM	TS UNLOADING ROOM	QUARENTINE ROOM	MEDIA FILLED UNIT IN INCUBATION	MATERIAL TO EXIT	MATERIAL TO EXIT wrt CORRIDOR	DECORTNING ROOM	DECORTNING ROOM wrt CORRIDOR
Date Time	°C TEMP	°C TEMP	°C TEMP	°C TEMP	°C TEMP	DP Pa	°C TEMP	DP Pa
04-11-2021 20:29	22.94	19.30	22.86	25.04	24.86	4	24.42	-9006
04-11-2021 20:30	22.94	19.31	22.86	25.06	24.86	4	24.42	-9006
04-11-2021 20:31	22.94	19.31	22.85	25.07	24.86	4	24.42	-9006
04-11-2021 20:32	22.94	19.30	22.85	25.06	24.86	4	24.42	-9006
04-11-2021 20:33	22.95	19.31	22.84	25.05	24.86	3	24.42	-9006
04-11-2021 20:34	22.94	19.30	22.84	25.05	24.85	4	24.42	-9006
04-11-2021 20:35	22.94	19.30	22.85	25.05	24.87	3	24.43	-9006
04-11-2021 20:36	22.95	19.29	22.85	25.04	24.86	4	24.42	-9006
04-11-2021 20:37	22.94	19.30	22.86	25.06	24.85	4	24.41	-9006
04-11-2021 20:38	22.94	19.30	22.84	25.08	24.85	4	24.42	-9006
04-11-2021 20:39	22.94	19.30	22.85	25.07	24.84	3	24.41	-9006
04-11-2021 20:40	22.94	19.30	22.85	25.07	24.86	3	24.40	-9006
04-11-2021 20:41	22.94	19.29	22.85	25.07	24.85	3	24.41	-9006
04-11-2021 20:42	22.94	19.30	22.84	25.06	24.87	3	24.41	-9006
04-11-2021 20:43	22.94	19.31	22.84	25.06	24.85	4	24.41	-9006
04-11-2021 20:44	22.94	19.30	22.85	25.07	24.85	4	24.40	-9006
04-11-2021 20:45	22.94	19.30	22.85	25.07	24.84	4	24.41	-9006
04-11-2021 20:46	22.93	19.30	22.87	25.06	24.84	4	24.40	-9006
04-11-2021 20:47	22.93	19.30	22.85	25.06	24.83	4	24.41	-9006
04-11-2021 20:48	22.94	19.30	22.86	25.07	24.84	4	24.40	-9006
04-11-2021 20:49	22.94	19.30	22.86	25.06	24.83	4	24.40	-9006
04-11-2021 20:50	22.93	19.30	22.85	25.05	24.83	4	24.40	-9006
04-11-2021 20:51	22.93	19.30	22.85	25.06	24.83	4	24.41	-9006
04-11-2021 20:52	22.93	19.31	22.83	25.07	24.84	3	24.40	-9006
04-11-2021 20:53	22.93	19.30	22.83	25.07	24.83	4	24.41	-9006
04-11-2021 20:54	22.93	19.29	22.84	25.08	24.83	4	24.38	-9006
04-11-2021 20:55	22.93	19.29	22.84	25.08	24.84	4	24.40	-9006
04-11-2021 20:56	22.93	19.30	22.85	25.06	24.84	4	24.40	-9006



Environmental Monitoring System

DATA REPORT

TS LOADING & UNLOADING-SPARE ROOM

Date Time	TS LOADING ROOM	TS UNLOADING ROOM	QUARENTINE ROOM	MEDIA FILLED UNIT IN INCUBATION	MATERIAL TO EXIT	MATERIAL TO EXIT wrt CORRIDOR	DECORTNING ROOM	DECORTNING ROOM wrt CORRIDOR
Date Time	°C TEMP	°C TEMP	°C TEMP	°C TEMP	°C TEMP	DP Pa	°C TEMP	DP Pa
04-11-2021 20:57	22.94	19.30	22.84	25.06	24.84	4	24.39	-9006
04-11-2021 20:58	22.93	19.30	22.83	25.06	24.82	4	24.40	-9006
04-11-2021 20:59	22.93	19.30	22.83	25.07	24.82	3	24.40	-9006
04-11-2021 21:00	22.93	19.30	22.83	25.06	24.83	4	24.40	-9006
04-11-2021 21:01	22.93	19.29	22.83	25.06	24.82	3	24.39	-9006
04-11-2021 21:02	22.93	19.30	22.83	25.07	24.82	4	24.39	-9006
04-11-2021 21:03	22.92	19.30	22.84	25.08	24.81	4	24.39	-9006
04-11-2021 21:04	22.92	19.29	22.82	25.07	24.82	4	24.39	-9006
04-11-2021 21:05	22.92	19.29	22.83	25.07	24.82	4	24.39	-9006
04-11-2021 21:06	22.92	19.29	22.84	25.06	24.82	4	24.39	-9006
04-11-2021 21:07	22.92	19.28	22.82	25.07	24.81	4	24.39	-9006
04-11-2021 21:08	22.92	19.29	22.83	25.06	24.81	4	24.38	-9006
04-11-2021 21:09	22.92	19.29	22.82	25.07	24.80	3	24.39	-9006
04-11-2021 21:10	22.92	19.29	22.83	25.07	24.80	4	24.39	-9006
04-11-2021 21:11	22.92	19.28	22.83	25.07	24.80	3	24.39	-9006
04-11-2021 21:12	22.92	19.28	22.81	25.08	24.79	4	24.39	-9006
04-11-2021 21:13	22.92	19.28	22.82	25.07	24.79	4	24.39	-9006
04-11-2021 21:14	22.92	19.28	22.82	25.06	24.77	4	24.38	-9006
04-11-2021 21:15	22.92	19.28	22.82	25.07	24.78	3	24.39	-9006
04-11-2021 21:16	22.91	19.28	22.80	25.07	24.77	4	24.40	-9006
04-11-2021 21:17	22.92	19.28	22.80	25.06	24.77	4	24.39	-9006
04-11-2021 21:18	22.91	19.29	22.81	25.06	24.77	3	24.39	-9006
04-11-2021 21:19	22.92	19.29	22.81	25.07	24.77	3	24.39	-9006
04-11-2021 21:20	22.91	19.27	22.81	25.08	24.78	4	24.39	-9006
04-11-2021 21:21	22.91	19.27	22.81	25.07	24.79	4	24.39	-9006
04-11-2021 21:22	22.91	19.27	22.81	25.08	24.77	4	24.39	-9006
04-11-2021 21:23	22.90	19.27	22.81	25.08	24.79	4	24.39	-9006
04-11-2021 21:24	22.90	19.27	22.82	25.09	24.78	4	24.39	-9006



Environmental Monitoring System

DATA REPORT

TS LOADING & UNLOADING-SPARE ROOM

Date Time	TS LOADING ROOM	TS UNLOADING ROOM	QUARENTINE ROOM	MEDIA FILLED UNIT IN INCUBATION	MATERIAL TO EXIT	MATERIAL TO EXIT wrt CORRIDOR	DECORTNING ROOM	DECORTNING ROOM wrt CORRIDOR
Date Time	°C TEMP	°C TEMP	°C TEMP	°C TEMP	°C TEMP	DP Pa	°C TEMP	DP Pa
04-11-2021 21:25	22.90	19.27	22.80	25.08	24.77	4	24.38	-9006
04-11-2021 21:26	22.90	19.27	22.80	25.08	24.77	3	24.38	-9006
04-11-2021 21:27	22.91	19.27	22.82	25.10	24.78	4	24.38	-9006
04-11-2021 21:28	22.90	19.28	22.82	25.10	24.78	3	24.38	-9006
04-11-2021 21:29	22.91	19.27	22.81	25.09	24.78	3	24.38	-9006
04-11-2021 21:30	22.91	19.28	22.80	25.08	24.76	4	24.38	-9006
04-11-2021 21:31	22.90	19.28	22.82	25.09	24.76	4	24.38	-9006
04-11-2021 21:32	22.90	19.28	22.81	25.09	24.77	4	24.37	-9006
04-11-2021 21:33	22.90	19.26	22.82	25.09	24.76	3	24.38	-9006
04-11-2021 21:34	22.89	19.26	22.83	25.08	24.77	4	24.37	-9006
04-11-2021 21:35	22.90	19.26	22.82	25.09	24.77	4	24.37	-9006
04-11-2021 21:36	22.89	19.26	22.83	25.08	24.77	4	24.37	-9006
04-11-2021 21:37	22.89	19.26	22.83	25.07	24.77	3	24.37	-9006
04-11-2021 21:38	22.89	19.26	22.83	25.08	24.76	4	24.37	-9006
04-11-2021 21:39	22.88	19.26	22.82	25.09	24.77	4	24.38	-9006
04-11-2021 21:40	22.87	19.25	22.83	25.08	24.78	4	24.38	-9006
04-11-2021 21:41	22.87	19.24	22.82	25.08	24.78	3	24.38	-9006
04-11-2021 21:42	22.87	19.25	22.81	25.09	24.78	4	24.37	-9006
04-11-2021 21:43	22.87	19.26	22.81	25.09	24.79	3	24.37	-9006
04-11-2021 21:44	22.86	19.25	22.81	25.09	24.79	4	24.37	-9006
04-11-2021 21:45	22.86	19.25	22.82	25.08	24.77	4	24.37	-9006
04-11-2021 21:46	22.86	19.24	22.82	25.08	24.78	4	24.38	-9006
04-11-2021 21:47	22.86	19.24	22.82	25.09	24.79	4	24.36	-9006
04-11-2021 21:48	22.85	19.24	22.81	25.08	24.78	4	24.38	-9006
04-11-2021 21:49	22.86	19.24	22.81	25.08	24.79	4	24.38	-9006
04-11-2021 21:50	22.85	19.24	22.81	25.08	24.79	4	24.37	-9006
04-11-2021 21:51	22.84	19.24	22.81	25.09	24.80	4	24.38	-9006
04-11-2021 21:52	22.84	19.25	22.77	25.08	24.79	4	24.38	-9006



Environmental Monitoring System

DATA REPORT

TS LOADING & UNLOADING-SPARE ROOM

Date Time	TS LOADING ROOM	TS UNLOADING ROOM	QUARENTINE ROOM	MEDIA FILLED UNIT IN INCUBATION	MATERIAL TO EXIT	MATERIAL TO EXIT wrt CORRIDOR	DECORTNING ROOM	DECORTNING ROOM wrt CORRIDOR
Date Time	°C TEMP	°C TEMP	°C TEMP	°C TEMP	°C TEMP	DP Pa	°C TEMP	DP Pa
04-11-2021 21:53	22.84	19.24	22.80	25.06	24.81	4	24.38	-9006
04-11-2021 21:54	22.84	19.24	22.80	25.06	24.79	4	24.37	-9006
04-11-2021 21:55	22.84	19.24	22.80	25.06	24.80	4	24.37	-9006
04-11-2021 21:56	22.83	19.23	22.80	25.06	24.79	4	24.38	-9006
04-11-2021 21:57	22.82	19.23	22.79	25.06	24.80	4	24.38	-9006
04-11-2021 21:58	22.83	19.22	22.80	25.06	24.81	3	24.38	-9006
04-11-2021 21:59	22.82	19.22	22.80	25.05	24.80	4	24.37	-9006
04-11-2021 22:00	22.81	19.22	22.79	25.06	24.81	3	24.37	-9006
04-11-2021 22:01	22.82	19.21	22.80	25.06	24.81	4	24.37	-9006
04-11-2021 22:02	22.81	19.22	22.77	25.07	24.82	4	24.37	-9006
04-11-2021 22:03	22.81	19.21	22.77	25.09	24.80	4	24.38	-9006
04-11-2021 22:04	22.80	19.21	22.76	25.10	24.81	4	24.37	-9006
04-11-2021 22:05	22.80	19.20	22.76	25.08	24.81	4	24.38	-9006
04-11-2021 22:06	22.79	19.20	22.75	25.06	24.81	3	24.37	-9006
04-11-2021 22:07	22.79	19.19	22.76	25.04	24.81	4	24.37	-9006
04-11-2021 22:08	22.78	19.20	22.77	25.04	24.80	4	24.38	-9006
04-11-2021 22:09	22.77	19.20	22.78	25.04	24.82	3	24.37	-9006
04-11-2021 22:10	22.77	19.19	22.76	25.03	24.82	4	24.38	-9006
04-11-2021 22:11	22.76	19.19	22.76	25.04	24.81	4	24.37	-9006
04-11-2021 22:12	22.76	19.19	22.76	25.04	24.81	4	24.37	-9006
04-11-2021 22:13	22.76	19.18	22.76	25.03	24.80	4	24.37	-9006
04-11-2021 22:14	22.75	19.18	22.76	25.03	24.81	4	24.37	-9006
04-11-2021 22:15	22.74	19.17	22.76	25.04	24.81	3	24.36	-9006
04-11-2021 22:16	22.75	19.18	22.74	25.02	24.81	4	24.37	-9006
04-11-2021 22:17	22.74	19.17	22.74	25.04	24.82	4	24.36	-9006
04-11-2021 22:18	22.74	19.16	22.75	25.01	24.82	3	24.36	-9006
04-11-2021 22:19	22.73	19.17	22.74	25.02	24.83	3	24.35	-9006
04-11-2021 22:20	22.73	19.16	22.73	25.02	24.82	4	24.36	-9006



Environmental Monitoring System

DATA REPORT

TS LOADING & UNLOADING-SPARE ROOM

Date Time	TS LOADING ROOM	TS UNLOADING ROOM	QUARENTINE ROOM	MEDIA FILLED UNIT IN INCUBATION	MATERIAL TO EXIT	MATERIAL TO EXIT wrt CORRIDOR	DECORTNING ROOM	DECORTNING ROOM wrt CORRIDOR
Date Time	°C TEMP	°C TEMP	°C TEMP	°C TEMP	°C TEMP	DP Pa	°C TEMP	DP Pa
04-11-2021 22:21	22.72	19.16	22.73	25.01	24.84	4	24.35	-9006
04-11-2021 22:22	22.72	19.16	22.73	25.01	24.83	4	24.35	-9006
04-11-2021 22:23	22.72	19.16	22.73	25.00	24.83	3	24.35	-9006
04-11-2021 22:24	22.70	19.14	22.72	25.00	24.82	3	24.34	-9006
04-11-2021 22:25	22.71	19.14	22.73	25.01	24.82	3	24.34	-9006
04-11-2021 22:26	22.70	19.14	22.72	25.01	24.83	4	24.34	-9006
04-11-2021 22:27	22.69	19.14	22.72	25.02	24.82	4	24.34	-9006
04-11-2021 22:28	22.69	19.14	22.72	25.02	24.83	4	24.33	-9006
04-11-2021 22:29	22.69	19.14	22.71	25.02	24.82	4	24.34	-9006
04-11-2021 22:30	22.69	19.13	22.71	25.00	24.82	4	24.34	-9006
04-11-2021 22:31	22.68	19.13	22.72	25.01	24.83	4	24.33	-9006
04-11-2021 22:32	22.68	19.14	22.70	25.01	24.83	4	24.33	-9006
04-11-2021 22:33	22.67	19.13	22.71	25.01	24.85	4	24.32	-9006
04-11-2021 22:34	22.66	19.12	22.72	25.00	24.83	4	24.33	-9006
04-11-2021 22:35	22.67	19.13	22.73	25.00	24.84	4	24.33	-9006
04-11-2021 22:36	22.66	19.12	22.72	25.00	24.84	4	24.32	-9006
04-11-2021 22:37	22.66	19.10	22.70	25.01	24.85	4	24.32	-9006
04-11-2021 22:38	22.65	19.12	22.70	25.03	24.85	3	24.32	-9006
04-11-2021 22:39	22.65	19.11	22.71	25.01	24.85	3	24.31	-9006
04-11-2021 22:40	22.65	19.10	22.70	25.01	24.84	4	24.31	-9006
04-11-2021 22:41	22.64	19.11	22.69	25.00	24.85	3	24.31	-9006
04-11-2021 22:42	22.64	19.09	22.70	24.99	24.85	3	24.31	-9006
04-11-2021 22:43	22.64	19.09	22.70	24.98	24.84	4	24.31	-9006
04-11-2021 22:44	22.64	19.09	22.69	24.98	24.84	4	24.31	-9006
04-11-2021 22:45	22.63	19.08	22.68	24.99	24.84	4	24.30	-9006
04-11-2021 22:46	22.62	19.10	22.68	24.98	24.85	4	24.30	-9006
04-11-2021 22:47	22.61	19.09	22.70	24.98	24.83	4	24.30	-9006
04-11-2021 22:48	22.61	19.09	22.68	24.99	24.84	4	24.29	-9006



Environmental Monitoring System

DATA REPORT

TS LOADING & UNLOADING-SPARE ROOM

Date Time	TS LOADING ROOM	TS UNLOADING ROOM	QUARENTINE ROOM	MEDIA FILLED UNIT IN INCUBATION	MATERIAL TO EXIT	MATERIAL TO EXIT wrt CORRIDOR	DECORTNING ROOM	DECORTNING ROOM wrt CORRIDOR
Date Time	°C TEMP	°C TEMP	°C TEMP	°C TEMP	°C TEMP	DP Pa	°C TEMP	DP Pa
04-11-2021 22:49	22.62	19.07	22.67	24.96	24.84	4	24.29	-9006
04-11-2021 22:50	22.61	19.07	22.67	24.98	24.84	4	24.28	-9006
04-11-2021 22:51	22.60	19.08	22.68	24.96	24.85	4	24.28	-9006
04-11-2021 22:52	22.60	19.07	22.69	24.96	24.85	4	24.28	-9006
04-11-2021 22:53	22.60	19.07	22.68	24.96	24.85	4	24.28	-9006
04-11-2021 22:54	22.59	19.08	22.67	24.99	24.85	4	24.28	-9006
04-11-2021 22:55	22.60	19.06	22.67	24.98	24.85	4	24.27	-9006
04-11-2021 22:56	22.59	19.06	22.65	24.99	24.86	4	24.27	-9006
04-11-2021 22:57	22.59	19.07	22.65	24.97	24.85	3	24.26	-9006
04-11-2021 22:58	22.59	19.07	22.64	24.97	24.84	4	24.26	-9006
04-11-2021 22:59	22.58	19.05	22.65	24.98	24.85	4	24.26	-9006
04-11-2021 23:00	22.58	19.04	22.64	24.99	24.83	3	24.25	-9006
04-11-2021 23:01	22.58	19.04	22.64	24.97	24.84	4	24.25	-9006
04-11-2021 23:02	22.57	19.04	22.64	24.98	24.85	4	24.25	-9006
04-11-2021 23:03	22.57	19.04	22.64	24.97	24.85	3	24.25	-9006
04-11-2021 23:04	22.57	19.03	22.65	24.97	24.85	3	24.24	-9006
04-11-2021 23:05	22.56	19.03	22.64	24.95	24.84	4	24.24	-9006
04-11-2021 23:06	22.56	19.03	22.62	24.94	24.84	4	24.23	-9006
04-11-2021 23:07	22.56	19.05	22.64	24.94	24.83	4	24.23	-9006
04-11-2021 23:08	22.56	19.03	22.64	24.93	24.83	4	24.24	-9006
04-11-2021 23:09	22.55	19.02	22.64	24.95	24.82	4	24.23	-9006
04-11-2021 23:10	22.55	19.03	22.63	24.95	24.82	4	24.22	-9006
04-11-2021 23:11	22.55	19.02	22.64	24.95	24.84	3	24.23	-9006
04-11-2021 23:12	22.55	19.02	22.63	24.96	24.82	4	24.22	-9006
04-11-2021 23:13	22.55	19.01	22.64	24.96	24.81	4	24.21	-9006
04-11-2021 23:14	22.55	19.01	22.63	24.94	24.81	4	24.21	-9006
04-11-2021 23:15	22.55	19.00	22.64	24.96	24.82	4	24.21	-9006
04-11-2021 23:16	22.54	19.01	22.63	24.95	24.82	3	24.21	-9006



Environmental Monitoring System

DATA REPORT

TS LOADING & UNLOADING-SPARE ROOM

Date Time	TS LOADING ROOM	TS UNLOADING ROOM	QUARENTINE ROOM	MEDIA FILLED UNIT IN INCUBATION	MATERIAL TO EXIT	MATERIAL TO EXIT wrt CORRIDOR	DECORTNING ROOM	DECORTNING ROOM wrt CORRIDOR
Date Time	°C TEMP	°C TEMP	°C TEMP	°C TEMP	°C TEMP	DP Pa	°C TEMP	DP Pa
04-11-2021 23:17	22.54	19.00	22.61	24.93	24.82	4	24.22	-9006
04-11-2021 23:18	22.54	19.00	22.62	24.92	24.84	4	24.21	-9006
04-11-2021 23:19	22.54	18.99	22.65	24.93	24.84	3	24.20	-9006
04-11-2021 23:20	22.54	19.00	22.63	24.94	24.83	4	24.20	-9006
04-11-2021 23:21	22.54	19.00	22.64	24.93	24.84	4	24.20	-9006
04-11-2021 23:22	22.53	18.99	22.63	24.92	24.82	4	24.20	-9006
04-11-2021 23:23	22.53	18.99	22.64	24.92	24.82	4	24.20	-9006
04-11-2021 23:24	22.53	18.99	22.64	24.91	24.82	4	24.19	-9006
04-11-2021 23:25	22.53	18.99	22.63	24.92	24.83	4	24.19	-9006
04-11-2021 23:26	22.52	18.99	22.63	24.92	24.82	4	24.19	-9006
04-11-2021 23:27	22.53	19.00	22.62	24.94	24.82	4	24.18	-9006
04-11-2021 23:28	22.53	18.99	22.62	24.93	24.81	4	24.18	-9006
04-11-2021 23:29	22.53	18.99	22.62	24.92	24.82	4	24.18	-9006
04-11-2021 23:30	22.52	19.00	22.63	24.90	24.82	4	24.18	-9006
04-11-2021 23:31	22.52	18.98	22.62	24.91	24.82	4	24.17	-9006
04-11-2021 23:32	22.52	18.99	22.61	24.89	24.82	4	24.17	-9006
04-11-2021 23:33	22.51	18.98	22.61	24.90	24.81	4	24.17	-9006
04-11-2021 23:34	22.51	18.98	22.60	24.89	24.81	4	24.17	-9006
04-11-2021 23:35	22.49	18.97	22.60	24.89	24.80	4	24.16	-9006
04-11-2021 23:36	22.50	18.99	22.62	24.89	24.81	3	24.15	-9006
04-11-2021 23:37	22.50	18.97	22.62	24.88	24.81	4	24.15	-9006
04-11-2021 23:38	22.50	18.98	22.62	24.86	24.81	4	24.15	-9006
04-11-2021 23:39	22.50	18.97	22.60	24.89	24.82	4	24.15	-9006
04-11-2021 23:40	22.50	18.97	22.60	24.88	24.81	4	24.15	-9006
04-11-2021 23:41	22.50	18.96	22.62	24.88	24.81	4	24.15	-9006
04-11-2021 23:42	22.50	18.97	22.63	24.88	24.80	4	24.13	-9006
04-11-2021 23:43	22.50	18.96	22.61	24.88	24.80	4	24.13	-9006
04-11-2021 23:44	22.49	18.96	22.62	24.87	24.80	4	24.13	-9006



Environmental Monitoring System

DATA REPORT

TS LOADING & UNLOADING-SPARE ROOM

Date Time	TS LOADING ROOM	TS UNLOADING ROOM	QUARENTINE ROOM	MEDIA FILLED UNIT IN INCUBATION	MATERIAL TO EXIT	MATERIAL TO EXIT wrt CORRIDOR	DECORTNING ROOM	DECORTNING ROOM wrt CORRIDOR
Date Time	°C TEMP	°C TEMP	°C TEMP	°C TEMP	°C TEMP	DP Pa	°C TEMP	DP Pa
04-11-2021 23:45	22.49	18.96	22.61	24.86	24.81	4	24.13	-9006
04-11-2021 23:46	22.48	18.95	22.62	24.86	24.80	4	24.13	-9006
04-11-2021 23:47	22.49	18.95	22.61	24.87	24.80	4	24.13	-9006
04-11-2021 23:48	22.49	18.96	22.61	24.86	24.79	4	24.12	-9006
04-11-2021 23:49	22.48	18.95	22.62	24.86	24.80	4	24.11	-9006
04-11-2021 23:50	22.48	18.95	22.61	24.87	24.79	3	24.11	-9006
04-11-2021 23:51	22.48	18.95	22.60	24.87	24.81	3	24.11	-9006
04-11-2021 23:52	22.47	18.95	22.60	24.87	24.80	4	24.11	-9006
04-11-2021 23:53	22.47	18.93	22.58	24.86	24.81	4	24.11	-9006
04-11-2021 23:54	22.47	18.93	22.59	24.86	24.80	5	24.10	-9006
04-11-2021 23:55	22.48	18.93	22.60	24.86	24.81	4	24.10	-9006
04-11-2021 23:56	22.47	18.93	22.60	24.85	24.81	4	24.09	-9006
04-11-2021 23:57	22.47	18.93	22.59	24.88	24.80	4	24.09	-9006
04-11-2021 23:58	22.48	18.94	22.60	24.89	24.80	4	24.09	-9006
04-11-2021 23:59	22.48	18.93	22.59	24.87	24.79	4	24.08	-9006
05-11-2021 00:00	22.47	18.92	22.61	24.85	24.78	4	24.08	-9006
Min Value	****	****	****	****	****	****	****	****
Max Value	****	****	****	****	****	****	****	****

End Of Report : From 04/11/2021 00:00:00 To 05/11/2021 00:00:00

ACTIVITY	NAME	SIGNATURE AND DATE
REVIEWED BY USER		
REVIEWED BY QA		