



## Environmental Monitoring System

### DATA REPORT

#### FILTRATION, VIAL FILLING, VIAL CAPPING (L4)

Date Time	FILTRATION ROOM (L4) wrt STERILE PASSAGE (L4)	FILTRATION ROOM (L4)	FILTRATION ROOM (L4)	VIAL LIQUID FILLING wrt STERILE PASSAGE (L4)	VIAL LIQUID FILL & STOP (L4)	VIAL LIQUID FILL & STOP (L4)	VIAL CAPPING ROOM (L4) wrt STERILE PASSAGE (L4)	VIAL CAPPING ROOM (L4)	VIAL CAPPING ROOM (L4)
Date Time	DP Pa	°C TEMP	% RH	DP Pa	°C TEMP	% RH	DP Pa	°C TEMP	% RH
Alarm Low Limit	6	17.0	35	10	17.0	35	6	22.0	40
Set Value									
Alarm High Limit	50	60.0	100	50	25.0	100	50	60.0	100
04-11-2021 00:00	5	25.6	49	20	22.5	56	7	23.2	56
04-11-2021 00:01	0	25.6	49	21	22.5	56	6	23.2	56
04-11-2021 00:02	5	25.6	49	21	22.6	56	7	23.2	56
04-11-2021 00:03	4	25.6	49	21	22.6	56	6	23.3	56
04-11-2021 00:04	5	25.6	49	20	22.6	56	6	23.3	56
04-11-2021 00:05	0	25.6	49	20	22.6	56	6	23.2	56
04-11-2021 00:06	5	25.7	49	21	22.6	55	7	23.2	56
04-11-2021 00:07	6	25.8	49	20	22.6	56	5	23.3	56
04-11-2021 00:08	5	25.8	49	21	22.6	55	6	23.2	56
04-11-2021 00:09	3	25.8	49	22	22.6	55	6	23.3	56
04-11-2021 00:10	4	25.8	49	21	22.6	55	6	23.3	56
04-11-2021 00:11	5	25.8	49	20	22.6	56	6	23.3	56
04-11-2021 00:12	6	25.8	49	21	22.6	55	5	23.3	56
04-11-2021 00:13	3	25.8	49	21	22.5	55	6	23.3	56
04-11-2021 00:14	4	25.8	49	22	22.5	56	7	23.2	56
04-11-2021 00:15	3	25.6	49	22	22.5	56	7	23.2	56
04-11-2021 00:16	4	25.6	49	21	22.4	56	7	23.2	56
04-11-2021 00:17	0	25.6	49	20	22.4	56	5	23.2	56
04-11-2021 00:18	5	25.6	49	20	22.4	56	5	23.2	56
04-11-2021 00:19	4	25.6	49	20	22.3	56	5	23.2	56
04-11-2021 00:20	3	25.6	49	21	22.3	56	6	23.2	56
04-11-2021 00:21	4	25.6	49	20	22.2	56	7	23.2	56
04-11-2021 00:22	0	25.6	49	22	22.2	56	7	23.1	56
04-11-2021 00:23	4	25.5	49	20	22.2	56	6	23.1	56



# Environmental Monitoring System

## DATA REPORT

### FILTRATION, VIAL FILLING, VIAL CAPPING (L4)

Date Time	FILTRATION ROOM (L4) wrt STERILE PASSAGE (L4)	FILTRATION ROOM (L4)	FILTRATION ROOM (L4)	VIAL LIQUID FILLING wrt STERILE PASSAGE (L4)	VIAL LIQUID FILL & STOP (L4)	VIAL LIQUID FILL & STOP (L4)	VIAL CAPPING ROOM (L4) wrt STERILE PASSAGE (L4)	VIAL CAPPING ROOM (L4)	VIAL CAPPING ROOM (L4)
Date Time	DP Pa	°C TEMP	% RH	DP Pa	°C TEMP	% RH	DP Pa	°C TEMP	% RH
04-11-2021 00:24	4	25.6	49	20	22.1	56	5	23.1	56
04-11-2021 00:25	0	25.6	49	21	22.1	56	7	23.0	56
04-11-2021 00:26	0	25.5	49	21	22.0	56	6	23.0	56
04-11-2021 00:27	4	25.5	49	20	21.9	57	6	23.0	56
04-11-2021 00:28	3	25.5	49	21	21.9	57	5	23.0	56
04-11-2021 00:29	4	25.5	49	20	21.9	57	6	22.9	56
04-11-2021 00:30	0	25.3	49	21	21.8	57	7	22.9	57
04-11-2021 00:31	4	25.3	49	20	21.8	57	7	22.9	57
04-11-2021 00:32	3	25.3	49	20	21.8	57	5	22.9	57
04-11-2021 00:33	3	25.3	49	20	21.9	57	5	22.8	57
04-11-2021 00:34	0	25.3	49	20	21.9	57	6	22.9	57
04-11-2021 00:35	3	25.3	49	20	21.8	57	6	22.8	57
04-11-2021 00:36	4	25.3	49	21	21.9	57	7	22.8	57
04-11-2021 00:37	0	25.3	49	21	21.9	57	6	22.9	57
04-11-2021 00:38	5	25.3	49	20	21.9	57	5	22.9	57
04-11-2021 00:39	4	25.3	49	21	22.0	57	5	22.9	57
04-11-2021 00:40	4	25.3	49	20	22.0	57	6	22.9	57
04-11-2021 00:41	4	25.3	49	21	22.1	56	6	22.9	57
04-11-2021 00:42	4	25.3	49	21	22.1	56	5	22.9	57
04-11-2021 00:43	0	25.3	49	20	22.1	56	5	22.9	57
04-11-2021 00:44	3	25.3	49	20	22.2	56	5	22.9	57
04-11-2021 00:45	0	25.3	49	21	22.2	56	5	23.0	57
04-11-2021 00:46	4	25.3	49	20	22.2	56	7	23.0	57
04-11-2021 00:47	4	25.5	49	20	22.2	56	5	23.0	56
04-11-2021 00:48	3	25.5	49	21	22.3	56	6	23.1	56
04-11-2021 00:49	3	25.5	49	21	22.3	56	5	23.1	56
04-11-2021 00:50	4	25.5	49	20	22.4	56	7	23.1	56



# Environmental Monitoring System

## DATA REPORT

### FILTRATION, VIAL FILLING, VIAL CAPPING (L4)

Date Time	FILTRATION ROOM (L4) wrt STERILE PASSAGE (L4)	FILTRATION ROOM (L4)	FILTRATION ROOM (L4)	VIAL LIQUID FILLING wrt STERILE PASSAGE (L4)	VIAL LIQUID FILL & STOP (L4)	VIAL LIQUID FILL & STOP (L4)	VIAL CAPPING ROOM (L4) wrt STERILE PASSAGE (L4)	VIAL CAPPING ROOM (L4)	VIAL CAPPING ROOM (L4)
Date Time	DP Pa	°C TEMP	% RH	DP Pa	°C TEMP	% RH	DP Pa	°C TEMP	% RH
04-11-2021 00:51	5	25.5	49	21	22.4	56	6	23.1	56
04-11-2021 00:52	4	25.5	49	19	22.4	56	6	23.2	56
04-11-2021 00:53	6	25.6	49	21	22.5	56	6	23.2	56
04-11-2021 00:54	4	25.5	49	21	22.5	56	6	23.2	56
04-11-2021 00:55	4	25.5	49	20	22.5	56	6	23.2	56
04-11-2021 00:56	5	25.6	49	20	22.6	56	6	23.2	56
04-11-2021 00:57	5	25.6	49	20	22.6	55	7	23.2	56
04-11-2021 00:58	4	25.6	49	20	22.6	55	5	23.2	56
04-11-2021 00:59	3	25.6	49	21	22.6	55	7	23.2	56
04-11-2021 01:00	4	25.6	49	20	22.6	55	5	23.2	56
04-11-2021 01:01	0	25.6	49	20	22.6	55	6	23.2	56
04-11-2021 01:02	4	25.6	49	21	22.6	55	6	23.2	56
04-11-2021 01:03	0	25.7	49	20	22.6	55	6	23.2	56
04-11-2021 01:04	5	25.7	49	21	22.6	55	6	23.2	56
04-11-2021 01:05	4	25.7	49	20	22.6	55	5	23.3	56
04-11-2021 01:06	4	25.7	49	19	22.5	55	7	23.2	56
04-11-2021 01:07	3	25.8	49	20	22.5	55	7	23.3	56
04-11-2021 01:08	0	25.8	49	21	22.5	55	6	23.2	56
04-11-2021 01:09	3	25.8	49	20	22.5	56	5	23.2	56
04-11-2021 01:10	3	25.7	49	20	22.5	56	6	23.2	56
04-11-2021 01:11	5	25.7	49	21	22.4	56	6	23.2	56
04-11-2021 01:12	3	25.7	49	20	22.4	56	5	23.2	56
04-11-2021 01:13	4	25.6	49	20	22.3	56	6	23.2	56
04-11-2021 01:14	4	25.6	49	20	22.3	56	5	23.2	56
04-11-2021 01:15	3	25.6	49	21	22.3	56	7	23.2	56
04-11-2021 01:16	4	25.6	49	22	22.2	56	6	23.1	56
04-11-2021 01:17	4	25.5	49	20	22.2	56	7	23.1	56



# Environmental Monitoring System

## DATA REPORT

### FILTRATION, VIAL FILLING, VIAL CAPPING (L4)

Date Time	FILTRATION ROOM (L4) wrt STERILE PASSAGE (L4)	FILTRATION ROOM (L4)	FILTRATION ROOM (L4)	VIAL LIQUID FILLING wrt STERILE PASSAGE (L4)	VIAL LIQUID FILL & STOP (L4)	VIAL LIQUID FILL & STOP (L4)	VIAL CAPPING ROOM (L4) wrt STERILE PASSAGE (L4)	VIAL CAPPING ROOM (L4)	VIAL CAPPING ROOM (L4)
Date Time	DP Pa	°C TEMP	% RH	DP Pa	°C TEMP	% RH	DP Pa	°C TEMP	% RH
04-11-2021 01:18	0	25.6	49	18	22.1	56	3	23.1	56
04-11-2021 01:19	5	25.6	49	20	22.0	57	6	23.1	56
04-11-2021 01:20	4	25.5	49	21	21.9	57	6	23.0	56
04-11-2021 01:21	4	25.5	49	20	21.9	57	5	23.0	56
04-11-2021 01:22	5	25.5	49	20	21.9	57	6	23.0	57
04-11-2021 01:23	4	25.5	49	20	21.9	57	6	22.9	57
04-11-2021 01:24	4	25.4	49	23	21.8	57	7	22.9	57
04-11-2021 01:25	3	25.4	49	20	21.8	57	5	22.9	57
04-11-2021 01:26	0	25.3	49	20	21.9	57	6	22.9	57
04-11-2021 01:27	4	25.3	49	20	21.8	57	6	22.9	57
04-11-2021 01:28	0	25.3	49	21	21.8	57	7	22.8	57
04-11-2021 01:29	3	25.3	49	20	21.8	57	5	22.8	57
04-11-2021 01:30	6	25.3	49	20	21.8	57	5	22.8	57
04-11-2021 01:31	0	25.3	49	20	21.8	57	6	22.8	57
04-11-2021 01:32	5	25.3	49	20	21.9	57	5	22.8	57
04-11-2021 01:33	0	25.3	49	21	21.9	57	5	22.9	57
04-11-2021 01:34	6	25.3	49	20	22.0	57	7	22.8	57
04-11-2021 01:35	4	25.3	49	20	22.1	57	6	22.9	57
04-11-2021 01:36	4	25.3	49	21	22.1	57	6	22.9	57
04-11-2021 01:37	0	25.3	49	21	22.2	56	7	22.9	57
04-11-2021 01:38	4	25.4	49	21	22.2	56	5	22.9	57
04-11-2021 01:39	0	25.4	49	18	22.2	56	4	23.0	57
04-11-2021 01:40	0	25.5	49	20	22.2	56	6	23.0	57
04-11-2021 01:41	4	25.5	49	20	22.3	56	7	23.0	56
04-11-2021 01:42	6	25.5	49	11	22.3	56	0	23.1	56
04-11-2021 01:43	4	25.5	49	20	22.3	56	6	23.1	56
04-11-2021 01:44	0	25.5	49	17	22.4	56	5	23.1	56



# Environmental Monitoring System

## DATA REPORT

### FILTRATION, VIAL FILLING, VIAL CAPPING (L4)

Date Time	FILTRATION ROOM (L4) wrt STERILE PASSAGE (L4)	FILTRATION ROOM (L4)	FILTRATION ROOM (L4)	VIAL LIQUID FILLING wrt STERILE PASSAGE (L4)	VIAL LIQUID FILL & STOP (L4)	VIAL LIQUID FILL & STOP (L4)	VIAL CAPPING ROOM (L4) wrt STERILE PASSAGE (L4)	VIAL CAPPING ROOM (L4)	VIAL CAPPING ROOM (L4)
Date Time	DP Pa	°C TEMP	% RH	DP Pa	°C TEMP	% RH	DP Pa	°C TEMP	% RH
04-11-2021 01:45	3	25.6	49	20	22.4	56	5	23.1	56
04-11-2021 01:46	5	25.6	50	20	22.5	56	6	23.2	56
04-11-2021 01:47	0	25.6	50	20	22.5	56	7	23.2	56
04-11-2021 01:48	4	25.5	51	17	22.5	56	3	23.2	56
04-11-2021 01:49	3	25.6	51	20	22.5	56	5	23.2	56
04-11-2021 01:50	0	25.6	51	21	22.5	56	6	23.2	56
04-11-2021 01:51	3	25.7	50	21	22.5	56	6	23.2	56
04-11-2021 01:52	3	25.7	50	18	22.5	56	5	23.2	56
04-11-2021 01:53	4	25.7	49	20	22.5	56	6	23.2	56
04-11-2021 01:54	0	25.8	49	21	22.6	56	5	23.2	56
04-11-2021 01:55	3	25.8	49	20	22.6	56	6	23.3	56
04-11-2021 01:56	5	25.8	49	20	22.6	56	6	23.4	56
04-11-2021 01:57	5	25.8	49	21	22.6	56	5	23.3	56
04-11-2021 01:58	3	25.8	49	20	22.6	56	6	23.4	56
04-11-2021 01:59	4	25.9	49	22	22.6	56	7	23.4	56
04-11-2021 02:00	3	25.9	49	21	22.6	56	5	23.4	56
04-11-2021 02:01	4	25.9	49	21	22.6	57	5	23.4	56
04-11-2021 02:02	4	25.9	49	21	22.6	57	6	23.4	56
04-11-2021 02:03	3	25.9	49	20	22.6	57	6	23.4	56
04-11-2021 02:04	0	25.9	48	23	22.7	58	6	23.4	56
04-11-2021 02:05	4	25.9	48	19	22.6	58	6	23.4	56
04-11-2021 02:06	4	25.9	48	19	22.6	58	6	23.3	56
04-11-2021 02:07	3	25.9	48	24	22.6	57	3	23.4	56
04-11-2021 02:08	0	25.9	49	24	22.6	57	7	23.3	56
04-11-2021 02:09	0	25.9	49	23	22.6	57	7	23.3	56
04-11-2021 02:10	0	25.9	49	22	22.6	56	10	23.2	56
04-11-2021 02:11	0	25.8	49	25	22.6	56	13	23.3	56



## Environmental Monitoring System

### DATA REPORT

#### FILTRATION, VIAL FILLING, VIAL CAPPING (L4)

Date Time	FILTRATION ROOM (L4) wrt STERILE PASSAGE (L4)	FILTRATION ROOM (L4)	FILTRATION ROOM (L4)	VIAL LIQUID FILLING wrt STERILE PASSAGE (L4)	VIAL LIQUID FILL & STOP (L4)	VIAL LIQUID FILL & STOP (L4)	VIAL CAPPING ROOM (L4) wrt STERILE PASSAGE (L4)	VIAL CAPPING ROOM (L4)	VIAL CAPPING ROOM (L4)
Date Time	DP Pa	°C TEMP	% RH	DP Pa	°C TEMP	% RH	DP Pa	°C TEMP	% RH
04-11-2021 02:12	0	25.8	49	22	22.6	56	7	23.3	57
04-11-2021 02:13	0	25.8	49	23	22.6	56	7	23.3	57
04-11-2021 02:14	0	25.8	49	22	22.6	56	7	23.3	57
04-11-2021 02:15	0	25.8	49	20	22.6	55	0	23.3	57
04-11-2021 02:16	0	25.8	49	20	22.6	55	0	23.3	57
04-11-2021 02:17	0	25.8	49	23	22.6	55	7	23.2	58
04-11-2021 02:18	0	25.8	49	25	22.6	55	6	23.2	58
04-11-2021 02:19	0	25.6	49	23	22.6	55	7	23.2	58
04-11-2021 02:20	0	25.6	49	23	22.6	55	6	23.2	58
04-11-2021 02:21	3	25.6	49	24	22.6	55	7	23.2	57
04-11-2021 02:22	3	25.6	49	24	22.6	55	7	23.2	57
04-11-2021 02:23	0	25.6	49	23	22.6	55	7	23.2	57
04-11-2021 02:24	0	25.6	49	23	22.6	55	7	23.1	57
04-11-2021 02:25	0	25.6	49	25	22.5	55	7	23.1	57
04-11-2021 02:26	4	25.6	49	25	22.5	56	7	23.1	57
04-11-2021 02:27	4	25.6	49	22	22.5	56	5	23.1	56
04-11-2021 02:28	0	25.6	49	23	22.5	56	7	23.1	57
04-11-2021 02:29	4	25.6	49	23	22.5	56	7	23.1	56
04-11-2021 02:30	3	25.5	49	23	22.5	56	7	23.1	57
04-11-2021 02:31	0	25.5	49	23	22.5	56	7	23.1	57
04-11-2021 02:32	0	25.6	49	22	22.5	56	7	23.1	57
04-11-2021 02:33	4	25.5	49	23	22.5	56	5	23.1	57
04-11-2021 02:34	0	25.5	49	20	22.5	56	3	23.0	57
04-11-2021 02:35	3	25.6	49	22	22.5	56	7	23.0	57
04-11-2021 02:36	3	25.5	49	23	22.5	56	7	23.0	57
04-11-2021 02:37	0	25.5	49	23	22.5	56	7	23.0	57
04-11-2021 02:38	0	25.6	49	23	22.5	56	7	23.0	57



## Environmental Monitoring System

### DATA REPORT

#### FILTRATION, VIAL FILLING, VIAL CAPPING (L4)

Date Time	FILTRATION ROOM (L4) wrt STERILE PASSAGE (L4)	FILTRATION ROOM (L4)	FILTRATION ROOM (L4)	VIAL LIQUID FILLING wrt STERILE PASSAGE (L4)	VIAL LIQUID FILL & STOP (L4)	VIAL LIQUID FILL & STOP (L4)	VIAL CAPPING ROOM (L4) wrt STERILE PASSAGE (L4)	VIAL CAPPING ROOM (L4)	VIAL CAPPING ROOM (L4)
Date Time	DP Pa	°C TEMP	% RH	DP Pa	°C TEMP	% RH	DP Pa	°C TEMP	% RH
04-11-2021 02:39	4	25.6	49	25	22.5	56	7	23.0	57
04-11-2021 02:40	0	25.6	49	24	22.5	56	7	23.0	57
04-11-2021 02:41	0	25.5	49	23	22.5	56	7	23.1	57
04-11-2021 02:42	0	25.5	49	23	22.6	56	7	23.1	57
04-11-2021 02:43	0	25.6	49	24	22.6	55	7	23.1	57
04-11-2021 02:44	0	25.6	49	24	22.6	55	7	23.1	57
04-11-2021 02:45	3	25.5	49	23	22.6	55	7	23.1	57
04-11-2021 02:46	3	25.6	49	26	22.6	55	7	23.1	57
04-11-2021 02:47	0	25.5	49	25	22.6	55	7	23.1	57
04-11-2021 02:48	0	25.6	49	23	22.6	55	7	23.1	57
04-11-2021 02:49	0	25.6	49	24	22.6	55	7	23.1	57
04-11-2021 02:50	3	25.6	49	24	22.6	55	7	23.1	57
04-11-2021 02:51	0	25.6	49	24	22.7	55	7	23.1	57
04-11-2021 02:52	0	25.6	49	23	22.7	55	7	23.1	56
04-11-2021 02:53	3	25.6	49	24	22.7	55	8	23.1	56
04-11-2021 02:54	0	25.6	49	23	22.7	55	7	23.1	56
04-11-2021 02:55	0	25.6	49	24	22.7	55	7	23.1	56
04-11-2021 02:56	0	25.6	49	23	22.7	55	8	23.1	56
04-11-2021 02:57	3	25.6	49	25	22.7	55	7	23.1	56
04-11-2021 02:58	0	25.6	49	23	22.7	55	6	23.2	56
04-11-2021 02:59	0	25.6	49	23	22.7	55	6	23.1	56
04-11-2021 03:00	0	25.6	49	24	22.7	55	7	23.1	56
04-11-2021 03:01	0	25.6	49	23	22.7	55	7	23.1	56
04-11-2021 03:02	0	25.7	49	22	22.7	55	7	23.2	56
04-11-2021 03:03	3	25.7	49	24	22.7	55	7	23.1	56
04-11-2021 03:04	0	25.7	48	23	22.7	55	7	23.1	56
04-11-2021 03:05	0	25.8	48	23	22.7	55	6	23.2	56



# Environmental Monitoring System

## DATA REPORT

### FILTRATION, VIAL FILLING, VIAL CAPPING (L4)

Date Time	FILTRATION ROOM (L4) wrt STERILE PASSAGE (L4)	FILTRATION ROOM (L4)	FILTRATION ROOM (L4)	VIAL LIQUID FILLING wrt STERILE PASSAGE (L4)	VIAL LIQUID FILL & STOP (L4)	VIAL LIQUID FILL & STOP (L4)	VIAL CAPPING ROOM (L4) wrt STERILE PASSAGE (L4)	VIAL CAPPING ROOM (L4)	VIAL CAPPING ROOM (L4)
Date Time	DP Pa	°C TEMP	% RH	DP Pa	°C TEMP	% RH	DP Pa	°C TEMP	% RH
04-11-2021 03:06	4	25.8	48	25	22.7	55	7	23.2	56
04-11-2021 03:07	0	25.8	48	23	22.7	55	5	23.1	56
04-11-2021 03:08	0	25.8	48	23	22.7	55	6	23.2	56
04-11-2021 03:09	0	25.8	48	24	22.7	55	7	23.2	56
04-11-2021 03:10	3	25.8	49	23	22.7	55	7	23.2	56
04-11-2021 03:11	5	25.6	49	20	22.6	55	5	23.2	56
04-11-2021 03:12	0	25.5	49	23	22.6	55	7	23.2	56
04-11-2021 03:13	0	25.3	50	24	22.6	55	7	23.2	56
04-11-2021 03:14	0	25.3	50	23	22.5	55	7	23.2	56
04-11-2021 03:15	0	25.2	50	24	22.5	55	4	23.2	56
04-11-2021 03:16	0	25.2	50	21	22.5	55	8	23.2	56
04-11-2021 03:17	0	25.2	50	23	22.5	55	7	23.2	56
04-11-2021 03:18	0	25.3	50	23	22.5	56	6	23.2	56
04-11-2021 03:19	4	25.3	50	25	22.6	56	9	23.2	57
04-11-2021 03:20	0	25.3	49	23	22.6	56	7	23.2	57
04-11-2021 03:21	0	25.4	49	22	22.6	56	8	23.2	57
04-11-2021 03:22	0	25.5	49	25	22.7	56	8	23.2	57
04-11-2021 03:23	0	25.5	49	25	22.7	56	7	23.2	57
04-11-2021 03:24	0	25.6	49	23	22.8	56	7	23.2	57
04-11-2021 03:25	0	25.6	49	22	22.8	56	7	23.2	57
04-11-2021 03:26	0	25.6	49	24	22.8	56	7	23.2	57
04-11-2021 03:27	5	25.6	49	26	22.9	56	7	23.2	57
04-11-2021 03:28	3	25.6	49	25	22.9	55	6	23.2	57
04-11-2021 03:29	4	25.6	49	24	22.9	55	7	23.3	57
04-11-2021 03:30	0	25.6	49	24	22.9	55	8	23.3	57
04-11-2021 03:31	3	25.6	49	23	23.0	55	7	23.3	57
04-11-2021 03:32	3	25.6	49	21	23.0	55	4	23.3	57





# Environmental Monitoring System

## DATA REPORT

### FILTRATION, VIAL FILLING, VIAL CAPPING (L4)

Date Time	FILTRATION ROOM (L4) wrt STERILE PASSAGE (L4)	FILTRATION ROOM (L4)	FILTRATION ROOM (L4)	VIAL LIQUID FILLING wrt STERILE PASSAGE (L4)	VIAL LIQUID FILL & STOP (L4)	VIAL LIQUID FILL & STOP (L4)	VIAL CAPPING ROOM (L4) wrt STERILE PASSAGE (L4)	VIAL CAPPING ROOM (L4)	VIAL CAPPING ROOM (L4)
Date Time	DP Pa	°C TEMP	% RH	DP Pa	°C TEMP	% RH	DP Pa	°C TEMP	% RH
04-11-2021 03:33	4	25.7	49	25	23.0	55	7	23.3	57
04-11-2021 03:34	3	25.7	49	23	23.0	55	7	23.3	57
04-11-2021 03:35	3	25.7	49	26	23.0	55	7	23.3	57
04-11-2021 03:36	6	25.8	49	24	23.0	55	7	23.4	57
04-11-2021 03:37	4	25.8	49	23	23.0	55	8	23.4	57
04-11-2021 03:38	0	25.8	49	25	23.0	55	8	23.4	56
04-11-2021 03:39	3	25.8	49	25	23.0	55	7	23.3	56
04-11-2021 03:40	3	25.8	49	26	23.0	55	8	23.3	56
04-11-2021 03:41	0	25.8	48	23	23.0	55	8	23.3	56
04-11-2021 03:42	3	25.8	48	25	23.0	55	8	23.3	56
04-11-2021 03:43	0	25.8	48	23	23.0	55	7	23.3	56
04-11-2021 03:44	0	25.8	48	23	23.0	55	7	23.4	56
04-11-2021 03:45	3	25.8	48	24	23.0	55	7	23.3	56
04-11-2021 03:46	4	25.8	48	25	23.0	55	7	23.3	56
04-11-2021 03:47	6	25.8	48	25	23.0	54	7	23.3	56
04-11-2021 03:48	0	25.9	48	23	23.0	54	7	23.3	56
04-11-2021 03:49	3	25.9	48	24	23.0	54	8	23.3	56
04-11-2021 03:50	0	25.9	48	23	22.9	54	8	23.3	55
04-11-2021 03:51	4	25.9	48	25	22.9	54	7	23.3	55
04-11-2021 03:52	0	25.9	48	25	22.9	54	8	23.3	55
04-11-2021 03:53	0	25.9	48	25	22.9	54	8	23.3	55
04-11-2021 03:54	0	25.9	48	24	22.9	54	7	23.3	56
04-11-2021 03:55	4	25.9	48	25	22.9	54	8	23.3	56
04-11-2021 03:56	4	25.9	48	24	23.0	54	8	23.3	56
04-11-2021 03:57	0	25.9	48	24	23.0	54	8	23.4	56
04-11-2021 03:58	0	25.9	48	24	23.0	54	7	23.4	56
04-11-2021 03:59	0	25.9	48	25	23.1	54	8	23.4	55



# Environmental Monitoring System

## DATA REPORT

### FILTRATION, VIAL FILLING, VIAL CAPPING (L4)

Date Time	FILTRATION ROOM (L4) wrt STERILE PASSAGE (L4)	FILTRATION ROOM (L4)	FILTRATION ROOM (L4)	VIAL LIQUID FILLING wrt STERILE PASSAGE (L4)	VIAL LIQUID FILL & STOP (L4)	VIAL LIQUID FILL & STOP (L4)	VIAL CAPPING ROOM (L4) wrt STERILE PASSAGE (L4)	VIAL CAPPING ROOM (L4)	VIAL CAPPING ROOM (L4)
Date Time	DP Pa	°C TEMP	% RH	DP Pa	°C TEMP	% RH	DP Pa	°C TEMP	% RH
04-11-2021 04:00	4	25.9	48	23	23.1	54	8	23.4	55
04-11-2021 04:01	3	25.9	48	25	23.1	54	7	23.4	55
04-11-2021 04:02	4	25.9	48	25	23.1	54	7	23.4	55
04-11-2021 04:03	0	25.9	48	25	23.1	54	8	23.4	55
04-11-2021 04:04	0	26.0	48	25	23.1	54	7	23.5	55
04-11-2021 04:05	0	26.0	48	25	23.2	54	8	23.5	55
04-11-2021 04:06	4	26.1	48	25	23.2	54	8	23.5	55
04-11-2021 04:07	0	26.1	48	25	23.2	54	7	23.5	55
04-11-2021 04:08	0	26.1	48	25	23.2	54	8	23.5	55
04-11-2021 04:09	4	26.1	48	24	23.3	53	8	23.5	55
04-11-2021 04:10	0	26.1	48	25	23.3	53	8	23.5	55
04-11-2021 04:11	0	26.1	48	24	23.3	53	7	23.5	55
04-11-2021 04:12	0	26.2	48	25	23.3	53	7	23.5	55
04-11-2021 04:13	3	26.2	48	23	23.3	53	7	23.5	55
04-11-2021 04:14	0	26.2	47	25	23.3	53	8	23.6	55
04-11-2021 04:15	3	26.2	47	25	23.3	53	8	23.6	55
04-11-2021 04:16	0	26.2	47	25	23.3	53	7	23.6	55
04-11-2021 04:17	0	26.2	47	25	23.3	53	8	23.6	55
04-11-2021 04:18	5	26.2	47	25	23.2	54	7	23.6	55
04-11-2021 04:19	3	26.2	47	24	23.2	54	7	23.6	55
04-11-2021 04:20	4	26.2	47	24	23.2	54	8	23.6	55
04-11-2021 04:21	4	26.3	47	24	23.2	54	8	23.5	55
04-11-2021 04:22	4	26.2	47	24	23.2	54	8	23.5	55
04-11-2021 04:23	4	26.2	47	23	23.2	54	7	23.5	55
04-11-2021 04:24	4	26.2	47	25	23.2	54	8	23.5	55
04-11-2021 04:25	0	26.2	48	25	23.1	54	8	23.5	55
04-11-2021 04:26	3	26.2	48	25	23.1	54	7	23.5	55



# Environmental Monitoring System

## DATA REPORT

### FILTRATION, VIAL FILLING, VIAL CAPPING (L4)

Date Time	FILTRATION ROOM (L4) wrt STERILE PASSAGE (L4)	FILTRATION ROOM (L4)	FILTRATION ROOM (L4)	VIAL LIQUID FILLING wrt STERILE PASSAGE (L4)	VIAL LIQUID FILL & STOP (L4)	VIAL LIQUID FILL & STOP (L4)	VIAL CAPPING ROOM (L4) wrt STERILE PASSAGE (L4)	VIAL CAPPING ROOM (L4)	VIAL CAPPING ROOM (L4)
Date Time	DP Pa	°C TEMP	% RH	DP Pa	°C TEMP	% RH	DP Pa	°C TEMP	% RH
04-11-2021 04:27	0	26.2	48	23	23.1	54	8	23.5	55
04-11-2021 04:28	0	26.2	48	24	23.1	54	8	23.5	55
04-11-2021 04:29	0	26.1	48	25	23.1	54	8	23.5	55
04-11-2021 04:30	0	26.1	48	23	23.1	54	8	23.4	55
04-11-2021 04:31	5	26.1	48	25	23.1	54	7	23.4	55
04-11-2021 04:32	4	26.1	48	25	23.1	54	7	23.4	55
04-11-2021 04:33	3	26.1	48	25	23.1	54	7	23.4	55
04-11-2021 04:34	3	26.2	48	24	23.1	54	7	23.4	55
04-11-2021 04:35	0	26.1	48	24	23.1	54	7	23.4	55
04-11-2021 04:36	0	26.1	48	24	23.1	54	8	23.4	55
04-11-2021 04:37	4	26.1	48	24	23.0	54	8	23.4	55
04-11-2021 04:38	3	26.1	48	25	23.0	54	8	23.4	55
04-11-2021 04:39	4	26.1	48	27	23.0	54	7	23.4	55
04-11-2021 04:40	0	26.1	48	25	23.1	54	8	23.3	55
04-11-2021 04:41	0	26.1	48	25	23.0	54	8	23.3	55
04-11-2021 04:42	0	26.1	48	24	23.0	54	7	23.3	55
04-11-2021 04:43	4	26.1	48	25	23.0	54	8	23.3	55
04-11-2021 04:44	4	26.1	48	27	23.0	54	10	23.3	55
04-11-2021 04:45	4	26.1	48	28	23.0	54	9	23.3	55
04-11-2021 04:46	0	26.1	48	25	23.0	54	8	23.3	55
04-11-2021 04:47	0	26.1	48	24	23.0	54	8	23.3	55
04-11-2021 04:48	0	26.1	48	25	23.0	54	8	23.3	55
04-11-2021 04:49	0	26.1	48	24	22.9	54	8	23.3	55
04-11-2021 04:50	0	26.1	48	25	22.9	54	8	23.3	55
04-11-2021 04:51	0	26.0	48	25	22.9	54	8	23.2	55
04-11-2021 04:52	6	25.9	48	27	22.9	54	10	23.3	55
04-11-2021 04:53	4	25.9	48	25	22.8	54	7	23.3	55



## Environmental Monitoring System

### DATA REPORT

#### FILTRATION, VIAL FILLING, VIAL CAPPING (L4)

Date Time	FILTRATION ROOM (L4) wrt STERILE PASSAGE (L4)	FILTRATION ROOM (L4)	FILTRATION ROOM (L4)	VIAL LIQUID FILLING wrt STERILE PASSAGE (L4)	VIAL LIQUID FILL & STOP (L4)	VIAL LIQUID FILL & STOP (L4)	VIAL CAPPING ROOM (L4) wrt STERILE PASSAGE (L4)	VIAL CAPPING ROOM (L4)	VIAL CAPPING ROOM (L4)
Date Time	DP Pa	°C TEMP	% RH	DP Pa	°C TEMP	% RH	DP Pa	°C TEMP	% RH
04-11-2021 04:54	0	25.9	48	25	22.8	54	7	23.2	55
04-11-2021 04:55	3	25.9	48	24	22.8	54	8	23.2	55
04-11-2021 04:56	4	25.9	48	25	22.8	54	8	23.2	55
04-11-2021 04:57	0	25.9	48	25	22.8	54	8	23.2	55
04-11-2021 04:58	0	25.9	48	26	22.8	54	8	23.2	55
04-11-2021 04:59	4	25.9	48	26	22.8	54	7	23.2	55
04-11-2021 05:00	0	25.9	48	25	22.8	54	7	23.2	55
04-11-2021 05:01	3	25.9	48	23	22.8	54	8	23.2	55
04-11-2021 05:02	0	25.9	48	26	22.8	54	8	23.2	56
04-11-2021 05:03	3	25.9	48	25	22.8	54	7	23.2	56
04-11-2021 05:04	4	25.9	48	25	22.8	54	8	23.2	56
04-11-2021 05:05	0	25.9	48	25	22.8	54	8	23.2	56
04-11-2021 05:06	0	25.9	48	25	22.9	54	7	23.2	55
04-11-2021 05:07	0	25.9	48	25	22.9	54	8	23.2	55
04-11-2021 05:08	3	25.9	48	25	22.9	54	7	23.2	55
04-11-2021 05:09	3	25.9	48	25	22.9	54	8	23.2	55
04-11-2021 05:10	4	25.9	48	25	22.9	54	9	23.3	55
04-11-2021 05:11	4	25.9	48	25	23.0	54	8	23.3	55
04-11-2021 05:12	4	26.0	48	26	23.0	54	8	23.3	55
04-11-2021 05:13	4	26.1	48	25	23.1	54	8	23.3	55
04-11-2021 05:14	4	26.1	48	25	23.1	54	7	23.4	55
04-11-2021 05:15	4	26.1	48	25	23.1	54	8	23.4	55
04-11-2021 05:16	0	26.1	47	26	23.1	54	7	23.4	55
04-11-2021 05:17	4	26.1	47	28	23.1	54	8	23.4	55
04-11-2021 05:18	4	26.1	47	23	23.2	53	5	23.4	55
04-11-2021 05:19	3	26.1	47	25	23.2	53	7	23.5	55
04-11-2021 05:20	0	26.2	47	25	23.2	53	8	23.5	55



## Environmental Monitoring System

### DATA REPORT

#### FILTRATION, VIAL FILLING, VIAL CAPPING (L4)

Date Time	FILTRATION ROOM (L4) wrt STERILE PASSAGE (L4)	FILTRATION ROOM (L4)	FILTRATION ROOM (L4)	VIAL LIQUID FILLING wrt STERILE PASSAGE (L4)	VIAL LIQUID FILL & STOP (L4)	VIAL LIQUID FILL & STOP (L4)	VIAL CAPPING ROOM (L4) wrt STERILE PASSAGE (L4)	VIAL CAPPING ROOM (L4)	VIAL CAPPING ROOM (L4)
Date Time	DP Pa	°C TEMP	% RH	DP Pa	°C TEMP	% RH	DP Pa	°C TEMP	% RH
04-11-2021 05:21	0	26.2	47	25	23.2	53	8	23.5	55
04-11-2021 05:22	4	26.2	47	25	23.2	53	7	23.5	55
04-11-2021 05:23	0	26.2	47	25	23.3	53	8	23.5	55
04-11-2021 05:24	0	26.2	47	25	23.3	53	8	23.5	55
04-11-2021 05:25	4	26.2	47	25	23.3	53	8	23.5	55
04-11-2021 05:26	3	26.2	47	26	23.3	53	9	23.6	55
04-11-2021 05:27	0	26.2	47	25	23.3	53	8	23.5	55
04-11-2021 05:28	5	26.2	47	25	23.3	53	7	23.6	55
04-11-2021 05:29	0	26.3	47	25	23.3	53	8	23.6	55
04-11-2021 05:30	4	26.2	47	25	23.3	53	8	23.6	55
04-11-2021 05:31	0	26.3	47	25	23.3	53	7	23.5	55
04-11-2021 05:32	0	26.3	47	26	23.3	53	8	23.5	55
04-11-2021 05:33	0	26.3	47	25	23.3	53	8	23.5	55
04-11-2021 05:34	3	26.3	47	26	23.2	53	8	23.5	55
04-11-2021 05:35	5	26.3	47	27	23.2	53	7	23.5	55
04-11-2021 05:36	0	26.2	47	25	23.2	53	8	23.5	55
04-11-2021 05:37	3	26.2	47	27	23.2	53	8	23.5	55
04-11-2021 05:38	0	26.2	47	26	23.2	53	8	23.5	55
04-11-2021 05:39	4	26.2	47	25	23.1	54	8	23.5	55
04-11-2021 05:40	0	26.2	47	24	23.1	54	8	23.4	55
04-11-2021 05:41	0	26.2	47	25	23.1	54	8	23.4	55
04-11-2021 05:42	0	26.2	47	23	23.1	54	8	23.4	55
04-11-2021 05:43	4	26.2	47	25	23.1	54	7	23.4	55
04-11-2021 05:44	6	26.2	47	24	23.1	54	7	23.4	55
04-11-2021 05:45	0	26.1	47	25	23.1	54	7	23.4	55
04-11-2021 05:46	0	26.2	47	25	23.1	54	7	23.4	55
04-11-2021 05:47	6	26.1	47	24	23.0	54	8	23.3	55



## Environmental Monitoring System

### DATA REPORT

#### FILTRATION, VIAL FILLING, VIAL CAPPING (L4)

Date Time	FILTRATION ROOM (L4) wrt STERILE PASSAGE (L4)	FILTRATION ROOM (L4)	FILTRATION ROOM (L4)	VIAL LIQUID FILLING wrt STERILE PASSAGE (L4)	VIAL LIQUID FILL & STOP (L4)	VIAL LIQUID FILL & STOP (L4)	VIAL CAPPING ROOM (L4) wrt STERILE PASSAGE (L4)	VIAL CAPPING ROOM (L4)	VIAL CAPPING ROOM (L4)
Date Time	DP Pa	°C TEMP	% RH	DP Pa	°C TEMP	% RH	DP Pa	°C TEMP	% RH
04-11-2021 05:48	5	26.1	47	25	23.0	54	8	23.3	55
04-11-2021 05:49	0	26.1	47	26	23.0	54	8	23.3	55
04-11-2021 05:50	6	26.1	47	24	23.0	54	7	23.3	55
04-11-2021 05:51	3	26.1	47	23	23.0	54	8	23.3	55
04-11-2021 05:52	4	26.1	47	26	23.0	54	8	23.3	55
04-11-2021 05:53	4	26.0	48	24	23.0	54	7	23.3	55
04-11-2021 05:54	0	26.0	48	23	23.0	54	8	23.3	55
04-11-2021 05:55	0	25.9	48	24	23.0	54	7	23.3	55
04-11-2021 05:56	0	25.9	48	21	23.0	54	5	23.3	55
04-11-2021 05:57	3	25.9	48	21	23.0	54	7	23.3	55
04-11-2021 05:58	4	25.9	48	25	22.9	54	7	23.3	55
04-11-2021 05:59	0	25.9	48	23	22.9	54	7	23.3	55
04-11-2021 06:00	0	25.9	48	20	22.9	54	7	23.3	55
04-11-2021 06:01	0	26.0	48	23	23.0	54	7	23.3	55
04-11-2021 06:02	0	26.0	48	23	23.0	54	6	23.3	55
04-11-2021 06:03	3	26.0	48	22	23.0	54	6	23.3	55
04-11-2021 06:04	3	26.1	48	24	23.0	54	5	23.3	55
04-11-2021 06:05	0	26.1	48	23	23.0	54	6	23.3	55
04-11-2021 06:06	0	26.1	48	24	23.1	54	7	23.3	55
04-11-2021 06:07	0	26.1	48	23	23.1	54	6	23.3	55
04-11-2021 06:08	3	26.1	48	23	23.1	54	7	23.4	55
04-11-2021 06:09	0	26.1	48	24	23.1	54	7	23.4	55
04-11-2021 06:10	0	26.1	48	20	23.1	54	3	23.4	55
04-11-2021 06:11	6	26.2	48	47	23.1	54	13	23.4	55
04-11-2021 06:12	4	26.2	48	21	23.1	54	7	23.4	55
04-11-2021 06:13	4	26.2	48	17	23.1	54	0	23.4	55
04-11-2021 06:14	0	26.2	48	23	23.1	54	8	23.4	55



# Environmental Monitoring System

## DATA REPORT

### FILTRATION, VIAL FILLING, VIAL CAPPING (L4)

Date Time	FILTRATION ROOM (L4) wrt STERILE PASSAGE (L4)	FILTRATION ROOM (L4)	FILTRATION ROOM (L4)	VIAL LIQUID FILLING wrt STERILE PASSAGE (L4)	VIAL LIQUID FILL & STOP (L4)	VIAL LIQUID FILL & STOP (L4)	VIAL CAPPING ROOM (L4) wrt STERILE PASSAGE (L4)	VIAL CAPPING ROOM (L4)	VIAL CAPPING ROOM (L4)
Date Time	DP Pa	°C TEMP	% RH	DP Pa	°C TEMP	% RH	DP Pa	°C TEMP	% RH
04-11-2021 06:15	0	26.2	48	24	23.1	54	8	23.4	55
04-11-2021 06:16	0	26.2	48	22	23.1	54	6	23.4	55
04-11-2021 06:17	0	26.2	48	24	23.1	54	5	23.4	55
04-11-2021 06:18	0	26.2	47	25	23.1	54	6	23.4	55
04-11-2021 06:19	3	26.2	48	21	23.1	54	7	23.4	55
04-11-2021 06:20	3	26.1	48	22	23.1	54	7	23.4	55
04-11-2021 06:21	0	26.2	48	23	23.1	54	7	23.4	55
04-11-2021 06:22	0	26.2	48	23	23.1	54	7	23.4	55
04-11-2021 06:23	0	26.1	48	23	23.0	54	6	23.4	55
04-11-2021 06:24	0	26.1	48	23	23.0	54	7	23.4	55
04-11-2021 06:25	0	26.1	48	23	23.0	54	7	23.4	55
04-11-2021 06:26	0	26.1	48	24	23.0	54	7	23.4	55
04-11-2021 06:27	3	26.1	48	22	23.0	54	5	23.3	56
04-11-2021 06:28	0	26.1	48	25	22.9	54	7	23.3	56
04-11-2021 06:29	4	26.1	48	23	22.9	55	6	23.3	56
04-11-2021 06:30	4	26.0	48	23	22.9	55	7	23.3	56
04-11-2021 06:31	4	25.9	48	23	22.8	55	5	23.2	56
04-11-2021 06:32	3	25.9	48	23	22.8	55	7	23.2	56
04-11-2021 06:33	0	25.9	48	24	22.8	55	6	23.2	56
04-11-2021 06:34	4	25.9	48	24	22.8	55	7	23.2	56
04-11-2021 06:35	4	25.9	48	23	22.7	55	3	23.2	56
04-11-2021 06:36	4	25.9	48	23	22.8	55	5	23.2	56
04-11-2021 06:37	0	25.9	48	23	22.7	55	6	23.2	56
04-11-2021 06:38	3	25.9	48	23	22.7	55	6	23.2	56
04-11-2021 06:39	0	25.9	48	22	22.7	55	6	23.2	56
04-11-2021 06:40	3	25.9	48	23	22.7	55	6	23.2	56
04-11-2021 06:41	0	25.9	48	25	22.7	55	7	23.2	56



# Environmental Monitoring System

## DATA REPORT

### FILTRATION, VIAL FILLING, VIAL CAPPING (L4)

Date Time	FILTRATION ROOM (L4) wrt STERILE PASSAGE (L4)	FILTRATION ROOM (L4)	FILTRATION ROOM (L4)	VIAL LIQUID FILLING wrt STERILE PASSAGE (L4)	VIAL LIQUID FILL & STOP (L4)	VIAL LIQUID FILL & STOP (L4)	VIAL CAPPING ROOM (L4) wrt STERILE PASSAGE (L4)	VIAL CAPPING ROOM (L4)	VIAL CAPPING ROOM (L4)
Date Time	DP Pa	°C TEMP	% RH	DP Pa	°C TEMP	% RH	DP Pa	°C TEMP	% RH
04-11-2021 06:42	3	25.9	48	23	22.7	55	7	23.2	56
04-11-2021 06:43	0	25.8	48	23	22.7	55	7	23.1	56
04-11-2021 06:44	0	25.8	48	23	22.7	55	7	23.1	56
04-11-2021 06:45	0	25.8	48	22	22.6	55	6	23.1	56
04-11-2021 06:46	3	25.8	48	23	22.6	55	6	23.1	56
04-11-2021 06:47	0	25.8	48	23	22.6	55	7	23.1	56
04-11-2021 06:48	3	25.8	48	23	22.6	55	6	23.1	56
04-11-2021 06:49	0	25.8	48	23	22.6	55	6	23.1	56
04-11-2021 06:50	0	25.8	48	23	22.6	55	5	23.1	56
04-11-2021 06:51	0	25.8	48	24	22.6	55	7	23.1	56
04-11-2021 06:52	0	25.8	48	23	22.6	55	6	23.1	56
04-11-2021 06:53	0	25.8	48	22	22.6	55	6	23.1	56
04-11-2021 06:54	0	25.8	48	23	22.6	55	7	23.1	56
04-11-2021 06:55	0	25.8	48	23	22.6	55	6	23.1	56
04-11-2021 06:56	5	25.8	48	22	22.6	55	7	23.1	56
04-11-2021 06:57	0	25.8	48	23	22.6	55	6	23.1	56
04-11-2021 06:58	4	25.8	48	25	22.6	55	6	23.1	56
04-11-2021 06:59	3	25.7	48	23	22.6	55	7	23.1	56
04-11-2021 07:00	0	25.6	48	22	22.6	55	6	23.1	56
04-11-2021 07:01	0	25.7	48	24	22.6	55	7	23.1	56
04-11-2021 07:02	0	25.6	48	24	22.6	55	7	23.1	56
04-11-2021 07:03	0	25.6	49	25	22.6	55	6	23.1	56
04-11-2021 07:04	3	25.6	49	23	22.6	55	6	23.1	56
04-11-2021 07:05	0	25.6	49	23	22.6	55	5	23.1	56
04-11-2021 07:06	3	25.6	49	23	22.6	55	7	23.1	56
04-11-2021 07:07	0	25.6	49	23	22.6	55	6	23.1	56
04-11-2021 07:08	0	25.6	49	23	22.6	55	7	23.1	56





## Environmental Monitoring System

### DATA REPORT

#### FILTRATION, VIAL FILLING, VIAL CAPPING (L4)

Date Time	FILTRATION ROOM (L4) wrt STERILE PASSAGE (L4)	FILTRATION ROOM (L4)	FILTRATION ROOM (L4)	VIAL LIQUID FILLING wrt STERILE PASSAGE (L4)	VIAL LIQUID FILL & STOP (L4)	VIAL LIQUID FILL & STOP (L4)	VIAL CAPPING ROOM (L4) wrt STERILE PASSAGE (L4)	VIAL CAPPING ROOM (L4)	VIAL CAPPING ROOM (L4)
Date Time	DP Pa	°C TEMP	% RH	DP Pa	°C TEMP	% RH	DP Pa	°C TEMP	% RH
04-11-2021 07:09	0	25.6	49	21	22.6	55	6	23.1	56
04-11-2021 07:10	4	25.6	49	23	22.6	55	7	23.1	56
04-11-2021 07:11	0	25.6	49	23	22.6	55	7	23.1	56
04-11-2021 07:12	0	25.6	49	23	22.6	55	6	23.1	56
04-11-2021 07:13	0	25.6	49	24	22.6	55	6	23.1	56
04-11-2021 07:14	0	25.6	49	23	22.6	55	6	23.1	57
04-11-2021 07:15	0	25.6	49	22	22.6	55	7	23.1	57
04-11-2021 07:16	0	25.6	49	23	22.6	55	7	23.1	57
04-11-2021 07:17	0	25.6	49	23	22.6	55	5	23.1	57
04-11-2021 07:18	0	25.6	49	24	22.6	55	6	23.1	57
04-11-2021 07:19	4	25.6	49	23	22.6	55	6	23.1	57
04-11-2021 07:20	0	25.7	49	25	22.6	55	7	23.1	57
04-11-2021 07:21	0	25.7	49	25	22.6	55	6	23.1	57
04-11-2021 07:22	3	25.7	49	23	22.6	55	6	23.1	57
04-11-2021 07:23	0	25.6	49	23	22.6	55	6	23.1	57
04-11-2021 07:24	0	25.6	49	23	22.6	55	6	23.1	57
04-11-2021 07:25	4	25.7	49	22	22.6	55	7	23.1	57
04-11-2021 07:26	0	25.7	49	23	22.6	55	7	23.1	57
04-11-2021 07:27	3	25.7	49	22	22.6	55	6	23.1	56
04-11-2021 07:28	0	25.8	49	24	22.6	55	6	23.1	57
04-11-2021 07:29	3	25.7	49	23	22.6	55	6	23.1	57
04-11-2021 07:30	0	25.8	49	22	22.7	55	5	23.1	57
04-11-2021 07:31	0	25.7	49	24	22.7	55	7	23.1	57
04-11-2021 07:32	0	25.8	49	23	22.7	55	6	23.1	57
04-11-2021 07:33	0	25.8	49	23	22.7	55	5	23.2	56
04-11-2021 07:34	3	25.8	49	24	22.7	55	6	23.1	56
04-11-2021 07:35	0	25.8	49	23	22.7	55	7	23.1	56



## Environmental Monitoring System

### DATA REPORT

#### FILTRATION, VIAL FILLING, VIAL CAPPING (L4)

Date Time	FILTRATION ROOM (L4) wrt STERILE PASSAGE (L4)	FILTRATION ROOM (L4)	FILTRATION ROOM (L4)	VIAL LIQUID FILLING wrt STERILE PASSAGE (L4)	VIAL LIQUID FILL & STOP (L4)	VIAL LIQUID FILL & STOP (L4)	VIAL CAPPING ROOM (L4) wrt STERILE PASSAGE (L4)	VIAL CAPPING ROOM (L4)	VIAL CAPPING ROOM (L4)
Date Time	DP Pa	°C TEMP	% RH	DP Pa	°C TEMP	% RH	DP Pa	°C TEMP	% RH
04-11-2021 07:36	0	25.8	49	23	22.7	55	5	23.2	56
04-11-2021 07:37	0	25.8	49	25	22.7	55	7	23.2	56
04-11-2021 07:38	0	25.8	49	23	22.7	55	7	23.2	56
04-11-2021 07:39	4	25.8	49	23	22.7	55	6	23.2	56
04-11-2021 07:40	0	25.8	49	23	22.7	55	6	23.2	56
04-11-2021 07:41	0	25.8	49	23	22.8	55	6	23.2	56
04-11-2021 07:42	0	25.8	49	24	22.8	55	6	23.2	56
04-11-2021 07:43	0	25.8	49	23	22.8	55	6	23.2	56
04-11-2021 07:44	0	25.8	49	23	22.8	55	6	23.2	56
04-11-2021 07:45	0	25.8	49	23	22.8	55	7	23.2	56
04-11-2021 07:46	0	25.8	49	25	22.7	55	6	23.2	56
04-11-2021 07:47	0	25.8	49	24	22.7	55	5	23.2	56
04-11-2021 07:48	3	25.8	49	23	22.7	55	6	23.2	56
04-11-2021 07:49	0	25.8	48	24	22.7	55	6	23.2	56
04-11-2021 07:50	0	25.8	48	23	22.7	55	5	23.2	56
04-11-2021 07:51	0	25.8	48	25	22.7	55	6	23.2	56
04-11-2021 07:52	0	25.8	48	22	22.7	55	6	23.2	56
04-11-2021 07:53	0	25.8	49	23	22.7	55	7	23.1	56
04-11-2021 07:54	0	25.8	49	24	22.6	55	6	23.1	57
04-11-2021 07:55	0	25.7	49	23	22.6	55	6	23.1	57
04-11-2021 07:56	0	25.7	49	23	22.6	55	6	23.1	57
04-11-2021 07:57	0	25.6	49	23	22.6	55	7	23.1	57
04-11-2021 07:58	4	25.6	49	23	22.6	56	6	23.1	57
04-11-2021 07:59	3	25.6	49	23	22.5	56	6	23.0	57
04-11-2021 08:00	0	25.6	49	23	22.5	56	7	23.0	57
04-11-2021 08:01	4	25.6	49	21	22.5	56	6	23.0	57
04-11-2021 08:02	3	25.6	49	23	22.4	56	7	23.0	57



## Environmental Monitoring System

### DATA REPORT

#### FILTRATION, VIAL FILLING, VIAL CAPPING (L4)

Date Time	FILTRATION ROOM (L4) wrt STERILE PASSAGE (L4)	FILTRATION ROOM (L4)	FILTRATION ROOM (L4)	VIAL LIQUID FILLING wrt STERILE PASSAGE (L4)	VIAL LIQUID FILL & STOP (L4)	VIAL LIQUID FILL & STOP (L4)	VIAL CAPPING ROOM (L4) wrt STERILE PASSAGE (L4)	VIAL CAPPING ROOM (L4)	VIAL CAPPING ROOM (L4)
Date Time	DP Pa	°C TEMP	% RH	DP Pa	°C TEMP	% RH	DP Pa	°C TEMP	% RH
04-11-2021 08:03	0	25.6	49	23	22.4	56	6	23.0	57
04-11-2021 08:04	4	25.6	49	22	22.4	56	7	23.0	57
04-11-2021 08:05	3	25.6	49	24	22.4	56	6	22.9	57
04-11-2021 08:06	0	25.5	49	23	22.4	56	6	22.9	57
04-11-2021 08:07	0	25.5	49	24	22.4	56	7	22.9	57
04-11-2021 08:08	0	25.5	49	24	22.4	56	6	22.9	57
04-11-2021 08:09	0	25.5	49	24	22.3	56	6	22.9	57
04-11-2021 08:10	0	25.5	49	23	22.3	56	7	22.8	57
04-11-2021 08:11	0	25.5	49	23	22.3	56	6	22.8	57
04-11-2021 08:12	4	25.5	49	23	22.3	56	6	22.8	57
04-11-2021 08:13	0	25.5	49	25	22.2	57	7	22.8	58
04-11-2021 08:14	0	25.5	50	23	22.2	57	7	22.7	58
04-11-2021 08:15	0	25.3	50	22	22.2	57	6	22.7	58
04-11-2021 08:16	0	25.3	50	23	22.2	57	6	22.7	58
04-11-2021 08:17	4	25.3	50	23	22.2	57	7	22.7	58
04-11-2021 08:18	0	25.3	50	24	22.1	57	7	22.7	58
04-11-2021 08:19	3	25.3	50	23	22.1	57	7	22.7	58
04-11-2021 08:20	0	25.3	50	24	22.1	57	6	22.7	58
04-11-2021 08:21	0	25.3	50	23	22.1	57	7	22.7	58
04-11-2021 08:22	0	25.3	50	24	22.1	57	7	22.7	58
04-11-2021 08:23	4	25.3	50	23	22.1	57	5	22.7	58
04-11-2021 08:24	0	25.3	50	23	22.2	57	7	22.7	58
04-11-2021 08:25	3	25.3	50	23	22.2	57	6	22.7	58
04-11-2021 08:26	4	25.3	50	24	22.2	57	6	22.7	58
04-11-2021 08:27	3	25.3	50	23	22.2	57	7	22.7	58
04-11-2021 08:28	0	25.3	50	22	22.3	57	6	22.8	58
04-11-2021 08:29	3	25.3	50	24	22.3	57	5	22.8	58



# Environmental Monitoring System

## DATA REPORT

### FILTRATION, VIAL FILLING, VIAL CAPPING (L4)

Date Time	FILTRATION ROOM (L4) wrt STERILE PASSAGE (L4)	FILTRATION ROOM (L4)	FILTRATION ROOM (L4)	VIAL LIQUID FILLING wrt STERILE PASSAGE (L4)	VIAL LIQUID FILL & STOP (L4)	VIAL LIQUID FILL & STOP (L4)	VIAL CAPPING ROOM (L4) wrt STERILE PASSAGE (L4)	VIAL CAPPING ROOM (L4)	VIAL CAPPING ROOM (L4)
Date Time	DP Pa	°C TEMP	% RH	DP Pa	°C TEMP	% RH	DP Pa	°C TEMP	% RH
04-11-2021 08:30	0	25.3	50	22	22.4	56	7	22.8	58
04-11-2021 08:31	0	25.5	50	23	22.4	56	7	22.9	58
04-11-2021 08:32	0	25.5	50	21	22.5	56	5	22.9	58
04-11-2021 08:33	0	25.5	50	23	22.5	56	7	22.9	58
04-11-2021 08:34	0	25.5	50	23	22.5	56	7	22.9	57
04-11-2021 08:35	0	25.5	50	23	22.5	56	7	23.0	57
04-11-2021 08:36	0	25.6	50	24	22.6	56	7	23.0	57
04-11-2021 08:37	0	25.6	50	24	22.6	56	7	23.0	57
04-11-2021 08:38	0	25.6	50	27	22.7	56	6	23.0	57
04-11-2021 08:39	0	25.6	50	23	22.7	56	5	23.0	57
04-11-2021 08:40	0	25.6	49	22	22.7	56	7	23.1	57
04-11-2021 08:41	3	25.6	49	21	22.7	56	5	23.1	57
04-11-2021 08:42	0	25.6	49	23	22.7	56	6	23.1	57
04-11-2021 08:43	3	25.6	49	23	22.7	56	7	23.1	57
04-11-2021 08:44	0	25.6	49	22	22.7	56	6	23.1	57
04-11-2021 08:45	0	25.6	49	24	22.7	56	6	23.1	57
04-11-2021 08:46	4	25.6	49	24	22.7	56	6	23.1	57
04-11-2021 08:47	0	25.6	49	23	22.6	56	7	23.1	57
04-11-2021 08:48	4	25.6	49	23	22.6	56	7	23.1	57
04-11-2021 08:49	5	25.6	50	23	22.6	56	6	23.1	57
04-11-2021 08:50	0	25.7	49	24	22.6	56	6	23.1	57
04-11-2021 08:51	0	25.6	49	23	22.6	56	6	23.1	57
04-11-2021 08:52	0	25.6	49	23	22.5	56	7	23.1	57
04-11-2021 08:53	3	25.6	49	23	22.5	56	5	23.0	57
04-11-2021 08:54	0	25.6	49	23	22.5	56	6	23.0	57
04-11-2021 08:55	0	25.6	49	23	22.5	56	7	23.0	57
04-11-2021 08:56	0	25.6	49	23	22.5	56	7	23.0	57



## Environmental Monitoring System

### DATA REPORT

#### FILTRATION, VIAL FILLING, VIAL CAPPING (L4)

Date Time	FILTRATION ROOM (L4) wrt STERILE PASSAGE (L4)	FILTRATION ROOM (L4)	FILTRATION ROOM (L4)	VIAL LIQUID FILLING wrt STERILE PASSAGE (L4)	VIAL LIQUID FILL & STOP (L4)	VIAL LIQUID FILL & STOP (L4)	VIAL CAPPING ROOM (L4) wrt STERILE PASSAGE (L4)	VIAL CAPPING ROOM (L4)	VIAL CAPPING ROOM (L4)
Date Time	DP Pa	°C TEMP	% RH	DP Pa	°C TEMP	% RH	DP Pa	°C TEMP	% RH
04-11-2021 08:57	5	25.6	49	22	22.4	56	7	23.0	57
04-11-2021 08:58	0	25.6	49	25	22.4	56	7	23.0	57
04-11-2021 08:59	0	25.6	49	23	22.4	56	5	23.0	57
04-11-2021 09:00	3	25.6	49	23	22.4	56	6	22.9	57
04-11-2021 09:01	0	25.6	49	23	22.4	56	6	22.9	57
04-11-2021 09:02	0	25.5	49	23	22.3	56	7	22.9	57
04-11-2021 09:03	0	25.5	50	24	22.3	56	6	22.9	57
04-11-2021 09:04	4	25.5	50	24	22.3	56	5	22.9	58
04-11-2021 09:05	0	25.5	50	23	22.3	56	6	22.8	58
04-11-2021 09:06	0	25.5	50	23	22.3	56	5	22.8	58
04-11-2021 09:07	0	25.5	50	24	22.3	56	6	22.8	58
04-11-2021 09:08	3	25.5	50	23	22.3	57	7	22.8	58
04-11-2021 09:09	0	25.5	50	23	22.3	57	7	22.8	58
04-11-2021 09:10	0	25.5	50	23	22.3	56	6	22.8	58
04-11-2021 09:11	0	25.5	50	23	22.3	57	6	22.8	58
04-11-2021 09:12	0	25.5	50	24	22.4	57	6	22.8	58
04-11-2021 09:13	5	25.5	50	23	22.3	57	7	22.8	58
04-11-2021 09:14	0	25.5	50	24	22.3	56	6	22.8	58
04-11-2021 09:15	0	25.5	50	23	22.4	56	6	22.8	58
04-11-2021 09:16	0	25.5	50	23	22.4	56	6	22.8	58
04-11-2021 09:17	0	25.5	50	24	22.4	56	7	22.8	58
04-11-2021 09:18	0	25.5	50	23	22.4	56	7	22.8	58
04-11-2021 09:19	3	25.5	50	23	22.4	56	6	22.8	58
04-11-2021 09:20	0	25.5	50	23	22.4	56	7	22.9	58
04-11-2021 09:21	0	25.5	50	25	22.4	56	6	22.9	58
04-11-2021 09:22	0	25.5	50	23	22.4	56	5	22.9	58
04-11-2021 09:23	3	25.5	50	23	22.4	56	6	22.9	58



## Environmental Monitoring System

### DATA REPORT

#### FILTRATION, VIAL FILLING, VIAL CAPPING (L4)

Date Time	FILTRATION ROOM (L4) wrt STERILE PASSAGE (L4)	FILTRATION ROOM (L4)	FILTRATION ROOM (L4)	VIAL LIQUID FILLING wrt STERILE PASSAGE (L4)	VIAL LIQUID FILL & STOP (L4)	VIAL LIQUID FILL & STOP (L4)	VIAL CAPPING ROOM (L4) wrt STERILE PASSAGE (L4)	VIAL CAPPING ROOM (L4)	VIAL CAPPING ROOM (L4)
Date Time	DP Pa	°C TEMP	% RH	DP Pa	°C TEMP	% RH	DP Pa	°C TEMP	% RH
04-11-2021 09:24	0	25.5	50	24	22.4	56	6	22.9	58
04-11-2021 09:25	3	25.5	50	22	22.4	56	7	22.9	58
04-11-2021 09:26	0	25.5	50	23	22.4	56	7	22.9	58
04-11-2021 09:27	0	25.6	50	23	22.4	56	6	22.9	58
04-11-2021 09:28	0	25.5	50	24	22.4	56	5	22.9	58
04-11-2021 09:29	3	25.5	50	23	22.4	57	7	22.9	58
04-11-2021 09:30	0	25.5	50	23	22.4	57	6	22.8	58
04-11-2021 09:31	3	25.5	50	25	22.4	57	7	22.9	58
04-11-2021 09:32	0	25.5	50	25	22.4	57	7	22.8	58
04-11-2021 09:33	0	25.5	50	22	22.4	57	6	22.8	58
04-11-2021 09:34	0	25.5	50	23	22.4	57	5	22.9	58
04-11-2021 09:35	0	25.5	50	23	22.4	57	6	22.8	58
04-11-2021 09:36	0	25.4	50	23	22.4	57	5	22.9	58
04-11-2021 09:37	0	25.5	50	23	22.4	57	7	22.9	58
04-11-2021 09:38	4	25.5	50	23	22.4	57	7	22.9	58
04-11-2021 09:39	4	25.5	50	22	22.4	57	6	22.9	58
04-11-2021 09:40	0	25.5	50	23	22.4	57	7	22.9	58
04-11-2021 09:41	0	25.5	50	21	22.4	57	4	22.9	58
04-11-2021 09:42	3	25.5	50	19	22.4	57	0	22.9	58
04-11-2021 09:43	4	25.5	50	24	22.4	57	7	22.9	58
04-11-2021 09:44	3	25.5	50	23	22.4	56	6	22.9	58
04-11-2021 09:45	0	25.5	50	23	22.4	56	6	22.9	58
04-11-2021 09:46	3	25.5	50	23	22.5	56	7	22.9	58
04-11-2021 09:47	0	25.5	50	23	22.5	56	6	23.0	58
04-11-2021 09:48	3	25.5	50	23	22.5	56	6	23.0	58
04-11-2021 09:49	5	25.5	50	13	22.5	56	0	23.0	58
04-11-2021 09:50	0	25.6	50	23	22.5	56	5	23.0	58



## Environmental Monitoring System

### DATA REPORT

#### FILTRATION, VIAL FILLING, VIAL CAPPING (L4)

Date Time	FILTRATION ROOM (L4) wrt STERILE PASSAGE (L4)	FILTRATION ROOM (L4)	FILTRATION ROOM (L4)	VIAL LIQUID FILLING wrt STERILE PASSAGE (L4)	VIAL LIQUID FILL & STOP (L4)	VIAL LIQUID FILL & STOP (L4)	VIAL CAPPING ROOM (L4) wrt STERILE PASSAGE (L4)	VIAL CAPPING ROOM (L4)	VIAL CAPPING ROOM (L4)
Date Time	DP Pa	°C TEMP	% RH	DP Pa	°C TEMP	% RH	DP Pa	°C TEMP	% RH
04-11-2021 09:51	0	25.6	50	23	22.5	56	7	23.0	58
04-11-2021 09:52	0	25.6	50	23	22.5	56	6	23.0	58
04-11-2021 09:53	0	25.6	50	23	22.5	56	7	23.0	58
04-11-2021 09:54	0	25.6	50	24	22.5	56	6	23.0	58
04-11-2021 09:55	4	25.6	50	23	22.5	56	6	23.0	58
04-11-2021 09:56	0	25.6	50	23	22.6	56	7	23.1	58
04-11-2021 09:57	3	25.6	50	23	22.6	56	6	23.1	58
04-11-2021 09:58	6	25.6	50	16	22.6	56	0	23.1	58
04-11-2021 09:59	0	25.6	50	23	22.6	56	6	23.1	58
04-11-2021 10:00	3	25.6	50	23	22.6	56	7	23.1	58
04-11-2021 10:01	4	25.6	50	24	22.6	56	6	23.1	57
04-11-2021 10:02	4	25.7	50	24	22.6	56	6	23.1	57
04-11-2021 10:03	0	25.6	50	24	22.6	56	5	23.1	57
04-11-2021 10:04	0	25.7	50	24	22.6	56	6	23.1	57
04-11-2021 10:05	3	25.7	50	23	22.6	56	6	23.1	57
04-11-2021 10:06	0	25.7	50	23	22.6	56	7	23.1	57
04-11-2021 10:07	0	25.6	50	23	22.6	56	7	23.2	57
04-11-2021 10:08	0	25.6	50	23	22.6	56	7	23.1	57
04-11-2021 10:09	3	25.6	50	23	22.6	56	6	23.1	57
04-11-2021 10:10	0	25.6	50	23	22.6	56	6	23.1	57
04-11-2021 10:11	0	25.6	50	23	22.5	56	5	23.1	57
04-11-2021 10:12	4	25.6	50	23	22.5	56	6	23.1	57
04-11-2021 10:13	0	25.6	50	24	22.5	57	6	23.1	57
04-11-2021 10:14	0	25.6	50	23	22.4	57	6	23.1	57
04-11-2021 10:15	0	25.6	50	25	22.4	57	6	23.0	57
04-11-2021 10:16	0	25.6	50	23	22.3	57	7	23.0	57
04-11-2021 10:17	3	25.6	50	24	22.3	57	7	23.0	57



## Environmental Monitoring System

### DATA REPORT

#### FILTRATION, VIAL FILLING, VIAL CAPPING (L4)

Date Time	FILTRATION ROOM (L4) wrt STERILE PASSAGE (L4)	FILTRATION ROOM (L4)	FILTRATION ROOM (L4)	VIAL LIQUID FILLING wrt STERILE PASSAGE (L4)	VIAL LIQUID FILL & STOP (L4)	VIAL LIQUID FILL & STOP (L4)	VIAL CAPPING ROOM (L4) wrt STERILE PASSAGE (L4)	VIAL CAPPING ROOM (L4)	VIAL CAPPING ROOM (L4)
Date Time	DP Pa	°C TEMP	% RH	DP Pa	°C TEMP	% RH	DP Pa	°C TEMP	% RH
04-11-2021 10:18	0	25.6	50	24	22.3	57	6	23.0	57
04-11-2021 10:19	3	25.6	50	24	22.2	57	6	23.0	57
04-11-2021 10:20	0	25.6	50	20	22.2	57	0	23.0	57
04-11-2021 10:21	3	25.5	50	23	22.2	57	6	22.9	57
04-11-2021 10:22	0	25.6	50	23	22.2	57	5	22.9	58
04-11-2021 10:23	0	25.6	50	23	22.2	57	6	22.9	58
04-11-2021 10:24	0	25.6	50	21	22.2	57	6	22.9	58
04-11-2021 10:25	3	25.5	50	24	22.3	57	6	22.9	58
04-11-2021 10:26	0	25.5	50	23	22.2	57	7	22.9	58
04-11-2021 10:27	0	25.5	50	23	22.2	57	7	22.8	58
04-11-2021 10:28	3	25.5	50	24	22.2	57	6	22.8	58
04-11-2021 10:29	0	25.5	50	23	22.2	57	6	22.8	58
04-11-2021 10:30	0	25.5	50	23	22.2	57	7	22.8	58
04-11-2021 10:31	0	25.5	50	24	22.3	57	7	22.8	58
04-11-2021 10:32	3	25.5	50	23	22.3	57	6	22.8	58
04-11-2021 10:33	4	25.5	50	23	22.2	57	7	22.8	58
04-11-2021 10:34	0	25.5	50	23	22.2	57	7	22.8	58
04-11-2021 10:35	3	25.5	50	23	22.2	57	6	22.8	58
04-11-2021 10:36	3	25.5	50	22	22.3	57	5	22.8	58
04-11-2021 10:37	0	25.5	50	23	22.3	57	6	22.8	58
04-11-2021 10:38	0	25.5	50	24	22.3	57	7	22.8	58
04-11-2021 10:39	0	25.5	50	25	22.3	57	7	22.8	58
04-11-2021 10:40	0	25.5	50	23	22.3	57	7	22.8	58
04-11-2021 10:41	0	25.5	50	23	22.3	57	7	22.9	58
04-11-2021 10:42	0	25.5	50	23	22.3	57	6	22.9	58
04-11-2021 10:43	0	25.5	50	24	22.4	57	6	22.9	58
04-11-2021 10:44	0	25.5	50	23	22.4	57	6	22.9	58





## Environmental Monitoring System

### DATA REPORT

#### FILTRATION, VIAL FILLING, VIAL CAPPING (L4)

Date Time	FILTRATION ROOM (L4) wrt STERILE PASSAGE (L4)	FILTRATION ROOM (L4)	FILTRATION ROOM (L4)	VIAL LIQUID FILLING wrt STERILE PASSAGE (L4)	VIAL LIQUID FILL & STOP (L4)	VIAL LIQUID FILL & STOP (L4)	VIAL CAPPING ROOM (L4) wrt STERILE PASSAGE (L4)	VIAL CAPPING ROOM (L4)	VIAL CAPPING ROOM (L4)
Date Time	DP Pa	°C TEMP	% RH	DP Pa	°C TEMP	% RH	DP Pa	°C TEMP	% RH
04-11-2021 10:45	3	25.5	50	23	22.4	57	6	22.9	58
04-11-2021 10:46	0	25.5	50	23	22.4	57	6	22.9	58
04-11-2021 10:47	0	25.6	50	24	22.4	57	7	22.9	58
04-11-2021 10:48	0	25.6	50	23	22.4	57	7	22.9	58
04-11-2021 10:49	0	25.6	50	23	22.4	57	6	22.9	58
04-11-2021 10:50	0	25.6	50	23	22.4	57	6	22.9	58
04-11-2021 10:51	3	25.5	50	24	22.4	57	6	22.9	58
04-11-2021 10:52	0	25.6	50	23	22.4	57	6	22.9	58
04-11-2021 10:53	4	25.5	50	25	22.4	57	7	22.9	58
04-11-2021 10:54	0	25.5	50	25	22.4	57	7	22.9	58
04-11-2021 10:55	0	25.5	50	22	22.4	57	7	22.9	58
04-11-2021 10:56	0	25.6	50	24	22.4	57	7	22.9	58
04-11-2021 10:57	0	25.6	50	22	22.4	57	6	22.9	58
04-11-2021 10:58	4	25.5	50	22	22.4	57	6	22.9	58
04-11-2021 10:59	0	25.5	50	24	22.4	57	6	22.9	58
04-11-2021 11:00	0	25.5	50	23	22.4	57	7	22.9	58
04-11-2021 11:01	0	25.6	50	25	22.4	57	6	22.9	58
04-11-2021 11:02	0	25.6	50	23	22.4	57	7	22.9	58
04-11-2021 11:03	0	25.6	50	24	22.4	57	7	22.9	58
04-11-2021 11:04	0	25.6	50	23	22.4	57	7	22.8	58
04-11-2021 11:05	0	25.6	50	25	22.4	57	6	22.9	58
04-11-2021 11:06	0	25.5	50	25	22.4	57	7	22.8	58
04-11-2021 11:07	0	25.5	50	23	22.4	57	7	22.9	58
04-11-2021 11:08	0	25.5	50	24	22.4	57	6	22.8	58
04-11-2021 11:09	0	25.5	50	25	22.4	57	5	22.9	58
04-11-2021 11:10	0	25.6	50	23	22.4	57	6	22.9	58
04-11-2021 11:11	0	25.5	50	24	22.4	57	6	22.9	58



## Environmental Monitoring System

### DATA REPORT

#### FILTRATION, VIAL FILLING, VIAL CAPPING (L4)

Date Time	FILTRATION ROOM (L4) wrt STERILE PASSAGE (L4)	FILTRATION ROOM (L4)	FILTRATION ROOM (L4)	VIAL LIQUID FILLING wrt STERILE PASSAGE (L4)	VIAL LIQUID FILL & STOP (L4)	VIAL LIQUID FILL & STOP (L4)	VIAL CAPPING ROOM (L4) wrt STERILE PASSAGE (L4)	VIAL CAPPING ROOM (L4)	VIAL CAPPING ROOM (L4)
Date Time	DP Pa	°C TEMP	% RH	DP Pa	°C TEMP	% RH	DP Pa	°C TEMP	% RH
04-11-2021 11:12	0	25.5	50	21	22.4	57	0	22.9	58
04-11-2021 11:13	0	25.5	50	24	22.4	57	4	22.9	58
04-11-2021 11:14	3	25.6	50	23	22.4	57	3	22.9	58
04-11-2021 11:15	0	25.6	50	23	22.4	57	4	22.9	58
04-11-2021 11:16	0	25.6	50	22	22.4	57	5	22.9	58
04-11-2021 11:17	0	25.5	50	20	22.4	57	5	22.9	58
04-11-2021 11:18	0	25.5	50	24	22.4	57	5	22.9	58
04-11-2021 11:19	0	25.6	50	23	22.5	57	5	22.9	58
04-11-2021 11:20	0	25.6	50	24	22.4	57	5	22.9	58
04-11-2021 11:21	4	25.6	50	23	22.5	57	6	22.9	58
04-11-2021 11:22	0	25.6	50	22	22.5	57	4	22.9	58
04-11-2021 11:23	0	25.6	50	23	22.5	57	4	22.9	58
04-11-2021 11:24	0	25.6	50	24	22.5	57	5	23.0	58
04-11-2021 11:25	0	25.6	50	23	22.5	57	5	23.0	58
04-11-2021 11:26	0	25.6	50	23	22.5	56	5	23.0	58
04-11-2021 11:27	4	25.6	50	24	22.6	56	5	23.0	58
04-11-2021 11:28	0	25.6	50	22	22.5	56	5	23.0	58
04-11-2021 11:29	0	25.6	50	23	22.5	56	5	23.0	58
04-11-2021 11:30	3	25.6	50	22	22.5	56	5	23.0	58
04-11-2021 11:31	0	25.6	50	24	22.5	56	5	23.0	58
04-11-2021 11:32	0	25.5	50	23	22.5	56	5	23.0	58
04-11-2021 11:33	0	25.6	50	23	22.5	57	5	23.0	58
04-11-2021 11:34	0	25.6	50	23	22.5	57	5	23.0	58
04-11-2021 11:35	0	25.6	50	21	22.5	57	4	22.9	58
04-11-2021 11:36	4	25.6	50	23	22.4	57	6	22.9	58
04-11-2021 11:37	0	25.6	50	23	22.4	57	5	22.9	58
04-11-2021 11:38	4	25.6	50	22	22.4	57	5	22.9	58



## Environmental Monitoring System

### DATA REPORT

#### FILTRATION, VIAL FILLING, VIAL CAPPING (L4)

Date Time	FILTRATION ROOM (L4) wrt STERILE PASSAGE (L4)	FILTRATION ROOM (L4)	FILTRATION ROOM (L4)	VIAL LIQUID FILLING wrt STERILE PASSAGE (L4)	VIAL LIQUID FILL & STOP (L4)	VIAL LIQUID FILL & STOP (L4)	VIAL CAPPING ROOM (L4) wrt STERILE PASSAGE (L4)	VIAL CAPPING ROOM (L4)	VIAL CAPPING ROOM (L4)
Date Time	DP Pa	°C TEMP	% RH	DP Pa	°C TEMP	% RH	DP Pa	°C TEMP	% RH
04-11-2021 11:39	4	25.6	50	23	22.3	57	5	22.9	58
04-11-2021 11:40	0	25.6	50	23	22.2	57	5	22.8	58
04-11-2021 11:41	0	25.6	50	24	22.2	57	5	22.8	58
04-11-2021 11:42	5	25.5	50	18	22.2	57	3	22.8	58
04-11-2021 11:43	3	25.5	50	23	22.2	58	6	22.8	59
04-11-2021 11:44	0	25.5	50	24	22.2	58	5	22.8	58
04-11-2021 11:45	0	25.5	50	23	22.1	58	7	22.7	58
04-11-2021 11:46	3	25.5	50	23	22.1	58	6	22.7	59
04-11-2021 11:47	0	25.5	50	23	22.1	58	5	22.7	59
04-11-2021 11:48	0	25.5	50	23	22.1	58	5	22.7	59
04-11-2021 11:49	0	25.3	50	23	22.1	58	5	22.7	59
04-11-2021 11:50	3	25.3	50	26	22.1	58	7	22.6	59
04-11-2021 11:51	4	25.3	50	23	22.0	58	5	22.6	59
04-11-2021 11:52	0	25.3	50	25	22.0	58	5	22.6	59
04-11-2021 11:53	0	25.3	50	23	22.0	58	7	22.6	59
04-11-2021 11:54	4	25.3	50	23	21.9	58	5	22.5	59
04-11-2021 11:55	0	25.3	50	23	22.0	58	6	22.5	59
04-11-2021 11:56	5	25.3	51	22	22.0	58	5	22.5	59
04-11-2021 11:57	0	25.3	51	22	22.0	58	5	22.5	59
04-11-2021 11:58	0	25.3	51	23	22.1	58	5	22.5	59
04-11-2021 11:59	0	25.3	51	23	22.1	58	5	22.5	59
04-11-2021 12:00	0	25.3	51	23	22.1	58	5	22.5	59
04-11-2021 12:01	3	25.3	51	22	22.1	58	5	22.6	59
04-11-2021 12:02	0	25.3	51	22	22.1	58	6	22.6	59
04-11-2021 12:03	3	25.3	51	23	22.1	58	5	22.6	59
04-11-2021 12:04	0	25.3	51	23	22.2	58	5	22.6	59
04-11-2021 12:05	0	25.3	51	24	22.2	58	5	22.6	59



# Environmental Monitoring System

## DATA REPORT

### FILTRATION, VIAL FILLING, VIAL CAPPING (L4)

Date Time	FILTRATION ROOM (L4) wrt STERILE PASSAGE (L4)	FILTRATION ROOM (L4)	FILTRATION ROOM (L4)	VIAL LIQUID FILLING wrt STERILE PASSAGE (L4)	VIAL LIQUID FILL & STOP (L4)	VIAL LIQUID FILL & STOP (L4)	VIAL CAPPING ROOM (L4) wrt STERILE PASSAGE (L4)	VIAL CAPPING ROOM (L4)	VIAL CAPPING ROOM (L4)
Date Time	DP Pa	°C TEMP	% RH	DP Pa	°C TEMP	% RH	DP Pa	°C TEMP	% RH
04-11-2021 12:06	4	25.3	51	24	22.2	58	5	22.7	59
04-11-2021 12:07	0	25.3	51	22	22.2	58	5	22.7	59
04-11-2021 12:08	4	25.3	51	21	22.3	57	5	22.7	59
04-11-2021 12:09	4	25.3	51	24	22.3	57	7	22.7	59
04-11-2021 12:10	0	25.3	51	23	22.3	57	5	22.8	59
04-11-2021 12:11	4	25.4	51	23	22.4	57	6	22.8	59
04-11-2021 12:12	3	25.5	50	23	22.4	57	5	22.9	59
04-11-2021 12:13	3	25.5	50	23	22.5	57	6	22.9	58
04-11-2021 12:14	4	25.5	50	23	22.5	57	6	22.9	58
04-11-2021 12:15	0	25.5	50	23	22.5	57	6	22.9	58
04-11-2021 12:16	0	25.6	50	23	22.6	57	5	23.0	58
04-11-2021 12:17	0	25.6	50	23	22.6	57	5	23.0	58
04-11-2021 12:18	4	25.6	50	23	22.6	57	6	23.0	58
04-11-2021 12:19	3	25.7	50	25	22.6	56	5	23.0	58
04-11-2021 12:20	0	25.6	50	22	22.6	56	6	23.1	58
04-11-2021 12:21	4	25.7	50	22	22.6	56	5	23.1	58
04-11-2021 12:22	3	25.6	50	23	22.7	56	5	23.1	58
04-11-2021 12:23	0	25.6	50	25	22.7	56	5	23.1	58
04-11-2021 12:24	0	25.6	50	23	22.7	56	6	23.1	58
04-11-2021 12:25	4	25.6	50	24	22.7	56	5	23.1	58
04-11-2021 12:26	0	25.6	50	22	22.7	56	6	23.1	58
04-11-2021 12:27	4	25.6	50	25	22.6	56	5	23.1	58
04-11-2021 12:28	4	25.6	50	24	22.6	56	6	23.0	58
04-11-2021 12:29	0	25.6	50	23	22.6	56	6	23.1	58
04-11-2021 12:30	3	25.6	50	23	22.6	56	6	23.1	58
04-11-2021 12:31	0	25.6	50	23	22.5	56	5	23.0	58
04-11-2021 12:32	3	25.6	50	23	22.5	57	5	23.0	58



# Environmental Monitoring System

## DATA REPORT

### FILTRATION, VIAL FILLING, VIAL CAPPING (L4)

Date Time	FILTRATION ROOM (L4) wrt STERILE PASSAGE (L4)	FILTRATION ROOM (L4)	FILTRATION ROOM (L4)	VIAL LIQUID FILLING wrt STERILE PASSAGE (L4)	VIAL LIQUID FILL & STOP (L4)	VIAL LIQUID FILL & STOP (L4)	VIAL CAPPING ROOM (L4) wrt STERILE PASSAGE (L4)	VIAL CAPPING ROOM (L4)	VIAL CAPPING ROOM (L4)
Date Time	DP Pa	°C TEMP	% RH	DP Pa	°C TEMP	% RH	DP Pa	°C TEMP	% RH
04-11-2021 12:33	0	25.6	50	24	22.5	57	6	23.0	58
04-11-2021 12:34	0	25.6	50	23	22.4	57	6	23.0	58
04-11-2021 12:35	0	25.5	50	25	22.4	57	5	23.0	58
04-11-2021 12:36	3	25.6	50	24	22.4	57	6	22.9	58
04-11-2021 12:37	3	25.6	50	24	22.4	57	5	22.9	58
04-11-2021 12:38	3	25.6	50	23	22.3	57	5	22.9	58
04-11-2021 12:39	0	25.6	50	23	22.3	57	6	22.9	58
04-11-2021 12:40	4	25.6	50	23	22.3	57	5	22.9	58
04-11-2021 12:41	0	25.6	50	22	22.3	57	5	22.8	58
04-11-2021 12:42	0	25.5	50	25	22.2	57	6	22.8	58
04-11-2021 12:43	3	25.5	50	23	22.2	57	7	22.8	58
04-11-2021 12:44	0	25.5	50	24	22.2	57	6	22.8	58
04-11-2021 12:45	4	25.5	50	22	22.1	57	5	22.7	58
04-11-2021 12:46	0	25.5	50	24	22.1	57	5	22.7	58
04-11-2021 12:47	0	25.5	50	23	22.1	57	5	22.7	58
04-11-2021 12:48	3	25.3	50	22	22.1	58	5	22.7	59
04-11-2021 12:49	3	25.3	50	22	22.1	58	5	22.6	59
04-11-2021 12:50	0	25.3	50	25	22.1	58	7	22.6	59
04-11-2021 12:51	0	25.3	50	24	22.1	57	7	22.6	59
04-11-2021 12:52	0	25.3	50	24	22.0	57	7	22.6	59
04-11-2021 12:53	0	25.3	50	23	22.0	58	7	22.6	59
04-11-2021 12:54	0	25.3	50	24	21.9	58	7	22.6	59
04-11-2021 12:55	4	25.3	51	24	22.0	58	6	22.6	59
04-11-2021 12:56	3	25.3	51	24	22.0	58	7	22.6	59
04-11-2021 12:57	0	25.3	51	23	21.9	58	7	22.6	59
04-11-2021 12:58	4	25.3	51	24	22.0	58	7	22.6	59
04-11-2021 12:59	0	25.3	51	23	22.1	58	7	22.6	59



## Environmental Monitoring System

### DATA REPORT

#### FILTRATION, VIAL FILLING, VIAL CAPPING (L4)

Date Time	FILTRATION ROOM (L4) wrt STERILE PASSAGE (L4)	FILTRATION ROOM (L4)	FILTRATION ROOM (L4)	VIAL LIQUID FILLING wrt STERILE PASSAGE (L4)	VIAL LIQUID FILL & STOP (L4)	VIAL LIQUID FILL & STOP (L4)	VIAL CAPPING ROOM (L4) wrt STERILE PASSAGE (L4)	VIAL CAPPING ROOM (L4)	VIAL CAPPING ROOM (L4)
Date Time	DP Pa	°C TEMP	% RH	DP Pa	°C TEMP	% RH	DP Pa	°C TEMP	% RH
04-11-2021 13:00	0	25.3	50	23	22.1	57	6	22.6	59
04-11-2021 13:01	0	25.3	50	22	22.1	57	7	22.6	59
04-11-2021 13:02	0	25.3	50	24	22.1	57	7	22.6	59
04-11-2021 13:03	0	25.3	50	22	22.1	57	6	22.6	59
04-11-2021 13:04	0	25.3	50	23	22.1	57	8	22.6	59
04-11-2021 13:05	4	25.3	50	24	22.2	57	7	22.7	58
04-11-2021 13:06	4	25.3	50	23	22.2	57	5	22.7	58
04-11-2021 13:07	0	25.3	50	24	22.2	57	7	22.7	58
04-11-2021 13:08	0	25.3	50	23	22.3	57	6	22.7	58
04-11-2021 13:09	0	25.3	50	23	22.3	57	6	22.7	58
04-11-2021 13:10	0	25.3	50	24	22.3	57	6	22.8	58
04-11-2021 13:11	4	25.3	50	24	22.4	57	6	22.8	58
04-11-2021 13:12	0	25.4	50	25	22.4	57	7	22.8	58
04-11-2021 13:13	4	25.5	50	23	22.5	57	7	22.9	58
04-11-2021 13:14	0	25.5	50	23	22.5	57	7	22.9	58
04-11-2021 13:15	4	25.5	50	23	22.5	57	7	22.9	58
04-11-2021 13:16	4	25.5	50	23	22.5	56	7	22.9	58
04-11-2021 13:17	4	25.6	50	23	22.6	56	7	22.9	58
04-11-2021 13:18	4	25.6	50	25	22.6	56	7	23.0	58
04-11-2021 13:19	0	25.6	50	23	22.6	56	6	23.0	58
04-11-2021 13:20	3	25.6	50	21	22.6	56	7	23.0	58
04-11-2021 13:21	4	25.6	50	23	22.6	56	5	23.0	58
04-11-2021 13:22	0	25.6	50	21	22.6	56	6	23.0	58
04-11-2021 13:23	0	25.6	50	23	22.6	56	6	23.0	58
04-11-2021 13:24	3	25.6	49	23	22.6	56	7	23.1	57
04-11-2021 13:25	4	25.6	49	25	22.6	56	7	23.1	57
04-11-2021 13:26	4	25.6	50	23	22.6	56	6	23.1	57



## Environmental Monitoring System

### DATA REPORT

#### FILTRATION, VIAL FILLING, VIAL CAPPING (L4)

Date Time	FILTRATION ROOM (L4) wrt STERILE PASSAGE (L4)	FILTRATION ROOM (L4)	FILTRATION ROOM (L4)	VIAL LIQUID FILLING wrt STERILE PASSAGE (L4)	VIAL LIQUID FILL & STOP (L4)	VIAL LIQUID FILL & STOP (L4)	VIAL CAPPING ROOM (L4) wrt STERILE PASSAGE (L4)	VIAL CAPPING ROOM (L4)	VIAL CAPPING ROOM (L4)
Date Time	DP Pa	°C TEMP	% RH	DP Pa	°C TEMP	% RH	DP Pa	°C TEMP	% RH
04-11-2021 13:27	0	25.6	50	25	22.6	56	7	23.1	57
04-11-2021 13:28	4	25.6	50	25	22.5	56	7	23.1	57
04-11-2021 13:29	0	25.6	50	23	22.5	56	7	23.1	57
04-11-2021 13:30	0	25.6	50	24	22.5	57	7	23.1	57
04-11-2021 13:31	4	25.6	50	23	22.5	57	6	23.1	58
04-11-2021 13:32	0	25.6	50	23	22.5	57	6	23.0	58
04-11-2021 13:33	0	25.7	50	23	22.5	57	7	23.0	58
04-11-2021 13:34	3	25.7	50	21	22.4	57	7	23.0	58
04-11-2021 13:35	4	25.6	50	24	22.4	57	7	23.0	58
04-11-2021 13:36	0	25.6	50	23	22.4	57	7	23.0	58
04-11-2021 13:37	0	25.6	50	23	22.4	57	6	23.0	58
04-11-2021 13:38	0	25.6	50	23	22.3	57	7	22.9	58
04-11-2021 13:39	4	25.6	50	23	22.3	57	6	22.9	58
04-11-2021 13:40	0	25.6	50	22	22.2	57	6	22.9	58
04-11-2021 13:41	0	25.5	50	24	22.2	57	7	22.9	58
04-11-2021 13:42	0	25.5	50	23	22.1	58	6	22.8	58
04-11-2021 13:43	0	25.5	50	23	22.1	58	6	22.8	58
04-11-2021 13:44	0	25.4	50	23	22.0	58	7	22.7	58
04-11-2021 13:45	5	25.3	50	25	21.9	57	6	22.7	58
04-11-2021 13:46	3	25.3	50	24	21.9	57	7	22.7	58
04-11-2021 13:47	0	25.3	50	24	21.9	58	6	22.6	58
04-11-2021 13:48	4	25.3	50	24	21.8	58	7	22.6	59
04-11-2021 13:49	0	25.3	51	23	21.8	58	8	22.6	59
04-11-2021 13:50	0	25.3	51	23	21.8	58	7	22.6	59
04-11-2021 13:51	0	25.2	51	23	21.8	58	7	22.5	59
04-11-2021 13:52	0	25.2	51	24	21.8	58	7	22.5	59
04-11-2021 13:53	0	25.2	51	23	21.7	58	7	22.5	59



## Environmental Monitoring System

### DATA REPORT

#### FILTRATION, VIAL FILLING, VIAL CAPPING (L4)

Date Time	FILTRATION ROOM (L4) wrt STERILE PASSAGE (L4)	FILTRATION ROOM (L4)	FILTRATION ROOM (L4)	VIAL LIQUID FILLING wrt STERILE PASSAGE (L4)	VIAL LIQUID FILL & STOP (L4)	VIAL LIQUID FILL & STOP (L4)	VIAL CAPPING ROOM (L4) wrt STERILE PASSAGE (L4)	VIAL CAPPING ROOM (L4)	VIAL CAPPING ROOM (L4)
Date Time	DP Pa	°C TEMP	% RH	DP Pa	°C TEMP	% RH	DP Pa	°C TEMP	% RH
04-11-2021 13:54	0	25.2	51	23	21.8	59	7	22.4	59
04-11-2021 13:55	5	25.1	51	25	21.8	58	7	22.4	59
04-11-2021 13:56	0	25.1	51	23	21.7	58	7	22.4	59
04-11-2021 13:57	4	25.1	51	23	21.7	58	7	22.4	59
04-11-2021 13:58	4	25.1	51	23	21.7	58	8	22.4	59
04-11-2021 13:59	3	25.1	51	24	21.8	58	6	22.4	59
04-11-2021 14:00	4	25.1	51	24	21.7	58	6	22.4	59
04-11-2021 14:01	3	25.1	51	23	21.8	58	7	22.4	59
04-11-2021 14:02	0	25.1	51	24	21.8	58	7	22.4	59
04-11-2021 14:03	3	25.1	51	24	21.8	58	6	22.4	59
04-11-2021 14:04	4	25.1	51	22	21.9	58	7	22.4	59
04-11-2021 14:05	4	25.1	51	23	21.9	58	6	22.4	59
04-11-2021 14:06	0	25.1	51	23	21.9	58	7	22.4	59
04-11-2021 14:07	0	25.2	51	22	22.0	58	6	22.5	59
04-11-2021 14:08	0	25.2	51	23	21.9	58	6	22.5	59
04-11-2021 14:09	4	25.2	51	25	22.1	58	5	22.5	59
04-11-2021 14:10	3	25.2	51	21	22.1	57	5	22.6	59
04-11-2021 14:11	3	25.3	51	23	22.2	57	6	22.6	59
04-11-2021 14:12	3	25.2	51	23	22.2	57	7	22.6	59
04-11-2021 14:13	4	25.3	51	23	22.2	57	7	22.7	59
04-11-2021 14:14	4	25.3	51	23	22.3	57	5	22.7	59
04-11-2021 14:15	0	25.3	51	23	22.4	57	6	22.7	59
04-11-2021 14:16	3	25.5	51	22	22.4	57	6	22.8	59
04-11-2021 14:17	3	25.5	51	23	22.4	57	6	22.8	58
04-11-2021 14:18	5	25.5	51	23	22.5	57	7	22.9	58
04-11-2021 14:19	0	25.5	50	23	22.5	57	6	22.9	58
04-11-2021 14:20	3	25.6	50	25	22.6	56	8	22.9	58





# Environmental Monitoring System

## DATA REPORT

### FILTRATION, VIAL FILLING, VIAL CAPPING (L4)

Date Time	FILTRATION ROOM (L4) wrt STERILE PASSAGE (L4)	FILTRATION ROOM (L4)	FILTRATION ROOM (L4)	VIAL LIQUID FILLING wrt STERILE PASSAGE (L4)	VIAL LIQUID FILL & STOP (L4)	VIAL LIQUID FILL & STOP (L4)	VIAL CAPPING ROOM (L4) wrt STERILE PASSAGE (L4)	VIAL CAPPING ROOM (L4)	VIAL CAPPING ROOM (L4)
Date Time	DP Pa	°C TEMP	% RH	DP Pa	°C TEMP	% RH	DP Pa	°C TEMP	% RH
04-11-2021 14:21	0	25.6	50	25	22.6	56	6	23.0	58
04-11-2021 14:22	0	25.6	50	23	22.6	56	7	23.0	58
04-11-2021 14:23	4	25.6	50	25	22.6	56	6	23.0	58
04-11-2021 14:24	4	25.6	50	25	22.6	56	7	23.1	58
04-11-2021 14:25	0	25.6	50	23	22.6	56	6	23.1	57
04-11-2021 14:26	3	25.7	50	22	22.6	56	6	23.1	57
04-11-2021 14:27	3	25.7	49	25	22.6	56	6	23.1	57
04-11-2021 14:28	0	25.7	49	22	22.6	56	7	23.1	57
04-11-2021 14:29	0	25.7	49	22	22.6	56	7	23.1	57
04-11-2021 14:30	4	25.7	49	23	22.6	56	7	23.1	57
04-11-2021 14:31	4	25.7	49	23	22.6	56	7	23.1	57
04-11-2021 14:32	5	25.8	49	23	22.6	56	7	23.1	57
04-11-2021 14:33	0	25.8	49	21	22.6	56	4	23.1	57
04-11-2021 14:34	0	25.8	49	23	22.5	56	6	23.1	57
04-11-2021 14:35	0	25.8	49	23	22.5	56	6	23.1	57
04-11-2021 14:36	0	25.8	49	24	22.5	56	6	23.1	57
04-11-2021 14:37	0	25.7	49	23	22.4	56	7	23.1	57
04-11-2021 14:38	4	25.6	49	23	22.4	56	7	23.1	57
04-11-2021 14:39	4	25.6	49	23	22.3	56	6	23.0	57
04-11-2021 14:40	3	25.6	49	23	22.3	56	6	23.0	57
04-11-2021 14:41	3	25.6	49	24	22.3	57	7	23.0	57
04-11-2021 14:42	3	25.6	49	23	22.2	57	6	23.0	57
04-11-2021 14:43	4	25.5	49	25	22.2	57	7	23.0	57
04-11-2021 14:44	4	25.5	49	26	22.2	57	7	23.0	57
04-11-2021 14:45	4	25.6	49	23	22.2	57	7	22.9	57
04-11-2021 14:46	0	25.6	49	24	22.1	57	7	22.9	57
04-11-2021 14:47	0	25.6	49	24	22.1	57	5	22.9	57



## Environmental Monitoring System

### DATA REPORT

#### FILTRATION, VIAL FILLING, VIAL CAPPING (L4)

Date Time	FILTRATION ROOM (L4) wrt STERILE PASSAGE (L4)	FILTRATION ROOM (L4)	FILTRATION ROOM (L4)	VIAL LIQUID FILLING wrt STERILE PASSAGE (L4)	VIAL LIQUID FILL & STOP (L4)	VIAL LIQUID FILL & STOP (L4)	VIAL CAPPING ROOM (L4) wrt STERILE PASSAGE (L4)	VIAL CAPPING ROOM (L4)	VIAL CAPPING ROOM (L4)
Date Time	DP Pa	°C TEMP	% RH	DP Pa	°C TEMP	% RH	DP Pa	°C TEMP	% RH
04-11-2021 14:48	3	25.6	50	23	22.1	57	7	22.9	58
04-11-2021 14:49	0	25.5	50	22	22.1	57	7	22.9	58
04-11-2021 14:50	0	25.6	50	23	22.1	57	7	22.9	58
04-11-2021 14:51	0	25.5	50	23	22.1	57	6	22.8	58
04-11-2021 14:52	4	25.5	50	23	22.1	57	7	22.8	58
04-11-2021 14:53	0	25.6	50	23	22.1	57	7	22.8	58
04-11-2021 14:54	3	25.6	50	23	22.1	57	6	22.8	58
04-11-2021 14:55	3	25.6	50	24	22.1	57	7	22.8	58
04-11-2021 14:56	4	25.5	50	22	22.1	57	7	22.8	58
04-11-2021 14:57	4	25.5	50	23	22.1	57	7	22.8	58
04-11-2021 14:58	0	25.5	50	23	22.1	57	6	22.8	58
04-11-2021 14:59	4	25.5	50	24	22.1	57	7	22.8	58
04-11-2021 15:00	4	25.5	50	23	22.0	57	7	22.8	58
04-11-2021 15:01	5	25.5	50	23	22.0	57	7	22.8	58
04-11-2021 15:02	3	25.5	50	23	21.9	57	7	22.8	58
04-11-2021 15:03	3	25.5	50	23	21.9	57	6	22.8	58
04-11-2021 15:04	0	25.5	50	25	22.0	57	7	22.8	58
04-11-2021 15:05	3	25.5	50	23	21.9	58	6	22.7	58
04-11-2021 15:06	3	25.4	50	23	21.9	58	7	22.7	58
04-11-2021 15:07	3	25.4	50	24	21.9	58	7	22.7	58
04-11-2021 15:08	0	25.3	50	23	21.9	58	7	22.7	58
04-11-2021 15:09	4	25.3	50	23	21.8	58	7	22.7	58
04-11-2021 15:10	0	25.3	50	24	21.8	58	5	22.7	58
04-11-2021 15:11	4	25.3	50	24	21.8	58	7	22.7	58
04-11-2021 15:12	4	25.4	50	23	21.8	58	7	22.7	58
04-11-2021 15:13	0	25.3	50	23	21.9	58	6	22.7	58
04-11-2021 15:14	3	25.3	50	24	21.9	58	7	22.7	58



## Environmental Monitoring System

### DATA REPORT

#### FILTRATION, VIAL FILLING, VIAL CAPPING (L4)

Date Time	FILTRATION ROOM (L4) wrt STERILE PASSAGE (L4)	FILTRATION ROOM (L4)	FILTRATION ROOM (L4)	VIAL LIQUID FILLING wrt STERILE PASSAGE (L4)	VIAL LIQUID FILL & STOP (L4)	VIAL LIQUID FILL & STOP (L4)	VIAL CAPPING ROOM (L4) wrt STERILE PASSAGE (L4)	VIAL CAPPING ROOM (L4)	VIAL CAPPING ROOM (L4)
Date Time	DP Pa	°C TEMP	% RH	DP Pa	°C TEMP	% RH	DP Pa	°C TEMP	% RH
04-11-2021 15:15	4	25.3	50	23	22.0	58	7	22.7	58
04-11-2021 15:16	0	25.3	50	23	22.0	58	6	22.7	58
04-11-2021 15:17	0	25.3	50	24	22.0	58	7	22.7	58
04-11-2021 15:18	4	25.3	50	23	21.9	57	7	22.7	58
04-11-2021 15:19	4	25.3	50	23	21.9	57	7	22.8	58
04-11-2021 15:20	4	25.3	50	23	22.1	57	7	22.8	58
04-11-2021 15:21	0	25.3	50	24	22.1	57	7	22.8	58
04-11-2021 15:22	3	25.5	50	23	22.1	57	7	22.8	58
04-11-2021 15:23	3	25.4	50	23	22.2	57	6	22.8	58
04-11-2021 15:24	3	25.5	50	23	22.2	57	7	22.8	58
04-11-2021 15:25	4	25.5	50	23	22.2	57	7	22.8	58
04-11-2021 15:26	5	25.5	50	23	22.2	57	7	22.9	58
04-11-2021 15:27	3	25.5	50	23	22.3	57	7	22.9	58
04-11-2021 15:28	4	25.5	50	23	22.3	57	7	22.9	58
04-11-2021 15:29	0	25.5	50	23	22.3	57	6	22.9	58
04-11-2021 15:30	3	25.5	50	23	22.4	57	7	22.9	58
04-11-2021 15:31	3	25.6	50	24	22.4	57	5	22.9	58
04-11-2021 15:32	3	25.6	50	23	22.4	57	7	22.9	58
04-11-2021 15:33	4	25.6	50	23	22.4	57	7	23.0	58
04-11-2021 15:34	4	25.6	50	23	22.5	56	7	23.0	58
04-11-2021 15:35	3	25.6	49	22	22.5	56	7	23.0	57
04-11-2021 15:36	0	25.6	49	23	22.5	56	7	23.0	57
04-11-2021 15:37	0	25.6	49	25	22.5	56	6	23.0	57
04-11-2021 15:38	0	25.6	49	25	22.5	56	7	23.0	57
04-11-2021 15:39	0	25.6	49	23	22.5	56	7	23.1	57
04-11-2021 15:40	4	25.6	49	23	22.5	56	7	23.1	57
04-11-2021 15:41	0	25.6	49	24	22.4	56	7	23.0	57



## Environmental Monitoring System

### DATA REPORT

#### FILTRATION, VIAL FILLING, VIAL CAPPING (L4)

Date Time	FILTRATION ROOM (L4) wrt STERILE PASSAGE (L4)	FILTRATION ROOM (L4)	FILTRATION ROOM (L4)	VIAL LIQUID FILLING wrt STERILE PASSAGE (L4)	VIAL LIQUID FILL & STOP (L4)	VIAL LIQUID FILL & STOP (L4)	VIAL CAPPING ROOM (L4) wrt STERILE PASSAGE (L4)	VIAL CAPPING ROOM (L4)	VIAL CAPPING ROOM (L4)
Date Time	DP Pa	°C TEMP	% RH	DP Pa	°C TEMP	% RH	DP Pa	°C TEMP	% RH
04-11-2021 15:42	4	25.6	49	24	22.4	56	6	23.0	57
04-11-2021 15:43	3	25.6	49	24	22.4	56	6	23.0	57
04-11-2021 15:44	4	25.6	49	23	22.4	56	7	23.0	57
04-11-2021 15:45	4	25.6	49	25	22.3	56	6	23.0	57
04-11-2021 15:46	0	25.6	49	25	22.3	56	7	23.0	57
04-11-2021 15:47	3	25.6	49	24	22.3	56	7	23.0	57
04-11-2021 15:48	4	25.6	49	24	22.2	57	7	23.0	57
04-11-2021 15:49	4	25.6	49	25	22.2	57	6	22.9	57
04-11-2021 15:50	3	25.6	49	22	22.2	57	7	22.9	57
04-11-2021 15:51	3	25.6	49	24	22.2	57	5	22.9	57
04-11-2021 15:52	3	25.5	49	24	22.2	57	6	22.9	57
04-11-2021 15:53	0	25.5	49	22	22.1	57	7	22.9	57
04-11-2021 15:54	4	25.5	49	25	22.1	57	7	22.9	57
04-11-2021 15:55	4	25.5	49	24	22.1	57	8	22.9	57
04-11-2021 15:56	0	25.5	49	22	22.1	57	7	22.9	57
04-11-2021 15:57	0	25.5	50	23	22.1	57	7	22.8	57
04-11-2021 15:58	4	25.5	50	24	22.0	57	7	22.8	58
04-11-2021 15:59	0	25.5	50	24	22.0	57	7	22.8	58
04-11-2021 16:00	4	25.5	50	23	22.1	57	7	22.8	58
04-11-2021 16:01	0	25.4	50	23	22.0	57	7	22.8	58
04-11-2021 16:02	4	25.3	50	23	22.1	57	7	22.8	58
04-11-2021 16:03	3	25.3	50	23	22.1	57	7	22.8	58
04-11-2021 16:04	4	25.3	50	23	22.1	57	6	22.8	58
04-11-2021 16:05	0	25.3	50	24	22.1	57	7	22.8	58
04-11-2021 16:06	0	25.3	50	23	22.2	57	6	22.8	58
04-11-2021 16:07	0	25.3	50	23	22.2	57	7	22.9	58
04-11-2021 16:08	3	25.5	50	23	22.2	57	7	22.9	57



## Environmental Monitoring System

### DATA REPORT

#### FILTRATION, VIAL FILLING, VIAL CAPPING (L4)

Date Time	FILTRATION ROOM (L4) wrt STERILE PASSAGE (L4)	FILTRATION ROOM (L4)	FILTRATION ROOM (L4)	VIAL LIQUID FILLING wrt STERILE PASSAGE (L4)	VIAL LIQUID FILL & STOP (L4)	VIAL LIQUID FILL & STOP (L4)	VIAL CAPPING ROOM (L4) wrt STERILE PASSAGE (L4)	VIAL CAPPING ROOM (L4)	VIAL CAPPING ROOM (L4)
Date Time	DP Pa	°C TEMP	% RH	DP Pa	°C TEMP	% RH	DP Pa	°C TEMP	% RH
04-11-2021 16:09	0	25.5	50	21	22.2	57	7	22.9	57
04-11-2021 16:10	3	25.5	50	23	22.3	57	7	22.9	57
04-11-2021 16:11	0	25.5	49	23	22.3	57	7	22.9	57
04-11-2021 16:12	3	25.5	49	24	22.3	56	5	22.9	57
04-11-2021 16:13	0	25.6	49	25	22.4	56	7	22.9	57
04-11-2021 16:14	3	25.6	49	21	22.4	56	7	23.0	57
04-11-2021 16:15	5	25.6	49	25	22.4	56	7	23.0	57
04-11-2021 16:16	0	25.6	49	23	22.4	56	5	23.0	57
04-11-2021 16:17	4	25.6	50	23	22.5	56	6	23.0	57
04-11-2021 16:18	6	25.6	49	23	22.5	56	7	23.0	57
04-11-2021 16:19	3	25.6	49	23	22.5	56	7	23.1	57
04-11-2021 16:20	3	25.6	49	22	22.5	56	6	23.1	57
04-11-2021 16:21	0	25.6	49	23	22.6	56	7	23.1	57
04-11-2021 16:22	4	25.7	49	24	22.6	56	6	23.1	57
04-11-2021 16:23	4	25.7	49	26	22.6	56	7	23.1	57
04-11-2021 16:24	4	25.8	49	23	22.6	56	7	23.1	57
04-11-2021 16:25	0	25.8	49	23	22.6	56	5	23.2	57
04-11-2021 16:26	4	25.8	49	23	22.6	56	6	23.2	57
04-11-2021 16:27	3	25.8	49	23	22.6	56	7	23.2	57
04-11-2021 16:28	0	25.8	49	23	22.6	56	7	23.2	57
04-11-2021 16:29	0	25.8	49	21	22.6	56	6	23.2	57
04-11-2021 16:30	0	25.8	49	24	22.6	56	6	23.2	57
04-11-2021 16:31	0	25.8	49	23	22.6	56	7	23.2	57
04-11-2021 16:32	0	25.8	49	24	22.5	56	6	23.2	57
04-11-2021 16:33	0	25.8	49	23	22.5	56	7	23.1	57
04-11-2021 16:34	4	25.8	49	22	22.5	56	6	23.1	57
04-11-2021 16:35	0	25.8	49	23	22.4	56	7	23.1	57



## Environmental Monitoring System

### DATA REPORT

#### FILTRATION, VIAL FILLING, VIAL CAPPING (L4)

Date Time	FILTRATION ROOM (L4) wrt STERILE PASSAGE (L4)	FILTRATION ROOM (L4)	FILTRATION ROOM (L4)	VIAL LIQUID FILLING wrt STERILE PASSAGE (L4)	VIAL LIQUID FILL & STOP (L4)	VIAL LIQUID FILL & STOP (L4)	VIAL CAPPING ROOM (L4) wrt STERILE PASSAGE (L4)	VIAL CAPPING ROOM (L4)	VIAL CAPPING ROOM (L4)
Date Time	DP Pa	°C TEMP	% RH	DP Pa	°C TEMP	% RH	DP Pa	°C TEMP	% RH
04-11-2021 16:36	0	25.8	49	24	22.4	56	7	23.1	57
04-11-2021 16:37	0	25.8	49	24	22.3	57	7	23.1	57
04-11-2021 16:38	0	25.8	49	25	22.3	57	7	23.1	57
04-11-2021 16:39	4	25.7	49	23	22.3	57	7	23.0	57
04-11-2021 16:40	0	25.6	49	23	22.2	57	7	23.0	57
04-11-2021 16:41	0	25.6	49	24	22.2	57	7	23.0	57
04-11-2021 16:42	3	25.6	49	23	22.2	57	7	23.0	57
04-11-2021 16:43	3	25.6	49	23	22.2	57	7	22.9	57
04-11-2021 16:44	3	25.6	49	23	22.1	57	7	22.9	57
04-11-2021 16:45	0	25.6	49	25	22.1	57	6	22.9	57
04-11-2021 16:46	4	25.6	49	25	22.0	57	7	22.9	57
04-11-2021 16:47	0	25.6	49	23	21.9	57	7	22.9	57
04-11-2021 16:48	0	25.5	49	24	22.0	57	7	22.8	57
04-11-2021 16:49	4	25.5	49	23	22.0	57	7	22.8	58
04-11-2021 16:50	3	25.5	50	23	21.9	57	6	22.8	58
04-11-2021 16:51	3	25.5	50	23	21.9	57	6	22.8	58
04-11-2021 16:52	0	25.5	50	23	22.0	57	6	22.8	58
04-11-2021 16:53	3	25.5	50	23	21.9	57	6	22.8	58
04-11-2021 16:54	3	25.4	50	23	22.0	57	7	22.8	58
04-11-2021 16:55	4	25.4	50	24	22.0	57	7	22.8	58
04-11-2021 16:56	4	25.3	50	24	22.1	57	6	22.8	58
04-11-2021 16:57	0	25.3	50	23	22.1	57	7	22.8	58
04-11-2021 16:58	0	25.3	50	23	22.1	57	7	22.8	58
04-11-2021 16:59	3	25.4	50	23	22.2	57	7	22.8	58
04-11-2021 17:00	4	25.5	50	24	22.2	57	7	22.9	58
04-11-2021 17:01	5	25.5	50	24	22.2	57	6	22.8	58
04-11-2021 17:02	0	25.5	50	24	22.3	57	6	22.9	58



# Environmental Monitoring System

## DATA REPORT

### FILTRATION, VIAL FILLING, VIAL CAPPING (L4)

Date Time	FILTRATION ROOM (L4) wrt STERILE PASSAGE (L4)	FILTRATION ROOM (L4)	FILTRATION ROOM (L4)	VIAL LIQUID FILLING wrt STERILE PASSAGE (L4)	VIAL LIQUID FILL & STOP (L4)	VIAL LIQUID FILL & STOP (L4)	VIAL CAPPING ROOM (L4) wrt STERILE PASSAGE (L4)	VIAL CAPPING ROOM (L4)	VIAL CAPPING ROOM (L4)
Date Time	DP Pa	°C TEMP	% RH	DP Pa	°C TEMP	% RH	DP Pa	°C TEMP	% RH
04-11-2021 17:03	4	25.5	50	23	22.3	57	6	22.9	58
04-11-2021 17:04	0	25.5	50	23	22.3	56	7	22.9	57
04-11-2021 17:05	0	25.6	49	24	22.4	56	7	23.0	57
04-11-2021 17:06	0	25.6	49	26	22.4	56	6	23.0	57
04-11-2021 17:07	3	25.5	49	23	22.5	56	7	23.0	57
04-11-2021 17:08	3	25.6	49	24	22.5	56	5	23.0	57
04-11-2021 17:09	4	25.6	49	23	22.5	56	6	23.1	57
04-11-2021 17:10	3	25.6	49	25	22.5	56	7	23.1	57
04-11-2021 17:11	0	25.6	49	23	22.6	56	7	23.1	57
04-11-2021 17:12	0	25.7	49	23	22.6	56	7	23.1	57
04-11-2021 17:13	0	25.8	49	23	22.6	56	7	23.2	57
04-11-2021 17:14	3	25.8	49	23	22.6	56	7	23.2	57
04-11-2021 17:15	0	25.8	49	23	22.6	56	6	23.2	57
04-11-2021 17:16	0	25.8	49	23	22.6	56	7	23.2	57
04-11-2021 17:17	4	25.8	49	23	22.6	56	7	23.2	57
04-11-2021 17:18	5	25.8	49	24	22.6	56	6	23.2	57
04-11-2021 17:19	0	25.8	49	23	22.6	56	5	23.2	57
04-11-2021 17:20	3	25.9	49	23	22.6	56	7	23.2	57
04-11-2021 17:21	0	25.8	49	23	22.6	56	7	23.3	57
04-11-2021 17:22	3	25.9	49	23	22.6	56	7	23.2	57
04-11-2021 17:23	0	25.9	49	24	22.6	56	7	23.3	57
04-11-2021 17:24	0	25.9	49	23	22.6	56	5	23.3	57
04-11-2021 17:25	5	25.9	49	23	22.6	56	5	23.2	57
04-11-2021 17:26	3	25.8	49	23	22.5	56	6	23.2	57
04-11-2021 17:27	4	25.8	49	23	22.5	56	7	23.2	57
04-11-2021 17:28	4	25.8	49	24	22.5	56	7	23.2	57
04-11-2021 17:29	4	25.8	49	22	22.5	56	7	23.2	57



# Environmental Monitoring System

## DATA REPORT

### FILTRATION, VIAL FILLING, VIAL CAPPING (L4)

Date Time	FILTRATION ROOM (L4) wrt STERILE PASSAGE (L4)	FILTRATION ROOM (L4)	FILTRATION ROOM (L4)	VIAL LIQUID FILLING wrt STERILE PASSAGE (L4)	VIAL LIQUID FILL & STOP (L4)	VIAL LIQUID FILL & STOP (L4)	VIAL CAPPING ROOM (L4) wrt STERILE PASSAGE (L4)	VIAL CAPPING ROOM (L4)	VIAL CAPPING ROOM (L4)
Date Time	DP Pa	°C TEMP	% RH	DP Pa	°C TEMP	% RH	DP Pa	°C TEMP	% RH
04-11-2021 17:30	5	25.8	49	23	22.4	56	6	23.2	57
04-11-2021 17:31	0	25.8	49	22	22.4	56	7	23.1	57
04-11-2021 17:32	0	25.8	49	23	22.4	56	5	23.1	57
04-11-2021 17:33	0	25.7	49	23	22.4	56	7	23.1	57
04-11-2021 17:34	3	25.6	49	23	22.3	57	7	23.1	57
04-11-2021 17:35	0	25.7	49	25	22.3	57	7	23.1	57
04-11-2021 17:36	0	25.6	49	23	22.3	57	7	23.1	57
04-11-2021 17:37	3	25.6	49	22	22.3	57	6	23.1	57
04-11-2021 17:38	4	25.6	49	23	22.3	57	7	23.1	57
04-11-2021 17:39	3	25.6	49	23	22.3	57	7	23.1	57
04-11-2021 17:40	0	25.6	49	22	22.3	57	7	23.0	57
04-11-2021 17:41	3	25.6	49	22	22.3	57	6	23.0	57
04-11-2021 17:42	0	25.6	49	24	22.3	57	7	23.0	57
04-11-2021 17:43	0	25.6	49	23	22.3	57	7	23.0	57
04-11-2021 17:44	0	25.6	49	23	22.3	57	5	23.0	57
04-11-2021 17:45	0	25.6	49	23	22.2	57	7	23.0	57
04-11-2021 17:46	0	25.6	49	23	22.3	57	7	23.0	57
04-11-2021 17:47	3	25.5	49	23	22.2	57	6	23.0	57
04-11-2021 17:48	0	25.6	49	24	22.2	57	7	23.0	57
04-11-2021 17:49	5	25.6	49	23	22.2	57	7	23.0	57
04-11-2021 17:50	0	25.6	49	23	22.2	57	6	23.0	57
04-11-2021 17:51	0	25.6	50	23	22.2	57	7	23.0	57
04-11-2021 17:52	0	25.6	49	23	22.3	57	7	23.0	57
04-11-2021 17:53	0	25.6	50	23	22.2	57	6	23.0	57
04-11-2021 17:54	3	25.6	49	23	22.3	57	6	23.0	57
04-11-2021 17:55	4	25.6	49	24	22.3	57	7	23.0	57
04-11-2021 17:56	0	25.6	49	23	22.3	57	7	23.0	57





## Environmental Monitoring System

### DATA REPORT

#### FILTRATION, VIAL FILLING, VIAL CAPPING (L4)

Date Time	FILTRATION ROOM (L4) wrt STERILE PASSAGE (L4)	FILTRATION ROOM (L4)	FILTRATION ROOM (L4)	VIAL LIQUID FILLING wrt STERILE PASSAGE (L4)	VIAL LIQUID FILL & STOP (L4)	VIAL LIQUID FILL & STOP (L4)	VIAL CAPPING ROOM (L4) wrt STERILE PASSAGE (L4)	VIAL CAPPING ROOM (L4)	VIAL CAPPING ROOM (L4)
Date Time	DP Pa	°C TEMP	% RH	DP Pa	°C TEMP	% RH	DP Pa	°C TEMP	% RH
04-11-2021 17:57	0	25.6	49	25	22.4	57	7	23.0	57
04-11-2021 17:58	0	25.6	49	23	22.4	57	6	23.0	57
04-11-2021 17:59	4	25.6	49	23	22.4	57	7	23.0	57
04-11-2021 18:00	4	25.6	49	23	22.4	57	7	23.0	57
04-11-2021 18:01	4	25.6	49	23	22.4	56	6	23.0	57
04-11-2021 18:02	0	25.6	49	21	22.4	56	7	23.0	57
04-11-2021 18:03	3	25.6	49	23	22.4	56	7	23.1	57
04-11-2021 18:04	4	25.6	49	22	22.4	56	6	23.1	57
04-11-2021 18:05	4	25.6	49	22	22.5	56	6	23.1	57
04-11-2021 18:06	3	25.6	49	25	22.5	56	6	23.1	57
04-11-2021 18:07	4	25.6	49	23	22.5	56	6	23.1	57
04-11-2021 18:08	0	25.7	49	23	22.5	56	7	23.1	57
04-11-2021 18:09	0	25.8	49	24	22.5	56	7	23.1	57
04-11-2021 18:10	4	25.8	49	23	22.5	56	7	23.1	57
04-11-2021 18:11	4	25.8	49	23	22.5	56	6	23.1	57
04-11-2021 18:12	4	25.8	49	22	22.5	56	6	23.1	57
04-11-2021 18:13	0	25.8	49	23	22.5	56	6	23.1	57
04-11-2021 18:14	3	25.8	49	25	22.5	56	6	23.2	57
04-11-2021 18:15	0	25.8	49	23	22.5	56	7	23.2	57
04-11-2021 18:16	3	25.8	49	23	22.5	56	7	23.1	57
04-11-2021 18:17	0	25.8	49	23	22.5	56	6	23.1	57
04-11-2021 18:18	3	25.8	49	23	22.5	56	7	23.2	57
04-11-2021 18:19	4	25.8	49	25	22.5	56	7	23.2	57
04-11-2021 18:20	0	25.8	49	25	22.5	56	6	23.2	57
04-11-2021 18:21	0	25.8	49	23	22.5	56	7	23.2	57
04-11-2021 18:22	4	25.8	49	23	22.5	56	7	23.2	57
04-11-2021 18:23	0	25.8	49	23	22.5	56	7	23.2	57



# Environmental Monitoring System

## DATA REPORT

### FILTRATION, VIAL FILLING, VIAL CAPPING (L4)

Date Time	FILTRATION ROOM (L4) wrt STERILE PASSAGE (L4)	FILTRATION ROOM (L4)	FILTRATION ROOM (L4)	VIAL LIQUID FILLING wrt STERILE PASSAGE (L4)	VIAL LIQUID FILL & STOP (L4)	VIAL LIQUID FILL & STOP (L4)	VIAL CAPPING ROOM (L4) wrt STERILE PASSAGE (L4)	VIAL CAPPING ROOM (L4)	VIAL CAPPING ROOM (L4)
Date Time	DP Pa	°C TEMP	% RH	DP Pa	°C TEMP	% RH	DP Pa	°C TEMP	% RH
04-11-2021 18:24	4	25.8	49	23	22.5	56	7	23.2	57
04-11-2021 18:25	4	25.8	49	23	22.5	56	6	23.2	57
04-11-2021 18:26	0	25.8	49	24	22.5	56	7	23.2	57
04-11-2021 18:27	3	25.8	49	22	22.5	56	6	23.2	57
04-11-2021 18:28	3	25.8	49	23	22.5	56	6	23.1	57
04-11-2021 18:29	0	25.8	49	23	22.5	56	6	23.1	57
04-11-2021 18:30	0	25.8	49	24	22.5	56	7	23.2	57
04-11-2021 18:31	0	25.8	49	24	22.4	56	7	23.1	57
04-11-2021 18:32	4	25.8	49	23	22.4	56	7	23.2	57
04-11-2021 18:33	0	25.8	49	23	22.4	56	7	23.2	57
04-11-2021 18:34	4	25.8	49	24	22.4	56	6	23.1	57
04-11-2021 18:35	3	25.8	49	23	22.4	56	5	23.1	57
04-11-2021 18:36	0	25.8	49	22	22.4	56	6	23.1	57
04-11-2021 18:37	0	25.8	49	25	22.4	56	6	23.1	57
04-11-2021 18:38	3	25.7	49	25	22.3	56	7	23.1	57
04-11-2021 18:39	0	25.8	49	24	22.3	56	7	23.1	57
04-11-2021 18:40	0	25.7	49	23	22.3	56	6	23.1	57
04-11-2021 18:41	3	25.7	49	23	22.3	56	6	23.1	57
04-11-2021 18:42	3	25.6	49	23	22.3	56	6	23.1	57
04-11-2021 18:43	0	25.6	49	23	22.3	56	6	23.0	57
04-11-2021 18:44	0	25.6	49	23	22.3	56	7	23.0	57
04-11-2021 18:45	4	25.6	49	25	22.2	57	7	23.0	57
04-11-2021 18:46	0	25.6	49	22	22.2	57	7	23.0	57
04-11-2021 18:47	0	25.6	49	23	22.2	57	7	23.0	57
04-11-2021 18:48	4	25.6	49	23	22.2	57	7	23.0	57
04-11-2021 18:49	0	25.6	49	23	22.2	57	6	23.0	57
04-11-2021 18:50	3	25.6	49	22	22.3	57	6	23.0	57



## Environmental Monitoring System

### DATA REPORT

#### FILTRATION, VIAL FILLING, VIAL CAPPING (L4)

Date Time	FILTRATION ROOM (L4) wrt STERILE PASSAGE (L4)	FILTRATION ROOM (L4)	FILTRATION ROOM (L4)	VIAL LIQUID FILLING wrt STERILE PASSAGE (L4)	VIAL LIQUID FILL & STOP (L4)	VIAL LIQUID FILL & STOP (L4)	VIAL CAPPING ROOM (L4) wrt STERILE PASSAGE (L4)	VIAL CAPPING ROOM (L4)	VIAL CAPPING ROOM (L4)
Date Time	DP Pa	°C TEMP	% RH	DP Pa	°C TEMP	% RH	DP Pa	°C TEMP	% RH
04-11-2021 18:51	3	25.6	49	23	22.3	57	6	23.0	57
04-11-2021 18:52	0	25.6	49	22	22.3	56	7	23.0	57
04-11-2021 18:53	3	25.6	49	23	22.3	56	7	23.0	57
04-11-2021 18:54	0	25.6	49	23	22.3	56	6	23.0	57
04-11-2021 18:55	0	25.6	49	24	22.4	56	5	23.0	57
04-11-2021 18:56	4	25.6	49	22	22.4	56	6	23.0	57
04-11-2021 18:57	0	25.6	49	23	22.4	56	6	23.1	57
04-11-2021 18:58	3	25.6	49	23	22.5	56	6	23.1	57
04-11-2021 18:59	4	25.6	49	23	22.5	56	7	23.1	57
04-11-2021 19:00	0	25.6	49	23	22.5	56	7	23.1	57
04-11-2021 19:01	0	25.6	49	23	22.5	56	7	23.1	57
04-11-2021 19:02	0	25.8	49	25	22.5	56	6	23.1	57
04-11-2021 19:03	4	25.7	49	24	22.5	56	6	23.1	57
04-11-2021 19:04	0	25.8	49	25	22.6	56	6	23.2	57
04-11-2021 19:05	4	25.7	49	23	22.6	56	6	23.2	57
04-11-2021 19:06	0	25.7	49	23	22.6	56	6	23.2	57
04-11-2021 19:07	3	25.8	49	23	22.6	56	5	23.2	57
04-11-2021 19:08	0	25.8	49	23	22.6	56	6	23.2	57
04-11-2021 19:09	3	25.8	49	23	22.6	56	6	23.2	57
04-11-2021 19:10	0	25.8	49	24	22.6	56	6	23.2	57
04-11-2021 19:11	4	25.8	49	25	22.6	56	7	23.2	57
04-11-2021 19:12	0	25.8	49	23	22.6	56	6	23.2	57
04-11-2021 19:13	4	25.9	49	23	22.6	56	6	23.2	57
04-11-2021 19:14	0	25.9	49	23	22.6	56	6	23.2	57
04-11-2021 19:15	4	25.9	49	23	22.6	56	7	23.2	56
04-11-2021 19:16	3	25.9	49	23	22.6	56	7	23.3	56
04-11-2021 19:17	0	25.9	49	23	22.6	56	7	23.2	56



# Environmental Monitoring System

## DATA REPORT

### FILTRATION, VIAL FILLING, VIAL CAPPING (L4)

Date Time	FILTRATION ROOM (L4) wrt STERILE PASSAGE (L4)	FILTRATION ROOM (L4)	FILTRATION ROOM (L4)	VIAL LIQUID FILLING wrt STERILE PASSAGE (L4)	VIAL LIQUID FILL & STOP (L4)	VIAL LIQUID FILL & STOP (L4)	VIAL CAPPING ROOM (L4) wrt STERILE PASSAGE (L4)	VIAL CAPPING ROOM (L4)	VIAL CAPPING ROOM (L4)
Date Time	DP Pa	°C TEMP	% RH	DP Pa	°C TEMP	% RH	DP Pa	°C TEMP	% RH
04-11-2021 19:18	0	25.9	49	23	22.6	56	7	23.2	56
04-11-2021 19:19	0	25.9	49	23	22.6	56	7	23.2	56
04-11-2021 19:20	0	25.9	49	23	22.6	56	6	23.3	56
04-11-2021 19:21	0	25.9	49	24	22.6	56	6	23.3	56
04-11-2021 19:22	0	25.9	49	23	22.6	56	6	23.3	56
04-11-2021 19:23	4	25.9	49	23	22.6	56	7	23.3	56
04-11-2021 19:24	0	25.9	49	23	22.6	56	7	23.3	56
04-11-2021 19:25	0	25.9	49	24	22.6	56	7	23.2	56
04-11-2021 19:26	0	25.9	49	23	22.6	56	7	23.2	57
04-11-2021 19:27	3	25.9	49	24	22.6	56	7	23.2	57
04-11-2021 19:28	3	25.9	49	23	22.6	56	6	23.2	57
04-11-2021 19:29	4	25.9	49	23	22.6	56	6	23.2	57
04-11-2021 19:30	3	25.9	49	23	22.6	56	7	23.2	57
04-11-2021 19:31	0	25.9	49	24	22.6	56	7	23.2	57
04-11-2021 19:32	4	25.8	49	25	22.6	56	5	23.2	57
04-11-2021 19:33	0	25.9	49	23	22.6	56	6	23.2	57
04-11-2021 19:34	3	25.9	49	22	22.6	56	7	23.2	57
04-11-2021 19:35	3	25.9	49	23	22.6	56	7	23.3	57
04-11-2021 19:36	3	25.9	49	23	22.5	56	7	23.2	57
04-11-2021 19:37	3	25.9	49	23	22.6	56	6	23.2	57
04-11-2021 19:38	0	25.9	49	24	22.6	56	7	23.2	57
04-11-2021 19:39	3	25.9	49	23	22.6	56	7	23.2	57
04-11-2021 19:40	0	25.9	49	23	22.6	56	6	23.2	57
04-11-2021 19:41	4	25.9	49	23	22.6	56	7	23.2	57
04-11-2021 19:42	0	25.9	49	23	22.6	56	7	23.2	57
04-11-2021 19:43	0	25.9	49	23	22.6	56	6	23.2	57
04-11-2021 19:44	0	25.9	49	25	22.6	56	7	23.2	57



## Environmental Monitoring System

### DATA REPORT

#### FILTRATION, VIAL FILLING, VIAL CAPPING (L4)

Date Time	FILTRATION ROOM (L4) wrt STERILE PASSAGE (L4)	FILTRATION ROOM (L4)	FILTRATION ROOM (L4)	VIAL LIQUID FILLING wrt STERILE PASSAGE (L4)	VIAL LIQUID FILL & STOP (L4)	VIAL LIQUID FILL & STOP (L4)	VIAL CAPPING ROOM (L4) wrt STERILE PASSAGE (L4)	VIAL CAPPING ROOM (L4)	VIAL CAPPING ROOM (L4)
Date Time	DP Pa	°C TEMP	% RH	DP Pa	°C TEMP	% RH	DP Pa	°C TEMP	% RH
04-11-2021 19:45	0	25.9	49	25	22.6	56	7	23.2	57
04-11-2021 19:46	0	25.9	49	23	22.6	56	7	23.2	57
04-11-2021 19:47	3	25.9	49	23	22.6	56	7	23.2	57
04-11-2021 19:48	0	25.9	49	24	22.6	56	7	23.2	57
04-11-2021 19:49	0	25.9	49	24	22.6	56	7	23.2	57
04-11-2021 19:50	4	25.9	49	23	22.6	56	7	23.2	57
04-11-2021 19:51	4	25.9	49	23	22.6	56	6	23.3	57
04-11-2021 19:52	0	25.9	49	23	22.6	56	6	23.2	57
04-11-2021 19:53	0	25.9	49	24	22.6	56	7	23.3	57
04-11-2021 19:54	0	25.9	49	23	22.6	56	6	23.3	57
04-11-2021 19:55	0	25.9	49	25	22.6	56	6	23.3	57
04-11-2021 19:56	0	25.8	49	25	22.7	56	7	23.3	57
04-11-2021 19:57	0	25.9	49	23	22.6	56	6	23.3	57
04-11-2021 19:58	4	25.9	49	23	22.6	56	7	23.3	56
04-11-2021 19:59	4	25.9	49	22	22.7	56	6	23.3	56
04-11-2021 20:00	0	25.9	49	23	22.7	56	7	23.3	57
04-11-2021 20:01	0	25.9	49	23	22.7	56	7	23.3	57
04-11-2021 20:02	4	25.9	49	23	22.7	56	7	23.3	57
04-11-2021 20:03	6	25.9	49	23	22.7	56	6	23.3	57
04-11-2021 20:04	0	25.9	49	23	22.7	56	6	23.3	57
04-11-2021 20:05	0	25.9	49	24	22.6	56	6	23.3	57
04-11-2021 20:06	0	25.9	49	23	22.6	56	5	23.3	57
04-11-2021 20:07	0	25.9	49	23	22.7	56	7	23.3	57
04-11-2021 20:08	0	25.9	49	27	22.6	56	7	23.3	57
04-11-2021 20:09	0	25.9	49	20	22.7	56	0	23.3	57
04-11-2021 20:10	0	25.9	49	21	22.6	56	9	23.3	57
04-11-2021 20:11	6	25.9	49	14	22.6	56	0	23.3	57



## Environmental Monitoring System

### DATA REPORT

#### FILTRATION, VIAL FILLING, VIAL CAPPING (L4)

Date Time	FILTRATION ROOM (L4) wrt STERILE PASSAGE (L4)	FILTRATION ROOM (L4)	FILTRATION ROOM (L4)	VIAL LIQUID FILLING wrt STERILE PASSAGE (L4)	VIAL LIQUID FILL & STOP (L4)	VIAL LIQUID FILL & STOP (L4)	VIAL CAPPING ROOM (L4) wrt STERILE PASSAGE (L4)	VIAL CAPPING ROOM (L4)	VIAL CAPPING ROOM (L4)
Date Time	DP Pa	°C TEMP	% RH	DP Pa	°C TEMP	% RH	DP Pa	°C TEMP	% RH
04-11-2021 20:12	3	25.9	49	23	22.6	56	5	23.3	57
04-11-2021 20:13	3	25.9	49	23	22.6	56	6	23.3	57
04-11-2021 20:14	0	25.9	49	23	22.7	56	7	23.2	57
04-11-2021 20:15	0	25.9	49	23	22.7	56	7	23.3	56
04-11-2021 20:16	0	25.9	49	23	22.7	56	6	23.2	57
04-11-2021 20:17	0	25.9	49	24	22.7	56	7	23.3	57
04-11-2021 20:18	4	25.9	49	23	22.7	56	5	23.2	57
04-11-2021 20:19	0	25.9	49	25	22.7	56	6	23.2	57
04-11-2021 20:20	0	25.9	49	23	22.7	56	6	23.2	57
04-11-2021 20:21	5	25.9	49	24	22.7	56	6	23.2	57
04-11-2021 20:22	0	25.9	49	23	22.7	56	7	23.2	57
04-11-2021 20:23	0	25.9	49	23	22.7	56	6	23.2	57
04-11-2021 20:24	0	25.8	49	23	22.7	56	7	23.2	57
04-11-2021 20:25	0	25.8	49	23	22.7	56	6	23.2	57
04-11-2021 20:26	0	25.8	49	23	22.7	56	7	23.2	57
04-11-2021 20:27	0	25.8	49	25	22.7	56	6	23.2	57
04-11-2021 20:28	4	25.8	50	22	22.7	56	7	23.2	57
04-11-2021 20:29	3	25.9	50	23	22.7	56	6	23.2	57
04-11-2021 20:30	5	25.8	50	23	22.7	56	7	23.2	57
04-11-2021 20:31	3	25.8	50	24	22.7	56	6	23.2	57
04-11-2021 20:32	3	25.8	50	23	22.7	56	7	23.2	57
04-11-2021 20:33	4	25.8	50	23	22.7	56	7	23.2	57
04-11-2021 20:34	0	25.8	49	23	22.7	56	6	23.2	57
04-11-2021 20:35	0	25.8	50	22	22.7	56	6	23.2	57
04-11-2021 20:36	4	25.8	49	23	22.7	56	6	23.2	57
04-11-2021 20:37	0	25.8	49	23	22.7	56	5	23.2	57
04-11-2021 20:38	0	25.8	49	22	22.7	56	7	23.2	57



# Environmental Monitoring System

## DATA REPORT

### FILTRATION, VIAL FILLING, VIAL CAPPING (L4)

Date Time	FILTRATION ROOM (L4) wrt STERILE PASSAGE (L4)	FILTRATION ROOM (L4)	FILTRATION ROOM (L4)	VIAL LIQUID FILLING wrt STERILE PASSAGE (L4)	VIAL LIQUID FILL & STOP (L4)	VIAL LIQUID FILL & STOP (L4)	VIAL CAPPING ROOM (L4) wrt STERILE PASSAGE (L4)	VIAL CAPPING ROOM (L4)	VIAL CAPPING ROOM (L4)
Date Time	DP Pa	°C TEMP	% RH	DP Pa	°C TEMP	% RH	DP Pa	°C TEMP	% RH
04-11-2021 20:39	4	25.8	49	22	22.7	56	7	23.2	57
04-11-2021 20:40	0	25.7	49	23	22.7	56	6	23.2	57
04-11-2021 20:41	0	25.8	49	24	22.7	56	6	23.2	57
04-11-2021 20:42	5	25.8	49	23	22.7	56	6	23.2	57
04-11-2021 20:43	0	25.8	49	23	22.7	56	6	23.2	57
04-11-2021 20:44	0	25.8	49	24	22.7	56	7	23.2	57
04-11-2021 20:45	0	25.8	49	23	22.7	56	6	23.2	57
04-11-2021 20:46	3	25.8	50	25	22.7	56	7	23.2	57
04-11-2021 20:47	0	25.8	50	24	22.7	56	7	23.2	57
04-11-2021 20:48	0	25.8	50	24	22.7	56	7	23.2	57
04-11-2021 20:49	0	25.8	50	23	22.7	56	6	23.2	57
04-11-2021 20:50	0	25.8	50	24	22.7	56	7	23.2	57
04-11-2021 20:51	0	25.8	49	23	22.7	56	7	23.2	57
04-11-2021 20:52	0	25.8	49	23	22.7	56	6	23.2	57
04-11-2021 20:53	0	25.8	49	25	22.7	56	6	23.2	57
04-11-2021 20:54	4	25.8	49	23	22.7	56	7	23.2	57
04-11-2021 20:55	0	25.8	49	23	22.6	56	6	23.2	57
04-11-2021 20:56	3	25.8	49	24	22.6	56	8	23.1	57
04-11-2021 20:57	0	25.8	49	25	22.6	56	6	23.2	57
04-11-2021 20:58	3	25.7	49	23	22.6	56	6	23.1	57
04-11-2021 20:59	4	25.7	49	23	22.6	56	5	23.1	57
04-11-2021 21:00	0	25.7	49	21	22.6	56	7	23.1	57
04-11-2021 21:01	3	25.6	49	24	22.6	56	7	23.1	57
04-11-2021 21:02	4	25.6	49	24	22.6	56	6	23.1	57
04-11-2021 21:03	3	25.6	49	23	22.6	56	5	23.0	57
04-11-2021 21:04	0	25.6	49	24	22.6	56	7	23.0	57
04-11-2021 21:05	0	25.6	49	24	22.6	56	7	23.0	57



# Environmental Monitoring System

## DATA REPORT

### FILTRATION, VIAL FILLING, VIAL CAPPING (L4)

Date Time	FILTRATION ROOM (L4) wrt STERILE PASSAGE (L4)	FILTRATION ROOM (L4)	FILTRATION ROOM (L4)	VIAL LIQUID FILLING wrt STERILE PASSAGE (L4)	VIAL LIQUID FILL & STOP (L4)	VIAL LIQUID FILL & STOP (L4)	VIAL CAPPING ROOM (L4) wrt STERILE PASSAGE (L4)	VIAL CAPPING ROOM (L4)	VIAL CAPPING ROOM (L4)
Date Time	DP Pa	°C TEMP	% RH	DP Pa	°C TEMP	% RH	DP Pa	°C TEMP	% RH
04-11-2021 21:06	0	25.6	49	23	22.7	56	6	23.0	57
04-11-2021 21:07	5	25.6	49	24	22.7	56	8	23.0	57
04-11-2021 21:08	0	25.6	50	25	22.7	56	7	23.0	57
04-11-2021 21:09	4	25.6	50	24	22.6	56	7	23.0	57
04-11-2021 21:10	0	25.5	50	23	22.7	56	7	23.0	58
04-11-2021 21:11	0	25.6	50	22	22.7	56	6	23.0	57
04-11-2021 21:12	0	25.6	50	23	22.6	56	7	23.0	57
04-11-2021 21:13	0	25.6	50	23	22.6	56	6	23.0	57
04-11-2021 21:14	0	25.6	50	23	22.6	56	7	23.0	57
04-11-2021 21:15	3	25.6	50	23	22.6	56	6	23.0	57
04-11-2021 21:16	3	25.6	50	22	22.6	56	6	23.1	57
04-11-2021 21:17	4	25.6	50	23	22.6	56	5	23.1	57
04-11-2021 21:18	4	25.6	50	24	22.6	56	6	23.1	57
04-11-2021 21:19	0	25.6	50	24	22.7	56	5	23.1	57
04-11-2021 21:20	0	25.6	50	24	22.7	56	6	23.2	57
04-11-2021 21:21	0	25.6	50	23	22.7	56	5	23.2	57
04-11-2021 21:22	0	25.8	49	24	22.7	56	6	23.2	57
04-11-2021 21:23	0	25.8	49	23	22.8	56	7	23.2	57
04-11-2021 21:24	0	25.8	49	23	22.8	56	7	23.3	57
04-11-2021 21:25	0	25.8	49	26	22.8	56	7	23.3	57
04-11-2021 21:26	4	25.8	49	23	22.8	56	6	23.3	57
04-11-2021 21:27	4	25.9	49	23	22.9	56	7	23.3	57
04-11-2021 21:28	0	25.9	49	23	22.9	56	6	23.3	57
04-11-2021 21:29	4	25.9	49	24	22.9	56	7	23.3	57
04-11-2021 21:30	0	25.9	49	24	22.9	56	7	23.3	57
04-11-2021 21:31	3	25.9	49	23	22.9	56	7	23.4	57
04-11-2021 21:32	4	25.9	50	22	22.9	56	6	23.4	57





# Environmental Monitoring System

## DATA REPORT

### FILTRATION, VIAL FILLING, VIAL CAPPING (L4)

Date Time	FILTRATION ROOM (L4) wrt STERILE PASSAGE (L4)	FILTRATION ROOM (L4)	FILTRATION ROOM (L4)	VIAL LIQUID FILLING wrt STERILE PASSAGE (L4)	VIAL LIQUID FILL & STOP (L4)	VIAL LIQUID FILL & STOP (L4)	VIAL CAPPING ROOM (L4) wrt STERILE PASSAGE (L4)	VIAL CAPPING ROOM (L4)	VIAL CAPPING ROOM (L4)
Date Time	DP Pa	°C TEMP	% RH	DP Pa	°C TEMP	% RH	DP Pa	°C TEMP	% RH
04-11-2021 21:33	5	25.9	50	23	22.9	56	6	23.4	57
04-11-2021 21:34	0	25.9	50	23	22.9	56	6	23.4	57
04-11-2021 21:35	0	25.9	50	22	22.9	56	7	23.4	57
04-11-2021 21:36	5	25.9	50	24	22.8	57	6	23.3	58
04-11-2021 21:37	3	25.9	50	23	22.8	57	6	23.4	58
04-11-2021 21:38	0	25.9	50	22	22.8	57	6	23.4	58
04-11-2021 21:39	6	25.9	50	23	22.8	57	7	23.3	58
04-11-2021 21:40	3	25.9	50	25	22.7	57	8	23.3	58
04-11-2021 21:41	0	25.9	50	24	22.7	57	6	23.3	58
04-11-2021 21:42	3	25.9	50	24	22.8	57	7	23.3	58
04-11-2021 21:43	0	25.9	50	23	22.8	57	6	23.3	58
04-11-2021 21:44	0	25.9	50	23	22.8	58	7	23.3	58
04-11-2021 21:45	3	25.9	50	24	22.8	58	5	23.3	58
04-11-2021 21:46	0	25.9	50	22	22.8	57	6	23.3	58
04-11-2021 21:47	3	25.9	50	23	22.8	57	5	23.3	58
04-11-2021 21:48	0	25.9	50	24	22.8	57	7	23.3	58
04-11-2021 21:49	0	25.9	51	23	22.8	57	7	23.3	58
04-11-2021 21:50	0	25.9	51	23	22.8	57	7	23.3	58
04-11-2021 21:51	0	25.9	51	23	22.8	57	7	23.3	58
04-11-2021 21:52	0	25.9	51	24	22.8	57	6	23.3	58
04-11-2021 21:53	3	25.9	51	23	22.8	57	7	23.3	58
04-11-2021 21:54	0	25.9	50	24	22.7	57	7	23.3	58
04-11-2021 21:55	3	25.9	50	23	22.7	57	7	23.3	58
04-11-2021 21:56	4	25.9	50	24	22.7	57	7	23.3	58
04-11-2021 21:57	0	25.9	50	23	22.7	57	7	23.3	58
04-11-2021 21:58	4	25.9	50	23	22.7	57	6	23.3	58
04-11-2021 21:59	3	25.9	50	23	22.7	57	6	23.3	57



## Environmental Monitoring System

### DATA REPORT

#### FILTRATION, VIAL FILLING, VIAL CAPPING (L4)

Date Time	FILTRATION ROOM (L4) wrt STERILE PASSAGE (L4)	FILTRATION ROOM (L4)	FILTRATION ROOM (L4)	VIAL LIQUID FILLING wrt STERILE PASSAGE (L4)	VIAL LIQUID FILL & STOP (L4)	VIAL LIQUID FILL & STOP (L4)	VIAL CAPPING ROOM (L4) wrt STERILE PASSAGE (L4)	VIAL CAPPING ROOM (L4)	VIAL CAPPING ROOM (L4)
Date Time	DP Pa	°C TEMP	% RH	DP Pa	°C TEMP	% RH	DP Pa	°C TEMP	% RH
04-11-2021 22:00	4	25.9	50	23	22.8	57	7	23.3	57
04-11-2021 22:01	0	25.9	50	24	22.8	56	7	23.3	57
04-11-2021 22:02	0	25.9	50	22	22.8	56	7	23.3	57
04-11-2021 22:03	3	26.0	50	23	22.8	56	5	23.4	57
04-11-2021 22:04	4	25.9	50	23	22.9	56	7	23.4	57
04-11-2021 22:05	4	25.9	50	24	22.9	56	7	23.4	57
04-11-2021 22:06	5	25.9	50	23	23.0	56	7	23.4	57
04-11-2021 22:07	3	26.1	50	21	23.1	56	3	23.5	57
04-11-2021 22:08	0	26.1	50	22	23.1	56	7	23.5	57
04-11-2021 22:09	4	26.1	50	22	23.2	56	7	23.5	57
04-11-2021 22:10	4	26.1	50	24	23.2	55	6	23.5	57
04-11-2021 22:11	4	26.2	50	23	23.2	55	7	23.6	57
04-11-2021 22:12	3	26.2	49	23	23.3	55	7	23.6	57
04-11-2021 22:13	0	26.2	49	23	23.3	55	6	23.6	56
04-11-2021 22:14	0	26.2	49	24	23.3	55	6	23.6	56
04-11-2021 22:15	0	26.2	49	21	23.3	55	7	23.7	56
04-11-2021 22:16	0	26.3	49	23	23.5	55	6	23.7	56
04-11-2021 22:17	0	26.3	49	22	23.5	55	7	23.6	56
04-11-2021 22:18	3	26.3	49	20	23.5	54	0	23.6	56
04-11-2021 22:19	3	26.3	49	23	23.4	54	6	23.7	56
04-11-2021 22:20	0	26.3	49	22	23.4	54	6	23.7	56
04-11-2021 22:21	0	26.3	49	24	23.4	54	6	23.7	56
04-11-2021 22:22	0	26.3	48	23	23.4	54	6	23.7	56
04-11-2021 22:23	0	26.3	48	23	23.4	54	6	23.7	56
04-11-2021 22:24	0	26.3	48	24	23.4	54	6	23.7	55
04-11-2021 22:25	4	26.3	48	24	23.4	54	6	23.7	55
04-11-2021 22:26	0	26.3	48	24	23.4	54	5	23.7	55



# Environmental Monitoring System

## DATA REPORT

### FILTRATION, VIAL FILLING, VIAL CAPPING (L4)

Date Time	FILTRATION ROOM (L4) wrt STERILE PASSAGE (L4)	FILTRATION ROOM (L4)	FILTRATION ROOM (L4)	VIAL LIQUID FILLING wrt STERILE PASSAGE (L4)	VIAL LIQUID FILL & STOP (L4)	VIAL LIQUID FILL & STOP (L4)	VIAL CAPPING ROOM (L4) wrt STERILE PASSAGE (L4)	VIAL CAPPING ROOM (L4)	VIAL CAPPING ROOM (L4)
Date Time	DP Pa	°C TEMP	% RH	DP Pa	°C TEMP	% RH	DP Pa	°C TEMP	% RH
04-11-2021 22:27	3	26.3	48	23	23.5	54	7	23.7	55
04-11-2021 22:28	0	26.4	48	24	23.4	54	6	23.7	55
04-11-2021 22:29	0	26.4	48	24	23.4	54	6	23.7	55
04-11-2021 22:30	0	26.2	48	22	23.4	54	6	23.7	55
04-11-2021 22:31	3	26.3	48	21	23.3	54	5	23.7	55
04-11-2021 22:32	0	26.3	48	23	23.3	54	7	23.7	55
04-11-2021 22:33	0	26.3	48	23	23.3	54	6	23.7	55
04-11-2021 22:34	0	26.3	48	23	23.3	54	6	23.6	55
04-11-2021 22:35	4	26.2	48	23	23.3	54	7	23.6	55
04-11-2021 22:36	0	26.2	48	23	23.3	54	7	23.6	55
04-11-2021 22:37	3	26.2	48	25	23.3	54	6	23.6	55
04-11-2021 22:38	3	26.2	48	23	23.3	54	7	23.6	55
04-11-2021 22:39	4	26.2	48	13	23.2	54	0	23.6	55
04-11-2021 22:40	0	26.2	48	22	23.2	54	7	23.6	55
04-11-2021 22:41	3	26.2	48	23	23.1	54	7	23.5	55
04-11-2021 22:42	0	26.2	48	23	23.1	54	6	23.5	55
04-11-2021 22:43	3	26.1	48	23	23.0	54	6	23.5	55
04-11-2021 22:44	3	26.1	48	25	23.0	55	6	23.5	56
04-11-2021 22:45	0	26.1	48	22	23.0	55	5	23.5	56
04-11-2021 22:46	4	26.1	48	23	22.9	55	7	23.5	56
04-11-2021 22:47	0	26.1	48	24	22.9	55	7	23.4	56
04-11-2021 22:48	4	26.1	48	23	22.9	55	7	23.4	56
04-11-2021 22:49	3	26.1	48	23	23.0	55	6	23.4	56
04-11-2021 22:50	0	26.1	48	23	23.0	55	7	23.4	56
04-11-2021 22:51	4	26.1	48	24	23.0	55	7	23.4	56
04-11-2021 22:52	4	26.1	48	24	22.9	55	6	23.4	56
04-11-2021 22:53	0	26.0	48	23	22.9	55	7	23.4	56



## Environmental Monitoring System

### DATA REPORT

#### FILTRATION, VIAL FILLING, VIAL CAPPING (L4)

Date Time	FILTRATION ROOM (L4) wrt STERILE PASSAGE (L4)	FILTRATION ROOM (L4)	FILTRATION ROOM (L4)	VIAL LIQUID FILLING wrt STERILE PASSAGE (L4)	VIAL LIQUID FILL & STOP (L4)	VIAL LIQUID FILL & STOP (L4)	VIAL CAPPING ROOM (L4) wrt STERILE PASSAGE (L4)	VIAL CAPPING ROOM (L4)	VIAL CAPPING ROOM (L4)
Date Time	DP Pa	°C TEMP	% RH	DP Pa	°C TEMP	% RH	DP Pa	°C TEMP	% RH
04-11-2021 22:54	0	26.0	48	23	22.9	55	6	23.4	56
04-11-2021 22:55	0	25.9	48	22	22.9	55	7	23.4	56
04-11-2021 22:56	5	26.0	48	21	22.9	55	6	23.4	56
04-11-2021 22:57	0	25.9	48	23	22.9	55	6	23.4	56
04-11-2021 22:58	4	25.9	48	24	22.9	55	7	23.4	56
04-11-2021 22:59	4	25.9	48	23	22.9	55	7	23.4	56
04-11-2021 23:00	0	25.9	48	23	22.9	55	6	23.4	56
04-11-2021 23:01	0	25.9	48	22	22.9	55	6	23.4	56
04-11-2021 23:02	0	25.9	48	23	22.9	55	6	23.4	56
04-11-2021 23:03	0	25.9	48	23	23.0	55	7	23.3	56
04-11-2021 23:04	0	25.9	48	23	23.0	55	7	23.4	56
04-11-2021 23:05	0	25.9	48	23	23.0	55	7	23.4	56
04-11-2021 23:06	3	25.9	48	23	23.0	54	6	23.4	56
04-11-2021 23:07	0	25.9	48	23	23.0	54	7	23.4	56
04-11-2021 23:08	0	25.9	48	23	23.1	54	7	23.4	56
04-11-2021 23:09	0	25.9	48	23	23.1	54	7	23.4	56
04-11-2021 23:10	0	25.9	48	23	23.1	54	7	23.4	56
04-11-2021 23:11	3	25.9	48	23	23.1	54	6	23.4	56
04-11-2021 23:12	0	25.9	48	23	23.1	54	6	23.4	56
04-11-2021 23:13	0	26.0	48	22	23.1	54	6	23.4	56
04-11-2021 23:14	4	26.1	48	23	23.2	54	7	23.4	56
04-11-2021 23:15	0	26.1	48	23	23.2	54	7	23.4	56
04-11-2021 23:16	4	26.1	48	24	23.2	54	6	23.4	55
04-11-2021 23:17	0	26.1	48	23	23.2	54	7	23.4	55
04-11-2021 23:18	0	26.1	48	24	23.2	54	7	23.4	55
04-11-2021 23:19	3	26.1	48	23	23.2	54	5	23.4	55
04-11-2021 23:20	0	26.1	48	23	23.2	54	6	23.4	55



## Environmental Monitoring System

### DATA REPORT

#### FILTRATION, VIAL FILLING, VIAL CAPPING (L4)

Date Time	FILTRATION ROOM (L4) wrt STERILE PASSAGE (L4)	FILTRATION ROOM (L4)	FILTRATION ROOM (L4)	VIAL LIQUID FILLING wrt STERILE PASSAGE (L4)	VIAL LIQUID FILL & STOP (L4)	VIAL LIQUID FILL & STOP (L4)	VIAL CAPPING ROOM (L4) wrt STERILE PASSAGE (L4)	VIAL CAPPING ROOM (L4)	VIAL CAPPING ROOM (L4)
Date Time	DP Pa	°C TEMP	% RH	DP Pa	°C TEMP	% RH	DP Pa	°C TEMP	% RH
04-11-2021 23:21	0	26.1	48	24	23.2	54	7	23.5	55
04-11-2021 23:22	0	26.1	48	23	23.2	54	6	23.5	55
04-11-2021 23:23	0	26.1	48	23	23.2	54	7	23.5	55
04-11-2021 23:24	0	26.1	48	23	23.2	54	6	23.5	55
04-11-2021 23:25	3	26.1	48	24	23.2	54	7	23.5	55
04-11-2021 23:26	0	26.1	48	22	23.2	54	7	23.5	55
04-11-2021 23:27	0	26.1	48	23	23.2	54	6	23.5	55
04-11-2021 23:28	0	26.1	48	22	23.2	54	6	23.5	55
04-11-2021 23:29	3	26.1	48	23	23.2	54	7	23.5	55
04-11-2021 23:30	0	26.1	48	23	23.2	54	7	23.5	55
04-11-2021 23:31	4	26.2	48	23	23.2	54	6	23.5	55
04-11-2021 23:32	0	26.2	48	23	23.2	54	5	23.5	55
04-11-2021 23:33	3	26.2	48	25	23.2	54	7	23.5	55
04-11-2021 23:34	0	26.2	48	22	23.2	54	6	23.5	55
04-11-2021 23:35	0	26.2	48	21	23.2	54	7	23.5	55
04-11-2021 23:36	3	26.2	48	25	23.2	54	7	23.5	55
04-11-2021 23:37	3	26.2	48	23	23.2	54	6	23.5	55
04-11-2021 23:38	0	26.1	48	23	23.2	54	7	23.5	55
04-11-2021 23:39	4	26.2	48	23	23.2	54	6	23.5	55
04-11-2021 23:40	4	26.2	48	24	23.2	54	6	23.5	55
04-11-2021 23:41	0	26.2	48	22	23.2	54	7	23.5	55
04-11-2021 23:42	0	26.2	48	24	23.2	54	6	23.5	55
04-11-2021 23:43	5	26.2	48	22	23.2	54	4	23.5	55
04-11-2021 23:44	0	26.1	48	25	23.2	54	7	23.5	55
04-11-2021 23:45	0	26.1	48	21	23.1	54	5	23.5	55
04-11-2021 23:46	0	26.1	48	22	23.1	54	7	23.5	55
04-11-2021 23:47	0	26.1	48	23	23.1	54	6	23.5	55



# Environmental Monitoring System

## DATA REPORT

### FILTRATION, VIAL FILLING, VIAL CAPPING (L4)

Date Time	FILTRATION ROOM (L4) wrt STERILE PASSAGE (L4)	FILTRATION ROOM (L4)	FILTRATION ROOM (L4)	VIAL LIQUID FILLING wrt STERILE PASSAGE (L4)	VIAL LIQUID FILL & STOP (L4)	VIAL LIQUID FILL & STOP (L4)	VIAL CAPPING ROOM (L4) wrt STERILE PASSAGE (L4)	VIAL CAPPING ROOM (L4)	VIAL CAPPING ROOM (L4)
Date Time	DP Pa	°C TEMP	% RH	DP Pa	°C TEMP	% RH	DP Pa	°C TEMP	% RH
04-11-2021 23:48	0	26.1	48	25	23.1	54	6	23.5	55
04-11-2021 23:49	3	26.1	48	23	23.1	54	6	23.5	55
04-11-2021 23:50	0	26.2	48	24	23.1	54	7	23.5	55
04-11-2021 23:51	0	26.1	48	23	23.1	54	7	23.5	55
04-11-2021 23:52	0	26.1	48	23	23.1	54	7	23.5	55
04-11-2021 23:53	3	26.1	48	24	23.1	54	5	23.5	55
04-11-2021 23:54	4	26.1	48	23	23.1	54	7	23.5	55
04-11-2021 23:55	0	26.1	48	23	23.1	54	7	23.5	55
04-11-2021 23:56	0	26.1	48	24	23.1	54	6	23.5	55
04-11-2021 23:57	0	26.1	48	23	23.1	54	6	23.5	55
04-11-2021 23:58	4	26.1	48	23	23.1	54	7	23.5	55
04-11-2021 23:59	3	26.1	48	23	23.1	54	6	23.4	55
05-11-2021 00:00	4	26.1	48	23	23.1	54	6	23.5	55
Min Value	****	****	****	****	****	****	****	****	****
Max Value	****	****	****	****	****	****	****	****	****

End Of Report : From 04/11/2021 00:00:00 To 05/11/2021 00:00:00

ACTIVITY	NAME	SIGNATURE AND DATE
REVIEWED BY USER		
REVIEWED BY QA		