



SOMERSET THERAPEUTICS LIMITED

DATA REPORT - SVP1 AND AMPOULE LINE EMS

AMPOULE WASHING AREA

Date Time	RH	Temperature	Differential Pressure
DD-MM-YYYY HH:MM:SS	Ampoule Washing Area (NMT 80%)	Ampoule Washing Area (NMT 30°C)	Ampoule Washing Area w.r.t Ampoule Decartoning Room (NLT 12 Pa)
06-05-2022 08:56:00	66.8	20.6	91
06-05-2022 09:26:00	70.1	21.2	36
06-05-2022 09:56:00	67.8	21.6	89
06-05-2022 10:26:00	68.8	21.4	90
06-05-2022 10:56:00	68.5	21.4	89
06-05-2022 11:26:00	69.3	21.7	96
06-05-2022 11:56:00	72.5	21.9	96
06-05-2022 12:26:00	69.4	21.9	95
06-05-2022 12:56:00	69.2	21.7	91
06-05-2022 13:26:00	68.7	21.7	103
06-05-2022 13:56:00	69.4	21.7	94
06-05-2022 14:26:00	69.2	21.8	88
06-05-2022 14:56:00	69	21.8	95
06-05-2022 15:26:00	68.6	21.8	97
06-05-2022 15:56:00	69.5	22	97
06-05-2022 16:26:00	68.8	22	92
06-05-2022 16:56:00	69.7	22	95
06-05-2022 17:26:00	69.4	22.1	97
06-05-2022 17:56:00	67.9	22	74
06-05-2022 18:26:00	67.2	21.7	68
06-05-2022 18:56:00	66.4	21.6	96
06-05-2022 19:26:00	66	21.6	97
06-05-2022 19:56:00	66.3	21.5	97
06-05-2022 20:26:00	66.7	21.6	97

ACTIVITY	NAME	SIGNATURE AND DATE
REVIEWED BY USER		
REVIEWED BY QA		



SOMERSET THERAPEUTICS LIMITED

DATA REPORT - SVP1 AND AMPOULE LINE EMS

AMPOULE WASHING AREA

Date Time	RH	Temperature	Differential Pressure
DD-MM-YYYY HH:MM:SS	Ampoule Washing Area (NMT 80%)	Ampoule Washing Area (NMT 30°C)	Ampoule Washing Area w.r.t Ampoule Decartoning Room (NLT 12 Pa)
06-05-2022 20:56:00	65.7	21.6	96
06-05-2022 21:26:00	64.7	21.3	97
06-05-2022 21:56:00	65.2	21.2	96
06-05-2022 22:26:00	65.4	21.2	97
06-05-2022 22:56:00	68.5	21.6	95
06-05-2022 23:26:00	69	21.7	82
06-05-2022 23:56:00	67	21.6	93
07-05-2022 00:26:00	65.9	21.4	94
07-05-2022 00:56:00	66.2	21.4	95
07-05-2022 01:26:00	66.3	21.4	94
07-05-2022 01:56:00	65.7	21.3	94
07-05-2022 02:26:00	65.2	21.2	93
07-05-2022 02:56:00	65.5	21.1	92
07-05-2022 03:26:00	66	21.3	92
07-05-2022 03:56:00	64.7	21.1	91
07-05-2022 04:26:00	64.6	20.9	89
07-05-2022 04:56:00	64.5	20.8	92
07-05-2022 05:26:00	65.4	20.7	92
07-05-2022 05:56:00	65.3	20.8	92
07-05-2022 06:26:00	65.1	20.8	92
07-05-2022 06:56:00	65.9	20.8	88
07-05-2022 07:26:00	67	20.9	93
07-05-2022 07:56:00	84.9	22.7	91
07-05-2022 08:26:00	82.3	24	91

ACTIVITY	NAME	SIGNATURE AND DATE
REVIEWED BY USER		
REVIEWED BY QA		



SOMERSET THERAPEUTICS LIMITED

DATA REPORT - SVP1 AND AMPOULE LINE EMS

AMPOULE WASHING AREA

Date Time	RH	Temperature	Differential Pressure
DD-MM-YYYY HH:MM:SS	Ampoule Washing Area (NMT 80%)	Ampoule Washing Area (NMT 30°C)	Ampoule Washing Area w.r.t Ampoule Decartoning Room (NLT 12 Pa)
07-05-2022 08:56:00	79.9	24.8	92

End Of Report : From 06-05-2022 08:56:15 To 07-05-2022 08:56:15

ACTIVITY	NAME	SIGNATURE AND DATE
REVIEWED BY USER		
REVIEWED BY QA		