



# SOMERSET THERAPEUTICS LIMITED

## DATA REPORT - SVP1 AND AMPOULE LINE EMS

### WASHING AND STERILIZATION AREA

| Date Time           | Temperature                               | RH                                       | Diffrential Pressure  | Diffrential Pressure  | Diffrential Pressure  |
|---------------------|---|--|---|---|---|
| DD-MM-YYYY HH:MM:SS | Washing and Sterilization Area (NMT 30°C) | Washing and Sterilization Area (NMT 80%) | Washing and Sterilization Area w.r.t Unit Preparation Room (NLT 6 Pa) | Washing and Sterilization Area w.r.t Ampoule Decartoning Room (NLT 12 Pa) | Washing and Sterilization Area w.r.t Injectable main corridor (NLT 12 Pa) |
| 04/05/2022 12:34:00 | 18.1                                      | 77.1                                     | 21  | 13  | 38  |
| 04/05/2022 13:04:00 | 18.1                                      | 77.1                                     | 21  | 13  | 38  |
| 04/05/2022 13:34:00 | 18.1                                      | 77.1                                     | 21  | 13  | 38  |
| 04/05/2022 14:04:00 | 18.1                                      | 77.1                                     | 21  | 13  | 38  |
| 04/05/2022 14:34:00 | 18.1                                      | 77.1                                     | 21  | 13  | 38  |
| 04/05/2022 15:04:00 | 18.1                                      | 77.1                                     | 21  | 13  | 38  |
| 04/05/2022 15:34:00 | 18.1                                      | 77.1                                     | 21  | 13  | 38  |
| 04/05/2022 16:04:00 | 18.1                                      | 77.1                                     | 21  | 13  | 38  |
| 04/05/2022 16:34:00 | 18.1                                      | 77.1                                     | 21  | 13  | 38  |
| 04/05/2022 17:04:00 | 18.1                                      | 77.1                                     | 21  | 13  | 38  |
| 04/05/2022 17:34:00 | 18.1                                      | 77.1                                     | 21  | 13  | 38  |
| 04/05/2022 18:04:00 | 18.1                                      | 77.1                                     | 21  | 13  | 38  |
| 04/05/2022 18:34:00 | 18.1                                      | 77.1                                     | 21  | 13  | 38  |
| 04/05/2022 19:04:00 | 18.1                                      | 77.1                                     | 21  | 13  | 38  |
| 04/05/2022 19:34:00 | 18.1                                      | 77.1                                     | 21  | 13  | 38  |
| 04/05/2022 20:04:00 | 18.1                                      | 77.1                                     | 21  | 13  | 38  |
| 04/05/2022 20:34:00 | 18.1                                      | 77.1                                     | 21  | 13  | 38  |
| 04/05/2022 21:04:00 | 18.1                                      | 77.1                                     | 21  | 13  | 38  |
| 04/05/2022 21:34:00 | 18.1                                      | 77.1                                     | 21  | 13  | 38  |
| 04/05/2022 22:04:00 | 18.1                                      | 77.1                                     | 21  | 13  | 38  |
| 04/05/2022 22:34:00 | 18.1                                      | 77.1                                     | 21  | 13  | 38  |
| 04/05/2022 23:04:00 | 18.1                                      | 77.1                                     | 21  | 13  | 38  |
| 04/05/2022 23:34:00 | 18.1                                      | 77.1                                     | 21  | 13  | 38  |
| 05/05/2022 00:04:00 | 18.1                                      | 77.1                                     | 21  | 13  | 38  |

| ACTIVITY         | NAME | SIGNATURE AND DATE |
|------------------|------|--------------------|
| REVIEWED BY USER |      |                    |
| REVIEWED BY QA   |      |                    |



# SOMERSET THERAPEUTICS LIMITED

## DATA REPORT - SVP1 AND AMPOULE LINE EMS

### WASHING AND STERILIZATION AREA

| Date Time           | Temperature                               | RH                                       | Diffrential Pressure  | Diffrential Pressure  | Diffrential Pressure  |
|---------------------|---|--|---|---|---|
| DD-MM-YYYY HH:MM:SS | Washing and Sterilization Area (NMT 30°C) | Washing and Sterilization Area (NMT 80%) | Washing and Sterilization Area w.r.t Unit Preparation Room (NLT 6 Pa) | Washing and Sterilization Area w.r.t Ampoule Decartoning Room (NLT 12 Pa) | Washing and Sterilization Area w.r.t Injectable main corridor (NLT 12 Pa) |
| 05/05/2022 00:34:00 | 18.1                                      | 77.1                                     | 21  | 13  | 38  |
| 05/05/2022 01:04:00 | 18.1                                      | 77.1                                     | 21  | 13  | 38  |
| 05/05/2022 01:34:00 | 18.1                                      | 77.1                                     | 21  | 13  | 38  |
| 05/05/2022 02:04:00 | 18.1                                      | 77.1                                     | 21  | 13  | 38  |
| 05/05/2022 02:34:00 | 18.1                                      | 77.1                                     | 21  | 13  | 38  |
| 05/05/2022 03:04:00 | 18.1                                      | 77.1                                     | 21  | 13  | 38  |
| 05/05/2022 03:34:00 | 18.1                                      | 77.1                                     | 21  | 13  | 38  |
| 05/05/2022 04:04:00 | 18.1                                      | 77.1                                     | 21  | 13  | 38  |
| 05/05/2022 04:34:00 | 18.1                                      | 77.1                                     | 21  | 13  | 38  |
| 05/05/2022 05:04:00 | 18.1                                      | 77.1                                     | 21  | 13  | 38  |
| 05/05/2022 05:34:00 | 18.1                                      | 77.1                                     | 21  | 13  | 38  |
| 05/05/2022 06:04:00 | 18.1                                      | 77.1                                     | 21  | 13  | 38  |
| 05/05/2022 06:34:00 | 18.1                                      | 77.1                                     | 21  | 13  | 38  |
| 05/05/2022 07:04:00 | 18.1                                      | 77.1                                     | 21  | 13  | 38  |
| 05/05/2022 07:34:00 | 18.1                                      | 77.1                                     | 21  | 13  | 38  |
| 05/05/2022 08:04:00 | 18.1                                      | 77.1                                     | 21  | 13  | 38  |
| 05/05/2022 08:34:00 | 18.1                                      | 77.1                                     | 21  | 13  | 38  |
| 05/05/2022 09:04:00 | 18.1                                      | 77.1                                     | 21  | 13  | 38  |
| 05/05/2022 09:34:00 | 18.1                                      | 77.1                                     | 21  | 13  | 38  |
| 05/05/2022 10:04:00 | 18.1                                      | 77.1                                     | 21  | 13  | 38  |
| 05/05/2022 10:34:00 | 18.1                                      | 77.1                                     | 21  | 13  | 38  |
| 05/05/2022 11:04:00 | 18.1                                      | 77.1                                     | 21  | 13  | 38  |
| 05/05/2022 11:34:00 | 18.1                                      | 77.1                                     | 21  | 13  | 38  |
| 05/05/2022 12:04:00 | 18.1                                      | 77.1                                     | 21  | 13  | 38  |

| ACTIVITY         | NAME | SIGNATURE AND DATE |
|------------------|------|--------------------|
| REVIEWED BY USER |      |                    |
| REVIEWED BY QA   |      |                    |



## SOMERSET THERAPEUTICS LIMITED

### DATA REPORT - SVP1 AND AMPOULE LINE EMS

#### WASHING AND STERILIZATION AREA

| Date Time           | Temperature                                  | RH  | Diffrential Pressure  | Diffrential Pressure  | Diffrential Pressure  |
|---------------------|--|---|---|---|---|
| DD-MM-YYYY HH:MM:SS | Washing and Sterilization Area<br>(NMT 30°C) | Washing and Sterilization Area<br>(NMT 80%) | Washing and Sterilization Area<br>w.r.t Unit Preparation Room<br>(NLT 6 Pa) | Washing and Sterilization Area<br>w.r.t Ampoule Decartoning<br>Room (NLT 12 Pa) | Washing and Sterilization Area<br>w.r.t Injectable main corridor<br>(NLT 12 Pa) |
| 05/05/2022 12:34:00 | 18.1   | 77.1  | 21  | 13  | 38  |
| Min Value           | 18.1   | 77.1  | 21  | 13  | 38  |
| Max Value           | 18.1   | 77.1  | 21  | 13  | 38  |

End Of Report : From 04-05-2022 12:34:45 To 05-05-2022 12:34:45

| ACTIVITY         | NAME | SIGNATURE AND DATE |
|------------------|------|--------------------|
| REVIEWED BY USER |      |                    |
| REVIEWED BY QA   |      |                    |