



SOMERSET THERAPEUTICS LIMITED

DATA REPORT - SVP1 AND AMPOULE LINE EMS

AMPOULE WASHING AREA

Date Time	RH	Temperature	Differential Pressure
DD-MM-YYYY HH:MM:SS	Ampoule Washing Area (NMT 80%)	Ampoule Washing Area (NMT 30°C)	Ampoule Washing Area w.r.t Ampoule Decartoning Room (NLT 12 Pa)
06-05-2022 09:32:00	68.4	22	35
06-05-2022 10:02:00	68.1	21.5	91
06-05-2022 10:32:00	68.8	21.4	90
06-05-2022 11:02:00	69.3	21.4	34
06-05-2022 11:32:00	69.3	21.7	97
06-05-2022 12:02:00	71.1	22	93
06-05-2022 12:32:00	69.3	21.8	89
06-05-2022 13:02:00	69	21.7	95
06-05-2022 13:32:00	69.3	21.7	103
06-05-2022 14:02:00	69.1	21.7	96
06-05-2022 14:32:00	68.9	21.8	94
06-05-2022 15:02:00	69.3	21.8	97
06-05-2022 15:32:00	69.2	21.8	96
06-05-2022 16:02:00	69.2	22	95
06-05-2022 16:32:00	68.7	22	95
06-05-2022 17:02:00	69.2	22	96
06-05-2022 17:32:00	69.5	22.1	94
06-05-2022 18:02:00	67.5	21.9	73
06-05-2022 18:32:00	66.8	21.7	74
06-05-2022 19:02:00	66.7	21.6	97
06-05-2022 19:32:00	66.1	21.6	96
06-05-2022 20:02:00	66.1	21.4	97
06-05-2022 20:32:00	66.4	21.6	95
06-05-2022 21:02:00	65.2	21.5	96

ACTIVITY	NAME	SIGNATURE AND DATE
REVIEWED BY USER		
REVIEWED BY QA		



SOMERSET THERAPEUTICS LIMITED

DATA REPORT - SVP1 AND AMPOULE LINE EMS

AMPOULE WASHING AREA

Date Time	RH	Temperature	Differential Pressure
DD-MM-YYYY HH:MM:SS	Ampoule Washing Area (NMT 80%)	Ampoule Washing Area (NMT 30°C)	Ampoule Washing Area w.r.t Ampoule Decartoning Room (NLT 12 Pa)
06-05-2022 21:32:00	64.7	21.3	97
06-05-2022 22:02:00	65.3	21.2	96
06-05-2022 22:32:00	66.4	21.2	95
06-05-2022 23:02:00	67.3	21.6	95
06-05-2022 23:32:00	68.4	21.8	95
07-05-2022 00:02:00	66.2	21.5	95
07-05-2022 00:32:00	66.1	21.4	94
07-05-2022 01:02:00	65.9	21.4	94
07-05-2022 01:32:00	65.7	21.4	94
07-05-2022 02:02:00	65.7	21.3	93
07-05-2022 02:32:00	65.2	21.2	93
07-05-2022 03:02:00	66.4	21.2	92
07-05-2022 03:32:00	65.1	21.3	90
07-05-2022 04:02:00	64.6	21	92
07-05-2022 04:32:00	64.5	20.9	90
07-05-2022 05:02:00	64.6	20.8	92
07-05-2022 05:32:00	65.5	20.8	91
07-05-2022 06:02:00	65.1	20.8	92
07-05-2022 06:32:00	65.2	20.8	92
07-05-2022 07:02:00	65.5	20.8	93
07-05-2022 07:32:00	68.1	21	93
07-05-2022 08:02:00	84.8	23.2	92
07-05-2022 08:32:00	81.8	24.1	92
07-05-2022 09:02:00	79.1	24.9	92

ACTIVITY	NAME	SIGNATURE AND DATE
REVIEWED BY USER		
REVIEWED BY QA		



SOMERSET THERAPEUTICS LIMITED

DATA REPORT - SVP1 AND AMPOULE LINE EMS

AMPOULE WASHING AREA

Date Time	RH	Temperature	Differential Pressure
DD-MM-YYYY HH:MM:SS	Ampoule Washing Area (NMT 80%)	Ampoule Washing Area (NMT 30°C)	Ampoule Washing Area w.r.t Ampoule Decartoning Room (NLT 12 Pa)
07-05-2022 09:32:00	****	****	****

End Of Report : From 06-05-2022 15:02:29 To 07-05-2022 15:02:29

ACTIVITY	NAME	SIGNATURE AND DATE
REVIEWED BY USER		
REVIEWED BY QA		