



SOMERSET THERAPEUTICS LIMITED

DATA REPORT - SVP1 AND AMPOULE LINE EMS

WASHING AND STERILIZATION AREA

Date Time	Temperature	RH	Diffrential Pressure	Diffrential Pressure	Diffrential Pressure
DD-MM-YYYY HH:MM:SS	Washing and Sterilization Area (NMT 30°C)	Washing and Sterilization Area (NMT 80%)	Washing and Sterilization Area w.r.t Unit Preparation Room (NLT 6 Pa)	Washing and Sterilization Area w.r.t Ampoule Decartoning Room (NLT 12 Pa)	Washing and Sterilization Area w.r.t Injectable main corridor (NLT 12 Pa)
21-05-2022 16:23:00	18	79	0	14	37
21-05-2022 16:24:00	18	79.1	0	14	36
21-05-2022 16:25:00	18	79.1	0	14	37
21-05-2022 16:26:00	18	78.9	0	14	36
21-05-2022 16:27:00	18	78.6	0	15	37
21-05-2022 16:28:00	18	78.3	0	14	37
21-05-2022 16:29:00	18	78.1	0	14	37
21-05-2022 16:30:00	18	78	0	14	36
21-05-2022 16:31:00	18	78.7	0	14	35
21-05-2022 16:32:00	18	79.8	0	14	36
21-05-2022 16:33:00	18.1	80.6	0	14	36
21-05-2022 16:34:00	18.1	81.1	0	13	32
21-05-2022 16:35:00	18.2	81.4	0	14	36
21-05-2022 16:36:00	18.2	81.3	0	13	36
21-05-2022 16:37:00	18.3	81.2	0	14	35
21-05-2022 16:38:00	18.3	81.1	0	14	33
21-05-2022 16:39:00	18.3	81.3	0	14	38
21-05-2022 16:40:00	18.3	80.5	0	14	38
21-05-2022 16:41:00	18.3	79.7	0	15	40
21-05-2022 16:42:00	18.3	79.2	0	14	38
21-05-2022 16:43:00	18.3	78.8	0	14	36
21-05-2022 16:44:00	18.3	78.4	0	13	36
21-05-2022 16:45:00	18.3	78	0	14	36
21-05-2022 16:46:00	18.2	78	0	13	35

ACTIVITY	NAME	SIGNATURE AND DATE
REVIEWED BY USER		
REVIEWED BY QA		



SOMERSET THERAPEUTICS LIMITED

DATA REPORT - SVP1 AND AMPOULE LINE EMS

WASHING AND STERILIZATION AREA

Date Time	Temperature	RH	Diffrential Pressure	Diffrential Pressure	Diffrential Pressure
DD-MM-YYYY HH:MM:SS	Washing and Sterilization Area (NMT 30°C)	Washing and Sterilization Area (NMT 80%)	Washing and Sterilization Area w.r.t Unit Preparation Room (NLT 6 Pa)	Washing and Sterilization Area w.r.t Ampoule Decartoning Room (NLT 12 Pa)	Washing and Sterilization Area w.r.t Injectable main corridor (NLT 12 Pa)
21-05-2022 16:47:00	18.2	77.9	0	14	36
21-05-2022 16:48:00	18.2	77.9	0	13	37
21-05-2022 16:49:00	18.2	78.2	0	14	36
21-05-2022 16:50:00	18.2	78.5	12	15	38
21-05-2022 16:51:00	18.2	78.5	21	16	38
21-05-2022 16:52:00	18.2	78.7	21	15	36
21-05-2022 16:53:00	18.2	78.6	21	16	40
21-05-2022 16:54:00	18.2	78.5	21	16	40
21-05-2022 16:55:00	18.2	78.2	21	16	40
21-05-2022 16:56:00	18.2	78	21	16	39
21-05-2022 16:57:00	18.1	78	21	16	38
21-05-2022 16:58:00	18.1	77.8	21	16	38
21-05-2022 16:59:00	18.1	77.7	19	16	38
21-05-2022 17:00:00	18.1	77.6	15	15	38
21-05-2022 17:01:00	18.1	77.5	15	16	38
21-05-2022 17:02:00	18	77.4	20	15	37
21-05-2022 17:03:00	18	77.3	20	16	38
21-05-2022 17:04:00	18	77.2	20	16	37
21-05-2022 17:05:00	18	77.1	19	15	38
21-05-2022 17:06:00	18	77.1	20	16	38
21-05-2022 17:07:00	18	77	20	16	37
21-05-2022 17:08:00	18	77	20	16	38
21-05-2022 17:09:00	17.9	77.1	20	16	38
21-05-2022 17:10:00	17.9	77.1	20	16	38

ACTIVITY	NAME	SIGNATURE AND DATE
REVIEWED BY USER		
REVIEWED BY QA		



SOMERSET THERAPEUTICS LIMITED

DATA REPORT - SVP1 AND AMPOULE LINE EMS

WASHING AND STERILIZATION AREA

Date Time	Temperature	RH	Diffrential Pressure	Diffrential Pressure	Diffrential Pressure
DD-MM-YYYY HH:MM:SS	Washing and Sterilization Area (NMT 30°C)	Washing and Sterilization Area (NMT 80%)	Washing and Sterilization Area w.r.t Unit Preparation Room (NLT 6 Pa)	Washing and Sterilization Area w.r.t Ampoule Decartoning Room (NLT 12 Pa)	Washing and Sterilization Area w.r.t Injectable main corridor (NLT 12 Pa)
21-05-2022 17:11:00	17.9	77.2	21	16	37
21-05-2022 17:12:00	17.9	77.2	21	16	36
21-05-2022 17:13:00	17.9	77.2	20	16	38
21-05-2022 17:14:00	17.9	77.2	21	16	38
21-05-2022 17:15:00	17.9	77.6	20	16	39
21-05-2022 17:16:00	18	77.3	21	16	38
21-05-2022 17:17:00	18.1	76.9	20	15	38
21-05-2022 17:18:00	18.2	76.7	21	16	37
21-05-2022 17:19:00	18.2	76.7	20	16	39
21-05-2022 17:20:00	18.1	76.8	17	15	37
21-05-2022 17:21:00	18.1	77	20	16	38
21-05-2022 17:22:00	18.1	77.1	12	15	37
21-05-2022 17:23:00	18.1	77.3	20	16	38
21-05-2022 17:24:00	18.1	77.2	20	16	38
21-05-2022 17:25:00	18.1	77.4	19	16	38
21-05-2022 17:26:00	18.1	77.6	19	16	37
21-05-2022 17:27:00	18.1	77.7	15	15	37
21-05-2022 17:28:00	18.1	78	18	16	38
21-05-2022 17:29:00	18.1	78.5	20	16	38
21-05-2022 17:30:00	18.1	78.7	20	16	37
21-05-2022 17:31:00	18.1	78.8	19	16	38
21-05-2022 17:32:00	18.1	79.3	18	16	38
21-05-2022 17:33:00	18.2	79.4	19	16	38
21-05-2022 17:34:00	18.2	79.1	19	16	38

ACTIVITY	NAME	SIGNATURE AND DATE
REVIEWED BY USER		
REVIEWED BY QA		



SOMERSET THERAPEUTICS LIMITED

DATA REPORT - SVP1 AND AMPOULE LINE EMS

WASHING AND STERILIZATION AREA

Date Time	Temperature	RH	Diffrential Pressure	Diffrential Pressure	Diffrential Pressure
DD-MM-YYYY HH:MM:SS	Washing and Sterilization Area (NMT 30°C)	Washing and Sterilization Area (NMT 80%)	Washing and Sterilization Area w.r.t Unit Preparation Room (NLT 6 Pa)	Washing and Sterilization Area w.r.t Ampoule Decartoning Room (NLT 12 Pa)	Washing and Sterilization Area w.r.t Injectable main corridor (NLT 12 Pa)
21-05-2022 17:35:00	18.2	78.8	20	16	38
21-05-2022 17:36:00	18.2	78.5	19	15	38
21-05-2022 17:37:00	18.2	78.6	15	16	38
21-05-2022 17:38:00	18.2	78.6	18	16	38
21-05-2022 17:39:00	18.2	78.5	18	16	38
21-05-2022 17:40:00	18.2	78.4	15	16	37
21-05-2022 17:41:00	18.1	78.5	15	16	38
21-05-2022 17:42:00	18.1	78.5	19	16	39
21-05-2022 17:43:00	18.1	78.6	20	16	38
21-05-2022 17:44:00	18.1	78.7	15	16	38
21-05-2022 17:45:00	18.1	79.1	20	15	38
21-05-2022 17:46:00	18.1	79.1	20	16	38
21-05-2022 17:47:00	18.2	78.9	20	16	38
21-05-2022 17:48:00	18.2	78.6	19	16	37
21-05-2022 17:49:00	18.2	78.3	19	16	38
21-05-2022 17:50:00	18.2	78.1	20	16	38
21-05-2022 17:51:00	18.1	77.9	20	16	38
21-05-2022 17:52:00	18.1	77.7	19	16	38
21-05-2022 17:53:00	18.1	77.6	20	13	34
21-05-2022 17:54:00	18.1	77.5	22	15	39
21-05-2022 17:55:00	18.1	77.5	21	15	38
21-05-2022 17:56:00	18.1	77.5	20	16	38
21-05-2022 17:57:00	18.1	77.4	21	16	35
21-05-2022 17:58:00	18.1	77.4	21	16	37

ACTIVITY	NAME	SIGNATURE AND DATE
REVIEWED BY USER		
REVIEWED BY QA		



SOMERSET THERAPEUTICS LIMITED

DATA REPORT - SVP1 AND AMPOULE LINE EMS

WASHING AND STERILIZATION AREA

Date Time	Temperature	RH	Diffrential Pressure	Diffrential Pressure	Diffrential Pressure
DD-MM-YYYY HH:MM:SS	Washing and Sterilization Area (NMT 30°C)	Washing and Sterilization Area (NMT 80%)	Washing and Sterilization Area w.r.t Unit Preparation Room (NLT 6 Pa)	Washing and Sterilization Area w.r.t Ampoule Decartoning Room (NLT 12 Pa)	Washing and Sterilization Area w.r.t Injectable main corridor (NLT 12 Pa)
21-05-2022 17:59:00	18.1	77.3	22	15	38
21-05-2022 18:00:00	18.1	77.1	22	16	39
21-05-2022 18:01:00	18.1	77.1	22	15	38
21-05-2022 18:02:00	18.1	77	22	15	39
21-05-2022 18:03:00	18.1	77	19	15	37
21-05-2022 18:04:00	18.1	77.2	18	16	38
21-05-2022 18:05:00	18.1	77.8	19	16	38
21-05-2022 18:06:00	18.1	78	20	16	38
21-05-2022 18:07:00	18.1	78.1	20	16	38
21-05-2022 18:08:00	18.1	78.2	19	16	38
21-05-2022 18:09:00	18.1	78.3	19	15	37
21-05-2022 18:10:00	18.2	78.6	20	16	37
21-05-2022 18:11:00	18.2	78.9	18	16	38
21-05-2022 18:12:00	18.2	78.8	18	16	38
21-05-2022 18:13:00	18.2	78.6	18	16	37
21-05-2022 18:14:00	18.2	78.4	18	15	38
21-05-2022 18:15:00	18.2	78.1	20	16	38
21-05-2022 18:16:00	18.2	78.1	14	15	37
21-05-2022 18:17:00	18.2	78.1	19	13	38
21-05-2022 18:18:00	18.2	78	19	16	38
21-05-2022 18:19:00	18.2	78	19	16	38
21-05-2022 18:20:00	18.2	77.9	20	16	39
21-05-2022 18:21:00	18.2	78.6	21	16	38
21-05-2022 18:22:00	18.2	79.3	20	16	37

ACTIVITY	NAME	SIGNATURE AND DATE
REVIEWED BY USER		
REVIEWED BY QA		



SOMERSET THERAPEUTICS LIMITED

DATA REPORT - SVP1 AND AMPOULE LINE EMS

WASHING AND STERILIZATION AREA

Date Time	Temperature	RH	Diffrential Pressure	Diffrential Pressure	Diffrential Pressure
DD-MM-YYYY HH:MM:SS	Washing and Sterilization Area (NMT 30°C)	Washing and Sterilization Area (NMT 80%)	Washing and Sterilization Area w.r.t Unit Preparation Room (NLT 6 Pa)	Washing and Sterilization Area w.r.t Ampoule Decartoning Room (NLT 12 Pa)	Washing and Sterilization Area w.r.t Injectable main corridor (NLT 12 Pa)
21-05-2022 18:23:00	18.2	79.6	19	15	38
21-05-2022 18:24:00	18.3	79.6	20	10	22
21-05-2022 18:25:00	18.3	79.2	18	15	37
21-05-2022 18:26:00	18.3	79	18	15	37
21-05-2022 18:27:00	18.3	78.7	20	16	39
21-05-2022 18:28:00	18.3	78.8	15	16	38
21-05-2022 18:29:00	18.3	78.9	20	15	37
21-05-2022 18:30:00	18.3	78.9	20	16	37
21-05-2022 18:31:00	18.3	79	19	16	38
21-05-2022 18:32:00	18.3	78.9	16	16	38
21-05-2022 18:33:00	18.3	78.9	15	15	38
21-05-2022 18:34:00	18.3	78.7	19	16	38
21-05-2022 18:35:00	18.3	78.5	18	16	38
21-05-2022 18:36:00	18.3	78.4	18	16	36
21-05-2022 18:37:00	18.3	78.2	18	16	37
21-05-2022 18:38:00	18.3	78.1	18	15	38
21-05-2022 18:39:00	18.3	78.1	18	16	37
21-05-2022 18:40:00	18.3	78	20	16	38
21-05-2022 18:41:00	18.3	77.9	20	16	38
21-05-2022 18:42:00	18.2	77.8	20	16	38
21-05-2022 18:43:00	18.2	77.8	19	16	38
21-05-2022 18:44:00	18.2	77.6	19	15	37
21-05-2022 18:45:00	18.2	77.4	19	15	36
21-05-2022 18:46:00	18.2	77.3	20	16	38

ACTIVITY	NAME	SIGNATURE AND DATE
REVIEWED BY USER		
REVIEWED BY QA		



SOMERSET THERAPEUTICS LIMITED

DATA REPORT - SVP1 AND AMPOULE LINE EMS

WASHING AND STERILIZATION AREA

Date Time	Temperature	RH	Diffrential Pressure	Diffrential Pressure	Diffrential Pressure
DD-MM-YYYY HH:MM:SS	Washing and Sterilization Area (NMT 30°C)	Washing and Sterilization Area (NMT 80%)	Washing and Sterilization Area w.r.t Unit Preparation Room (NLT 6 Pa)	Washing and Sterilization Area w.r.t Ampoule Decartoning Room (NLT 12 Pa)	Washing and Sterilization Area w.r.t Injectable main corridor (NLT 12 Pa)
21-05-2022 18:47:00	18.2	77.1	19	15	38
21-05-2022 18:48:00	18.2	77.1	19	15	38
21-05-2022 18:49:00	18.1	77.2	19	15	37
21-05-2022 18:50:00	18.1	77.4	19	16	38
21-05-2022 18:51:00	18.1	77.6	19	15	38
21-05-2022 18:52:00	18.1	77.7	19	16	39
21-05-2022 18:53:00	18.1	77.9	19	16	38
21-05-2022 18:54:00	18.1	77.9	19	16	38
21-05-2022 18:55:00	18.1	77.9	19	16	38
21-05-2022 18:56:00	18.1	77.8	18	16	38
21-05-2022 18:57:00	18.1	77.7	19	16	38
21-05-2022 18:58:00	18.1	77.5	19	15	38
21-05-2022 18:59:00	18.1	77.4	19	16	38
21-05-2022 19:00:00	18.1	77.2	19	16	38
21-05-2022 19:01:00	18	77.2	19	16	39
21-05-2022 19:02:00	18	77.2	18	15	38
21-05-2022 19:03:00	18	77.2	19	16	38
21-05-2022 19:04:00	18	77.4	20	16	38
21-05-2022 19:05:00	18	77.5	20	16	38
21-05-2022 19:06:00	18	77.7	20	16	38
21-05-2022 19:07:00	18	77.7	20	16	38
21-05-2022 19:08:00	18	77.7	20	15	37
21-05-2022 19:09:00	18	77.7	19	16	38
21-05-2022 19:10:00	18	77.7	19	16	39

ACTIVITY	NAME	SIGNATURE AND DATE
REVIEWED BY USER		
REVIEWED BY QA		



SOMERSET THERAPEUTICS LIMITED

DATA REPORT - SVP1 AND AMPOULE LINE EMS

WASHING AND STERILIZATION AREA

Date Time	Temperature	RH	Diffrential Pressure	Diffrential Pressure	Diffrential Pressure
DD-MM-YYYY HH:MM:SS	Washing and Sterilization Area (NMT 30°C)	Washing and Sterilization Area (NMT 80%)	Washing and Sterilization Area w.r.t Unit Preparation Room (NLT 6 Pa)	Washing and Sterilization Area w.r.t Ampoule Decartoning Room (NLT 12 Pa)	Washing and Sterilization Area w.r.t Injectable main corridor (NLT 12 Pa)
21-05-2022 19:11:00	18	77.7	19	15	38
21-05-2022 19:12:00	18	77.8	19	16	38
21-05-2022 19:13:00	18	77.8	20	16	38
21-05-2022 19:14:00	18	77.8	19	16	38
21-05-2022 19:15:00	18	77.9	19	16	39
21-05-2022 19:16:00	18	78.1	20	15	37
21-05-2022 19:17:00	18	78.1	19	15	38
21-05-2022 19:18:00	18	78	18	15	38
21-05-2022 19:19:00	18	77.9	20	16	38
21-05-2022 19:20:00	18	78.5	19	16	38
21-05-2022 19:21:00	18	78.2	18	16	35
21-05-2022 19:22:00	18.1	77.7	19	15	38
21-05-2022 19:23:00	18.1	77.5	19	15	38
21-05-2022 19:24:00	18.1	77.4	20	17	37
21-05-2022 19:25:00	18.1	77.3	19	16	37
21-05-2022 19:26:00	18.1	77.2	20	16	40
21-05-2022 19:27:00	18.1	77.2	19	15	40
21-05-2022 19:28:00	18	77.2	19	16	38
21-05-2022 19:29:00	18	77.4	19	16	38
21-05-2022 19:30:00	18	77.5	18	16	39
21-05-2022 19:31:00	18	77.5	19	16	38
21-05-2022 19:32:00	18	77.5	19	16	38
21-05-2022 19:33:00	18	77.5	20	16	39
21-05-2022 19:34:00	18	77.4	21	14	30

ACTIVITY	NAME	SIGNATURE AND DATE
REVIEWED BY USER		
REVIEWED BY QA		



SOMERSET THERAPEUTICS LIMITED

DATA REPORT - SVP1 AND AMPOULE LINE EMS

WASHING AND STERILIZATION AREA

Date Time	Temperature	RH	Diffrential Pressure	Diffrential Pressure	Diffrential Pressure
DD-MM-YYYY HH:MM:SS	Washing and Sterilization Area (NMT 30°C)	Washing and Sterilization Area (NMT 80%)	Washing and Sterilization Area w.r.t Unit Preparation Room (NLT 6 Pa)	Washing and Sterilization Area w.r.t Ampoule Decartoning Room (NLT 12 Pa)	Washing and Sterilization Area w.r.t Injectable main corridor (NLT 12 Pa)
21-05-2022 19:35:00	18	77.4	19	16	38
21-05-2022 19:36:00	18	77.4	19	16	37
21-05-2022 19:37:00	18	77.5	20	16	37
21-05-2022 19:38:00	18	77.5	20	16	38
21-05-2022 19:39:00	18	77.5	19	16	39
21-05-2022 19:40:00	18	77.5	20	16	39
21-05-2022 19:41:00	18	77.6	20	16	39
21-05-2022 19:42:00	18	77.7	19	16	38
21-05-2022 19:43:00	18	77.6	19	16	38
21-05-2022 19:44:00	18	77.6	20	16	35
21-05-2022 19:45:00	18	77.5	19	14	38
21-05-2022 19:46:00	18	77.7	19	16	37
21-05-2022 19:47:00	18	77.7	18	16	38
21-05-2022 19:48:00	18	77.4	19	16	38
21-05-2022 19:49:00	18	77.3	20	16	38
21-05-2022 19:50:00	18	77.4	19	16	39
21-05-2022 19:51:00	18	77.5	18	15	36
21-05-2022 19:52:00	18	77.6	19	16	35
21-05-2022 19:53:00	18	77.7	19	16	39
21-05-2022 19:54:00	18	77.7	19	16	38
21-05-2022 19:55:00	18	77.6	19	15	37
21-05-2022 19:56:00	18	77.6	19	16	39
21-05-2022 19:57:00	18	77.5	20	16	38
21-05-2022 19:58:00	18	77.5	19	15	38

ACTIVITY	NAME	SIGNATURE AND DATE
REVIEWED BY USER		
REVIEWED BY QA		



SOMERSET THERAPEUTICS LIMITED

DATA REPORT - SVP1 AND AMPOULE LINE EMS

WASHING AND STERILIZATION AREA

Date Time	Temperature	RH	Diffrential Pressure	Diffrential Pressure	Diffrential Pressure
DD-MM-YYYY HH:MM:SS	Washing and Sterilization Area (NMT 30°C)	Washing and Sterilization Area (NMT 80%)	Washing and Sterilization Area w.r.t Unit Preparation Room (NLT 6 Pa)	Washing and Sterilization Area w.r.t Ampoule Decartoning Room (NLT 12 Pa)	Washing and Sterilization Area w.r.t Injectable main corridor (NLT 12 Pa)
21-05-2022 19:59:00	18	77.5	19	16	38
21-05-2022 20:00:00	18	77.5	20	15	38
21-05-2022 20:01:00	18	77.4	19	16	38
21-05-2022 20:02:00	18	77.3	20	15	36
21-05-2022 20:03:00	18	77.3	19	16	38
21-05-2022 20:04:00	18	77.3	19	15	38
21-05-2022 20:05:00	18	77.2	20	16	38
21-05-2022 20:06:00	18	77.1	20	16	38
21-05-2022 20:07:00	18	77	20	16	38
21-05-2022 20:08:00	18	76.8	20	16	38
21-05-2022 20:09:00	18	76.7	11	16	37
21-05-2022 20:10:00	18	76.7	20	15	38
21-05-2022 20:11:00	18	77.4	19	16	36
21-05-2022 20:12:00	18	77.8	16	15	37
21-05-2022 20:13:00	18	78	15	16	38
21-05-2022 20:14:00	18	78.2	18	16	38
21-05-2022 20:15:00	18.1	78.4	11	15	39
21-05-2022 20:16:00	18	78.5	18	16	40
21-05-2022 20:17:00	18.1	78.4	19	16	39
21-05-2022 20:18:00	18	78.3	18	15	37
21-05-2022 20:19:00	18	78.1	19	16	39
21-05-2022 20:20:00	18.1	78	19	16	39
21-05-2022 20:21:00	18.1	77.9	19	16	39
21-05-2022 20:22:00	18.1	77.9	18	15	35

ACTIVITY	NAME	SIGNATURE AND DATE
REVIEWED BY USER		
REVIEWED BY QA		



SOMERSET THERAPEUTICS LIMITED

DATA REPORT - SVP1 AND AMPOULE LINE EMS

WASHING AND STERILIZATION AREA

Date Time	Temperature	RH	Diffrential Pressure	Diffrential Pressure	Diffrential Pressure
DD-MM-YYYY HH:MM:SS	Washing and Sterilization Area (NMT 30°C)	Washing and Sterilization Area (NMT 80%)	Washing and Sterilization Area w.r.t Unit Preparation Room (NLT 6 Pa)	Washing and Sterilization Area w.r.t Ampoule Decartoning Room (NLT 12 Pa)	Washing and Sterilization Area w.r.t Injectable main corridor (NLT 12 Pa)
21-05-2022 20:23:00	18.1	78	18	15	38
21-05-2022 20:24:00	18.1	78	19	15	39
21-05-2022 20:25:00	18.1	78.2	19	16	39
21-05-2022 20:26:00	18.1	78.4	19	16	38
21-05-2022 20:27:00	18.2	78.6	19	16	38
21-05-2022 20:28:00	18.2	78.3	19	16	38
21-05-2022 20:29:00	18.2	78.2	19	15	38
21-05-2022 20:30:00	18.2	78.2	19	16	34
21-05-2022 20:31:00	18.2	78.1	20	15	39
21-05-2022 20:32:00	18.2	78.1	18	12	35
21-05-2022 20:33:00	18.2	78.1	19	15	36
21-05-2022 20:34:00	18.2	78.1	19	16	37
21-05-2022 20:35:00	18.2	78.1	18	15	38
21-05-2022 20:36:00	18.2	78.2	18	15	38
21-05-2022 20:37:00	18.2	78.1	19	16	38
21-05-2022 20:38:00	18.2	78	19	16	39
21-05-2022 20:39:00	18.2	77.9	19	16	39
21-05-2022 20:40:00	18.2	77.8	19	16	38
21-05-2022 20:41:00	18.2	77.7	19	15	37
21-05-2022 20:42:00	18.2	77.5	19	16	37
21-05-2022 20:43:00	18.2	77.5	18	16	37
21-05-2022 20:44:00	18.2	78.2	20	16	38
21-05-2022 20:45:00	18.4	77.4	19	16	38
21-05-2022 20:46:00	18.4	77.1	15	16	37

ACTIVITY	NAME	SIGNATURE AND DATE
REVIEWED BY USER		
REVIEWED BY QA		



SOMERSET THERAPEUTICS LIMITED

DATA REPORT - SVP1 AND AMPOULE LINE EMS

WASHING AND STERILIZATION AREA

Date Time	Temperature	RH	Diffrential Pressure	Diffrential Pressure	Diffrential Pressure
DD-MM-YYYY HH:MM:SS	Washing and Sterilization Area (NMT 30°C)	Washing and Sterilization Area (NMT 80%)	Washing and Sterilization Area w.r.t Unit Preparation Room (NLT 6 Pa)	Washing and Sterilization Area w.r.t Ampoule Decartoning Room (NLT 12 Pa)	Washing and Sterilization Area w.r.t Injectable main corridor (NLT 12 Pa)
21-05-2022 20:47:00	18.4	77	15	15	38
21-05-2022 20:48:00	18.4	76.9	19	16	37
21-05-2022 20:49:00	18.3	77	18	16	34
21-05-2022 20:50:00	18.3	77.1	19	14	38
21-05-2022 20:51:00	18.3	77.2	19	16	38
21-05-2022 20:52:00	18.3	77.4	18	16	39
21-05-2022 20:53:00	18.3	77.7	19	16	38
21-05-2022 20:54:00	18.2	77.9	20	16	39
21-05-2022 20:55:00	18.2	78	19	16	39
21-05-2022 20:56:00	18.3	78.1	20	16	39
21-05-2022 20:57:00	18.2	78.3	19	16	39
21-05-2022 20:58:00	18.2	78.2	19	16	39
21-05-2022 20:59:00	18.2	78	20	16	38
21-05-2022 21:00:00	18.2	77.9	20	16	39
21-05-2022 21:01:00	18.2	77.7	19	16	38
21-05-2022 21:02:00	18.2	77.6	19	14	37
21-05-2022 21:03:00	18.2	77.6	20	15	37
21-05-2022 21:04:00	18.2	77.7	19	16	39
21-05-2022 21:05:00	18.2	77.7	19	17	42
21-05-2022 21:06:00	18.2	77.7	20	17	42
21-05-2022 21:07:00	18.2	77.6	21	17	41
21-05-2022 21:08:00	18.2	77.6	21	17	40
21-05-2022 21:09:00	18.2	77.7	20	17	41
21-05-2022 21:10:00	18.1	77.9	20	17	42

ACTIVITY	NAME	SIGNATURE AND DATE
REVIEWED BY USER		
REVIEWED BY QA		



SOMERSET THERAPEUTICS LIMITED

DATA REPORT - SVP1 AND AMPOULE LINE EMS

WASHING AND STERILIZATION AREA

Date Time	Temperature	RH	Diffrential Pressure	Diffrential Pressure	Diffrential Pressure
DD-MM-YYYY HH:MM:SS	Washing and Sterilization Area (NMT 30°C)	Washing and Sterilization Area (NMT 80%)	Washing and Sterilization Area w.r.t Unit Preparation Room (NLT 6 Pa)	Washing and Sterilization Area w.r.t Ampoule Decartoning Room (NLT 12 Pa)	Washing and Sterilization Area w.r.t Injectable main corridor (NLT 12 Pa)
21-05-2022 21:11:00	18.1	77.7	21	17	41
21-05-2022 21:12:00	18.1	77.6	19	17	42
21-05-2022 21:13:00	18.2	77.5	20	17	41
21-05-2022 21:14:00	18.2	77.6	19	17	42
21-05-2022 21:15:00	18.2	77.6	20	17	42
21-05-2022 21:16:00	18.2	77.5	21	17	42
21-05-2022 21:17:00	18.2	77.5	19	17	41
21-05-2022 21:18:00	18.2	77.4	19	17	41
21-05-2022 21:19:00	18.2	77.4	21	17	41
21-05-2022 21:20:00	18.1	77.3	20	17	42
21-05-2022 21:21:00	18.1	77.2	20	17	41
21-05-2022 21:22:00	18.1	77.1	21	17	41
21-05-2022 21:23:00	18.1	77.2	20	17	42
21-05-2022 21:24:00	18.2	77.3	19	17	41
21-05-2022 21:25:00	18.1	77.3	20	15	42
21-05-2022 21:26:00	18.1	77.3	20	17	41
21-05-2022 21:27:00	18.2	77.2	20	17	41
21-05-2022 21:28:00	18.2	77.2	20	17	42
21-05-2022 21:29:00	18.2	77.1	20	17	42
21-05-2022 21:30:00	18.2	77	20	17	42
21-05-2022 21:31:00	18.2	77	20	17	41
21-05-2022 21:32:00	18.2	77	20	17	41
21-05-2022 21:33:00	18.2	77.1	20	17	42
21-05-2022 21:34:00	18.2	77.2	20	17	42

ACTIVITY	NAME	SIGNATURE AND DATE
REVIEWED BY USER		
REVIEWED BY QA		



SOMERSET THERAPEUTICS LIMITED

DATA REPORT - SVP1 AND AMPOULE LINE EMS

WASHING AND STERILIZATION AREA

Date Time	Temperature	RH	Diffrential Pressure	Diffrential Pressure	Diffrential Pressure
DD-MM-YYYY HH:MM:SS	Washing and Sterilization Area (NMT 30°C)	Washing and Sterilization Area (NMT 80%)	Washing and Sterilization Area w.r.t Unit Preparation Room (NLT 6 Pa)	Washing and Sterilization Area w.r.t Ampoule Decartoning Room (NLT 12 Pa)	Washing and Sterilization Area w.r.t Injectable main corridor (NLT 12 Pa)
21-05-2022 21:35:00	18.2	77.3	20	17	41
21-05-2022 21:36:00	18.2	77.3	19	17	40
21-05-2022 21:37:00	18.2	77.4	20	17	41
21-05-2022 21:38:00	18.2	77.7	20	17	41
21-05-2022 21:39:00	18.2	78.1	19	17	41
21-05-2022 21:40:00	18.2	78.3	19	17	43
21-05-2022 21:41:00	18.2	78.3	19	16	42
21-05-2022 21:42:00	18.2	78.2	19	18	42
21-05-2022 21:43:00	18.2	78.2	21	17	41
21-05-2022 21:44:00	18.2	78.2	20	17	42
21-05-2022 21:45:00	18.2	78.1	20	16	41
21-05-2022 21:46:00	18.3	78	16	17	41
21-05-2022 21:47:00	18.3	77.8	19	16	40
21-05-2022 21:48:00	18.3	77.7	19	17	42
21-05-2022 21:49:00	18.3	77.5	21	17	42
21-05-2022 21:50:00	18.3	78	18	16	42
21-05-2022 21:51:00	18.3	78.2	19	17	40
21-05-2022 21:52:00	18.3	77.7	20	17	41
21-05-2022 21:53:00	18.2	77.7	20	17	40
21-05-2022 21:54:00	18.3	77.7	19	17	41
21-05-2022 21:55:00	18.3	77.7	20	17	41
21-05-2022 21:56:00	18.3	77.5	19	16	39
21-05-2022 21:57:00	18.3	77.4	19	14	35
21-05-2022 21:58:00	18.2	77.3	19	16	39

ACTIVITY	NAME	SIGNATURE AND DATE
REVIEWED BY USER		
REVIEWED BY QA		



SOMERSET THERAPEUTICS LIMITED

DATA REPORT - SVP1 AND AMPOULE LINE EMS

WASHING AND STERILIZATION AREA

Date Time	Temperature	RH	Diffrential Pressure	Diffrential Pressure	Diffrential Pressure
DD-MM-YYYY HH:MM:SS	Washing and Sterilization Area (NMT 30°C)	Washing and Sterilization Area (NMT 80%)	Washing and Sterilization Area w.r.t Unit Preparation Room (NLT 6 Pa)	Washing and Sterilization Area w.r.t Ampoule Decartoning Room (NLT 12 Pa)	Washing and Sterilization Area w.r.t Injectable main corridor (NLT 12 Pa)
21-05-2022 21:59:00	18.2	77.3	18	14	36
21-05-2022 22:00:00	18.2	77.2	19	16	38
21-05-2022 22:01:00	18.2	77.1	20	16	38
21-05-2022 22:02:00	18.2	77.1	19	16	38
21-05-2022 22:03:00	18.2	77.3	19	15	38
21-05-2022 22:04:00	18.2	77.4	19	16	38
21-05-2022 22:05:00	18.2	77.5	19	15	36
21-05-2022 22:06:00	18.2	77.5	20	16	33
21-05-2022 22:07:00	18.2	77.4	20	14	37
21-05-2022 22:08:00	18.2	77.4	21	15	36
21-05-2022 22:09:00	18.2	77.4	22	16	36
21-05-2022 22:10:00	18.2	77.4	21	16	38
21-05-2022 22:11:00	18.2	77.5	22	16	39
21-05-2022 22:12:00	18.2	77.5	20	16	38
21-05-2022 22:13:00	18.2	77.6	21	15	37
21-05-2022 22:14:00	18.2	77.7	20	15	36
21-05-2022 22:15:00	18.1	77.6	21	16	37
21-05-2022 22:16:00	18.1	77.5	20	16	38
21-05-2022 22:17:00	18.1	77.4	19	16	39
21-05-2022 22:18:00	18.1	77.3	20	15	36
21-05-2022 22:19:00	18.1	77.3	21	15	37
21-05-2022 22:20:00	18.1	77.4	21	16	38
21-05-2022 22:21:00	18.1	77.6	20	16	38
21-05-2022 22:22:00	18.1	77.7	20	15	37

ACTIVITY	NAME	SIGNATURE AND DATE
REVIEWED BY USER		
REVIEWED BY QA		



SOMERSET THERAPEUTICS LIMITED

DATA REPORT - SVP1 AND AMPOULE LINE EMS

WASHING AND STERILIZATION AREA

Date Time	Temperature	RH	Diffrential Pressure	Diffrential Pressure	Diffrential Pressure
DD-MM-YYYY HH:MM:SS	Washing and Sterilization Area (NMT 30°C)	Washing and Sterilization Area (NMT 80%)	Washing and Sterilization Area w.r.t Unit Preparation Room (NLT 6 Pa)	Washing and Sterilization Area w.r.t Ampoule Decartoning Room (NLT 12 Pa)	Washing and Sterilization Area w.r.t Injectable main corridor (NLT 12 Pa)
21-05-2022 22:23:00	18.1	77.7	20	15	36
21-05-2022 22:24:00	18.1	77.6	21	16	33
21-05-2022 22:25:00	18.1	77.5	21	15	35
21-05-2022 22:26:00	18.1	77.4	21	16	38
21-05-2022 22:27:00	18.1	77.3	20	16	37
21-05-2022 22:28:00	18	77.3	21	16	38
21-05-2022 22:29:00	18	77.4	21	15	37
21-05-2022 22:30:00	18	77.5	21	16	38
21-05-2022 22:31:00	18	77.7	21	16	38
21-05-2022 22:32:00	18	77.8	20	16	38
21-05-2022 22:33:00	18.1	77.8	21	15	38
21-05-2022 22:34:00	18.1	77.8	20	16	35
21-05-2022 22:35:00	18.1	77.7	20	16	36
21-05-2022 22:36:00	18	77.7	20	17	38
21-05-2022 22:37:00	18.1	77.6	21	17	40
21-05-2022 22:38:00	18	77.5	19	17	41
21-05-2022 22:39:00	18	77.6	16	17	41
21-05-2022 22:40:00	18	77.7	19	17	41
21-05-2022 22:41:00	18	78	18	16	40
21-05-2022 22:42:00	18	78.6	19	16	38
21-05-2022 22:43:00	18	78.8	20	16	39
21-05-2022 22:44:00	18	78.7	19	15	38
21-05-2022 22:45:00	18	78.5	20	16	38
21-05-2022 22:46:00	18	78.3	20	16	36

ACTIVITY	NAME	SIGNATURE AND DATE
REVIEWED BY USER		
REVIEWED BY QA		



SOMERSET THERAPEUTICS LIMITED

DATA REPORT - SVP1 AND AMPOULE LINE EMS

WASHING AND STERILIZATION AREA

Date Time	Temperature	RH	Diffrential Pressure	Diffrential Pressure	Diffrential Pressure
DD-MM-YYYY HH:MM:SS	Washing and Sterilization Area (NMT 30°C)	Washing and Sterilization Area (NMT 80%)	Washing and Sterilization Area w.r.t Unit Preparation Room (NLT 6 Pa)	Washing and Sterilization Area w.r.t Ampoule Decartoning Room (NLT 12 Pa)	Washing and Sterilization Area w.r.t Injectable main corridor (NLT 12 Pa)
21-05-2022 22:47:00	18	81.6	21	16	37
21-05-2022 22:48:00	18.2	79	21	16	38
21-05-2022 22:49:00	18.4	78	20	16	37
21-05-2022 22:50:00	18.5	77.2	21	15	36
21-05-2022 22:51:00	18.6	76.7	20	16	37
21-05-2022 22:52:00	18.5	76.4	20	16	38
21-05-2022 22:53:00	18.4	76.3	20	16	37
21-05-2022 22:54:00	18.3	76.3	20	16	37
21-05-2022 22:55:00	18.2	76.4	21	15	37
21-05-2022 22:56:00	18.2	76.4	21	16	37
21-05-2022 22:57:00	18.1	76.4	21	15	37
21-05-2022 22:58:00	18.1	76.5	16	16	37
21-05-2022 22:59:00	18.1	76.7	19	16	36
21-05-2022 23:00:00	18	76.8	20	16	38
21-05-2022 23:01:00	18	76.7	20	16	38
21-05-2022 23:02:00	18	76.7	19	16	37
21-05-2022 23:03:00	18	76.6	20	15	36
21-05-2022 23:04:00	18	76.5	20	16	37
21-05-2022 23:05:00	18	76.4	19	16	38
21-05-2022 23:06:00	17.9	76.6	20	15	38
21-05-2022 23:07:00	17.9	76.8	20	16	38
21-05-2022 23:08:00	17.9	77	20	16	38
21-05-2022 23:09:00	17.9	77.2	19	15	35
21-05-2022 23:10:00	17.9	77.3	19	14	37

ACTIVITY	NAME	SIGNATURE AND DATE
REVIEWED BY USER		
REVIEWED BY QA		



SOMERSET THERAPEUTICS LIMITED

DATA REPORT - SVP1 AND AMPOULE LINE EMS

WASHING AND STERILIZATION AREA

Date Time	Temperature	RH	Diffrential Pressure	Diffrential Pressure	Diffrential Pressure
DD-MM-YYYY HH:MM:SS	Washing and Sterilization Area (NMT 30°C)	Washing and Sterilization Area (NMT 80%)	Washing and Sterilization Area w.r.t Unit Preparation Room (NLT 6 Pa)	Washing and Sterilization Area w.r.t Ampoule Decartoning Room (NLT 12 Pa)	Washing and Sterilization Area w.r.t Injectable main corridor (NLT 12 Pa)
21-05-2022 23:11:00	17.9	77.4	20	16	38
21-05-2022 23:12:00	17.9	77.3	20	16	38
21-05-2022 23:13:00	17.9	77.3	19	16	38
21-05-2022 23:14:00	17.9	77.4	20	16	38
21-05-2022 23:15:00	17.9	77.4	20	16	37
21-05-2022 23:16:00	17.9	77.5	20	16	38
21-05-2022 23:17:00	17.9	77.6	20	16	38
21-05-2022 23:18:00	17.9	77.7	20	16	37
21-05-2022 23:19:00	17.9	77.8	20	16	38
21-05-2022 23:20:00	17.9	77.8	18	14	37
21-05-2022 23:21:00	17.9	77.7	20	16	44
21-05-2022 23:22:00	17.9	77.8	20	16	38
21-05-2022 23:23:00	17.9	77.7	15	16	40
21-05-2022 23:24:00	17.9	77.7	19	15	37
21-05-2022 23:25:00	17.9	77.7	20	16	37
21-05-2022 23:26:00	17.9	77.7	20	16	38
21-05-2022 23:27:00	17.9	77.7	20	16	38
21-05-2022 23:28:00	17.9	77.8	21	15	39
21-05-2022 23:29:00	17.9	78	21	16	39
21-05-2022 23:30:00	17.9	78	21	16	39
21-05-2022 23:31:00	17.9	77.9	21	16	37
21-05-2022 23:32:00	17.9	78.2	15	15	34
21-05-2022 23:33:00	17.9	78.4	18	15	39
21-05-2022 23:34:00	17.9	78.3	20	15	37

ACTIVITY	NAME	SIGNATURE AND DATE
REVIEWED BY USER		
REVIEWED BY QA		



SOMERSET THERAPEUTICS LIMITED

DATA REPORT - SVP1 AND AMPOULE LINE EMS

WASHING AND STERILIZATION AREA

Date Time	Temperature	RH	Diffrential Pressure	Diffrential Pressure	Diffrential Pressure
DD-MM-YYYY HH:MM:SS	Washing and Sterilization Area (NMT 30°C)	Washing and Sterilization Area (NMT 80%)	Washing and Sterilization Area w.r.t Unit Preparation Room (NLT 6 Pa)	Washing and Sterilization Area w.r.t Ampoule Decartoning Room (NLT 12 Pa)	Washing and Sterilization Area w.r.t Injectable main corridor (NLT 12 Pa)
21-05-2022 23:35:00	17.9	78.3	18	16	36
21-05-2022 23:36:00	17.9	78.3	19	15	38
21-05-2022 23:37:00	18	78.3	19	16	37
21-05-2022 23:38:00	18	78.4	19	15	38
21-05-2022 23:39:00	18	78.7	19	16	39
21-05-2022 23:40:00	18	78.8	19	15	38
21-05-2022 23:41:00	18	78.7	20	15	38
21-05-2022 23:42:00	18	78.5	20	16	38
21-05-2022 23:43:00	18	78.2	20	16	38
21-05-2022 23:44:00	18	78	12	16	37
21-05-2022 23:45:00	18	78	19	16	37
21-05-2022 23:46:00	18	78.1	19	16	41
21-05-2022 23:47:00	18	78.3	19	16	41
21-05-2022 23:48:00	18	78.7	19	16	38
21-05-2022 23:49:00	18	78.9	19	16	38
21-05-2022 23:50:00	18.1	79	19	16	39
21-05-2022 23:51:00	18.1	79.2	18	16	38
21-05-2022 23:52:00	18.1	79.4	19	16	38
21-05-2022 23:53:00	18.1	79.7	19	16	38
21-05-2022 23:54:00	18.1	79.8	18	16	38
21-05-2022 23:55:00	18.2	80	19	16	39
21-05-2022 23:56:00	18.2	80.4	19	16	38
21-05-2022 23:57:00	18.3	80.6	20	16	37
21-05-2022 23:58:00	18.3	80.4	19	15	37

ACTIVITY	NAME	SIGNATURE AND DATE
REVIEWED BY USER		
REVIEWED BY QA		



SOMERSET THERAPEUTICS LIMITED

DATA REPORT - SVP1 AND AMPOULE LINE EMS

WASHING AND STERILIZATION AREA

Date Time	Temperature	RH	Diffrential Pressure	Diffrential Pressure	Diffrential Pressure
DD-MM-YYYY HH:MM:SS	Washing and Sterilization Area (NMT 30°C)	Washing and Sterilization Area (NMT 80%)	Washing and Sterilization Area w.r.t Unit Preparation Room (NLT 6 Pa)	Washing and Sterilization Area w.r.t Ampoule Decartoning Room (NLT 12 Pa)	Washing and Sterilization Area w.r.t Injectable main corridor (NLT 12 Pa)
21-05-2022 23:59:00	18.3	80.1	15	15	39
22-05-2022 00:00:00	18.3	79.9	18	15	38
22-05-2022 00:01:00	18.3	79.9	19	16	37
22-05-2022 00:02:00	18.3	80.4	18	16	38
22-05-2022 00:03:00	18.3	80.8	18	15	36
22-05-2022 00:04:00	18.4	81.7	17	16	38
22-05-2022 00:05:00	18.4	82.1	19	16	38
22-05-2022 00:06:00	18.4	82.4	19	15	38
22-05-2022 00:07:00	18.4	83	18	16	38
22-05-2022 00:08:00	18.4	82.5	19	14	34
22-05-2022 00:09:00	18.4	82.7	21	16	38
22-05-2022 00:10:00	18.4	82.8	22	16	38
22-05-2022 00:11:00	18.4	82.6	21	16	39
22-05-2022 00:12:00	18.4	83.1	20	16	38
22-05-2022 00:13:00	18.4	82.8	21	16	38
22-05-2022 00:14:00	18.4	83.1	21	16	38
22-05-2022 00:15:00	18.5	83.7	21	16	37
22-05-2022 00:16:00	18.5	83.1	22	16	37
22-05-2022 00:17:00	18.5	83.1	21	16	34
22-05-2022 00:18:00	18.5	82.5	21	15	37
22-05-2022 00:19:00	18.5	82.3	21	16	38
22-05-2022 00:20:00	18.5	82.2	21	15	39
22-05-2022 00:21:00	18.5	82.7	21	16	39
22-05-2022 00:22:00	18.5	82.4	21	16	38

ACTIVITY	NAME	SIGNATURE AND DATE
REVIEWED BY USER		
REVIEWED BY QA		



SOMERSET THERAPEUTICS LIMITED

DATA REPORT - SVP1 AND AMPOULE LINE EMS

WASHING AND STERILIZATION AREA

Date Time	Temperature	RH	Diffrential Pressure	Diffrential Pressure	Diffrential Pressure
DD-MM-YYYY HH:MM:SS	Washing and Sterilization Area (NMT 30°C)	Washing and Sterilization Area (NMT 80%)	Washing and Sterilization Area w.r.t Unit Preparation Room (NLT 6 Pa)	Washing and Sterilization Area w.r.t Ampoule Decartoning Room (NLT 12 Pa)	Washing and Sterilization Area w.r.t Injectable main corridor (NLT 12 Pa)
22-05-2022 00:23:00	18.5	82	21	16	38
22-05-2022 00:24:00	18.5	82.7	20	16	38
22-05-2022 00:25:00	18.5	82.9	20	16	37
22-05-2022 00:26:00	18.5	82.5	20	16	37
22-05-2022 00:27:00	18.5	82.4	21	16	38
22-05-2022 00:28:00	18.5	82.1	21	16	39
22-05-2022 00:29:00	18.4	82	20	15	39
22-05-2022 00:30:00	18.4	82	21	16	38
22-05-2022 00:31:00	18.4	82.5	21	16	38
22-05-2022 00:32:00	18.4	82.2	20	16	38
22-05-2022 00:33:00	18.4	82.1	20	16	38
22-05-2022 00:34:00	18.4	82.3	21	16	38
22-05-2022 00:35:00	18.4	81.9	20	16	38
22-05-2022 00:36:00	18.4	82.3	21	16	38
22-05-2022 00:37:00	18.4	81.7	21	15	39
22-05-2022 00:38:00	18.4	81.9	20	15	39
22-05-2022 00:39:00	18.4	82.5	22	16	39
22-05-2022 00:40:00	18.4	82.2	20	16	38
22-05-2022 00:41:00	18.4	81.9	20	16	38
22-05-2022 00:42:00	18.4	82.2	21	16	39
22-05-2022 00:43:00	18.4	82.4	19	15	39
22-05-2022 00:44:00	18.4	82	21	16	38
22-05-2022 00:45:00	18.4	82.2	20	16	39
22-05-2022 00:46:00	18.4	82	20	16	39

ACTIVITY	NAME	SIGNATURE AND DATE
REVIEWED BY USER		
REVIEWED BY QA		



SOMERSET THERAPEUTICS LIMITED

DATA REPORT - SVP1 AND AMPOULE LINE EMS

WASHING AND STERILIZATION AREA

Date Time	Temperature	RH	Diffrential Pressure	Diffrential Pressure	Diffrential Pressure
DD-MM-YYYY HH:MM:SS	Washing and Sterilization Area (NMT 30°C)	Washing and Sterilization Area (NMT 80%)	Washing and Sterilization Area w.r.t Unit Preparation Room (NLT 6 Pa)	Washing and Sterilization Area w.r.t Ampoule Decartoning Room (NLT 12 Pa)	Washing and Sterilization Area w.r.t Injectable main corridor (NLT 12 Pa)
22-05-2022 00:47:00	18.4	81.9	21	15	38
22-05-2022 00:48:00	18.4	82	21	16	38
22-05-2022 00:49:00	18.4	81.7	21	16	39
22-05-2022 00:50:00	18.4	82	21	16	37
22-05-2022 00:51:00	18.4	82.1	20	16	38
22-05-2022 00:52:00	18.4	81	19	15	37
22-05-2022 00:53:00	18.4	79.9	19	16	38
22-05-2022 00:54:00	18.4	79.5	19	16	38
22-05-2022 00:55:00	18.4	79.3	19	16	38
22-05-2022 00:56:00	18.4	79.3	19	16	39
22-05-2022 00:57:00	18.4	79.8	20	16	39
22-05-2022 00:58:00	18.4	80	20	16	38
22-05-2022 00:59:00	18.4	80.1	18	16	39
22-05-2022 01:00:00	18.4	80	18	17	38
22-05-2022 01:01:00	18.4	79.7	19	15	39
22-05-2022 01:02:00	18.4	79.4	20	16	38
22-05-2022 01:03:00	18.4	79	19	15	37
22-05-2022 01:04:00	18.4	78.5	17	15	38
22-05-2022 01:05:00	18.3	78.2	18	15	37
22-05-2022 01:06:00	18.3	78.2	19	16	38
22-05-2022 01:07:00	18.3	78.2	19	16	38
22-05-2022 01:08:00	18.3	78.2	19	15	37
22-05-2022 01:09:00	18.3	78.4	20	16	39
22-05-2022 01:10:00	18.4	77.9	19	16	38

ACTIVITY	NAME	SIGNATURE AND DATE
REVIEWED BY USER		
REVIEWED BY QA		



SOMERSET THERAPEUTICS LIMITED

DATA REPORT - SVP1 AND AMPOULE LINE EMS

WASHING AND STERILIZATION AREA

Date Time	Temperature	RH	Diffrential Pressure	Diffrential Pressure	Diffrential Pressure
DD-MM-YYYY HH:MM:SS	Washing and Sterilization Area (NMT 30°C)	Washing and Sterilization Area (NMT 80%)	Washing and Sterilization Area w.r.t Unit Preparation Room (NLT 6 Pa)	Washing and Sterilization Area w.r.t Ampoule Decartoning Room (NLT 12 Pa)	Washing and Sterilization Area w.r.t Injectable main corridor (NLT 12 Pa)
22-05-2022 01:11:00	18.6	77.2	19	16	37
22-05-2022 01:12:00	18.6	76.7	16	16	36
22-05-2022 01:13:00	18.7	76.2	20	16	37
22-05-2022 01:14:00	18.8	75.9	19	15	37
22-05-2022 01:15:00	18.8	75.7	18	16	37
22-05-2022 01:16:00	18.8	75.7	19	16	38
22-05-2022 01:17:00	18.8	75.5	20	14	36
22-05-2022 01:18:00	18.8	75.3	19	16	38
22-05-2022 01:19:00	18.8	75	18	16	37
22-05-2022 01:20:00	18.8	74.8	20	15	37
22-05-2022 01:21:00	18.8	74.7	19	16	37
22-05-2022 01:22:00	18.7	74.8	20	16	38
22-05-2022 01:23:00	18.7	74.9	18	16	38
22-05-2022 01:24:00	18.6	75.2	20	16	38
22-05-2022 01:25:00	18.6	75.4	20	16	38
22-05-2022 01:26:00	18.6	75.6	19	16	38
22-05-2022 01:27:00	18.5	75.7	19	16	38
22-05-2022 01:28:00	18.5	75.7	20	16	38
22-05-2022 01:29:00	18.5	75.7	20	16	38
22-05-2022 01:30:00	18.5	75.7	19	16	38
22-05-2022 01:31:00	18.5	75.8	18	13	33
22-05-2022 01:32:00	18.5	76	19	15	36
22-05-2022 01:33:00	18.5	76.2	19	16	38
22-05-2022 01:34:00	18.5	76.3	19	16	38

ACTIVITY	NAME	SIGNATURE AND DATE
REVIEWED BY USER		
REVIEWED BY QA		



SOMERSET THERAPEUTICS LIMITED

DATA REPORT - SVP1 AND AMPOULE LINE EMS

WASHING AND STERILIZATION AREA

Date Time	Temperature	RH	Diffrential Pressure	Diffrential Pressure	Diffrential Pressure
DD-MM-YYYY HH:MM:SS	Washing and Sterilization Area (NMT 30°C)	Washing and Sterilization Area (NMT 80%)	Washing and Sterilization Area w.r.t Unit Preparation Room (NLT 6 Pa)	Washing and Sterilization Area w.r.t Ampoule Decartoning Room (NLT 12 Pa)	Washing and Sterilization Area w.r.t Injectable main corridor (NLT 12 Pa)
22-05-2022 01:35:00	18.5	76.3	20	16	37
22-05-2022 01:36:00	18.5	76.2	19	15	37
22-05-2022 01:37:00	18.5	76	19	16	37
22-05-2022 01:38:00	18.4	76	18	14	38
22-05-2022 01:39:00	18.4	75.9	15	15	34
22-05-2022 01:40:00	18.4	76	16	16	38
22-05-2022 01:41:00	18.4	76.3	19	14	38
22-05-2022 01:42:00	18.4	76.4	19	16	38
22-05-2022 01:43:00	18.4	76.6	19	15	38
22-05-2022 01:44:00	18.4	76.6	19	16	38
22-05-2022 01:45:00	18.4	76.5	19	16	38
22-05-2022 01:46:00	18.4	76.4	19	16	37
22-05-2022 01:47:00	18.3	76.4	18	14	36
22-05-2022 01:48:00	18.3	76.4	20	16	37
22-05-2022 01:49:00	18.2	76.5	19	15	33
22-05-2022 01:50:00	18.2	76.6	19	15	37
22-05-2022 01:51:00	18.1	76.8	19	16	38
22-05-2022 01:52:00	18.1	77	20	16	37
22-05-2022 01:53:00	18.1	77	19	16	38
22-05-2022 01:54:00	18.1	77	19	16	37
22-05-2022 01:55:00	18.1	77	19	16	37
22-05-2022 01:56:00	18	77	20	16	34
22-05-2022 01:57:00	18	77	19	15	37
22-05-2022 01:58:00	18	77.1	19	16	37

ACTIVITY	NAME	SIGNATURE AND DATE
REVIEWED BY USER		
REVIEWED BY QA		



SOMERSET THERAPEUTICS LIMITED

DATA REPORT - SVP1 AND AMPOULE LINE EMS

WASHING AND STERILIZATION AREA

Date Time	Temperature	RH	Diffrential Pressure	Diffrential Pressure	Diffrential Pressure
DD-MM-YYYY HH:MM:SS	Washing and Sterilization Area (NMT 30°C)	Washing and Sterilization Area (NMT 80%)	Washing and Sterilization Area w.r.t Unit Preparation Room (NLT 6 Pa)	Washing and Sterilization Area w.r.t Ampoule Decartoning Room (NLT 12 Pa)	Washing and Sterilization Area w.r.t Injectable main corridor (NLT 12 Pa)
22-05-2022 01:59:00	18	77.1	19	15	37
22-05-2022 02:00:00	18	77.2	19	15	37
22-05-2022 02:01:00	18	77	19	15	37
22-05-2022 02:02:00	18	76.9	20	16	37
22-05-2022 02:03:00	18	76.7	19	16	37
22-05-2022 02:04:00	18	76.7	19	15	38
22-05-2022 02:05:00	18	76.8	19	16	38
22-05-2022 02:06:00	18	77	19	16	38
22-05-2022 02:07:00	17.9	77.1	20	15	36
22-05-2022 02:08:00	17.9	77.4	19	16	37
22-05-2022 02:09:00	18	77.8	19	15	37
22-05-2022 02:10:00	18	77.6	19	16	37
22-05-2022 02:11:00	18	77.6	19	16	37
22-05-2022 02:12:00	18	77.5	19	15	37
22-05-2022 02:13:00	18	77.5	19	16	37
22-05-2022 02:14:00	18	77.5	20	16	37
22-05-2022 02:15:00	18	77.5	19	16	36
22-05-2022 02:16:00	18	77.6	18	15	37
22-05-2022 02:17:00	18	77.5	19	16	37
22-05-2022 02:18:00	18	77.3	20	15	37
22-05-2022 02:19:00	18	77.2	20	15	37
22-05-2022 02:20:00	18	76.9	19	16	37
22-05-2022 02:21:00	18	76.8	19	16	37
22-05-2022 02:22:00	18	76.7	20	16	36

ACTIVITY	NAME	SIGNATURE AND DATE
REVIEWED BY USER		
REVIEWED BY QA		



SOMERSET THERAPEUTICS LIMITED

DATA REPORT - SVP1 AND AMPOULE LINE EMS

WASHING AND STERILIZATION AREA

Date Time	Temperature	RH	Diffrential Pressure	Diffrential Pressure	Diffrential Pressure
DD-MM-YYYY HH:MM:SS	Washing and Sterilization Area (NMT 30°C)	Washing and Sterilization Area (NMT 80%)	Washing and Sterilization Area w.r.t Unit Preparation Room (NLT 6 Pa)	Washing and Sterilization Area w.r.t Ampoule Decartoning Room (NLT 12 Pa)	Washing and Sterilization Area w.r.t Injectable main corridor (NLT 12 Pa)
22-05-2022 02:23:00	18	76.7	20	16	37
22-05-2022 02:24:00	18	76.7	20	16	37
22-05-2022 02:25:00	18	76.7	19	16	37
22-05-2022 02:26:00	18	76.7	19	16	37
22-05-2022 02:27:00	18	76.5	20	15	37
22-05-2022 02:28:00	18	76.4	19	16	37
22-05-2022 02:29:00	18	76.3	20	15	36
22-05-2022 02:30:00	18	76.3	19	15	35
22-05-2022 02:31:00	18	76.3	20	16	36
22-05-2022 02:32:00	18	76.5	19	16	37
22-05-2022 02:33:00	18	76.5	19	16	37
22-05-2022 02:34:00	18	76.6	19	16	38
22-05-2022 02:35:00	18	76.5	20	16	37
22-05-2022 02:36:00	18	76.4	19	16	37
22-05-2022 02:37:00	18	76.4	20	15	37
22-05-2022 02:38:00	18	76.3	20	15	37
22-05-2022 02:39:00	18	76.4	21	16	37
22-05-2022 02:40:00	17.9	76.5	19	16	37
22-05-2022 02:41:00	18	76.6	19	15	37
22-05-2022 02:42:00	18	76.7	20	15	36
22-05-2022 02:43:00	18	76.6	20	15	37
22-05-2022 02:44:00	17.9	76.5	20	15	37
22-05-2022 02:45:00	17.9	76.4	19	16	37
22-05-2022 02:46:00	17.9	76.4	20	16	38

ACTIVITY	NAME	SIGNATURE AND DATE
REVIEWED BY USER		
REVIEWED BY QA		



SOMERSET THERAPEUTICS LIMITED

DATA REPORT - SVP1 AND AMPOULE LINE EMS

WASHING AND STERILIZATION AREA

Date Time	Temperature	RH	Diffrential Pressure	Diffrential Pressure	Diffrential Pressure
DD-MM-YYYY HH:MM:SS	Washing and Sterilization Area (NMT 30°C)	Washing and Sterilization Area (NMT 80%)	Washing and Sterilization Area w.r.t Unit Preparation Room (NLT 6 Pa)	Washing and Sterilization Area w.r.t Ampoule Decartoning Room (NLT 12 Pa)	Washing and Sterilization Area w.r.t Injectable main corridor (NLT 12 Pa)
22-05-2022 02:47:00	17.9	76.5	20	16	37
22-05-2022 02:48:00	18	76.9	20	16	37
22-05-2022 02:49:00	18	77.4	19	16	37
22-05-2022 02:50:00	18	76.9	19	15	37
22-05-2022 02:51:00	18	76.8	19	15	37
22-05-2022 02:52:00	18	76.6	19	16	37
22-05-2022 02:53:00	17.9	76.5	20	16	36
22-05-2022 02:54:00	17.9	76.4	20	16	37
22-05-2022 02:55:00	17.9	76.5	19	16	37
22-05-2022 02:56:00	17.9	76.6	20	16	36
22-05-2022 02:57:00	17.9	76.7	19	16	37
22-05-2022 02:58:00	17.9	76.7	20	15	37
22-05-2022 02:59:00	17.9	76.5	20	16	37
22-05-2022 03:00:00	17.9	76.4	20	15	37
22-05-2022 03:01:00	17.9	76.3	20	16	37
22-05-2022 03:02:00	17.9	76.2	20	16	37
22-05-2022 03:03:00	17.9	76.3	18	15	37
22-05-2022 03:04:00	17.9	76.4	20	16	37
22-05-2022 03:05:00	17.9	76.5	19	16	36
22-05-2022 03:06:00	17.9	76.5	20	16	37
22-05-2022 03:07:00	17.9	76.4	19	16	37
22-05-2022 03:08:00	17.9	76.3	19	15	37
22-05-2022 03:09:00	17.9	76.2	21	16	37
22-05-2022 03:10:00	17.9	76.1	19	16	37

ACTIVITY	NAME	SIGNATURE AND DATE
REVIEWED BY USER		
REVIEWED BY QA		



SOMERSET THERAPEUTICS LIMITED

DATA REPORT - SVP1 AND AMPOULE LINE EMS

WASHING AND STERILIZATION AREA

Date Time	Temperature	RH	Diffrential Pressure	Diffrential Pressure	Diffrential Pressure
DD-MM-YYYY HH:MM:SS	Washing and Sterilization Area (NMT 30°C)	Washing and Sterilization Area (NMT 80%)	Washing and Sterilization Area w.r.t Unit Preparation Room (NLT 6 Pa)	Washing and Sterilization Area w.r.t Ampoule Decartoning Room (NLT 12 Pa)	Washing and Sterilization Area w.r.t Injectable main corridor (NLT 12 Pa)
22-05-2022 03:11:00	17.9	76.3	19	16	37
22-05-2022 03:12:00	17.9	76.4	20	16	37
22-05-2022 03:13:00	17.8	76.6	19	16	36
22-05-2022 03:14:00	17.8	76.5	19	16	37
22-05-2022 03:15:00	17.8	76.5	20	16	37
22-05-2022 03:16:00	17.8	76.5	19	15	37
22-05-2022 03:17:00	17.8	76.4	20	15	36
22-05-2022 03:18:00	17.8	76.4	19	15	37
22-05-2022 03:19:00	17.8	76.5	20	15	37
22-05-2022 03:20:00	17.8	76.5	20	15	37
22-05-2022 03:21:00	17.8	76.6	20	15	37
22-05-2022 03:22:00	17.8	76.5	21	15	37
22-05-2022 03:23:00	17.8	76.4	20	15	36
22-05-2022 03:24:00	17.8	76.4	20	15	37
22-05-2022 03:25:00	17.8	76.3	19	16	37
22-05-2022 03:26:00	17.8	76.3	20	15	36
22-05-2022 03:27:00	17.8	76.4	19	15	37
22-05-2022 03:28:00	17.8	76.5	20	16	36
22-05-2022 03:29:00	17.8	76.6	20	15	37
22-05-2022 03:30:00	17.8	76.5	19	15	36
22-05-2022 03:31:00	17.8	76.4	19	15	37
22-05-2022 03:32:00	17.8	76.4	19	16	37
22-05-2022 03:33:00	17.8	76.3	19	15	36
22-05-2022 03:34:00	17.8	76.4	20	15	37

ACTIVITY	NAME	SIGNATURE AND DATE
REVIEWED BY USER		
REVIEWED BY QA		



SOMERSET THERAPEUTICS LIMITED

DATA REPORT - SVP1 AND AMPOULE LINE EMS

WASHING AND STERILIZATION AREA

Date Time	Temperature	RH	Diffrential Pressure	Diffrential Pressure	Diffrential Pressure
DD-MM-YYYY HH:MM:SS	Washing and Sterilization Area (NMT 30°C)	Washing and Sterilization Area (NMT 80%)	Washing and Sterilization Area w.r.t Unit Preparation Room (NLT 6 Pa)	Washing and Sterilization Area w.r.t Ampoule Decartoning Room (NLT 12 Pa)	Washing and Sterilization Area w.r.t Injectable main corridor (NLT 12 Pa)
22-05-2022 03:35:00	17.8	76.5	19	15	37
22-05-2022 03:36:00	17.8	76.5	19	15	37
22-05-2022 03:37:00	17.8	76.5	19	16	37
22-05-2022 03:38:00	17.8	76.5	20	14	36
22-05-2022 03:39:00	17.8	76.4	20	16	37
22-05-2022 03:40:00	17.8	76.3	20	16	35
22-05-2022 03:41:00	17.8	76.3	19	15	36
22-05-2022 03:42:00	17.8	76.3	20	15	37
22-05-2022 03:43:00	17.8	76.4	20	15	36
22-05-2022 03:44:00	17.8	76.5	20	15	36
22-05-2022 03:45:00	17.8	76.4	20	15	37
22-05-2022 03:46:00	17.8	76.3	19	15	36
22-05-2022 03:47:00	17.8	76.2	21	16	36
22-05-2022 03:48:00	17.8	76.2	19	15	37
22-05-2022 03:49:00	17.8	76.2	19	15	37
22-05-2022 03:50:00	17.7	76.3	18	15	36
22-05-2022 03:51:00	17.7	76.4	19	15	36
22-05-2022 03:52:00	17.7	76.4	20	15	37
22-05-2022 03:53:00	17.7	76.4	19	16	37
22-05-2022 03:54:00	17.7	76.3	19	15	36
22-05-2022 03:55:00	17.7	76.2	20	15	36
22-05-2022 03:56:00	17.7	76.2	19	15	36
22-05-2022 03:57:00	17.7	76.3	21	16	37
22-05-2022 03:58:00	17.7	76.4	19	13	32

ACTIVITY	NAME	SIGNATURE AND DATE
REVIEWED BY USER		
REVIEWED BY QA		



SOMERSET THERAPEUTICS LIMITED

DATA REPORT - SVP1 AND AMPOULE LINE EMS

WASHING AND STERILIZATION AREA

Date Time	Temperature	RH	Diffrential Pressure	Diffrential Pressure	Diffrential Pressure
DD-MM-YYYY HH:MM:SS	Washing and Sterilization Area (NMT 30°C)	Washing and Sterilization Area (NMT 80%)	Washing and Sterilization Area w.r.t Unit Preparation Room (NLT 6 Pa)	Washing and Sterilization Area w.r.t Ampoule Decartoning Room (NLT 12 Pa)	Washing and Sterilization Area w.r.t Injectable main corridor (NLT 12 Pa)
22-05-2022 03:59:00	17.7	76.5	19	16	34
22-05-2022 04:00:00	17.7	76.6	19	15	36
22-05-2022 04:01:00	17.7	76.6	20	26	49
22-05-2022 04:02:00	17.7	76.3	21	26	68
22-05-2022 04:03:00	17.7	76.4	18	15	37
22-05-2022 04:04:00	17.7	76.3	19	16	36
22-05-2022 04:05:00	17.7	76.4	18	15	36
22-05-2022 04:06:00	17.7	76.5	18	15	37
22-05-2022 04:07:00	17.7	76.7	19	14	35
22-05-2022 04:08:00	17.7	76.7	19	15	37
22-05-2022 04:09:00	17.7	76.6	19	14	34
22-05-2022 04:10:00	17.7	76.5	18	14	34
22-05-2022 04:11:00	17.7	76.4	18	14	33
22-05-2022 04:12:00	17.7	76.4	19	14	34
22-05-2022 04:13:00	17.7	76.5	19	14	34
22-05-2022 04:14:00	17.6	76.6	19	14	33
22-05-2022 04:15:00	17.6	76.8	19	14	34
22-05-2022 04:16:00	17.6	76.7	19	15	34
22-05-2022 04:17:00	17.6	76.6	18	13	33
22-05-2022 04:18:00	17.6	76.5	19	16	36
22-05-2022 04:19:00	17.6	76.4	22	41	92
22-05-2022 04:20:00	17.6	76.3	23	40	92
22-05-2022 04:21:00	17.6	76.4	18	15	36
22-05-2022 04:22:00	17.6	76.6	18	16	39

ACTIVITY	NAME	SIGNATURE AND DATE
REVIEWED BY USER		
REVIEWED BY QA		



SOMERSET THERAPEUTICS LIMITED

DATA REPORT - SVP1 AND AMPOULE LINE EMS

WASHING AND STERILIZATION AREA

Date Time	Temperature	RH	Diffrential Pressure	Diffrential Pressure	Diffrential Pressure
DD-MM-YYYY HH:MM:SS	Washing and Sterilization Area (NMT 30°C)	Washing and Sterilization Area (NMT 80%)	Washing and Sterilization Area w.r.t Unit Preparation Room (NLT 6 Pa)	Washing and Sterilization Area w.r.t Ampoule Decartoning Room (NLT 12 Pa)	Washing and Sterilization Area w.r.t Injectable main corridor (NLT 12 Pa)
22-05-2022 04:23:00	17.6	76.7	19	15	36
22-05-2022 04:24:00	17.6	76.6	19	15	34
22-05-2022 04:25:00	17.6	76.6	19	15	34
22-05-2022 04:26:00	17.6	76.5	19	15	34
22-05-2022 04:27:00	17.6	76.4	19	15	35
22-05-2022 04:28:00	17.6	76.5	18	15	34
22-05-2022 04:29:00	17.6	76.6	18	15	34
22-05-2022 04:30:00	17.6	76.7	18	15	35
22-05-2022 04:31:00	17.6	76.8	19	15	35
22-05-2022 04:32:00	17.6	76.7	19	14	34
22-05-2022 04:33:00	17.5	76.6	19	14	34
22-05-2022 04:34:00	17.5	76.6	19	14	34
22-05-2022 04:35:00	17.5	76.6	19	15	34
22-05-2022 04:36:00	17.5	76.8	19	15	34
22-05-2022 04:37:00	17.5	76.9	19	15	34
22-05-2022 04:38:00	17.5	76.9	18	15	35
22-05-2022 04:39:00	17.5	76.9	19	15	34
22-05-2022 04:40:00	17.5	76.8	19	15	34
22-05-2022 04:41:00	17.5	76.7	19	15	34
22-05-2022 04:42:00	17.5	76.7	18	15	34
22-05-2022 04:43:00	17.5	76.8	19	15	34
22-05-2022 04:44:00	17.5	76.9	18	14	34
22-05-2022 04:45:00	17.5	77	19	15	34
22-05-2022 04:46:00	17.5	76.9	19	15	34

ACTIVITY	NAME	SIGNATURE AND DATE
REVIEWED BY USER		
REVIEWED BY QA		



SOMERSET THERAPEUTICS LIMITED

DATA REPORT - SVP1 AND AMPOULE LINE EMS

WASHING AND STERILIZATION AREA

Date Time	Temperature	RH	Diffrential Pressure	Diffrential Pressure	Diffrential Pressure
DD-MM-YYYY HH:MM:SS	Washing and Sterilization Area (NMT 30°C)	Washing and Sterilization Area (NMT 80%)	Washing and Sterilization Area w.r.t Unit Preparation Room (NLT 6 Pa)	Washing and Sterilization Area w.r.t Ampoule Decartoning Room (NLT 12 Pa)	Washing and Sterilization Area w.r.t Injectable main corridor (NLT 12 Pa)
22-05-2022 04:47:00	17.5	76.8	19	15	35
22-05-2022 04:48:00	17.4	76.7	19	15	35
22-05-2022 04:49:00	17.4	76.7	20	15	35
22-05-2022 04:50:00	17.4	76.8	18	14	35
22-05-2022 04:51:00	17.4	76.9	19	15	34
22-05-2022 04:52:00	17.4	77	19	15	34
22-05-2022 04:53:00	17.4	76.9	19	15	34
22-05-2022 04:54:00	17.4	76.9	19	15	35
22-05-2022 04:55:00	17.4	76.8	19	15	34
22-05-2022 04:56:00	17.4	76.8	19	14	35
22-05-2022 04:57:00	17.4	76.8	19	15	35
22-05-2022 04:58:00	17.4	76.8	19	14	35
22-05-2022 04:59:00	17.4	77	19	14	34
22-05-2022 05:00:00	17.4	77	19	14	35
22-05-2022 05:01:00	17.4	76.8	19	15	34
22-05-2022 05:02:00	17.4	76.8	19	15	34
22-05-2022 05:03:00	17.4	76.7	18	15	35
22-05-2022 05:04:00	17.4	76.7	19	15	34
22-05-2022 05:05:00	17.4	76.8	19	15	35
22-05-2022 05:06:00	17.4	76.9	19	15	34
22-05-2022 05:07:00	17.4	77	20	15	34
22-05-2022 05:08:00	17.4	76.9	19	15	35
22-05-2022 05:09:00	17.4	76.9	19	15	34
22-05-2022 05:10:00	17.4	76.8	19	15	35

ACTIVITY	NAME	SIGNATURE AND DATE
REVIEWED BY USER		
REVIEWED BY QA		



SOMERSET THERAPEUTICS LIMITED

DATA REPORT - SVP1 AND AMPOULE LINE EMS

WASHING AND STERILIZATION AREA

Date Time	Temperature	RH	Diffrential Pressure	Diffrential Pressure	Diffrential Pressure
DD-MM-YYYY HH:MM:SS	Washing and Sterilization Area (NMT 30°C)	Washing and Sterilization Area (NMT 80%)	Washing and Sterilization Area w.r.t Unit Preparation Room (NLT 6 Pa)	Washing and Sterilization Area w.r.t Ampoule Decartoning Room (NLT 12 Pa)	Washing and Sterilization Area w.r.t Injectable main corridor (NLT 12 Pa)
22-05-2022 05:11:00	17.3	76.7	18	15	35
22-05-2022 05:12:00	17.3	76.9	19	15	34
22-05-2022 05:13:00	17.4	77	18	15	34
22-05-2022 05:14:00	17.4	77	19	15	34
22-05-2022 05:15:00	17.3	77	19	15	34
22-05-2022 05:16:00	17.3	76.9	19	15	34
22-05-2022 05:17:00	17.3	76.8	20	15	35
22-05-2022 05:18:00	17.3	76.7	20	15	34
22-05-2022 05:19:00	17.3	76.8	19	15	34
22-05-2022 05:20:00	17.3	76.9	20	15	35
22-05-2022 05:21:00	17.3	77	19	15	35
22-05-2022 05:22:00	17.3	77	19	14	31
22-05-2022 05:23:00	17.3	77	19	15	34
22-05-2022 05:24:00	17.3	76.8	19	14	33
22-05-2022 05:25:00	17.3	76.8	19	15	35
22-05-2022 05:26:00	17.3	76.8	18	15	35
22-05-2022 05:27:00	17.3	77	19	13	36
22-05-2022 05:28:00	17.3	77.1	19	13	35
22-05-2022 05:29:00	17.3	77	19	14	35
22-05-2022 05:30:00	17.3	77	20	15	36
22-05-2022 05:31:00	17.3	76.9	19	14	35
22-05-2022 05:32:00	17.3	76.9	19	15	35
22-05-2022 05:33:00	17.3	77	20	15	34
22-05-2022 05:34:00	17.3	77.1	20	15	35

ACTIVITY	NAME	SIGNATURE AND DATE
REVIEWED BY USER		
REVIEWED BY QA		



SOMERSET THERAPEUTICS LIMITED

DATA REPORT - SVP1 AND AMPOULE LINE EMS

WASHING AND STERILIZATION AREA

Date Time	Temperature	RH	Diffrential Pressure	Diffrential Pressure	Diffrential Pressure
DD-MM-YYYY HH:MM:SS	Washing and Sterilization Area (NMT 30°C)	Washing and Sterilization Area (NMT 80%)	Washing and Sterilization Area w.r.t Unit Preparation Room (NLT 6 Pa)	Washing and Sterilization Area w.r.t Ampoule Decartoning Room (NLT 12 Pa)	Washing and Sterilization Area w.r.t Injectable main corridor (NLT 12 Pa)
22-05-2022 05:35:00	17.3	77.1	20	15	35
22-05-2022 05:36:00	17.3	77.1	19	15	34
22-05-2022 05:37:00	17.3	77	19	15	34
22-05-2022 05:38:00	17.3	76.9	19	14	31
22-05-2022 05:39:00	17.3	76.9	20	15	34
22-05-2022 05:40:00	17.2	77	19	14	35
22-05-2022 05:41:00	17.2	77.1	19	15	34
22-05-2022 05:42:00	17.2	77.2	20	15	35
22-05-2022 05:43:00	17.2	77.1	20	15	35
22-05-2022 05:44:00	17.3	77	19	15	35
22-05-2022 05:45:00	17.2	76.9	19	15	34
22-05-2022 05:46:00	17.2	76.9	20	15	35
22-05-2022 05:47:00	17.2	77	20	15	35
22-05-2022 05:48:00	17.3	77	19	15	35
22-05-2022 05:49:00	17.2	77.1	20	15	34
22-05-2022 05:50:00	17.2	77	19	15	34
22-05-2022 05:51:00	17.2	76.9	19	15	35
22-05-2022 05:52:00	17.2	76.8	19	15	35
22-05-2022 05:53:00	17.2	76.8	19	15	35
22-05-2022 05:54:00	17.2	76.9	19	15	35
22-05-2022 05:55:00	17.2	77	19	15	35
22-05-2022 05:56:00	17.2	77	20	15	35
22-05-2022 05:57:00	17.2	77	20	13	28
22-05-2022 05:58:00	17.2	76.9	19	14	31

ACTIVITY	NAME	SIGNATURE AND DATE
REVIEWED BY USER		
REVIEWED BY QA		



SOMERSET THERAPEUTICS LIMITED

DATA REPORT - SVP1 AND AMPOULE LINE EMS

WASHING AND STERILIZATION AREA

Date Time	Temperature	RH	Diffrential Pressure	Diffrential Pressure	Diffrential Pressure
DD-MM-YYYY HH:MM:SS	Washing and Sterilization Area (NMT 30°C)	Washing and Sterilization Area (NMT 80%)	Washing and Sterilization Area w.r.t Unit Preparation Room (NLT 6 Pa)	Washing and Sterilization Area w.r.t Ampoule Decartoning Room (NLT 12 Pa)	Washing and Sterilization Area w.r.t Injectable main corridor (NLT 12 Pa)
22-05-2022 05:59:00	17.2	76.9	20	15	35
22-05-2022 06:00:00	17.2	77	19	15	34
22-05-2022 06:01:00	17.2	77.1	19	14	34
22-05-2022 06:02:00	17.2	77.1	19	12	32
22-05-2022 06:03:00	17.2	77.1	19	15	34
22-05-2022 06:04:00	17.2	77	19	14	33
22-05-2022 06:05:00	17.2	76.8	20	15	35
22-05-2022 06:06:00	17.2	76.8	19	15	35
22-05-2022 06:07:00	17.2	76.9	20	14	35
22-05-2022 06:08:00	17.2	77.1	19	14	35
22-05-2022 06:09:00	17.2	77.1	18	14	34
22-05-2022 06:10:00	17.2	77	19	13	31
22-05-2022 06:11:00	17.2	76.9	20	14	34
22-05-2022 06:12:00	17.2	76.8	19	14	35
22-05-2022 06:13:00	17.1	76.8	19	15	35
22-05-2022 06:14:00	17.1	76.9	20	15	36
22-05-2022 06:15:00	17.1	77	19	15	35
22-05-2022 06:16:00	17.1	77	21	15	35
22-05-2022 06:17:00	17.1	77	20	14	36
22-05-2022 06:18:00	17.1	76.9	19	15	35
22-05-2022 06:19:00	17.1	77	19	15	35
22-05-2022 06:20:00	17.1	77	20	14	35
22-05-2022 06:21:00	17.1	77.1	20	14	35
22-05-2022 06:22:00	17.1	77.1	20	15	35

ACTIVITY	NAME	SIGNATURE AND DATE
REVIEWED BY USER		
REVIEWED BY QA		



SOMERSET THERAPEUTICS LIMITED

DATA REPORT - SVP1 AND AMPOULE LINE EMS

WASHING AND STERILIZATION AREA

Date Time	Temperature	RH	Diffrential Pressure	Diffrential Pressure	Diffrential Pressure
DD-MM-YYYY HH:MM:SS	Washing and Sterilization Area (NMT 30°C)	Washing and Sterilization Area (NMT 80%)	Washing and Sterilization Area w.r.t Unit Preparation Room (NLT 6 Pa)	Washing and Sterilization Area w.r.t Ampoule Decartoning Room (NLT 12 Pa)	Washing and Sterilization Area w.r.t Injectable main corridor (NLT 12 Pa)
22-05-2022 06:23:00	17.1	77.1	20	15	35
22-05-2022 06:24:00	17.1	77	19	15	36
22-05-2022 06:25:00	17.1	77	19	15	36
22-05-2022 06:26:00	17	77.1	19	15	36
22-05-2022 06:27:00	17.1	77.2	20	14	35
22-05-2022 06:28:00	17.1	77.2	19	14	36
22-05-2022 06:29:00	17.1	77.2	19	15	36
22-05-2022 06:30:00	17.1	77.1	19	14	36
22-05-2022 06:31:00	17.1	77	19	15	36
22-05-2022 06:32:00	17.1	77	19	15	36
22-05-2022 06:33:00	17.1	77.1	19	14	36
22-05-2022 06:34:00	17.1	77.2	20	14	36
22-05-2022 06:35:00	17.1	77.1	19	15	36
22-05-2022 06:36:00	17.1	77	19	15	36
22-05-2022 06:37:00	17.1	76.9	19	15	36
22-05-2022 06:38:00	17.1	76.8	20	15	36
22-05-2022 06:39:00	17.1	76.9	20	14	36
22-05-2022 06:40:00	17.1	77	19	15	36
22-05-2022 06:41:00	17.1	77.1	20	15	36
22-05-2022 06:42:00	17.1	77	20	15	36
22-05-2022 06:43:00	17.1	77	20	14	36
22-05-2022 06:44:00	17.1	77	19	15	37
22-05-2022 06:45:00	17.1	77.1	20	14	37
22-05-2022 06:46:00	17.1	77.1	19	14	36

ACTIVITY	NAME	SIGNATURE AND DATE
REVIEWED BY USER		
REVIEWED BY QA		



SOMERSET THERAPEUTICS LIMITED

DATA REPORT - SVP1 AND AMPOULE LINE EMS

WASHING AND STERILIZATION AREA

Date Time	Temperature	RH	Diffrential Pressure	Diffrential Pressure	Diffrential Pressure
DD-MM-YYYY HH:MM:SS	Washing and Sterilization Area (NMT 30°C)	Washing and Sterilization Area (NMT 80%)	Washing and Sterilization Area w.r.t Unit Preparation Room (NLT 6 Pa)	Washing and Sterilization Area w.r.t Ampoule Decartoning Room (NLT 12 Pa)	Washing and Sterilization Area w.r.t Injectable main corridor (NLT 12 Pa)
22-05-2022 06:47:00	17.1	77	19	15	37
22-05-2022 06:48:00	17.1	76.9	19	15	37
22-05-2022 06:49:00	17.1	76.9	19	14	37
22-05-2022 06:50:00	17.1	77	20	15	36
22-05-2022 06:51:00	17.1	77	20	14	36
22-05-2022 06:52:00	17.1	77	19	15	36
22-05-2022 06:53:00	17.1	76.9	19	13	36
22-05-2022 06:54:00	17.1	76.9	20	14	36
22-05-2022 06:55:00	17.1	77	20	15	36
22-05-2022 06:56:00	17.1	77	20	15	36
22-05-2022 06:57:00	17.1	77	20	14	37
22-05-2022 06:58:00	17.1	76.8	19	15	36
22-05-2022 06:59:00	17.1	76.8	19	14	36
22-05-2022 07:00:00	17.1	76.8	20	15	37
22-05-2022 07:01:00	17.1	77	20	14	36
22-05-2022 07:02:00	17.1	77	19	14	36
22-05-2022 07:03:00	17.1	76.9	19	14	35
22-05-2022 07:04:00	17.1	76.9	20	15	36
22-05-2022 07:05:00	17.1	76.8	18	15	36
22-05-2022 07:06:00	17.1	76.7	19	15	36
22-05-2022 07:07:00	17.1	76.9	20	14	37
22-05-2022 07:08:00	17.1	77	19	14	36
22-05-2022 07:09:00	17.1	77	20	15	36
22-05-2022 07:10:00	17.1	76.9	19	15	37

ACTIVITY	NAME	SIGNATURE AND DATE
REVIEWED BY USER		
REVIEWED BY QA		



SOMERSET THERAPEUTICS LIMITED

DATA REPORT - SVP1 AND AMPOULE LINE EMS

WASHING AND STERILIZATION AREA

Date Time	Temperature	RH	Diffrential Pressure	Diffrential Pressure	Diffrential Pressure
DD-MM-YYYY HH:MM:SS	Washing and Sterilization Area (NMT 30°C)	Washing and Sterilization Area (NMT 80%)	Washing and Sterilization Area w.r.t Unit Preparation Room (NLT 6 Pa)	Washing and Sterilization Area w.r.t Ampoule Decartoning Room (NLT 12 Pa)	Washing and Sterilization Area w.r.t Injectable main corridor (NLT 12 Pa)
22-05-2022 07:11:00	17.1	76.9	20	15	36
22-05-2022 07:12:00	17.1	77	20	14	36
22-05-2022 07:13:00	17.1	77	19	15	36
22-05-2022 07:14:00	17.1	77	20	14	36
22-05-2022 07:15:00	17.1	76.9	19	14	36
22-05-2022 07:16:00	17.1	76.9	20	14	36
22-05-2022 07:17:00	17	76.9	19	14	36
22-05-2022 07:18:00	17	76.9	19	14	37
22-05-2022 07:19:00	17	77	19	15	36
22-05-2022 07:20:00	17	77.1	20	14	36
22-05-2022 07:21:00	17	77.1	20	14	36
22-05-2022 07:22:00	17	77	20	15	37
22-05-2022 07:23:00	17	76.9	20	15	36
22-05-2022 07:24:00	17	76.9	19	14	37
22-05-2022 07:25:00	17	76.8	20	14	37
22-05-2022 07:26:00	17	77	20	14	37
22-05-2022 07:27:00	17	77.1	19	14	37
22-05-2022 07:28:00	17	76.9	19	14	36
22-05-2022 07:29:00	17	76.8	19	14	37
22-05-2022 07:30:00	17	76.8	19	14	36
22-05-2022 07:31:00	17	76.7	20	14	36
22-05-2022 07:32:00	17	76.8	21	14	36
22-05-2022 07:33:00	17	76.9	20	15	37
22-05-2022 07:34:00	16.9	77	20	14	36

ACTIVITY	NAME	SIGNATURE AND DATE
REVIEWED BY USER		
REVIEWED BY QA		



SOMERSET THERAPEUTICS LIMITED

DATA REPORT - SVP1 AND AMPOULE LINE EMS

WASHING AND STERILIZATION AREA

Date Time	Temperature	RH	Diffrential Pressure	Diffrential Pressure	Diffrential Pressure
DD-MM-YYYY HH:MM:SS	Washing and Sterilization Area (NMT 30°C)	Washing and Sterilization Area (NMT 80%)	Washing and Sterilization Area w.r.t Unit Preparation Room (NLT 6 Pa)	Washing and Sterilization Area w.r.t Ampoule Decartoning Room (NLT 12 Pa)	Washing and Sterilization Area w.r.t Injectable main corridor (NLT 12 Pa)
22-05-2022 07:35:00	17	77.1	20	15	37
22-05-2022 07:36:00	16.9	77	19	15	36
22-05-2022 07:37:00	17	76.9	19	15	36
22-05-2022 07:38:00	17	76.9	20	14	36
22-05-2022 07:39:00	16.9	76.9	20	15	37
22-05-2022 07:40:00	16.9	77.1	19	14	37
22-05-2022 07:41:00	16.9	77.2	20	14	36
22-05-2022 07:42:00	17	77.2	20	15	36
22-05-2022 07:43:00	16.9	77.2	19	14	35
22-05-2022 07:44:00	17	77.2	19	14	36
22-05-2022 07:45:00	16.9	77.2	20	14	36
22-05-2022 07:46:00	17	77.2	20	15	37
22-05-2022 07:47:00	16.9	77.3	19	14	36
22-05-2022 07:48:00	17	77.4	20	17	44
22-05-2022 07:49:00	17	77.4	20	20	49
22-05-2022 07:50:00	17	77.4	19	16	41
22-05-2022 07:51:00	17	77.5	21	15	36
22-05-2022 07:52:00	17	77.5	19	15	37
22-05-2022 07:53:00	17	77.5	19	14	37
22-05-2022 07:54:00	17	77.5	20	16	37
22-05-2022 07:55:00	17	77.7	19	20	50
22-05-2022 07:56:00	17	77.7	19	20	49
22-05-2022 07:57:00	17	77.8	20	14	37
22-05-2022 07:58:00	17	77.8	20	16	39

ACTIVITY	NAME	SIGNATURE AND DATE
REVIEWED BY USER		
REVIEWED BY QA		



SOMERSET THERAPEUTICS LIMITED

DATA REPORT - SVP1 AND AMPOULE LINE EMS

WASHING AND STERILIZATION AREA

Date Time	Temperature	RH	Diffrential Pressure	Diffrential Pressure	Diffrential Pressure
DD-MM-YYYY HH:MM:SS	Washing and Sterilization Area (NMT 30°C)	Washing and Sterilization Area (NMT 80%)	Washing and Sterilization Area w.r.t Unit Preparation Room (NLT 6 Pa)	Washing and Sterilization Area w.r.t Ampoule Decartoning Room (NLT 12 Pa)	Washing and Sterilization Area w.r.t Injectable main corridor (NLT 12 Pa)
22-05-2022 07:59:00	17	77.8	19	14	37
22-05-2022 08:00:00	17	77.6	19	14	36
22-05-2022 08:01:00	17	77.6	20	14	37
22-05-2022 08:02:00	17	77.5	19	14	37
22-05-2022 08:03:00	17	77.5	20	15	37
22-05-2022 08:04:00	17	77.5	19	15	37
22-05-2022 08:05:00	17	77.6	21	14	37
22-05-2022 08:06:00	17	77.6	20	15	36
22-05-2022 08:07:00	17	77.6	20	14	37
22-05-2022 08:08:00	17	77.5	19	14	36
22-05-2022 08:09:00	17	77.4	21	15	36
22-05-2022 08:10:00	17	77.4	20	14	37
22-05-2022 08:11:00	17	77.3	19	14	37
22-05-2022 08:12:00	17	77.3	19	15	37
22-05-2022 08:13:00	17	77.4	20	15	37
22-05-2022 08:14:00	17	77.4	19	15	37
22-05-2022 08:15:00	17	77.5	19	15	37
22-05-2022 08:16:00	17	77.4	19	14	37
22-05-2022 08:17:00	17	77.3	20	14	37
22-05-2022 08:18:00	17	77.3	19	14	37
22-05-2022 08:19:00	17	77.2	20	15	37
22-05-2022 08:20:00	17	77.2	20	14	37
22-05-2022 08:21:00	16.9	77.2	19	15	37
22-05-2022 08:22:00	16.9	77.3	19	16	37

ACTIVITY	NAME	SIGNATURE AND DATE
REVIEWED BY USER		
REVIEWED BY QA		



SOMERSET THERAPEUTICS LIMITED

DATA REPORT - SVP1 AND AMPOULE LINE EMS

WASHING AND STERILIZATION AREA

Date Time	Temperature	RH	Diffrential Pressure	Diffrential Pressure	Diffrential Pressure
DD-MM-YYYY HH:MM:SS	Washing and Sterilization Area (NMT 30°C)	Washing and Sterilization Area (NMT 80%)	Washing and Sterilization Area w.r.t Unit Preparation Room (NLT 6 Pa)	Washing and Sterilization Area w.r.t Ampoule Decartoning Room (NLT 12 Pa)	Washing and Sterilization Area w.r.t Injectable main corridor (NLT 12 Pa)
22-05-2022 08:23:00	17	77.4	20	15	37
22-05-2022 08:24:00	16.9	77.5	20	14	37
22-05-2022 08:25:00	16.9	77.3	20	15	37
22-05-2022 08:26:00	16.9	77.3	20	15	37
22-05-2022 08:27:00	16.9	77.3	20	14	37
22-05-2022 08:28:00	16.9	77.2	20	15	37
22-05-2022 08:29:00	16.9	77.2	20	15	37
22-05-2022 08:30:00	16.9	77.2	20	15	36
22-05-2022 08:31:00	16.9	77.4	20	15	37
22-05-2022 08:32:00	16.9	77.5	20	15	37
22-05-2022 08:33:00	16.9	77.5	19	15	38
22-05-2022 08:34:00	16.9	77.4	20	15	37
22-05-2022 08:35:00	16.9	77.4	20	15	36
22-05-2022 08:36:00	16.9	77.4	19	15	36
22-05-2022 08:37:00	16.9	77.4	19	15	37
22-05-2022 08:38:00	16.9	77.3	20	15	34
22-05-2022 08:39:00	16.9	77.4	19	13	38
22-05-2022 08:40:00	16.9	77.5	20	14	37
22-05-2022 08:41:00	16.9	77.6	19	15	37
22-05-2022 08:42:00	16.9	77.7	19	15	37
22-05-2022 08:43:00	16.9	77.6	21	17	42
22-05-2022 08:44:00	16.9	77.5	19	17	43
22-05-2022 08:45:00	16.9	77.6	19	17	42
22-05-2022 08:46:00	16.9	77.6	18	17	43

ACTIVITY	NAME	SIGNATURE AND DATE
REVIEWED BY USER		
REVIEWED BY QA		



SOMERSET THERAPEUTICS LIMITED

DATA REPORT - SVP1 AND AMPOULE LINE EMS

WASHING AND STERILIZATION AREA

Date Time	Temperature	RH	Diffrential Pressure	Diffrential Pressure	Diffrential Pressure
DD-MM-YYYY HH:MM:SS	Washing and Sterilization Area (NMT 30°C)	Washing and Sterilization Area (NMT 80%)	Washing and Sterilization Area w.r.t Unit Preparation Room (NLT 6 Pa)	Washing and Sterilization Area w.r.t Ampoule Decartoning Room (NLT 12 Pa)	Washing and Sterilization Area w.r.t Injectable main corridor (NLT 12 Pa)
22-05-2022 08:47:00	16.9	77.6	19	14	39
22-05-2022 08:48:00	16.9	77.6	19	6	16
22-05-2022 08:49:00	16.9	77.8	20	6	15
22-05-2022 08:50:00	16.9	77.9	19	6	16
22-05-2022 08:51:00	16.9	78	19	6	16
22-05-2022 08:52:00	16.9	78.1	19	6	16
22-05-2022 08:53:00	16.9	78.1	20	6	16
22-05-2022 08:54:00	16.9	78	20	6	16
22-05-2022 08:55:00	16.9	78	20	6	16
22-05-2022 08:56:00	16.9	78.1	19	6	15
22-05-2022 08:57:00	16.9	78	19	6	16
22-05-2022 08:58:00	16.9	78	19	6	16
22-05-2022 08:59:00	16.9	78.1	20	6	15
22-05-2022 09:00:00	16.9	78.2	19	6	16
22-05-2022 09:01:00	17	78.2	19	6	15
22-05-2022 09:02:00	17	78.3	19	6	16
22-05-2022 09:03:00	17	78.2	20	6	15
22-05-2022 09:04:00	17	78.1	19	6	15
22-05-2022 09:05:00	17	78.1	19	6	16
22-05-2022 09:06:00	17	78.1	19	6	15
22-05-2022 09:07:00	17	78.1	19	6	16
22-05-2022 09:08:00	17	78.1	19	5	15
22-05-2022 09:09:00	17	78.1	19	6	15
22-05-2022 09:10:00	17	78.2	19	6	15

ACTIVITY	NAME	SIGNATURE AND DATE
REVIEWED BY USER		
REVIEWED BY QA		



SOMERSET THERAPEUTICS LIMITED

DATA REPORT - SVP1 AND AMPOULE LINE EMS

WASHING AND STERILIZATION AREA

Date Time	Temperature	RH	Diffrential Pressure	Diffrential Pressure	Diffrential Pressure
DD-MM-YYYY HH:MM:SS	Washing and Sterilization Area (NMT 30°C)	Washing and Sterilization Area (NMT 80%)	Washing and Sterilization Area w.r.t Unit Preparation Room (NLT 6 Pa)	Washing and Sterilization Area w.r.t Ampoule Decartoning Room (NLT 12 Pa)	Washing and Sterilization Area w.r.t Injectable main corridor (NLT 12 Pa)
22-05-2022 09:11:00	17	78.2	19	6	15
22-05-2022 09:12:00	17	78.2	19	6	15
22-05-2022 09:13:00	17	78.1	20	6	15
22-05-2022 09:14:00	17	78	20	6	15
22-05-2022 09:15:00	17	77.9	19	6	15
22-05-2022 09:16:00	17	77.9	18	5	16
22-05-2022 09:17:00	17	77.9	20	6	15
22-05-2022 09:18:00	17	77.8	20	6	15
22-05-2022 09:19:00	17	77.8	19	6	15
22-05-2022 09:20:00	17	77.9	20	6	15
22-05-2022 09:21:00	17	78	20	6	15
22-05-2022 09:22:00	17	77.9	20	6	15
22-05-2022 09:23:00	17	77.9	18	6	16
22-05-2022 09:24:00	17	77.7	20	6	15
22-05-2022 09:25:00	16.9	77.6	19	6	16
22-05-2022 09:26:00	16.9	77.6	19	6	15
22-05-2022 09:27:00	16.9	77.6	19	6	16
22-05-2022 09:28:00	16.9	77.5	20	6	15
22-05-2022 09:29:00	16.9	77.4	19	6	14
22-05-2022 09:30:00	16.9	77.4	18	10	26
22-05-2022 09:31:00	16.9	77.4	19	9	23
22-05-2022 09:32:00	16.9	77.5	19	10	24
22-05-2022 09:33:00	16.9	77.6	19	10	23
22-05-2022 09:34:00	16.9	77.6	20	10	24

ACTIVITY	NAME	SIGNATURE AND DATE
REVIEWED BY USER		
REVIEWED BY QA		



SOMERSET THERAPEUTICS LIMITED

DATA REPORT - SVP1 AND AMPOULE LINE EMS

WASHING AND STERILIZATION AREA

Date Time	Temperature	RH	Diffrential Pressure	Diffrential Pressure	Diffrential Pressure
DD-MM-YYYY HH:MM:SS	Washing and Sterilization Area (NMT 30°C)	Washing and Sterilization Area (NMT 80%)	Washing and Sterilization Area w.r.t Unit Preparation Room (NLT 6 Pa)	Washing and Sterilization Area w.r.t Ampoule Decartoning Room (NLT 12 Pa)	Washing and Sterilization Area w.r.t Injectable main corridor (NLT 12 Pa)
22-05-2022 09:35:00	16.9	77.5	19	9	24
22-05-2022 09:36:00	16.9	77.4	19	10	23
22-05-2022 09:37:00	16.9	77.4	20	10	23
22-05-2022 09:38:00	16.9	77.4	19	10	23
22-05-2022 09:39:00	16.9	77.3	19	10	23
22-05-2022 09:40:00	16.9	77.4	19	10	23
22-05-2022 09:41:00	16.9	77.5	20	10	24
22-05-2022 09:42:00	16.9	77.6	20	6	15
22-05-2022 09:43:00	16.9	77.7	20	6	16
22-05-2022 09:44:00	16.9	77.7	19	6	15
22-05-2022 09:45:00	16.9	77.6	20	8	17
22-05-2022 09:46:00	16.9	77.6	20	9	22
22-05-2022 09:47:00	16.9	77.6	19	13	29
22-05-2022 09:48:00	16.9	77.5	19	13	33
22-05-2022 09:49:00	16.9	77.6	19	10	24
22-05-2022 09:50:00	16.9	77.7	19	10	23
22-05-2022 09:51:00	16.9	77.8	19	10	24
22-05-2022 09:52:00	16.9	77.9	19	15	36
22-05-2022 09:53:00	16.9	78	20	15	36
22-05-2022 09:54:00	16.9	78	19	15	37
22-05-2022 09:55:00	16.9	78	18	15	37
22-05-2022 09:56:00	16.9	78	19	15	37
22-05-2022 09:57:00	16.9	78.1	19	14	37
22-05-2022 09:58:00	16.9	78.1	19	15	36

ACTIVITY	NAME	SIGNATURE AND DATE
REVIEWED BY USER		
REVIEWED BY QA		



SOMERSET THERAPEUTICS LIMITED

DATA REPORT - SVP1 AND AMPOULE LINE EMS

WASHING AND STERILIZATION AREA

Date Time	Temperature	RH	Diffrential Pressure	Diffrential Pressure	Diffrential Pressure
DD-MM-YYYY HH:MM:SS	Washing and Sterilization Area (NMT 30°C)	Washing and Sterilization Area (NMT 80%)	Washing and Sterilization Area w.r.t Unit Preparation Room (NLT 6 Pa)	Washing and Sterilization Area w.r.t Ampoule Decartoning Room (NLT 12 Pa)	Washing and Sterilization Area w.r.t Injectable main corridor (NLT 12 Pa)
22-05-2022 09:59:00	16.9	78.2	20	4	14
22-05-2022 10:00:00	16.9	78.3	20	2	4
22-05-2022 10:01:00	16.9	78.5	21	2	6
22-05-2022 10:02:00	16.9	78.6	20	3	5
22-05-2022 10:03:00	16.9	78.6	21	3	5
22-05-2022 10:04:00	16.9	78.6	20	3	5
22-05-2022 10:05:00	17	78.6	20	3	5
22-05-2022 10:06:00	17	78.6	20	2	4
22-05-2022 10:07:00	17	78.6	20	3	4
22-05-2022 10:08:00	17	78.6	20	2	5
22-05-2022 10:09:00	17	78.8	20	3	5
22-05-2022 10:10:00	17	78.9	20	2	4
22-05-2022 10:11:00	17	79	20	2	5
22-05-2022 10:12:00	17	79	20	3	5
22-05-2022 10:13:00	17	78.9	20	3	5
22-05-2022 10:14:00	17	78.9	20	2	6
22-05-2022 10:15:00	17	78.8	20	3	6
22-05-2022 10:16:00	17	78.8	19	3	5
22-05-2022 10:17:00	17	78.9	19	2	6
22-05-2022 10:18:00	17	78.9	19	3	4
22-05-2022 10:19:00	17	79.1	20	3	4
22-05-2022 10:20:00	17	79.2	19	3	6
22-05-2022 10:21:00	17	79.1	20	3	5
22-05-2022 10:22:00	17	79.1	19	2	5

ACTIVITY	NAME	SIGNATURE AND DATE
REVIEWED BY USER		
REVIEWED BY QA		



SOMERSET THERAPEUTICS LIMITED

DATA REPORT - SVP1 AND AMPOULE LINE EMS

WASHING AND STERILIZATION AREA

Date Time	Temperature	RH	Diffrential Pressure	Diffrential Pressure	Diffrential Pressure
DD-MM-YYYY HH:MM:SS	Washing and Sterilization Area (NMT 30°C)	Washing and Sterilization Area (NMT 80%)	Washing and Sterilization Area w.r.t Unit Preparation Room (NLT 6 Pa)	Washing and Sterilization Area w.r.t Ampoule Decartoning Room (NLT 12 Pa)	Washing and Sterilization Area w.r.t Injectable main corridor (NLT 12 Pa)
22-05-2022 10:23:00	17	79	20	2	5
22-05-2022 10:24:00	17	79	20	3	5
22-05-2022 10:25:00	17	78.9	21	2	5
22-05-2022 10:26:00	17	79	20	3	5
22-05-2022 10:27:00	17	79	21	2	7
22-05-2022 10:28:00	17	79.1	19	3	6
22-05-2022 10:29:00	17	79.2	19	3	5
22-05-2022 10:30:00	17	79.3	19	3	5
22-05-2022 10:31:00	17	79.2	19	3	4
22-05-2022 10:32:00	17	79.2	20	2	5
22-05-2022 10:33:00	17	79.2	19	3	4
22-05-2022 10:34:00	17	79.2	20	2	5
22-05-2022 10:35:00	17	79.2	20	3	6
22-05-2022 10:36:00	17	79.1	20	2	5
22-05-2022 10:37:00	17	79.2	20	3	4
22-05-2022 10:38:00	17	79.3	20	2	5
22-05-2022 10:39:00	17	79.4	21	3	5
22-05-2022 10:40:00	17	79.5	20	2	5
22-05-2022 10:41:00	17.1	79.4	20	2	6
22-05-2022 10:42:00	17	79.3	20	2	6
22-05-2022 10:43:00	17.1	79.3	20	3	4
22-05-2022 10:44:00	17.1	79.3	21	3	5
22-05-2022 10:45:00	17.1	79.2	19	3	5
22-05-2022 10:46:00	17.1	79.2	19	2	4

ACTIVITY	NAME	SIGNATURE AND DATE
REVIEWED BY USER		
REVIEWED BY QA		



SOMERSET THERAPEUTICS LIMITED

DATA REPORT - SVP1 AND AMPOULE LINE EMS

WASHING AND STERILIZATION AREA

Date Time	Temperature	RH	Diffrential Pressure	Diffrential Pressure	Diffrential Pressure
DD-MM-YYYY HH:MM:SS	Washing and Sterilization Area (NMT 30°C)	Washing and Sterilization Area (NMT 80%)	Washing and Sterilization Area w.r.t Unit Preparation Room (NLT 6 Pa)	Washing and Sterilization Area w.r.t Ampoule Decartoning Room (NLT 12 Pa)	Washing and Sterilization Area w.r.t Injectable main corridor (NLT 12 Pa)
22-05-2022 10:47:00	17.1	79.2	20	3	4
22-05-2022 10:48:00	17.1	79.3	19	3	4
22-05-2022 10:49:00	17.1	79.5	19	2	3
22-05-2022 10:50:00	17.1	79.5	20	2	3
22-05-2022 10:51:00	17.1	79.4	20	2	4
22-05-2022 10:52:00	17.1	79.4	19	2	4
22-05-2022 10:53:00	17.1	79.3	20	3	4
22-05-2022 10:54:00	17.1	79.3	20	3	6
22-05-2022 10:55:00	17.1	79.3	20	3	5
22-05-2022 10:56:00	17.1	79.3	20	2	4
22-05-2022 10:57:00	17.1	79.3	19	2	4
22-05-2022 10:58:00	17.1	79.3	20	2	4
22-05-2022 10:59:00	17.1	79.2	20	3	5
22-05-2022 11:00:00	17.1	79.2	20	2	6
22-05-2022 11:01:00	17.1	79.2	20	3	5
22-05-2022 11:02:00	17.1	79.3	20	2	7
22-05-2022 11:03:00	17.1	79.4	20	3	5
22-05-2022 11:04:00	17.1	79.4	20	3	6
22-05-2022 11:05:00	17.1	79.3	20	3	6
22-05-2022 11:06:00	17.1	79.3	21	2	6
22-05-2022 11:07:00	17.1	79.2	20	3	4
22-05-2022 11:08:00	17.1	79.3	20	3	4
22-05-2022 11:09:00	17.1	79.3	20	2	6
22-05-2022 11:10:00	17	79.2	21	3	7

ACTIVITY	NAME	SIGNATURE AND DATE
REVIEWED BY USER		
REVIEWED BY QA		



SOMERSET THERAPEUTICS LIMITED

DATA REPORT - SVP1 AND AMPOULE LINE EMS

WASHING AND STERILIZATION AREA

Date Time	Temperature	RH	Diffrential Pressure	Diffrential Pressure	Diffrential Pressure
DD-MM-YYYY HH:MM:SS	Washing and Sterilization Area (NMT 30°C)	Washing and Sterilization Area (NMT 80%)	Washing and Sterilization Area w.r.t Unit Preparation Room (NLT 6 Pa)	Washing and Sterilization Area w.r.t Ampoule Decartoning Room (NLT 12 Pa)	Washing and Sterilization Area w.r.t Injectable main corridor (NLT 12 Pa)
22-05-2022 11:11:00	17	79.2	19	2	5
22-05-2022 11:12:00	17	79.2	20	2	5
22-05-2022 11:13:00	17	79.2	20	3	6
22-05-2022 11:14:00	17	79.2	19	3	4
22-05-2022 11:15:00	17	79.2	20	2	5
22-05-2022 11:16:00	17	79.2	20	2	5
22-05-2022 11:17:00	17	79.3	20	2	5
22-05-2022 11:18:00	17	79.5	19	2	4
22-05-2022 11:19:00	17	79.5	20	2	4
22-05-2022 11:20:00	17	79.4	19	2	3
22-05-2022 11:21:00	17	79.3	20	2	5
22-05-2022 11:22:00	17.1	79.3	20	2	5
22-05-2022 11:23:00	17.1	79.3	21	2	5
22-05-2022 11:24:00	17.1	79.2	19	3	5
22-05-2022 11:25:00	17.1	79.2	21	3	4
22-05-2022 11:26:00	17.1	79.3	20	3	5
22-05-2022 11:27:00	17	79.2	19	3	5
22-05-2022 11:28:00	17.1	79.3	20	3	6
22-05-2022 11:29:00	17	79.3	19	3	6
22-05-2022 11:30:00	17	79.3	20	3	5
22-05-2022 11:31:00	17	79.3	20	3	5
22-05-2022 11:32:00	17	79.3	20	2	5
22-05-2022 11:33:00	17	79.4	20	3	4
22-05-2022 11:34:00	17	79.4	21	3	5

ACTIVITY	NAME	SIGNATURE AND DATE
REVIEWED BY USER		
REVIEWED BY QA		



SOMERSET THERAPEUTICS LIMITED

DATA REPORT - SVP1 AND AMPOULE LINE EMS

WASHING AND STERILIZATION AREA

Date Time	Temperature	RH	Diffrential Pressure	Diffrential Pressure	Diffrential Pressure
DD-MM-YYYY HH:MM:SS	Washing and Sterilization Area (NMT 30°C)	Washing and Sterilization Area (NMT 80%)	Washing and Sterilization Area w.r.t Unit Preparation Room (NLT 6 Pa)	Washing and Sterilization Area w.r.t Ampoule Decartoning Room (NLT 12 Pa)	Washing and Sterilization Area w.r.t Injectable main corridor (NLT 12 Pa)
22-05-2022 11:35:00	17	79.5	20	2	4
22-05-2022 11:36:00	17	79.5	20	2	6
22-05-2022 11:37:00	17	79.6	20	3	5
22-05-2022 11:38:00	17	79.7	19	3	6
22-05-2022 11:39:00	17.1	79.8	20	2	5
22-05-2022 11:40:00	17.1	79.9	20	2	5
22-05-2022 11:41:00	17.1	80.1	20	3	6
22-05-2022 11:42:00	17.1	80.1	20	3	4
22-05-2022 11:43:00	17.1	80	20	3	5
22-05-2022 11:44:00	17.1	79.9	19	3	4
22-05-2022 11:45:00	17.1	79.9	19	2	4
22-05-2022 11:46:00	17.1	79.8	21	3	4
22-05-2022 11:47:00	17.1	79.8	20	3	5
22-05-2022 11:48:00	17.1	79.7	21	3	4
22-05-2022 11:49:00	17.1	79.6	20	2	5
22-05-2022 11:50:00	17.1	79.6	20	2	5
22-05-2022 11:51:00	17.1	79.5	20	3	6
22-05-2022 11:52:00	17.1	79.5	20	2	5
22-05-2022 11:53:00	17.1	79.4	20	3	5
22-05-2022 11:54:00	17.1	79.4	20	3	4
22-05-2022 11:55:00	17.1	79.4	20	2	4
22-05-2022 11:56:00	17.1	79.3	19	3	5
22-05-2022 11:57:00	17.1	79.3	20	2	4
22-05-2022 11:58:00	17.1	79.3	20	2	4

ACTIVITY	NAME	SIGNATURE AND DATE
REVIEWED BY USER		
REVIEWED BY QA		



SOMERSET THERAPEUTICS LIMITED

DATA REPORT - SVP1 AND AMPOULE LINE EMS

WASHING AND STERILIZATION AREA

Date Time	Temperature	RH	Diffrential Pressure	Diffrential Pressure	Diffrential Pressure
DD-MM-YYYY HH:MM:SS	Washing and Sterilization Area (NMT 30°C)	Washing and Sterilization Area (NMT 80%)	Washing and Sterilization Area w.r.t Unit Preparation Room (NLT 6 Pa)	Washing and Sterilization Area w.r.t Ampoule Decartoning Room (NLT 12 Pa)	Washing and Sterilization Area w.r.t Injectable main corridor (NLT 12 Pa)
22-05-2022 11:59:00	17.1	79.2	20	3	5
22-05-2022 12:00:00	17.1	79.1	20	3	3
22-05-2022 12:01:00	17.1	79.2	20	2	3
22-05-2022 12:02:00	17	79.2	20	3	5
22-05-2022 12:03:00	17	79.1	20	3	5
22-05-2022 12:04:00	17	79.1	20	3	4
22-05-2022 12:05:00	17	79.2	20	3	4
22-05-2022 12:06:00	17	79.2	19	3	5
22-05-2022 12:07:00	17	79.2	19	2	6
22-05-2022 12:08:00	17	79.2	19	3	6
22-05-2022 12:09:00	17	79.2	19	2	6
22-05-2022 12:10:00	17	79.2	19	2	7
22-05-2022 12:11:00	17	79.2	20	3	6
22-05-2022 12:12:00	17	79.3	19	3	5
22-05-2022 12:13:00	17	79.3	20	3	5
22-05-2022 12:14:00	17	79.3	20	2	6
22-05-2022 12:15:00	17	79.3	19	2	5
22-05-2022 12:16:00	17	79.4	20	3	6
22-05-2022 12:17:00	17	79.4	19	3	6
22-05-2022 12:18:00	17	79.6	19	3	5
22-05-2022 12:19:00	17	79.7	20	3	7
22-05-2022 12:20:00	17	79.9	20	3	7
22-05-2022 12:21:00	17	79.8	20	3	6
22-05-2022 12:22:00	17	79.8	19	3	7

ACTIVITY	NAME	SIGNATURE AND DATE
REVIEWED BY USER		
REVIEWED BY QA		



SOMERSET THERAPEUTICS LIMITED

DATA REPORT - SVP1 AND AMPOULE LINE EMS

WASHING AND STERILIZATION AREA

Date Time	Temperature	RH	Diffrential Pressure	Diffrential Pressure	Diffrential Pressure
DD-MM-YYYY HH:MM:SS	Washing and Sterilization Area (NMT 30°C)	Washing and Sterilization Area (NMT 80%)	Washing and Sterilization Area w.r.t Unit Preparation Room (NLT 6 Pa)	Washing and Sterilization Area w.r.t Ampoule Decartoning Room (NLT 12 Pa)	Washing and Sterilization Area w.r.t Injectable main corridor (NLT 12 Pa)
22-05-2022 12:23:00	17	79.7	19	3	7
22-05-2022 12:24:00	17	79.7	20	3	7
22-05-2022 12:25:00	17	79.7	20	3	5
22-05-2022 12:26:00	17.1	79.6	19	3	6
22-05-2022 12:27:00	17.1	79.6	19	3	7
22-05-2022 12:28:00	17	79.6	20	2	6
22-05-2022 12:29:00	17.1	79.6	19	2	6
22-05-2022 12:30:00	17	79.5	19	3	6
22-05-2022 12:31:00	17	79.5	19	3	5
22-05-2022 12:32:00	17	79.5	19	3	5
22-05-2022 12:33:00	17	79.5	19	2	5
22-05-2022 12:34:00	17	79.5	19	3	5
22-05-2022 12:35:00	17	79.5	20	2	5
22-05-2022 12:36:00	17	79.5	20	2	5
22-05-2022 12:37:00	17	79.5	19	2	4
22-05-2022 12:38:00	17	79.5	18	3	5
22-05-2022 12:39:00	17	79.5	20	3	7
22-05-2022 12:40:00	17	79.5	20	2	5
22-05-2022 12:41:00	17	79.5	20	2	6
22-05-2022 12:42:00	17	79.5	19	3	6
22-05-2022 12:43:00	17	79.5	20	3	6
22-05-2022 12:44:00	17	79.4	21	3	6
22-05-2022 12:45:00	17	79.5	21	3	7
22-05-2022 12:46:00	17	79.5	20	3	7

ACTIVITY	NAME	SIGNATURE AND DATE
REVIEWED BY USER		
REVIEWED BY QA		



SOMERSET THERAPEUTICS LIMITED

DATA REPORT - SVP1 AND AMPOULE LINE EMS

WASHING AND STERILIZATION AREA

Date Time	Temperature	RH	Diffrential Pressure	Diffrential Pressure	Diffrential Pressure
DD-MM-YYYY HH:MM:SS	Washing and Sterilization Area (NMT 30°C)	Washing and Sterilization Area (NMT 80%)	Washing and Sterilization Area w.r.t Unit Preparation Room (NLT 6 Pa)	Washing and Sterilization Area w.r.t Ampoule Decartoning Room (NLT 12 Pa)	Washing and Sterilization Area w.r.t Injectable main corridor (NLT 12 Pa)
22-05-2022 12:47:00	17	79.5	19	3	5
22-05-2022 12:48:00	17	79.5	20	2	5
22-05-2022 12:49:00	17	79.6	20	3	6
22-05-2022 12:50:00	17	79.5	20	3	6
22-05-2022 12:51:00	17	79.4	19	3	6
22-05-2022 12:52:00	17	79.5	19	4	7
22-05-2022 12:53:00	17	79.5	20	3	6
22-05-2022 12:54:00	17	79.5	19	3	6
22-05-2022 12:55:00	17	79.5	20	3	7
22-05-2022 12:56:00	17	79.5	20	3	5
22-05-2022 12:57:00	17	79.6	20	3	4
22-05-2022 12:58:00	17	79.6	19	2	5
22-05-2022 12:59:00	17	79.6	20	3	6
22-05-2022 13:00:00	17	79.6	20	3	5
22-05-2022 13:01:00	17	79.6	19	3	5
22-05-2022 13:02:00	17	79.6	20	3	5
22-05-2022 13:03:00	17	79.6	20	3	7
22-05-2022 13:04:00	17	79.6	21	3	6
22-05-2022 13:05:00	17	79.5	20	3	6
22-05-2022 13:06:00	17	79.5	19	3	7
22-05-2022 13:07:00	17	79.5	20	3	6
22-05-2022 13:08:00	17	79.6	20	2	6
22-05-2022 13:09:00	17	79.6	20	3	6
22-05-2022 13:10:00	17	79.6	19	2	6

ACTIVITY	NAME	SIGNATURE AND DATE
REVIEWED BY USER		
REVIEWED BY QA		



SOMERSET THERAPEUTICS LIMITED

DATA REPORT - SVP1 AND AMPOULE LINE EMS

WASHING AND STERILIZATION AREA

Date Time	Temperature	RH	Diffrential Pressure	Diffrential Pressure	Diffrential Pressure
DD-MM-YYYY HH:MM:SS	Washing and Sterilization Area (NMT 30°C)	Washing and Sterilization Area (NMT 80%)	Washing and Sterilization Area w.r.t Unit Preparation Room (NLT 6 Pa)	Washing and Sterilization Area w.r.t Ampoule Decartoning Room (NLT 12 Pa)	Washing and Sterilization Area w.r.t Injectable main corridor (NLT 12 Pa)
22-05-2022 13:11:00	17	79.6	19	3	5
22-05-2022 13:12:00	17	79.5	19	2	6
22-05-2022 13:13:00	17	79.6	19	4	7
22-05-2022 13:14:00	17	79.6	19	3	7
22-05-2022 13:15:00	17	79.6	19	2	5
22-05-2022 13:16:00	17	79.5	20	2	6
22-05-2022 13:17:00	17	79.5	20	2	6
22-05-2022 13:18:00	17	79.5	19	2	5
22-05-2022 13:19:00	17	79.5	20	2	6
22-05-2022 13:20:00	17	79.5	20	2	7
22-05-2022 13:21:00	17	79.5	19	3	6
22-05-2022 13:22:00	17	79.5	20	2	5
22-05-2022 13:23:00	17	79.5	19	2	7
22-05-2022 13:24:00	17	79.5	19	3	7
22-05-2022 13:25:00	17	79.6	20	3	7
22-05-2022 13:26:00	17	79.6	20	3	7
22-05-2022 13:27:00	17	79.6	20	4	8
22-05-2022 13:28:00	17	79.6	20	4	7
22-05-2022 13:29:00	17	79.6	20	4	7
22-05-2022 13:30:00	17	79.6	20	2	6
22-05-2022 13:31:00	17	79.6	21	3	6
22-05-2022 13:32:00	17	79.6	20	3	7
22-05-2022 13:33:00	17	79.6	21	3	6
22-05-2022 13:34:00	17	79.5	19	3	6

ACTIVITY	NAME	SIGNATURE AND DATE
REVIEWED BY USER		
REVIEWED BY QA		



SOMERSET THERAPEUTICS LIMITED

DATA REPORT - SVP1 AND AMPOULE LINE EMS

WASHING AND STERILIZATION AREA

Date Time	Temperature	RH	Diffrential Pressure	Diffrential Pressure	Diffrential Pressure
DD-MM-YYYY HH:MM:SS	Washing and Sterilization Area (NMT 30°C)	Washing and Sterilization Area (NMT 80%)	Washing and Sterilization Area w.r.t Unit Preparation Room (NLT 6 Pa)	Washing and Sterilization Area w.r.t Ampoule Decartoning Room (NLT 12 Pa)	Washing and Sterilization Area w.r.t Injectable main corridor (NLT 12 Pa)
22-05-2022 13:35:00	17	79.5	19	3	5
22-05-2022 13:36:00	17	79.5	19	2	5
22-05-2022 13:37:00	17	79.5	20	2	6
22-05-2022 13:38:00	17	79.5	19	3	6
22-05-2022 13:39:00	17	79.4	20	2	5
22-05-2022 13:40:00	17	79.4	20	3	5
22-05-2022 13:41:00	17	79.4	20	3	6
22-05-2022 13:42:00	17	79.4	20	2	6
22-05-2022 13:43:00	17	79.3	19	3	5
22-05-2022 13:44:00	17	79.3	19	2	6
22-05-2022 13:45:00	17	79.3	20	2	5
22-05-2022 13:46:00	16.9	79.4	19	3	7
22-05-2022 13:47:00	16.9	79.4	19	3	7
22-05-2022 13:48:00	16.9	79.4	20	2	6
22-05-2022 13:49:00	16.9	79.4	20	3	7
22-05-2022 13:50:00	16.9	79.5	20	2	6
22-05-2022 13:51:00	16.9	79.5	19	3	7
22-05-2022 13:52:00	16.9	79.5	19	3	5
22-05-2022 13:53:00	16.9	79.5	20	2	5
22-05-2022 13:54:00	16.9	79.4	20	2	6
22-05-2022 13:55:00	16.9	79.3	19	3	7
22-05-2022 13:56:00	16.9	79.4	19	3	7
22-05-2022 13:57:00	17	79.4	20	2	6
22-05-2022 13:58:00	16.9	79.4	19	2	6

ACTIVITY	NAME	SIGNATURE AND DATE
REVIEWED BY USER		
REVIEWED BY QA		



SOMERSET THERAPEUTICS LIMITED

DATA REPORT - SVP1 AND AMPOULE LINE EMS

WASHING AND STERILIZATION AREA

Date Time	Temperature	RH	Diffrential Pressure	Diffrential Pressure	Diffrential Pressure
DD-MM-YYYY HH:MM:SS	Washing and Sterilization Area (NMT 30°C)	Washing and Sterilization Area (NMT 80%)	Washing and Sterilization Area w.r.t Unit Preparation Room (NLT 6 Pa)	Washing and Sterilization Area w.r.t Ampoule Decartoning Room (NLT 12 Pa)	Washing and Sterilization Area w.r.t Injectable main corridor (NLT 12 Pa)
22-05-2022 13:59:00	16.9	79.5	20	2	6
22-05-2022 14:00:00	16.9	79.5	20	3	7
22-05-2022 14:01:00	16.9	79.5	20	3	7
22-05-2022 14:02:00	16.9	79.5	20	3	6
22-05-2022 14:03:00	16.9	79.5	20	3	7
22-05-2022 14:04:00	16.9	79.6	20	3	7
22-05-2022 14:05:00	16.9	79.6	20	2	5
22-05-2022 14:06:00	16.9	79.6	20	2	6
22-05-2022 14:07:00	16.9	79.6	20	3	8
22-05-2022 14:08:00	17	79.6	19	10	21
22-05-2022 14:09:00	17	79.5	19	15	38
22-05-2022 14:10:00	17	79.5	19	15	37
22-05-2022 14:11:00	17	79.5	21	15	38
22-05-2022 14:12:00	17	79.5	19	14	37
22-05-2022 14:13:00	17	79.4	18	15	37
22-05-2022 14:14:00	17	79.4	18	15	37
22-05-2022 14:15:00	17	79.3	19	16	38
22-05-2022 14:16:00	17	79.3	19	16	37
22-05-2022 14:17:00	17	79.3	18	14	37
22-05-2022 14:18:00	17	79.2	19	15	33
22-05-2022 14:19:00	17	79.1	20	14	37
22-05-2022 14:20:00	17	79	20	14	38
22-05-2022 14:21:00	17	79	21	15	37
22-05-2022 14:22:00	17	78.9	20	15	36

ACTIVITY	NAME	SIGNATURE AND DATE
REVIEWED BY USER		
REVIEWED BY QA		



SOMERSET THERAPEUTICS LIMITED

DATA REPORT - SVP1 AND AMPOULE LINE EMS

WASHING AND STERILIZATION AREA

Date Time	Temperature	RH	Diffrential Pressure	Diffrential Pressure	Diffrential Pressure
DD-MM-YYYY HH:MM:SS	Washing and Sterilization Area (NMT 30°C)	Washing and Sterilization Area (NMT 80%)	Washing and Sterilization Area w.r.t Unit Preparation Room (NLT 6 Pa)	Washing and Sterilization Area w.r.t Ampoule Decartoning Room (NLT 12 Pa)	Washing and Sterilization Area w.r.t Injectable main corridor (NLT 12 Pa)
22-05-2022 14:23:00	17	78.9	21	15	36
22-05-2022 14:24:00	17	78.9	21	14	37
22-05-2022 14:25:00	17	79	20	14	34
22-05-2022 14:26:00	17	79	20	12	31
22-05-2022 14:27:00	17	79	21	14	36
22-05-2022 14:28:00	17	79.1	21	15	33
22-05-2022 14:29:00	17	79.1	20	13	33
22-05-2022 14:30:00	17	79.1	20	13	36
22-05-2022 14:31:00	17	79	21	14	37
22-05-2022 14:32:00	17	79	20	15	36
22-05-2022 14:33:00	17	79.1	22	14	36
22-05-2022 14:34:00	17	79	21	15	36
22-05-2022 14:35:00	17	79	22	15	36
22-05-2022 14:36:00	17	79	21	15	36
22-05-2022 14:37:00	17	79	21	15	35
22-05-2022 14:38:00	17	79	21	13	34
22-05-2022 14:39:00	17	79	21	12	33
22-05-2022 14:40:00	17	78.9	20	15	36
22-05-2022 14:41:00	17	78.9	20	15	35
22-05-2022 14:42:00	17	78.9	16	14	32
22-05-2022 14:43:00	17	79.1	21	15	35
22-05-2022 14:44:00	17	79.5	20	12	25
22-05-2022 14:45:00	17	79.6	20	15	35
22-05-2022 14:46:00	17	79.8	21	15	33

ACTIVITY	NAME	SIGNATURE AND DATE
REVIEWED BY USER		
REVIEWED BY QA		



SOMERSET THERAPEUTICS LIMITED

DATA REPORT - SVP1 AND AMPOULE LINE EMS

WASHING AND STERILIZATION AREA

Date Time	Temperature	RH	Diffrential Pressure	Diffrential Pressure	Diffrential Pressure
DD-MM-YYYY HH:MM:SS	Washing and Sterilization Area (NMT 30°C)	Washing and Sterilization Area (NMT 80%)	Washing and Sterilization Area w.r.t Unit Preparation Room (NLT 6 Pa)	Washing and Sterilization Area w.r.t Ampoule Decartoning Room (NLT 12 Pa)	Washing and Sterilization Area w.r.t Injectable main corridor (NLT 12 Pa)
22-05-2022 14:47:00	17	80	20	15	36
22-05-2022 14:48:00	17	80.2	20	15	36
22-05-2022 14:49:00	17.1	80.7	21	14	36
22-05-2022 14:50:00	17.1	80.8	21	15	36
22-05-2022 14:51:00	17.1	80.6	21	14	36
22-05-2022 14:52:00	17.1	80.5	21	15	36
22-05-2022 14:53:00	17.1	80.4	20	15	37
22-05-2022 14:54:00	17.1	80.3	17	14	32
22-05-2022 14:55:00	17.1	80.4	20	14	33
22-05-2022 14:56:00	17.1	80.2	22	14	35
22-05-2022 14:57:00	17.2	80.1	20	15	36
22-05-2022 14:58:00	17.2	79.8	21	15	37
22-05-2022 14:59:00	17.2	81.1	22	15	36
22-05-2022 15:00:00	17.2	87	20	15	35
22-05-2022 15:01:00	17.3	86.2	21	15	34
22-05-2022 15:02:00	17.3	84.1	21	15	35
22-05-2022 15:03:00	17.4	82.8	21	15	36
22-05-2022 15:04:00	17.4	82.1	21	15	36
22-05-2022 15:05:00	17.4	81.5	21	14	35
22-05-2022 15:06:00	17.4	81	21	15	36
22-05-2022 15:07:00	17.3	80.3	21	12	30
22-05-2022 15:08:00	17.3	80	21	14	36
22-05-2022 15:09:00	17.3	79.6	20	14	34
22-05-2022 15:10:00	17.2	79.6	20	15	32

ACTIVITY	NAME	SIGNATURE AND DATE
REVIEWED BY USER		
REVIEWED BY QA		



SOMERSET THERAPEUTICS LIMITED

DATA REPORT - SVP1 AND AMPOULE LINE EMS

WASHING AND STERILIZATION AREA

Date Time	Temperature	RH	Diffrential Pressure	Diffrential Pressure	Diffrential Pressure
DD-MM-YYYY HH:MM:SS	Washing and Sterilization Area (NMT 30°C)	Washing and Sterilization Area (NMT 80%)	Washing and Sterilization Area w.r.t Unit Preparation Room (NLT 6 Pa)	Washing and Sterilization Area w.r.t Ampoule Decartoning Room (NLT 12 Pa)	Washing and Sterilization Area w.r.t Injectable main corridor (NLT 12 Pa)
22-05-2022 15:11:00	17.2	79.5	21	14	33
22-05-2022 15:12:00	17.2	79.3	21	15	37
22-05-2022 15:13:00	17.1	79.3	21	12	32
22-05-2022 15:14:00	17.1	79.3	21	15	32
22-05-2022 15:15:00	17.1	79.3	21	13	37
22-05-2022 15:16:00	17.1	79.3	22	15	36
22-05-2022 15:17:00	17.1	79.2	21	15	37
22-05-2022 15:18:00	17.1	79.2	21	15	32
22-05-2022 15:19:00	17.1	79.3	14	14	36
22-05-2022 15:20:00	17	79.2	20	12	25
22-05-2022 15:21:00	17	79.4	20	15	37
22-05-2022 15:22:00	17.1	80.4	19	15	31
22-05-2022 15:23:00	17.1	80.9	20	15	36
22-05-2022 15:24:00	17.1	81.3	20	14	32
22-05-2022 15:25:00	17.2	81.5	20	15	36
22-05-2022 15:26:00	17.2	81.2	19	15	36
22-05-2022 15:27:00	17.2	80.9	20	15	37
22-05-2022 15:28:00	17.2	80.6	20	15	36
22-05-2022 15:29:00	17.2	80.3	20	15	35
22-05-2022 15:30:00	17.1	80	20	15	36
22-05-2022 15:31:00	17.1	79.8	20	12	32
22-05-2022 15:32:00	17.1	79.6	21	14	32
22-05-2022 15:33:00	17.1	79.5	20	14	36
22-05-2022 15:34:00	17.1	80	18	13	31

ACTIVITY	NAME	SIGNATURE AND DATE
REVIEWED BY USER		
REVIEWED BY QA		



SOMERSET THERAPEUTICS LIMITED

DATA REPORT - SVP1 AND AMPOULE LINE EMS

WASHING AND STERILIZATION AREA

Date Time	Temperature	RH	Diffrential Pressure	Diffrential Pressure	Diffrential Pressure
DD-MM-YYYY HH:MM:SS	Washing and Sterilization Area (NMT 30°C)	Washing and Sterilization Area (NMT 80%)	Washing and Sterilization Area w.r.t Unit Preparation Room (NLT 6 Pa)	Washing and Sterilization Area w.r.t Ampoule Decartoning Room (NLT 12 Pa)	Washing and Sterilization Area w.r.t Injectable main corridor (NLT 12 Pa)
22-05-2022 15:35:00	17.1	80.4	21	13	35
22-05-2022 15:36:00	17.1	80.4	18	14	35
22-05-2022 15:37:00	17.1	80.4	20	14	36
22-05-2022 15:38:00	17.1	80.2	20	15	36
22-05-2022 15:39:00	17.1	80	21	14	36
22-05-2022 15:40:00	17.1	79.8	20	15	35
22-05-2022 15:41:00	17.1	80.2	20	15	36
22-05-2022 15:42:00	17.1	79.9	20	14	35
22-05-2022 15:43:00	17.1	79.7	21	14	36
22-05-2022 15:44:00	17.1	79.5	19	14	33
22-05-2022 15:45:00	17.1	79.5	19	15	36
22-05-2022 15:46:00	17.1	79.4	12	12	30
22-05-2022 15:47:00	17.1	79.4	21	12	34
22-05-2022 15:48:00	17.1	79.4	19	14	33
22-05-2022 15:49:00	17.1	79.5	20	15	36
22-05-2022 15:50:00	17.1	79.4	20	15	36
22-05-2022 15:51:00	17.1	79.4	20	15	36
22-05-2022 15:52:00	17.1	79.4	20	14	37
22-05-2022 15:53:00	17.1	79.9	20	15	36
22-05-2022 15:54:00	17.1	80.5	20	14	36
22-05-2022 15:55:00	17.1	80.8	20	15	37
22-05-2022 15:56:00	17.1	80.8	19	15	37
22-05-2022 15:57:00	17.2	80.6	20	14	36
22-05-2022 15:58:00	17.2	80.4	19	14	36

ACTIVITY	NAME	SIGNATURE AND DATE
REVIEWED BY USER		
REVIEWED BY QA		



SOMERSET THERAPEUTICS LIMITED

DATA REPORT - SVP1 AND AMPOULE LINE EMS

WASHING AND STERILIZATION AREA

Date Time	Temperature	RH	Diffrential Pressure	Diffrential Pressure	Diffrential Pressure
DD-MM-YYYY HH:MM:SS	Washing and Sterilization Area (NMT 30°C)	Washing and Sterilization Area (NMT 80%)	Washing and Sterilization Area w.r.t Unit Preparation Room (NLT 6 Pa)	Washing and Sterilization Area w.r.t Ampoule Decartoning Room (NLT 12 Pa)	Washing and Sterilization Area w.r.t Injectable main corridor (NLT 12 Pa)
22-05-2022 15:59:00	17.2	80.4	19	15	38
22-05-2022 16:00:00	17.2	81.4	20	14	37
22-05-2022 16:01:00	17.3	82.4	20	15	37
22-05-2022 16:02:00	17.3	83.1	20	15	38
22-05-2022 16:03:00	17.4	83.6	20	15	36
22-05-2022 16:04:00	17.5	83.6	19	15	36
22-05-2022 16:05:00	17.5	83.9	20	15	37
22-05-2022 16:06:00	17.6	84	19	15	37
22-05-2022 16:07:00	17.6	83.8	20	15	37
22-05-2022 16:08:00	17.7	83.6	19	15	36
22-05-2022 16:09:00	17.7	83.6	19	15	38
22-05-2022 16:10:00	17.8	83.9	19	15	38
22-05-2022 16:11:00	17.8	84.2	19	15	35
22-05-2022 16:12:00	17.9	84.1	15	15	37
22-05-2022 16:13:00	17.9	83.7	19	14	37
22-05-2022 16:14:00	17.9	83.2	21	14	33
22-05-2022 16:15:00	17.9	82.9	20	15	35
22-05-2022 16:16:00	17.9	82.7	19	14	36
22-05-2022 16:17:00	17.9	82.4	15	15	35
22-05-2022 16:18:00	18	82.2	17	15	36
22-05-2022 16:19:00	18	82.3	18	15	35
22-05-2022 16:20:00	18	82.4	19	15	37
22-05-2022 16:21:00	18	82.5	20	15	36
22-05-2022 16:22:00	18	82.2	16	15	36

ACTIVITY	NAME	SIGNATURE AND DATE
REVIEWED BY USER		
REVIEWED BY QA		



SOMERSET THERAPEUTICS LIMITED

DATA REPORT - SVP1 AND AMPOULE LINE EMS

WASHING AND STERILIZATION AREA

Date Time	Temperature	RH	Diffrential Pressure	Diffrential Pressure	Diffrential Pressure
DD-MM-YYYY HH:MM:SS	Washing and Sterilization Area (NMT 30°C)	Washing and Sterilization Area (NMT 80%)	Washing and Sterilization Area w.r.t Unit Preparation Room (NLT 6 Pa)	Washing and Sterilization Area w.r.t Ampoule Decartoning Room (NLT 12 Pa)	Washing and Sterilization Area w.r.t Injectable main corridor (NLT 12 Pa)
22-05-2022 16:23:00	18.1	82.5	20	15	36

End Of Report : From 21-05-2022 16:23:29 To 22-05-2022 16:23:29

ACTIVITY	NAME	SIGNATURE AND DATE
REVIEWED BY USER		
REVIEWED BY QA		