

### DATA REPORT - SVP1 AND AMPOULE LINE EMS

| Date Time Diffrential Pressure |   |
|--------------------------------|---|
| DD-MM-YYYY HH:MM:SS            | Manufacturing Corridor Airlock w.r.t Injectable main corridor (NLT 12 Pa) |
|                                |   |
| 10-07-2022 09:49:00            | 29  |
| 10-07-2022 10:04:00            | 28  |
| 10-07-2022 10:19:00            | 30  |
| 10-07-2022 10:34:00            | 37  |
| 10-07-2022 10:49:00            | 34  |
| 10-07-2022 11:04:00            | 37  |
| 10-07-2022 11:19:00            | 39  |
| 10-07-2022 11:34:00            | 38  |
| 10-07-2022 11:49:00            | 39  |
| 10-07-2022 12:04:00            | 38  |
| 10-07-2022 12:19:00            | 21  |
| 10-07-2022 12:34:00            | 0   |
| 10-07-2022 12:49:00            | 0   |
| 10-07-2022 13:04:00            | 0   |
| 10-07-2022 13:19:00            | 0   |
| 10-07-2022 13:34:00            | 0   |
| 10-07-2022 13:49:00            | 0   |
| 10-07-2022 14:04:00            | 0   |
| 10-07-2022 14:19:00            | 0   |
| 10-07-2022 14:34:00            | 0   |
| 10-07-2022 14:49:00            | 0   |
| 10-07-2022 15:04:00            | 0   |
| 10-07-2022 15:19:00            | 0   |
| 10-07-2022 15:34:00            | 0   |

| ACTIVITY         | NAME | SIGNATURE AND DATE |
|------------------|------|--------------------|
| REVIEWED BY USER |      |                    |
| REVIEWED BY QA   |      |                    |



### DATA REPORT - SVP1 AND AMPOULE LINE EMS

| Date Time           | Diffrential Pressure  |
|---------------------|---|
| DD-MM-YYYY HH:MM:SS | Manufacturing Corridor Airlock w.r.t Injectable main corridor (NLT 12 Pa) |
|                     |   |
| 10-07-2022 15:49:00 | 0   |
| 10-07-2022 16:04:00 | 0   |
| 10-07-2022 16:19:00 | 0   |
| 10-07-2022 16:34:00 | 0   |
| 10-07-2022 16:49:00 | 0   |
| 10-07-2022 17:04:00 | 0   |
| 10-07-2022 17:19:00 | 0   |
| 10-07-2022 17:34:00 | 0   |
| 10-07-2022 17:49:00 | 0   |
| 10-07-2022 18:04:00 | 0   |
| 10-07-2022 18:19:00 | 0   |
| 10-07-2022 18:34:00 | 0   |
| 10-07-2022 18:49:00 | 47  |
| 10-07-2022 19:04:00 | 46  |
| 10-07-2022 19:19:00 | 46  |
| 10-07-2022 19:34:00 | 46  |
| 10-07-2022 19:49:00 | 42  |
| 10-07-2022 20:04:00 | 29  |
| 10-07-2022 20:19:00 | 29  |
| 10-07-2022 20:34:00 | 28  |
| 10-07-2022 20:49:00 | 37  |
| 10-07-2022 21:04:00 | 34  |
| 10-07-2022 21:19:00 | 33  |
| 10-07-2022 21:34:00 | 33  |

| ACTIVITY         | NAME | SIGNATURE AND DATE |
|------------------|------|--------------------|
| REVIEWED BY USER |      |                    |
| REVIEWED BY QA   |      |                    |



### DATA REPORT - SVP1 AND AMPOULE LINE EMS

| Date Time           | Diffrential Pressure  |
|---------------------|---|
| DD-MM-YYYY HH:MM:SS | Manufacturing Corridor Airlock w.r.t Injectable main corridor (NLT 12 Pa) |
|                     |   |
| 10-07-2022 21:49:00 | 34  |
| 10-07-2022 22:04:00 | 35  |
| 10-07-2022 22:19:00 | 34  |
| 10-07-2022 22:34:00 | 45  |
| 10-07-2022 22:49:00 | 37  |
| 10-07-2022 23:04:00 | 47  |
| 10-07-2022 23:19:00 | 33  |
| 10-07-2022 23:34:00 | 29  |
| 10-07-2022 23:49:00 | 35  |
| 11-07-2022 00:04:00 | 33  |
| 11-07-2022 00:19:00 | 33  |
| 11-07-2022 00:34:00 | 32  |
| 11-07-2022 00:49:00 | 38  |
| 11-07-2022 01:04:00 | 32  |
| 11-07-2022 01:19:00 | 37  |
| 11-07-2022 01:34:00 | 28  |
| 11-07-2022 01:49:00 | 37  |
| 11-07-2022 02:04:00 | 37  |
| 11-07-2022 02:19:00 | 36  |
| 11-07-2022 02:34:00 | 36  |
| 11-07-2022 02:49:00 | 37  |
| 11-07-2022 03:04:00 | 34  |
| 11-07-2022 03:19:00 | 35  |
| 11-07-2022 03:34:00 | 35  |

| ACTIVITY         | NAME | SIGNATURE AND DATE |
|------------------|------|--------------------|
| REVIEWED BY USER |      |                    |
| REVIEWED BY QA   |      |                    |



### DATA REPORT - SVP1 AND AMPOULE LINE EMS

| Date Time           | Diffrential Pressure  |
|---------------------|---|
| DD-MM-YYYY HH:MM:SS | Manufacturing Corridor Airlock w.r.t Injectable main corridor (NLT 12 Pa) |
|                     |   |
| 11-07-2022 03:49:00 | 35  |
| 11-07-2022 04:04:00 | 36  |
| 11-07-2022 04:19:00 | 35  |
| 11-07-2022 04:34:00 | 32  |
| 11-07-2022 04:49:00 | 35  |
| 11-07-2022 05:04:00 | 36  |
| 11-07-2022 05:19:00 | 36  |
| 11-07-2022 05:34:00 | 35  |
| 11-07-2022 05:49:00 | 36  |
| 11-07-2022 06:04:00 | 31  |
| 11-07-2022 06:19:00 | 35  |
| 11-07-2022 06:34:00 | 32  |
| 11-07-2022 06:49:00 | 36  |
| 11-07-2022 07:04:00 | 46  |
| 11-07-2022 07:19:00 | 36  |
| 11-07-2022 07:34:00 | 34  |
| 11-07-2022 07:49:00 | 42  |
| 11-07-2022 08:04:00 | 28  |
| 11-07-2022 08:19:00 | 33  |
| 11-07-2022 08:34:00 | 36  |
| 11-07-2022 08:49:00 | 38  |
| 11-07-2022 09:04:00 | 35  |
| 11-07-2022 09:19:00 | 60  |
| 11-07-2022 09:34:00 | 40  |

| ACTIVITY         | NAME | SIGNATURE AND DATE |
|------------------|------|--------------------|
| REVIEWED BY USER |      |                    |
| REVIEWED BY QA   |      |                    |



### DATA REPORT - SVP1 AND AMPOULE LINE EMS

### MANUFACTURING CORRIDOR

|                     | Date Time           | Diffrential Pressure  |  |
|---------------------|---------------------|---|--|
| DD-MM-YYYY HH:MM:SS |                     | Manufacturing Corridor Airlock w.r.t Injectable main corridor (NLT 12 Pa) |  |
|                     |                     |   |  |
|                     | 11-07-2022 09:49:00 | 41  |  |
|                     | Min Value           | 0   |  |
|                     | Max Value           | 60  |  |

End Of Report: From 10-07-2022 09:49:47 To 11-07-2022 09:49:47

| ACTIVITY         | NAME | SIGNATURE AND DATE |
|------------------|------|--------------------|
| REVIEWED BY USER |      |                    |
| REVIEWED BY QA   |      |                    |