



SOMERSET THERAPEUTICS LIMITED

DATA REPORT - SVP1 AND AMPOULE LINE EMS

AMPOULE WASHING AREA

Date Time	RH	Temperature	Differential Pressure
DD-MM-YYYY HH:MM:SS	Ampoule Washing Area (NMT 80%)	Ampoule Washing Area (NMT 30°C)	Ampoule Washing Area w.r.t Ampoule Decartoning Room (NLT 12 Pa)
06-05-2022 13:05:00	69	21.7	94
06-05-2022 13:35:00	69.1	21.7	100
06-05-2022 14:05:00	69.2	21.7	93
06-05-2022 14:35:00	68.9	21.8	95
06-05-2022 15:05:00	69.4	21.8	95
06-05-2022 15:35:00	69.5	21.9	95
06-05-2022 16:05:00	69	22	94
06-05-2022 16:35:00	68.9	22	96
06-05-2022 17:05:00	69.2	22	96
06-05-2022 17:35:00	69.3	22.1	94
06-05-2022 18:05:00	67.2	21.9	74
06-05-2022 18:35:00	66.7	21.6	74
06-05-2022 19:05:00	66.8	21.6	95
06-05-2022 19:35:00	66	21.5	96
06-05-2022 20:05:00	66.5	21.5	96
06-05-2022 20:35:00	66.6	21.6	96
06-05-2022 21:05:00	65.1	21.5	96
06-05-2022 21:35:00	65	21.2	97
06-05-2022 22:05:00	65.3	21.2	96
06-05-2022 22:35:00	66.8	21.2	96
06-05-2022 23:05:00	67	21.6	94
06-05-2022 23:35:00	67.8	21.7	94
07-05-2022 00:05:00	66.1	21.6	94
07-05-2022 00:35:00	66.1	21.4	94

ACTIVITY	NAME	SIGNATURE AND DATE
REVIEWED BY USER		
REVIEWED BY QA		



SOMERSET THERAPEUTICS LIMITED

DATA REPORT - SVP1 AND AMPOULE LINE EMS

AMPOULE WASHING AREA

Date Time	RH	Temperature	Differential Pressure
DD-MM-YYYY HH:MM:SS	Ampoule Washing Area (NMT 80%)	Ampoule Washing Area (NMT 30°C)	Ampoule Washing Area w.r.t Ampoule Decartoning Room (NLT 12 Pa)
07-05-2022 01:05:00	66.1	21.4	94
07-05-2022 01:35:00	65.6	21.4	89
07-05-2022 02:05:00	65.6	21.3	93
07-05-2022 02:35:00	65.2	21.2	93
07-05-2022 03:05:00	66.3	21.2	93
07-05-2022 03:35:00	64.8	21.2	87
07-05-2022 04:05:00	64.6	21	91
07-05-2022 04:35:00	64.6	20.9	90
07-05-2022 05:05:00	64.6	20.8	92
07-05-2022 05:35:00	65.5	20.8	92
07-05-2022 06:05:00	65.1	20.8	92
07-05-2022 06:35:00	64.9	20.8	92
07-05-2022 07:05:00	70.8	20.8	75
07-05-2022 07:35:00	69.3	21	93
07-05-2022 08:05:00	84.5	23.3	91
07-05-2022 08:35:00	81.5	24.2	92
07-05-2022 09:05:00	79	25	93
07-05-2022 09:35:00	****	****	****
07-05-2022 10:05:00	****	****	****
07-05-2022 10:35:00	****	****	****
07-05-2022 11:05:00	****	****	****
07-05-2022 11:35:00	****	****	****
07-05-2022 12:05:00	****	****	****
07-05-2022 12:35:00	****	****	****

ACTIVITY	NAME	SIGNATURE AND DATE
REVIEWED BY USER		
REVIEWED BY QA		



SOMERSET THERAPEUTICS LIMITED

DATA REPORT - SVP1 AND AMPOULE LINE EMS

AMPOULE WASHING AREA

Date Time	RH	Temperature	Differential Pressure
DD-MM-YYYY HH:MM:SS	Ampoule Washing Area (NMT 80%)	Ampoule Washing Area (NMT 30°C)	Ampoule Washing Area w.r.t Ampoule Decartoning Room (NLT 12 Pa)
07-05-2022 13:05:00	****	****	****

End Of Report : From 06-05-2022 13:05:31 To 07-05-2022 13:05:31

ACTIVITY	NAME	SIGNATURE AND DATE
REVIEWED BY USER		
REVIEWED BY QA		