



SOMERSET THERAPEUTICS LIMITED

DATA REPORT - SVP1 AND AMPOULE LINE EMS

WASHING AND STERILIZATION AREA

Date Time	Temperature	RH	Diffrential Pressure	Diffrential Pressure	Diffrential Pressure
DD-MM-YYYY HH:MM:SS	Washing and Sterilization Area (NMT 30°C)	Washing and Sterilization Area (NMT 80%)	Washing and Sterilization Area w.r.t Unit Preparation Room (NLT 6 Pa)	Washing and Sterilization Area w.r.t Ampoule Decartoning Room (NLT 12 Pa)	Washing and Sterilization Area w.r.t Injectable main corridor (NLT 12 Pa)
04-05-2022 12:36:00	20.3	78.3	22	21	52
04-05-2022 13:06:00	20.2	78.2	22	20	49
04-05-2022 13:36:00	20.3	77.9	22	20	50
04-05-2022 14:06:00	20.6	81.7	0	18	47
04-05-2022 14:36:00	20.5	77.7	0	18	49
04-05-2022 15:06:00	20.4	76.7	0	18	50
04-05-2022 15:36:00	20.4	78.6	23	21	51
04-05-2022 16:06:00	20.5	79.1	22	21	53
04-05-2022 16:36:00	20.5	77.9	0	18	50
04-05-2022 17:06:00	20.3	77.2	0	18	50
04-05-2022 17:36:00	20.1	76.3	0	18	47
04-05-2022 18:06:00	19.9	76.4	0	17	47
04-05-2022 18:36:00	20.2	79.1	0	18	49
04-05-2022 19:06:00	19.9	76.8	0	18	49
04-05-2022 19:36:00	20	75.5	22	20	51
04-05-2022 20:06:00	19.5	76.7	23	20	50
04-05-2022 20:36:00	19.5	75.4	23	20	50
04-05-2022 21:06:00	19.4	74.7	23	19	47
04-05-2022 21:36:00	19.7	76.7	23	19	51
04-05-2022 22:06:00	19.7	77.6	21	18	48
04-05-2022 22:36:00	19.5	75.5	0	14	40
04-05-2022 23:06:00	19.1	75.5	0	16	45
04-05-2022 23:36:00	18.5	75.4	22	17	47
05-05-2022 00:06:00	18.5	75.9	0	17	47

ACTIVITY	NAME	SIGNATURE AND DATE
REVIEWED BY USER		
REVIEWED BY QA		



SOMERSET THERAPEUTICS LIMITED

DATA REPORT - SVP1 AND AMPOULE LINE EMS

WASHING AND STERILIZATION AREA

Date Time	Temperature	RH	Diffrential Pressure	Diffrential Pressure	Diffrential Pressure
DD-MM-YYYY HH:MM:SS	Washing and Sterilization Area (NMT 30°C)	Washing and Sterilization Area (NMT 80%)	Washing and Sterilization Area w.r.t Unit Preparation Room (NLT 6 Pa)	Washing and Sterilization Area w.r.t Ampoule Decartoning Room (NLT 12 Pa)	Washing and Sterilization Area w.r.t Injectable main corridor (NLT 12 Pa)
05-05-2022 00:36:00	18.1	74.6	16	19	49
05-05-2022 01:06:00	18.3	72.6	0	14	40
05-05-2022 01:36:00	17.7	73.5	0	17	46
05-05-2022 02:06:00	17.5	73.9	0	17	48
05-05-2022 02:36:00	17.4	74.2	0	17	47
05-05-2022 03:06:00	17.3	74.2	0	16	46
05-05-2022 03:36:00	17.6	75.2	20	18	49
05-05-2022 04:06:00	17.8	77.6	22	20	50
05-05-2022 04:36:00	17.9	75.3	23	19	47
05-05-2022 05:06:00	18.7	74.1	21	19	48
05-05-2022 05:36:00	18	73.7	22	20	49
05-05-2022 06:06:00	17.6	74	22	20	50
05-05-2022 06:36:00	17.5	74.4	21	19	48
05-05-2022 07:06:00	17.8	76.1	21	17	44
05-05-2022 07:36:00	18.2	78.6	0	17	48
05-05-2022 08:06:00	18.3	76.2	0	17	48
05-05-2022 08:36:00	18.4	75.9	0	16	45
05-05-2022 09:06:00	18.9	76.5	0	18	50
05-05-2022 09:36:00	18.9	77	0	18	50
05-05-2022 10:06:00	19.4	81	0	19	51
05-05-2022 10:36:00	20.3	76.4	0	17	47
05-05-2022 11:06:00	20.4	76.3	0	15	44
05-05-2022 11:36:00	20.2	77.9	0	17	47
05-05-2022 12:06:00	20.3	78.8	0	18	49

ACTIVITY	NAME	SIGNATURE AND DATE
REVIEWED BY USER		
REVIEWED BY QA		



SOMERSET THERAPEUTICS LIMITED

DATA REPORT - SVP1 AND AMPOULE LINE EMS

WASHING AND STERILIZATION AREA

Date Time	Temperature	RH	Diffrential Pressure	Diffrential Pressure	Diffrential Pressure
DD-MM-YYYY HH:MM:SS	Washing and Sterilization Area (NMT 30°C)	Washing and Sterilization Area (NMT 80%)	Washing and Sterilization Area w.r.t Unit Preparation Room (NLT 6 Pa)	Washing and Sterilization Area w.r.t Ampoule Decartoning Room (NLT 12 Pa)	Washing and Sterilization Area w.r.t Injectable main corridor (NLT 12 Pa)
05-05-2022 12:36:00	20.3	78.4	0	18	48
Min Value	17.3	72.6	0	14	40
Max Value	20.6	81.7	23	21	53

End Of Report : From 04-05-2022 12:36:08 To 05-05-2022 12:36:08

ACTIVITY	NAME	SIGNATURE AND DATE
REVIEWED BY USER		
REVIEWED BY QA		