



# Environmental Monitoring System

## DATA REPORT

### STERILE EXIT CHANGE ROOMS (L3)

Date Time	STERILE PASSAGE (L3) wrt EXIT ROOM-1 (L3)	STERILE EXIT ROOM-1 (L3)	ASEPTIC EXIT ROOM-1 (L3) wrt EXIT ROOM-2 (L3)	STERILE EXIT ROOM-2 (L3)	ASEPTIC EXIT ROOM-2 (L3) wrt EXIT ROOM-3 (L3)	STERILE EXIT ROOM-3 (L3)
Date Time	DP Pa	°C TEMP	DP Pa	°C TEMP	DP Pa	°C TEMP
Alarm Low Limit						
Set Value						
Alarm High Limit						
21-10-2021 00:00	23	22.9	18	23.1	21	23.3
21-10-2021 00:01	23	22.9	18	23.1	21	23.3
21-10-2021 00:02	21	22.9	18	23.1	21	23.3
21-10-2021 00:03	21	22.9	18	23.1	20	23.3
21-10-2021 00:04	21	22.9	19	23.1	21	23.3
21-10-2021 00:05	20	22.9	19	23.1	20	23.3
21-10-2021 00:06	21	22.9	19	23.1	21	23.3
21-10-2021 00:07	23	22.9	19	23.1	21	23.3
21-10-2021 00:08	22	22.9	20	23.1	21	23.3
21-10-2021 00:09	21	22.9	20	23.1	21	23.3
21-10-2021 00:10	23	22.9	20	23.1	21	23.3
21-10-2021 00:11	21	22.9	20	23.1	21	23.3
21-10-2021 00:12	22	22.8	20	23.1	20	23.3
21-10-2021 00:13	23	22.9	19	23.1	20	23.3
21-10-2021 00:14	23	22.9	20	23.1	21	23.3
21-10-2021 00:15	22	22.9	19	23.1	21	23.3
21-10-2021 00:16	24	22.9	19	23.0	21	23.3
21-10-2021 00:17	22	22.9	19	23.0	21	23.3
21-10-2021 00:18	23	22.8	21	23.0	21	23.3
21-10-2021 00:19	23	22.8	20	23.0	21	23.3
21-10-2021 00:20	23	22.8	20	23.0	21	23.3
21-10-2021 00:21	23	22.8	20	23.0	21	23.3
21-10-2021 00:22	23	22.8	20	23.0	21	23.3
21-10-2021 00:23	23	22.8	20	23.0	21	23.2
21-10-2021 00:24	22	22.8	20	23.0	21	23.2



# Environmental Monitoring System

## DATA REPORT

### STERILE EXIT CHANGE ROOMS (L3)

Date Time	STERILE PASSAGE (L3) wrt EXIT ROOM-1 (L3)	STERILE EXIT ROOM-1 (L3)	ASEPTIC EXIT ROOM-1 (L3) wrt EXIT ROOM-2 (L3)	STERILE EXIT ROOM-2 (L3)	ASEPTIC EXIT ROOM-2 (L3) wrt EXIT ROOM-3 (L3)	STERILE EXIT ROOM-3 (L3)
Date Time	DP Pa	°C TEMP	DP Pa	°C TEMP	DP Pa	°C TEMP
21-10-2021 00:25	22	22.8	20	22.9	21	23.2
21-10-2021 00:26	23	22.8	20	22.9	21	23.2
21-10-2021 00:27	23	22.7	20	22.9	21	23.2
21-10-2021 00:28	22	22.7	18	22.9	21	23.2
21-10-2021 00:29	23	22.6	20	22.9	21	23.2
21-10-2021 00:30	25	22.6	20	22.9	21	23.2
21-10-2021 00:31	23	22.6	20	22.9	20	23.2
21-10-2021 00:32	23	22.6	20	22.8	21	23.2
21-10-2021 00:33	23	22.6	20	22.8	21	23.2
21-10-2021 00:34	23	22.6	20	22.8	21	23.2
21-10-2021 00:35	23	22.6	20	22.8	21	23.2
21-10-2021 00:36	23	22.6	20	22.8	21	23.2
21-10-2021 00:37	21	22.6	18	22.8	21	23.1
21-10-2021 00:38	23	22.6	19	22.8	21	23.2
21-10-2021 00:39	23	22.6	20	22.8	21	23.2
21-10-2021 00:40	23	22.5	20	22.8	21	23.1
21-10-2021 00:41	28	22.6	21	22.8	21	23.1
21-10-2021 00:42	24	22.5	21	22.8	22	23.1
21-10-2021 00:43	28	22.6	21	22.8	22	23.1
21-10-2021 00:44	26	22.5	21	22.8	22	23.1
21-10-2021 00:45	27	22.5	21	22.8	23	23.1
21-10-2021 00:46	27	22.5	21	22.8	22	23.1
21-10-2021 00:47	27	22.5	21	22.8	21	23.1
21-10-2021 00:48	27	22.5	21	22.8	23	23.1
21-10-2021 00:49	27	22.5	21	22.8	21	23.1
21-10-2021 00:50	28	22.5	21	22.9	22	23.1
21-10-2021 00:51	28	22.6	22	22.9	22	23.1
21-10-2021 00:52	27	22.6	21	22.9	22	23.1



# Environmental Monitoring System

## DATA REPORT

### STERILE EXIT CHANGE ROOMS (L3)

Date Time	STERILE PASSAGE (L3) wrt EXIT ROOM-1 (L3)	STERILE EXIT ROOM-1 (L3)	ASEPTIC EXIT ROOM-1 (L3) wrt EXIT ROOM-2 (L3)	STERILE EXIT ROOM-2 (L3)	ASEPTIC EXIT ROOM-2 (L3) wrt EXIT ROOM-3 (L3)	STERILE EXIT ROOM-3 (L3)
Date Time	DP Pa	°C TEMP	DP Pa	°C TEMP	DP Pa	°C TEMP
21-10-2021 00:53	27	22.6	22	22.9	22	23.1
21-10-2021 00:54	27	22.6	21	22.9	22	23.1
21-10-2021 00:55	25	22.6	20	22.9	21	23.1
21-10-2021 00:56	26	22.6	21	22.9	23	23.1
21-10-2021 00:57	26	22.6	21	22.9	21	23.1
21-10-2021 00:58	26	22.6	22	23.0	22	23.1
21-10-2021 00:59	23	22.6	20	23.0	21	23.1
21-10-2021 01:00	24	22.6	20	23.0	21	23.1
21-10-2021 01:01	27	22.6	21	23.0	22	23.1
21-10-2021 01:02	25	22.6	23	23.0	21	23.1
21-10-2021 01:03	26	22.6	21	23.0	22	23.1
21-10-2021 01:04	26	22.7	21	23.0	22	23.1
21-10-2021 01:05	25	22.7	21	23.0	22	23.1
21-10-2021 01:06	26	22.7	21	23.0	23	23.1
21-10-2021 01:07	27	22.7	22	23.0	23	23.1
21-10-2021 01:08	27	22.7	21	23.0	21	23.1
21-10-2021 01:09	27	22.7	21	23.1	22	23.1
21-10-2021 01:10	25	22.7	22	23.1	22	23.1
21-10-2021 01:11	27	22.7	23	23.1	22	23.1
21-10-2021 01:12	27	22.7	21	23.1	21	23.1
21-10-2021 01:13	26	22.7	21	23.1	23	23.1
21-10-2021 01:14	23	22.7	19	23.1	21	23.1
21-10-2021 01:15	24	22.8	20	23.1	21	23.1
21-10-2021 01:16	23	22.7	20	23.1	21	23.1
21-10-2021 01:17	25	22.8	21	23.1	22	23.1
21-10-2021 01:18	24	22.8	20	23.1	21	23.1
21-10-2021 01:19	25	22.8	20	23.1	21	23.1
21-10-2021 01:20	25	22.8	21	23.1	21	23.1



# Environmental Monitoring System

## DATA REPORT

### STERILE EXIT CHANGE ROOMS (L3)

Date Time	STERILE PASSAGE (L3) wrt EXIT ROOM-1 (L3)	STERILE EXIT ROOM-1 (L3)	ASEPTIC EXIT ROOM-1 (L3) wrt EXIT ROOM-2 (L3)	STERILE EXIT ROOM-2 (L3)	ASEPTIC EXIT ROOM-2 (L3) wrt EXIT ROOM-3 (L3)	STERILE EXIT ROOM-3 (L3)
Date Time	DP Pa	°C TEMP	DP Pa	°C TEMP	DP Pa	°C TEMP
21-10-2021 01:21	24	22.8	20	23.1	21	23.1
21-10-2021 01:22	26	22.8	22	23.1	21	23.1
21-10-2021 01:23	26	22.8	22	23.1	22	23.1
21-10-2021 01:24	29	22.7	21	23.1	23	23.1
21-10-2021 01:25	26	22.7	21	23.1	21	23.2
21-10-2021 01:26	27	22.7	23	23.1	22	23.2
21-10-2021 01:27	24	22.7	21	23.1	21	23.2
21-10-2021 01:28	25	22.8	21	23.1	21	23.2
21-10-2021 01:29	23	22.8	21	23.1	21	23.2
21-10-2021 01:30	26	22.8	21	23.1	22	23.2
21-10-2021 01:31	23	22.8	21	23.1	21	23.1
21-10-2021 01:32	26	22.8	20	23.1	20	23.1
21-10-2021 01:33	25	22.7	21	23.0	22	23.1
21-10-2021 01:34	25	22.7	22	23.0	22	23.1
21-10-2021 01:35	27	22.7	21	23.0	22	23.1
21-10-2021 01:36	26	22.7	21	23.0	21	23.1
21-10-2021 01:37	26	22.7	21	23.0	21	23.1
21-10-2021 01:38	26	22.7	21	23.0	22	23.1
21-10-2021 01:39	24	22.7	20	22.9	21	23.1
21-10-2021 01:40	23	22.7	20	22.9	21	23.1
21-10-2021 01:41	26	22.7	21	22.9	21	23.1
21-10-2021 01:42	27	22.7	23	22.9	22	23.1
21-10-2021 01:43	23	22.7	20	22.9	21	23.1
21-10-2021 01:44	24	22.7	20	22.9	21	23.1
21-10-2021 01:45	24	22.7	21	22.8	20	23.1
21-10-2021 01:46	23	22.6	21	22.8	21	23.1
21-10-2021 01:47	25	22.6	21	22.8	21	23.1
21-10-2021 01:48	25	22.6	20	22.8	22	23.0



# Environmental Monitoring System

## DATA REPORT

### STERILE EXIT CHANGE ROOMS (L3)

Date Time	STERILE PASSAGE (L3) wrt EXIT ROOM-1 (L3)	STERILE EXIT ROOM-1 (L3)	ASEPTIC EXIT ROOM-1 (L3) wrt EXIT ROOM-2 (L3)	STERILE EXIT ROOM-2 (L3)	ASEPTIC EXIT ROOM-2 (L3) wrt EXIT ROOM-3 (L3)	STERILE EXIT ROOM-3 (L3)
Date Time	DP Pa	°C TEMP	DP Pa	°C TEMP	DP Pa	°C TEMP
21-10-2021 01:49	23	22.6	20	22.8	21	23.0
21-10-2021 01:50	26	22.6	21	22.8	21	23.0
21-10-2021 01:51	25	22.6	21	22.7	21	23.0
21-10-2021 01:52	24	22.6	21	22.7	21	23.0
21-10-2021 01:53	23	22.6	20	22.7	21	23.0
21-10-2021 01:54	22	22.6	20	22.7	21	23.0
21-10-2021 01:55	26	22.6	22	22.7	23	23.0
21-10-2021 01:56	25	22.6	21	22.7	22	23.0
21-10-2021 01:57	23	22.6	20	22.7	21	23.0
21-10-2021 01:58	24	22.6	21	22.7	21	23.0
21-10-2021 01:59	27	22.6	22	22.7	22	23.0
21-10-2021 02:00	26	22.6	21	22.7	22	23.0
21-10-2021 02:01	26	22.6	21	22.7	23	23.0
21-10-2021 02:02	27	22.6	21	22.7	21	22.9
21-10-2021 02:03	26	22.6	21	22.7	23	22.9
21-10-2021 02:04	27	22.6	21	22.7	22	22.9
21-10-2021 02:05	26	22.7	21	22.8	21	22.9
21-10-2021 02:06	26	22.7	21	22.8	21	22.9
21-10-2021 02:07	26	22.7	21	22.8	22	22.9
21-10-2021 02:08	27	22.7	21	22.8	22	22.9
21-10-2021 02:09	26	22.7	22	22.8	21	22.9
21-10-2021 02:10	22	22.7	20	22.8	21	22.9
21-10-2021 02:11	23	22.7	20	22.8	21	23.0
21-10-2021 02:12	23	22.7	19	22.8	21	23.0
21-10-2021 02:13	23	22.8	20	22.9	20	23.0
21-10-2021 02:14	22	22.8	20	22.9	22	23.0
21-10-2021 02:15	24	22.8	20	22.9	21	23.0
21-10-2021 02:16	26	22.8	21	22.9	23	23.0



# Environmental Monitoring System

## DATA REPORT

### STERILE EXIT CHANGE ROOMS (L3)

Date Time	STERILE PASSAGE (L3) wrt EXIT ROOM-1 (L3)	STERILE EXIT ROOM-1 (L3)	ASEPTIC EXIT ROOM-1 (L3) wrt EXIT ROOM-2 (L3)	STERILE EXIT ROOM-2 (L3)	ASEPTIC EXIT ROOM-2 (L3) wrt EXIT ROOM-3 (L3)	STERILE EXIT ROOM-3 (L3)
Date Time	DP Pa	°C TEMP	DP Pa	°C TEMP	DP Pa	°C TEMP
21-10-2021 02:17	26	22.8	23	22.9	23	23.0
21-10-2021 02:18	26	22.7	21	22.9	22	23.0
21-10-2021 02:19	25	22.8	22	22.9	21	23.0
21-10-2021 02:20	26	22.8	21	22.9	23	23.0
21-10-2021 02:21	27	22.7	21	23.0	22	23.0
21-10-2021 02:22	26	22.7	21	23.0	22	23.0
21-10-2021 02:23	26	22.7	22	23.0	22	23.0
21-10-2021 02:24	24	22.7	21	23.0	21	23.0
21-10-2021 02:25	25	22.8	21	23.0	21	23.0
21-10-2021 02:26	23	22.8	21	23.0	21	23.0
21-10-2021 02:27	24	22.8	20	23.0	22	23.0
21-10-2021 02:28	26	22.8	22	23.0	21	23.0
21-10-2021 02:29	23	22.8	19	23.0	21	23.0
21-10-2021 02:30	23	22.8	20	23.0	22	23.1
21-10-2021 02:31	23	22.9	20	23.0	21	23.1
21-10-2021 02:32	22	22.9	20	23.0	22	23.1
21-10-2021 02:33	25	22.9	18	23.1	20	23.1
21-10-2021 02:34	25	22.9	20	23.1	21	23.1
21-10-2021 02:35	23	22.9	21	23.1	21	23.1
21-10-2021 02:36	27	22.9	22	23.1	21	23.1
21-10-2021 02:37	27	22.9	21	23.1	22	23.1
21-10-2021 02:38	26	22.9	21	23.1	21	23.1
21-10-2021 02:39	27	22.9	21	23.1	21	23.1
21-10-2021 02:40	26	22.9	21	23.1	22	23.1
21-10-2021 02:41	26	22.9	22	23.1	22	23.1
21-10-2021 02:42	27	22.9	23	23.1	23	23.1
21-10-2021 02:43	26	22.9	21	23.1	21	23.2
21-10-2021 02:44	26	22.9	22	23.1	22	23.2



# Environmental Monitoring System

## DATA REPORT

### STERILE EXIT CHANGE ROOMS (L3)

Date Time	STERILE PASSAGE (L3) wrt EXIT ROOM-1 (L3)	STERILE EXIT ROOM-1 (L3)	ASEPTIC EXIT ROOM-1 (L3) wrt EXIT ROOM-2 (L3)	STERILE EXIT ROOM-2 (L3)	ASEPTIC EXIT ROOM-2 (L3) wrt EXIT ROOM-3 (L3)	STERILE EXIT ROOM-3 (L3)
Date Time	DP Pa	°C TEMP	DP Pa	°C TEMP	DP Pa	°C TEMP
21-10-2021 02:45	27	22.9	21	23.1	22	23.2
21-10-2021 02:46	26	22.9	21	23.1	21	23.2
21-10-2021 02:47	25	22.9	21	23.1	22	23.2
21-10-2021 02:48	26	22.8	22	23.1	22	23.2
21-10-2021 02:49	29	22.8	22	23.1	23	23.2
21-10-2021 02:50	22	22.9	20	23.1	21	23.2
21-10-2021 02:51	22	22.9	19	23.1	20	23.2
21-10-2021 02:52	23	22.9	20	23.1	20	23.2
21-10-2021 02:53	21	22.9	19	23.2	20	23.2
21-10-2021 02:54	21	22.9	20	23.1	21	23.2
21-10-2021 02:55	21	23.0	20	23.1	20	23.2
21-10-2021 02:56	21	23.0	18	23.1	21	23.2
21-10-2021 02:57	23	23.0	18	23.1	21	23.3
21-10-2021 02:58	21	23.0	18	23.1	21	23.3
21-10-2021 02:59	21	23.0	18	23.1	21	23.3
21-10-2021 03:00	22	22.9	19	23.1	20	23.3
21-10-2021 03:01	22	22.9	19	23.1	21	23.3
21-10-2021 03:02	22	22.9	19	23.1	21	23.3
21-10-2021 03:03	24	22.9	19	23.1	21	23.3
21-10-2021 03:04	23	22.9	20	23.1	20	23.3
21-10-2021 03:05	23	22.9	21	23.1	20	23.3
21-10-2021 03:06	22	22.9	20	23.1	21	23.3
21-10-2021 03:07	22	22.9	20	23.1	21	23.3
21-10-2021 03:08	24	22.9	20	23.1	20	23.3
21-10-2021 03:09	28	22.9	21	23.1	23	23.3
21-10-2021 03:10	22	22.9	20	23.0	21	23.3
21-10-2021 03:11	23	22.9	20	23.0	21	23.3
21-10-2021 03:12	25	22.9	22	23.0	22	23.3



# Environmental Monitoring System

## DATA REPORT

### STERILE EXIT CHANGE ROOMS (L3)

Date Time	STERILE PASSAGE (L3) wrt EXIT ROOM-1 (L3)	STERILE EXIT ROOM-1 (L3)	ASEPTIC EXIT ROOM-1 (L3) wrt EXIT ROOM-2 (L3)	STERILE EXIT ROOM-2 (L3)	ASEPTIC EXIT ROOM-2 (L3) wrt EXIT ROOM-3 (L3)	STERILE EXIT ROOM-3 (L3)
Date Time	DP Pa	°C TEMP	DP Pa	°C TEMP	DP Pa	°C TEMP
21-10-2021 03:13	26	22.9	21	23.0	22	23.2
21-10-2021 03:14	22	22.8	20	23.0	21	23.2
21-10-2021 03:15	22	22.8	19	23.0	20	23.2
21-10-2021 03:16	23	22.8	20	23.0	20	23.2
21-10-2021 03:17	23	22.8	20	23.0	21	23.2
21-10-2021 03:18	22	22.9	20	23.0	21	23.2
21-10-2021 03:19	23	22.9	19	23.0	20	23.2
21-10-2021 03:20	23	22.8	19	23.0	21	23.2
21-10-2021 03:21	24	22.8	20	23.0	21	23.3
21-10-2021 03:22	23	22.8	20	22.9	21	23.3
21-10-2021 03:23	23	22.8	20	23.0	21	23.3
21-10-2021 03:24	23	22.8	20	22.9	21	23.3
21-10-2021 03:25	23	22.8	19	22.9	21	23.2
21-10-2021 03:26	23	22.8	20	22.9	21	23.3
21-10-2021 03:27	23	22.8	20	22.9	21	23.2
21-10-2021 03:28	23	22.8	20	22.9	21	23.2
21-10-2021 03:29	23	22.8	20	22.9	20	23.2
21-10-2021 03:30	23	22.8	19	22.9	21	23.2
21-10-2021 03:31	23	22.7	20	22.8	22	23.2
21-10-2021 03:32	23	22.7	20	22.8	21	23.2
21-10-2021 03:33	30	22.6	0	22.8	33	23.2
21-10-2021 03:34	31	22.6	21	22.8	4	23.2
21-10-2021 03:35	23	22.6	20	22.8	16	22.7
21-10-2021 03:36	22	22.6	20	22.8	17	22.4
21-10-2021 03:37	24	22.6	20	22.8	15	22.3
21-10-2021 03:38	23	22.6	20	22.8	15	22.2
21-10-2021 03:39	23	22.6	20	22.8	17	22.1
21-10-2021 03:40	23	22.7	20	22.8	16	22.1





# Environmental Monitoring System

## DATA REPORT

### STERILE EXIT CHANGE ROOMS (L3)

Date Time	STERILE PASSAGE (L3) wrt EXIT ROOM-1 (L3)	STERILE EXIT ROOM-1 (L3)	ASEPTIC EXIT ROOM-1 (L3) wrt EXIT ROOM-2 (L3)	STERILE EXIT ROOM-2 (L3)	ASEPTIC EXIT ROOM-2 (L3) wrt EXIT ROOM-3 (L3)	STERILE EXIT ROOM-3 (L3)
Date Time	DP Pa	°C TEMP	DP Pa	°C TEMP	DP Pa	°C TEMP
21-10-2021 03:41	21	22.7	20	22.8	17	22.0
21-10-2021 03:42	23	22.7	20	22.8	20	22.4
21-10-2021 03:43	22	22.6	20	22.8	20	22.5
21-10-2021 03:44	24	22.7	20	22.9	21	22.6
21-10-2021 03:45	23	22.7	18	22.9	22	22.6
21-10-2021 03:46	21	22.7	19	22.7	21	22.7
21-10-2021 03:47	23	22.7	20	22.6	22	22.7
21-10-2021 03:48	22	22.7	19	22.6	22	22.7
21-10-2021 03:49	23	22.7	19	22.5	21	22.7
21-10-2021 03:50	21	22.7	20	22.5	21	22.8
21-10-2021 03:51	22	22.7	20	22.5	23	22.8
21-10-2021 03:52	23	22.8	19	22.4	21	22.8
21-10-2021 03:53	23	22.8	20	22.6	21	22.8
21-10-2021 03:54	22	22.8	20	22.6	21	22.8
21-10-2021 03:55	22	22.8	20	22.7	21	22.8
21-10-2021 03:56	22	22.9	20	22.7	21	22.8
21-10-2021 03:57	22	22.9	20	22.7	21	22.8
21-10-2021 03:58	22	22.9	20	22.7	21	22.8
21-10-2021 03:59	22	22.9	21	22.8	21	22.8
21-10-2021 04:00	21	22.9	21	22.8	21	22.8
21-10-2021 04:01	22	22.9	20	22.8	21	22.8
21-10-2021 04:02	23	22.9	20	22.8	21	22.8
21-10-2021 04:03	11	22.6	30	22.9	22	22.8
21-10-2021 04:04	8	22.3	30	22.9	21	22.9
21-10-2021 04:05	13	22.2	27	22.9	21	22.9
21-10-2021 04:06	11	22.1	28	22.9	21	22.9
21-10-2021 04:07	13	22.0	29	22.9	21	22.9
21-10-2021 04:08	11	21.9	29	22.9	21	22.9



# Environmental Monitoring System

## DATA REPORT

### STERILE EXIT CHANGE ROOMS (L3)

Date Time	STERILE PASSAGE (L3) wrt EXIT ROOM-1 (L3)	STERILE EXIT ROOM-1 (L3)	ASEPTIC EXIT ROOM-1 (L3) wrt EXIT ROOM-2 (L3)	STERILE EXIT ROOM-2 (L3)	ASEPTIC EXIT ROOM-2 (L3) wrt EXIT ROOM-3 (L3)	STERILE EXIT ROOM-3 (L3)
Date Time	DP Pa	°C TEMP	DP Pa	°C TEMP	DP Pa	°C TEMP
21-10-2021 04:09	11	21.8	29	22.9	20	22.9
21-10-2021 04:10	21	22.0	19	22.9	21	22.9
21-10-2021 04:11	23	22.2	20	23.0	22	22.9
21-10-2021 04:12	23	22.3	20	23.0	22	22.9
21-10-2021 04:13	21	22.4	19	23.0	21	22.9
21-10-2021 04:14	23	22.5	20	23.0	21	22.9
21-10-2021 04:15	23	22.5	20	23.0	22	22.9
21-10-2021 04:16	23	22.6	20	23.0	21	22.9
21-10-2021 04:17	24	22.7	20	23.0	21	22.9
21-10-2021 04:18	23	22.7	20	23.0	20	22.9
21-10-2021 04:19	22	22.7	19	23.0	21	22.9
21-10-2021 04:20	22	22.7	20	23.1	21	22.9
21-10-2021 04:21	0	22.7	31	23.0	26	23.0
21-10-2021 04:22	21	22.7	20	23.1	21	23.0
21-10-2021 04:23	22	22.7	20	23.1	21	23.0
21-10-2021 04:24	21	22.8	20	23.1	20	23.0
21-10-2021 04:25	22	22.8	20	23.1	21	23.0
21-10-2021 04:26	25	22.8	19	23.1	20	23.0
21-10-2021 04:27	21	22.8	20	23.1	21	23.0
21-10-2021 04:28	22	22.8	20	23.1	21	23.0
21-10-2021 04:29	22	22.8	20	23.1	21	23.0
21-10-2021 04:30	23	22.8	20	23.1	22	23.0
21-10-2021 04:31	21	22.8	19	23.1	21	23.0
21-10-2021 04:32	22	22.9	21	23.1	21	23.0
21-10-2021 04:33	21	22.9	20	23.1	21	23.0
21-10-2021 04:34	23	22.9	20	23.1	21	23.0
21-10-2021 04:35	20	22.8	18	23.1	20	23.0
21-10-2021 04:36	22	22.9	20	23.1	21	23.0



# Environmental Monitoring System

## DATA REPORT

### STERILE EXIT CHANGE ROOMS (L3)

Date Time	STERILE PASSAGE (L3) wrt EXIT ROOM-1 (L3)	STERILE EXIT ROOM-1 (L3)	ASEPTIC EXIT ROOM-1 (L3) wrt EXIT ROOM-2 (L3)	STERILE EXIT ROOM-2 (L3)	ASEPTIC EXIT ROOM-2 (L3) wrt EXIT ROOM-3 (L3)	STERILE EXIT ROOM-3 (L3)
Date Time	DP Pa	°C TEMP	DP Pa	°C TEMP	DP Pa	°C TEMP
21-10-2021 04:37	22	22.8	20	23.1	21	23.0
21-10-2021 04:38	22	22.8	20	23.1	21	23.0
21-10-2021 04:39	23	22.8	21	23.1	21	23.0
21-10-2021 04:40	21	22.9	20	23.1	21	23.0
21-10-2021 04:41	21	22.9	20	23.1	22	23.0
21-10-2021 04:42	22	22.9	20	23.1	21	23.0
21-10-2021 04:43	23	22.9	20	23.1	21	23.0
21-10-2021 04:44	21	22.8	20	23.1	21	23.0
21-10-2021 04:45	23	22.8	20	23.0	22	23.0
21-10-2021 04:46	22	22.8	20	23.0	21	23.0
21-10-2021 04:47	23	22.8	20	23.0	21	23.0
21-10-2021 04:48	22	22.8	20	23.0	22	23.0
21-10-2021 04:49	21	22.8	20	23.0	22	23.0
21-10-2021 04:50	23	22.8	20	23.0	21	23.0
21-10-2021 04:51	22	22.7	20	23.0	21	23.0
21-10-2021 04:52	21	22.7	20	23.0	22	23.0
21-10-2021 04:53	22	22.7	19	22.9	21	23.0
21-10-2021 04:54	23	22.7	20	22.9	21	23.0
21-10-2021 04:55	21	22.7	20	22.9	21	23.0
21-10-2021 04:56	21	22.7	20	22.9	20	22.9
21-10-2021 04:57	24	22.7	22	22.9	22	22.9
21-10-2021 04:58	21	22.7	20	22.8	21	22.9
21-10-2021 04:59	21	22.6	20	22.8	21	22.9
21-10-2021 05:00	22	22.6	20	22.8	21	22.9
21-10-2021 05:01	22	22.6	20	22.8	21	22.9
21-10-2021 05:02	21	22.6	20	22.8	21	22.9
21-10-2021 05:03	23	22.6	19	22.8	21	22.9
21-10-2021 05:04	23	22.6	20	22.8	21	22.9



# Environmental Monitoring System

## DATA REPORT

### STERILE EXIT CHANGE ROOMS (L3)

Date Time	STERILE PASSAGE (L3) wrt EXIT ROOM-1 (L3)	STERILE EXIT ROOM-1 (L3)	ASEPTIC EXIT ROOM-1 (L3) wrt EXIT ROOM-2 (L3)	STERILE EXIT ROOM-2 (L3)	ASEPTIC EXIT ROOM-2 (L3) wrt EXIT ROOM-3 (L3)	STERILE EXIT ROOM-3 (L3)
Date Time	DP Pa	°C TEMP	DP Pa	°C TEMP	DP Pa	°C TEMP
21-10-2021 05:05	22	22.6	20	22.8	21	22.9
21-10-2021 05:06	21	22.6	20	22.8	21	22.9
21-10-2021 05:07	21	22.6	19	22.8	21	22.9
21-10-2021 05:08	21	22.6	20	22.8	21	22.9
21-10-2021 05:09	21	22.7	20	22.8	21	22.9
21-10-2021 05:10	21	22.6	19	22.8	21	22.9
21-10-2021 05:11	22	22.6	20	22.8	21	22.9
21-10-2021 05:12	23	22.6	21	22.8	21	22.9
21-10-2021 05:13	22	22.6	20	22.8	21	22.9
21-10-2021 05:14	23	22.6	20	22.8	21	22.9
21-10-2021 05:15	22	22.7	20	22.8	21	22.9
21-10-2021 05:16	23	22.6	20	22.9	21	22.9
21-10-2021 05:17	21	22.6	20	22.9	22	22.9
21-10-2021 05:18	21	22.7	20	22.9	21	22.9
21-10-2021 05:19	23	22.7	20	22.9	21	22.9
21-10-2021 05:20	21	22.7	20	22.9	21	22.9
21-10-2021 05:21	21	22.7	20	22.9	21	22.9
21-10-2021 05:22	22	22.7	20	22.9	21	22.9
21-10-2021 05:23	22	22.8	20	22.9	21	22.9
21-10-2021 05:24	21	22.8	20	22.9	21	22.9
21-10-2021 05:25	21	22.8	20	22.9	21	22.9
21-10-2021 05:26	22	22.8	20	22.9	21	22.9
21-10-2021 05:27	21	22.8	19	22.9	21	22.9
21-10-2021 05:28	21	22.8	20	22.9	21	22.9
21-10-2021 05:29	22	22.8	20	23.0	21	22.9
21-10-2021 05:30	21	22.8	20	23.0	22	22.9
21-10-2021 05:31	21	22.8	21	23.0	21	22.9
21-10-2021 05:32	22	22.8	20	23.0	20	22.9



# Environmental Monitoring System

## DATA REPORT

### STERILE EXIT CHANGE ROOMS (L3)

Date Time	STERILE PASSAGE (L3) wrt EXIT ROOM-1 (L3)	STERILE EXIT ROOM-1 (L3)	ASEPTIC EXIT ROOM-1 (L3) wrt EXIT ROOM-2 (L3)	STERILE EXIT ROOM-2 (L3)	ASEPTIC EXIT ROOM-2 (L3) wrt EXIT ROOM-3 (L3)	STERILE EXIT ROOM-3 (L3)
Date Time	DP Pa	°C TEMP	DP Pa	°C TEMP	DP Pa	°C TEMP
21-10-2021 05:33	21	22.8	20	23.0	21	22.9
21-10-2021 05:34	23	22.8	20	23.0	21	22.9
21-10-2021 05:35	22	22.8	20	23.0	21	22.9
21-10-2021 05:36	22	22.8	20	23.0	21	22.9
21-10-2021 05:37	21	22.8	20	23.0	21	22.9
21-10-2021 05:38	22	22.8	20	23.0	21	22.9
21-10-2021 05:39	21	22.8	20	23.0	20	22.9
21-10-2021 05:40	21	22.9	19	23.0	21	22.9
21-10-2021 05:41	22	22.9	20	23.0	21	22.9
21-10-2021 05:42	22	22.9	20	23.0	21	22.9
21-10-2021 05:43	22	22.9	20	23.0	21	22.9
21-10-2021 05:44	21	22.9	20	23.1	21	23.0
21-10-2021 05:45	23	22.9	20	23.1	21	23.0
21-10-2021 05:46	21	22.9	20	23.1	21	23.0
21-10-2021 05:47	21	22.9	20	23.1	20	23.0
21-10-2021 05:48	22	22.9	20	23.1	21	23.0
21-10-2021 05:49	22	22.9	20	23.1	20	23.0
21-10-2021 05:50	23	22.9	20	23.1	20	23.0
21-10-2021 05:51	23	23.0	20	23.1	20	23.0
21-10-2021 05:52	22	23.0	20	23.1	21	23.0
21-10-2021 05:53	23	23.0	20	23.1	21	23.0
21-10-2021 05:54	22	23.0	20	23.1	21	23.0
21-10-2021 05:55	23	23.0	20	23.1	20	23.0
21-10-2021 05:56	23	23.0	20	23.1	21	23.0
21-10-2021 05:57	22	23.0	20	23.1	21	23.0
21-10-2021 05:58	21	23.0	21	23.1	20	23.0
21-10-2021 05:59	21	23.0	18	23.1	20	23.0
21-10-2021 06:00	22	23.0	20	23.1	21	23.0



# Environmental Monitoring System

## DATA REPORT

### STERILE EXIT CHANGE ROOMS (L3)

Date Time	STERILE PASSAGE (L3) wrt EXIT ROOM-1 (L3)	STERILE EXIT ROOM-1 (L3)	ASEPTIC EXIT ROOM-1 (L3) wrt EXIT ROOM-2 (L3)	STERILE EXIT ROOM-2 (L3)	ASEPTIC EXIT ROOM-2 (L3) wrt EXIT ROOM-3 (L3)	STERILE EXIT ROOM-3 (L3)
Date Time	DP Pa	°C TEMP	DP Pa	°C TEMP	DP Pa	°C TEMP
21-10-2021 06:01	23	23.0	20	23.1	21	23.0
21-10-2021 06:02	22	23.0	20	23.1	21	23.0
21-10-2021 06:03	27	23.0	21	23.1	21	23.0
21-10-2021 06:04	23	23.0	21	23.1	21	23.0
21-10-2021 06:05	23	23.0	20	23.1	20	23.0
21-10-2021 06:06	21	23.0	20	23.1	21	23.0
21-10-2021 06:07	22	22.9	20	23.1	21	23.0
21-10-2021 06:08	21	23.0	20	23.1	21	23.0
21-10-2021 06:09	26	23.0	21	23.1	21	23.0
21-10-2021 06:10	22	22.9	20	23.0	21	23.0
21-10-2021 06:11	22	22.9	20	23.0	21	23.0
21-10-2021 06:12	23	22.9	20	23.0	21	23.0
21-10-2021 06:13	25	22.9	20	23.0	21	23.0
21-10-2021 06:14	23	22.9	20	23.0	21	23.0
21-10-2021 06:15	23	22.9	20	23.0	21	23.0
21-10-2021 06:16	23	22.8	20	23.0	21	23.0
21-10-2021 06:17	24	22.8	19	23.0	20	23.0
21-10-2021 06:18	22	22.8	20	23.0	21	23.0
21-10-2021 06:19	23	22.7	20	23.0	20	23.0
21-10-2021 06:20	22	22.7	20	22.9	21	23.0
21-10-2021 06:21	24	22.7	20	22.9	20	23.0
21-10-2021 06:22	27	22.7	22	22.9	21	23.0
21-10-2021 06:23	23	22.6	20	22.9	21	23.0
21-10-2021 06:24	24	22.6	20	22.9	21	23.0
21-10-2021 06:25	23	22.6	20	22.9	21	23.1
21-10-2021 06:26	23	22.5	19	22.9	20	23.0
21-10-2021 06:27	22	22.5	20	22.8	21	23.0
21-10-2021 06:28	23	22.5	19	22.8	21	23.0



# Environmental Monitoring System

## DATA REPORT

### STERILE EXIT CHANGE ROOMS (L3)

Date Time	STERILE PASSAGE (L3) wrt EXIT ROOM-1 (L3)	STERILE EXIT ROOM-1 (L3)	ASEPTIC EXIT ROOM-1 (L3) wrt EXIT ROOM-2 (L3)	STERILE EXIT ROOM-2 (L3)	ASEPTIC EXIT ROOM-2 (L3) wrt EXIT ROOM-3 (L3)	STERILE EXIT ROOM-3 (L3)
Date Time	DP Pa	°C TEMP	DP Pa	°C TEMP	DP Pa	°C TEMP
21-10-2021 06:29	23	22.5	19	22.8	22	23.0
21-10-2021 06:30	23	22.4	20	22.8	21	23.0
21-10-2021 06:31	23	22.4	20	22.8	21	23.0
21-10-2021 06:32	23	22.4	20	22.8	20	23.0
21-10-2021 06:33	24	22.4	20	22.8	21	23.0
21-10-2021 06:34	24	22.4	20	22.8	22	23.0
21-10-2021 06:35	24	22.4	19	22.8	21	23.0
21-10-2021 06:36	24	22.4	20	22.8	21	23.0
21-10-2021 06:37	21	22.4	19	22.8	20	23.0
21-10-2021 06:38	22	22.4	20	22.8	21	23.0
21-10-2021 06:39	23	22.4	20	22.8	21	23.0
21-10-2021 06:40	23	22.4	20	22.8	20	23.0
21-10-2021 06:41	23	22.4	21	22.8	20	23.0
21-10-2021 06:42	23	22.4	19	22.8	20	23.0
21-10-2021 06:43	23	22.4	20	22.8	21	23.0
21-10-2021 06:44	23	22.4	19	22.8	21	23.0
21-10-2021 06:45	22	22.5	20	22.8	20	23.0
21-10-2021 06:46	23	22.5	20	22.8	21	23.0
21-10-2021 06:47	23	22.5	20	22.8	21	23.0
21-10-2021 06:48	23	22.5	20	22.9	21	23.0
21-10-2021 06:49	25	22.5	19	22.9	21	23.0
21-10-2021 06:50	23	22.5	19	22.9	20	23.0
21-10-2021 06:51	22	22.6	20	22.9	20	23.0
21-10-2021 06:52	23	22.6	20	22.9	21	23.0
21-10-2021 06:53	23	22.6	20	22.9	21	23.0
21-10-2021 06:54	23	22.6	20	22.9	21	23.0
21-10-2021 06:55	23	22.6	20	22.9	21	23.0
21-10-2021 06:56	23	22.6	20	23.0	21	23.0



# Environmental Monitoring System

## DATA REPORT

### STERILE EXIT CHANGE ROOMS (L3)

Date Time	STERILE PASSAGE (L3) wrt EXIT ROOM-1 (L3)	STERILE EXIT ROOM-1 (L3)	ASEPTIC EXIT ROOM-1 (L3) wrt EXIT ROOM-2 (L3)	STERILE EXIT ROOM-2 (L3)	ASEPTIC EXIT ROOM-2 (L3) wrt EXIT ROOM-3 (L3)	STERILE EXIT ROOM-3 (L3)
Date Time	DP Pa	°C TEMP	DP Pa	°C TEMP	DP Pa	°C TEMP
21-10-2021 06:57	23	22.6	20	23.0	20	23.0
21-10-2021 06:58	22	22.6	19	23.0	21	23.0
21-10-2021 06:59	23	22.7	20	23.0	21	23.0
21-10-2021 07:00	23	22.7	19	23.0	20	23.0
21-10-2021 07:01	22	22.7	20	23.0	20	23.0
21-10-2021 07:02	26	22.7	20	23.0	21	23.0
21-10-2021 07:03	23	22.7	18	23.0	20	23.0
21-10-2021 07:04	23	22.7	20	23.0	21	23.0
21-10-2021 07:05	23	22.7	20	23.0	21	23.0
21-10-2021 07:06	23	22.7	20	23.1	20	23.0
21-10-2021 07:07	23	22.7	19	23.1	21	23.0
21-10-2021 07:08	23	22.7	19	23.1	20	23.0
21-10-2021 07:09	24	22.7	20	23.1	21	23.0
21-10-2021 07:10	24	22.8	20	23.1	21	23.0
21-10-2021 07:11	23	22.8	19	23.1	21	23.1
21-10-2021 07:12	26	22.8	20	23.1	20	23.0
21-10-2021 07:13	23	22.8	15	23.1	18	23.1
21-10-2021 07:14	23	22.7	16	23.1	18	23.0
21-10-2021 07:15	23	22.7	17	23.1	18	23.1
21-10-2021 07:16	23	22.8	16	23.1	16	23.1
21-10-2021 07:17	25	22.7	16	23.1	18	23.0
21-10-2021 07:18	24	22.7	16	23.1	18	23.1
21-10-2021 07:19	23	22.7	16	23.1	18	23.1
21-10-2021 07:20	23	22.7	16	23.1	18	23.1
21-10-2021 07:21	23	22.7	17	23.1	16	23.1
21-10-2021 07:22	24	22.7	16	23.1	18	23.0
21-10-2021 07:23	25	22.7	16	23.1	18	23.1
21-10-2021 07:24	23	22.7	16	23.1	18	23.1





# Environmental Monitoring System

## DATA REPORT

### STERILE EXIT CHANGE ROOMS (L3)

Date Time	STERILE PASSAGE (L3) wrt EXIT ROOM-1 (L3)	STERILE EXIT ROOM-1 (L3)	ASEPTIC EXIT ROOM-1 (L3) wrt EXIT ROOM-2 (L3)	STERILE EXIT ROOM-2 (L3)	ASEPTIC EXIT ROOM-2 (L3) wrt EXIT ROOM-3 (L3)	STERILE EXIT ROOM-3 (L3)
Date Time	DP Pa	°C TEMP	DP Pa	°C TEMP	DP Pa	°C TEMP
21-10-2021 07:25	24	22.7	16	23.1	17	23.1
21-10-2021 07:26	25	22.7	16	23.1	18	23.1
21-10-2021 07:27	24	22.7	16	23.1	18	23.1
21-10-2021 07:28	23	22.7	16	23.1	17	23.1
21-10-2021 07:29	23	22.7	16	23.1	18	23.1
21-10-2021 07:30	24	22.7	16	23.1	18	23.1
21-10-2021 07:31	23	22.7	16	23.1	17	23.1
21-10-2021 07:32	23	22.7	16	23.1	16	23.1
21-10-2021 07:33	22	22.6	15	23.1	16	23.1
21-10-2021 07:34	23	22.6	16	23.1	17	23.1
21-10-2021 07:35	23	22.6	15	23.0	16	23.1
21-10-2021 07:36	24	22.6	16	23.0	18	23.0
21-10-2021 07:37	24	22.5	18	23.0	18	23.0
21-10-2021 07:38	24	22.5	20	23.0	20	23.1
21-10-2021 07:39	23	22.5	20	23.0	21	23.1
21-10-2021 07:40	23	22.5	20	23.0	21	23.1
21-10-2021 07:41	25	22.5	20	22.9	21	23.1
21-10-2021 07:42	23	22.4	20	22.9	21	23.1
21-10-2021 07:43	27	22.4	20	22.9	23	23.1
21-10-2021 07:44	20	22.4	17	22.9	20	23.1
21-10-2021 07:45	19	22.4	18	22.9	20	23.2
21-10-2021 07:46	18	22.4	17	22.9	19	23.2
21-10-2021 07:47	20	22.4	16	22.9	20	23.2
21-10-2021 07:48	18	22.4	16	22.8	19	23.2
21-10-2021 07:49	25	22.4	20	22.8	21	23.2
21-10-2021 07:50	25	22.3	20	22.8	21	23.2
21-10-2021 07:51	21	22.3	18	22.8	20	23.1
21-10-2021 07:52	23	22.3	19	22.8	21	23.2



## Environmental Monitoring System

### DATA REPORT

#### STERILE EXIT CHANGE ROOMS (L3)

Date Time	STERILE PASSAGE (L3) wrt EXIT ROOM-1 (L3)	STERILE EXIT ROOM-1 (L3)	ASEPTIC EXIT ROOM-1 (L3) wrt EXIT ROOM-2 (L3)	STERILE EXIT ROOM-2 (L3)	ASEPTIC EXIT ROOM-2 (L3) wrt EXIT ROOM-3 (L3)	STERILE EXIT ROOM-3 (L3)
Date Time	DP Pa	°C TEMP	DP Pa	°C TEMP	DP Pa	°C TEMP
21-10-2021 07:53	24	22.3	20	22.8	22	23.2
21-10-2021 07:54	22	22.3	18	22.8	21	23.2
21-10-2021 07:55	23	22.3	19	22.8	21	23.2
21-10-2021 07:56	23	22.3	20	22.8	23	23.1
21-10-2021 07:57	23	22.3	19	22.8	22	23.2
21-10-2021 07:58	22	22.4	17	22.8	21	23.1
21-10-2021 07:59	20	22.4	17	22.8	20	23.2
21-10-2021 08:00	23	22.4	20	22.8	22	23.2
21-10-2021 08:01	29	22.4	22	22.8	21	23.2
21-10-2021 08:02	24	22.4	20	22.8	21	23.2
21-10-2021 08:03	20	22.4	22	22.8	22	23.1
21-10-2021 08:04	20	22.5	22	22.8	22	23.1
21-10-2021 08:05	21	22.6	22	22.9	23	23.1
21-10-2021 08:06	26	22.6	20	22.9	20	23.1
21-10-2021 08:07	25	22.6	20	22.9	21	23.1
21-10-2021 08:08	24	22.6	20	22.9	21	23.1
21-10-2021 08:09	25	22.6	20	22.9	21	23.1
21-10-2021 08:10	27	22.6	21	22.9	23	23.1
21-10-2021 08:11	25	22.6	20	22.9	23	23.1
21-10-2021 08:12	23	22.6	19	23.0	21	23.2
21-10-2021 08:13	24	22.6	20	23.0	21	23.2
21-10-2021 08:14	24	22.6	20	23.0	21	23.2
21-10-2021 08:15	25	22.6	20	23.0	21	23.2
21-10-2021 08:16	24	22.7	19	23.0	22	23.2
21-10-2021 08:17	24	22.7	20	23.0	22	23.2
21-10-2021 08:18	23	22.7	18	23.0	21	23.2
21-10-2021 08:19	24	22.7	20	23.1	21	23.2
21-10-2021 08:20	27	22.7	21	23.1	22	23.2



# Environmental Monitoring System

## DATA REPORT

### STERILE EXIT CHANGE ROOMS (L3)

Date Time	STERILE PASSAGE (L3) wrt EXIT ROOM-1 (L3)	STERILE EXIT ROOM-1 (L3)	ASEPTIC EXIT ROOM-1 (L3) wrt EXIT ROOM-2 (L3)	STERILE EXIT ROOM-2 (L3)	ASEPTIC EXIT ROOM-2 (L3) wrt EXIT ROOM-3 (L3)	STERILE EXIT ROOM-3 (L3)
Date Time	DP Pa	°C TEMP	DP Pa	°C TEMP	DP Pa	°C TEMP
21-10-2021 08:21	26	22.7	20	23.1	21	23.2
21-10-2021 08:22	23	22.7	20	23.1	21	23.2
21-10-2021 08:23	23	22.7	20	23.1	20	23.2
21-10-2021 08:24	24	22.7	20	23.1	21	23.2
21-10-2021 08:25	24	22.7	20	23.1	21	23.2
21-10-2021 08:26	25	22.7	20	23.1	22	23.1
21-10-2021 08:27	23	22.7	18	23.1	21	23.1
21-10-2021 08:28	24	22.7	19	23.0	21	23.1
21-10-2021 08:29	24	22.7	19	23.0	21	23.1
21-10-2021 08:30	24	22.7	19	23.0	21	23.1
21-10-2021 08:31	23	22.6	19	23.0	21	23.1
21-10-2021 08:32	23	22.6	19	23.0	21	23.1
21-10-2021 08:33	25	22.6	20	23.0	22	23.1
21-10-2021 08:34	23	22.6	19	22.9	22	23.1
21-10-2021 08:35	21	22.6	18	22.9	21	23.2
21-10-2021 08:36	23	22.5	19	22.9	21	23.2
21-10-2021 08:37	23	22.5	18	22.9	21	23.1
21-10-2021 08:38	25	22.5	20	22.9	22	23.2
21-10-2021 08:39	23	22.4	20	22.8	21	23.1
21-10-2021 08:40	23	22.5	18	22.8	21	23.1
21-10-2021 08:41	23	22.5	19	22.8	21	23.1
21-10-2021 08:42	21	22.5	20	22.8	21	23.1
21-10-2021 08:43	24	22.5	20	22.7	23	23.0
21-10-2021 08:44	22	22.5	20	22.7	22	23.0
21-10-2021 08:45	23	22.4	20	22.7	22	23.0
21-10-2021 08:46	23	22.4	19	22.7	22	23.0
21-10-2021 08:47	23	22.5	19	22.7	21	23.0
21-10-2021 08:48	23	22.4	20	22.6	21	23.0



# Environmental Monitoring System

## DATA REPORT

### STERILE EXIT CHANGE ROOMS (L3)

Date Time	STERILE PASSAGE (L3) wrt EXIT ROOM-1 (L3)	STERILE EXIT ROOM-1 (L3)	ASEPTIC EXIT ROOM-1 (L3) wrt EXIT ROOM-2 (L3)	STERILE EXIT ROOM-2 (L3)	ASEPTIC EXIT ROOM-2 (L3) wrt EXIT ROOM-3 (L3)	STERILE EXIT ROOM-3 (L3)
Date Time	DP Pa	°C TEMP	DP Pa	°C TEMP	DP Pa	°C TEMP
21-10-2021 08:49	23	22.4	20	22.6	22	22.9
21-10-2021 08:50	23	22.4	20	22.6	22	23.0
21-10-2021 08:51	21	22.4	19	22.6	21	23.0
21-10-2021 08:52	23	22.4	19	22.6	21	23.0
21-10-2021 08:53	23	22.4	20	22.6	22	23.0
21-10-2021 08:54	23	22.4	20	22.6	21	23.0
21-10-2021 08:55	24	22.4	21	22.6	21	22.9
21-10-2021 08:56	25	22.4	21	22.6	22	22.9
21-10-2021 08:57	23	22.4	20	22.6	23	22.9
21-10-2021 08:58	24	22.4	20	22.6	21	22.9
21-10-2021 08:59	23	22.4	19	22.6	22	22.9
21-10-2021 09:00	23	22.4	19	22.6	21	22.9
21-10-2021 09:01	24	22.4	19	22.6	21	22.9
21-10-2021 09:02	24	22.4	20	22.6	22	22.9
21-10-2021 09:03	23	22.4	20	22.6	22	22.9
21-10-2021 09:04	23	22.4	20	22.6	21	22.9
21-10-2021 09:05	22	22.4	18	22.7	21	22.9
21-10-2021 09:06	23	22.5	19	22.7	21	22.9
21-10-2021 09:07	23	22.5	20	22.7	21	22.9
21-10-2021 09:08	23	22.5	19	22.7	21	22.9
21-10-2021 09:09	23	22.6	19	22.7	20	22.9
21-10-2021 09:10	22	22.6	18	22.7	22	22.9
21-10-2021 09:11	23	22.6	19	22.8	21	22.9
21-10-2021 09:12	20	22.6	17	22.8	20	22.9
21-10-2021 09:13	23	22.6	20	22.8	22	22.9
21-10-2021 09:14	22	22.6	19	22.8	22	22.9
21-10-2021 09:15	22	22.6	15	22.8	21	22.9
21-10-2021 09:16	26	22.6	19	22.8	21	22.9



# Environmental Monitoring System

## DATA REPORT

### STERILE EXIT CHANGE ROOMS (L3)

Date Time	STERILE PASSAGE (L3) wrt EXIT ROOM-1 (L3)	STERILE EXIT ROOM-1 (L3)	ASEPTIC EXIT ROOM-1 (L3) wrt EXIT ROOM-2 (L3)	STERILE EXIT ROOM-2 (L3)	ASEPTIC EXIT ROOM-2 (L3) wrt EXIT ROOM-3 (L3)	STERILE EXIT ROOM-3 (L3)
Date Time	DP Pa	°C TEMP	DP Pa	°C TEMP	DP Pa	°C TEMP
21-10-2021 09:17	24	22.6	20	22.8	21	22.9
21-10-2021 09:18	21	22.6	17	22.9	20	22.9
21-10-2021 09:19	25	22.6	19	22.9	21	22.9
21-10-2021 09:20	23	22.7	20	22.9	22	22.9
21-10-2021 09:21	23	22.7	19	22.9	21	22.9
21-10-2021 09:22	25	22.7	21	22.9	21	22.9
21-10-2021 09:23	24	22.7	19	22.9	20	22.9
21-10-2021 09:24	23	22.7	19	22.9	21	22.9
21-10-2021 09:25	24	22.7	20	22.9	21	22.9
21-10-2021 09:26	24	22.6	16	22.9	18	22.9
21-10-2021 09:27	22	22.6	19	22.9	20	22.9
21-10-2021 09:28	26	22.6	19	22.9	20	22.9
21-10-2021 09:29	23	22.6	18	22.9	20	22.9
21-10-2021 09:30	22	22.6	18	22.9	20	22.9
21-10-2021 09:31	23	22.5	18	22.9	21	22.9
21-10-2021 09:32	25	22.5	20	22.9	21	22.9
21-10-2021 09:33	24	22.5	19	22.9	20	22.9
21-10-2021 09:34	28	22.5	22	22.8	21	22.9
21-10-2021 09:35	30	22.5	21	22.8	22	22.9
21-10-2021 09:36	23	22.5	19	22.8	21	22.9
21-10-2021 09:37	24	22.4	17	22.8	19	22.9
21-10-2021 09:38	27	22.4	30	22.8	0	23.0
21-10-2021 09:39	25	22.4	20	22.8	20	22.9
21-10-2021 09:40	23	22.4	18	22.8	19	22.9
21-10-2021 09:41	29	22.4	20	22.7	21	22.9
21-10-2021 09:42	23	22.4	19	22.7	20	22.9
21-10-2021 09:43	21	22.4	20	22.7	20	22.9
21-10-2021 09:44	24	22.4	18	22.7	20	22.9



# Environmental Monitoring System

## DATA REPORT

### STERILE EXIT CHANGE ROOMS (L3)

Date Time	STERILE PASSAGE (L3) wrt EXIT ROOM-1 (L3)	STERILE EXIT ROOM-1 (L3)	ASEPTIC EXIT ROOM-1 (L3) wrt EXIT ROOM-2 (L3)	STERILE EXIT ROOM-2 (L3)	ASEPTIC EXIT ROOM-2 (L3) wrt EXIT ROOM-3 (L3)	STERILE EXIT ROOM-3 (L3)
Date Time	DP Pa	°C TEMP	DP Pa	°C TEMP	DP Pa	°C TEMP
21-10-2021 09:45	24	22.4	18	22.7	20	22.9
21-10-2021 09:46	26	22.3	20	22.7	20	22.9
21-10-2021 09:47	24	22.3	18	22.6	19	22.9
21-10-2021 09:48	27	22.3	20	22.6	21	22.9
21-10-2021 09:49	24	22.3	18	22.6	21	22.8
21-10-2021 09:50	29	22.2	21	22.6	22	22.8
21-10-2021 09:51	25	22.3	19	22.5	20	22.8
21-10-2021 09:52	23	22.2	18	22.5	20	22.8
21-10-2021 09:53	23	22.2	19	22.5	21	22.8
21-10-2021 09:54	27	22.2	19	22.5	19	22.8
21-10-2021 09:55	23	22.2	20	22.5	20	22.8
21-10-2021 09:56	23	22.2	18	22.5	20	22.8
21-10-2021 09:57	27	22.1	20	22.5	21	22.8
21-10-2021 09:58	28	22.2	21	22.5	21	22.8
21-10-2021 09:59	24	22.1	19	22.4	20	22.8
21-10-2021 10:00	23	22.1	18	22.4	20	22.8
21-10-2021 10:01	24	22.1	18	22.4	19	22.8
21-10-2021 10:02	25	22.1	19	22.4	20	22.8
21-10-2021 10:03	21	22.1	16	22.4	18	22.8
21-10-2021 10:04	30	22.1	21	22.4	20	22.7
21-10-2021 10:05	22	22.0	19	22.4	20	22.7
21-10-2021 10:06	27	22.0	18	22.4	19	22.7
21-10-2021 10:07	25	22.0	18	22.4	19	22.7
21-10-2021 10:08	25	22.0	19	22.5	20	22.7
21-10-2021 10:09	23	22.0	18	22.5	21	22.7
21-10-2021 10:10	23	22.1	18	22.5	20	22.7
21-10-2021 10:11	24	22.1	18	22.5	20	22.7
21-10-2021 10:12	25	22.1	18	22.5	20	22.7



# Environmental Monitoring System

## DATA REPORT

### STERILE EXIT CHANGE ROOMS (L3)

Date Time	STERILE PASSAGE (L3) wrt EXIT ROOM-1 (L3)	STERILE EXIT ROOM-1 (L3)	ASEPTIC EXIT ROOM-1 (L3) wrt EXIT ROOM-2 (L3)	STERILE EXIT ROOM-2 (L3)	ASEPTIC EXIT ROOM-2 (L3) wrt EXIT ROOM-3 (L3)	STERILE EXIT ROOM-3 (L3)
Date Time	DP Pa	°C TEMP	DP Pa	°C TEMP	DP Pa	°C TEMP
21-10-2021 10:13	21	22.1	16	22.5	18	22.7
21-10-2021 10:14	21	22.2	18	22.6	18	22.7
21-10-2021 10:15	23	22.2	19	22.6	20	22.7
21-10-2021 10:16	21	22.2	17	22.6	20	22.7
21-10-2021 10:17	20	22.2	16	22.6	20	22.7
21-10-2021 10:18	28	22.3	20	22.6	19	22.7
21-10-2021 10:19	23	22.3	17	22.7	18	22.8
21-10-2021 10:20	23	22.3	17	22.7	19	22.8
21-10-2021 10:21	23	22.4	19	22.7	20	22.8
21-10-2021 10:22	21	22.4	18	22.7	20	22.8
21-10-2021 10:23	21	22.4	18	22.7	20	22.8
21-10-2021 10:24	23	22.5	18	22.8	19	22.8
21-10-2021 10:25	23	22.5	19	22.8	21	22.8
21-10-2021 10:26	28	22.5	20	22.8	21	22.8
21-10-2021 10:27	23	22.5	18	22.8	20	22.8
21-10-2021 10:28	23	22.5	18	22.8	20	22.8
21-10-2021 10:29	23	22.5	18	22.8	20	22.8
21-10-2021 10:30	21	22.5	18	22.8	18	22.8
21-10-2021 10:31	23	22.5	18	22.8	20	22.8
21-10-2021 10:32	23	22.5	19	22.7	20	22.8
21-10-2021 10:33	21	22.5	17	22.7	20	22.8
21-10-2021 10:34	22	22.5	18	22.7	20	22.8
21-10-2021 10:35	22	22.5	18	22.7	20	22.8
21-10-2021 10:36	21	22.5	16	22.7	18	22.8
21-10-2021 10:37	23	22.5	18	22.7	20	22.8
21-10-2021 10:38	21	22.4	18	22.7	20	22.8
21-10-2021 10:39	23	22.4	19	22.6	20	22.8
21-10-2021 10:40	23	22.4	18	22.6	20	22.8



# Environmental Monitoring System

## DATA REPORT

### STERILE EXIT CHANGE ROOMS (L3)

Date Time	STERILE PASSAGE (L3) wrt EXIT ROOM-1 (L3)	STERILE EXIT ROOM-1 (L3)	ASEPTIC EXIT ROOM-1 (L3) wrt EXIT ROOM-2 (L3)	STERILE EXIT ROOM-2 (L3)	ASEPTIC EXIT ROOM-2 (L3) wrt EXIT ROOM-3 (L3)	STERILE EXIT ROOM-3 (L3)
Date Time	DP Pa	°C TEMP	DP Pa	°C TEMP	DP Pa	°C TEMP
21-10-2021 10:41	21	22.4	16	22.6	19	22.7
21-10-2021 10:42	23	22.4	19	22.6	20	22.7
21-10-2021 10:43	23	22.3	17	22.6	20	22.7
21-10-2021 10:44	22	22.4	18	22.6	19	22.7
21-10-2021 10:45	23	22.3	17	22.5	20	22.7
21-10-2021 10:46	21	22.3	16	22.5	19	22.7
21-10-2021 10:47	24	22.3	19	22.5	20	22.7
21-10-2021 10:48	22	22.3	18	22.5	19	22.7
21-10-2021 10:49	23	22.3	18	22.5	20	22.7
21-10-2021 10:50	23	22.3	19	22.5	20	22.7
21-10-2021 10:51	25	22.3	18	22.5	19	22.7
21-10-2021 10:52	15	22.3	23	22.4	22	22.7
21-10-2021 10:53	22	22.3	18	22.4	19	22.7
21-10-2021 10:54	21	22.3	17	22.4	20	22.7
21-10-2021 10:55	23	22.3	21	22.4	21	22.7
21-10-2021 10:56	21	22.2	18	22.4	19	22.7
21-10-2021 10:57	21	22.3	18	22.4	20	22.7
21-10-2021 10:58	24	22.2	19	22.4	20	22.7
21-10-2021 10:59	22	22.2	18	22.4	19	22.6
21-10-2021 11:00	22	22.2	18	22.4	20	22.6
21-10-2021 11:01	21	22.2	18	22.4	20	22.6
21-10-2021 11:02	26	22.2	20	22.4	20	22.6
21-10-2021 11:03	26	22.2	20	22.4	21	22.6
21-10-2021 11:04	26	22.2	16	22.4	18	22.6
21-10-2021 11:05	25	22.1	19	22.4	20	22.6
21-10-2021 11:06	25	22.1	18	22.4	20	22.6
21-10-2021 11:07	23	22.1	18	22.4	20	22.6
21-10-2021 11:08	23	22.2	18	22.4	20	22.6





# Environmental Monitoring System

## DATA REPORT

### STERILE EXIT CHANGE ROOMS (L3)

Date Time	STERILE PASSAGE (L3) wrt EXIT ROOM-1 (L3)	STERILE EXIT ROOM-1 (L3)	ASEPTIC EXIT ROOM-1 (L3) wrt EXIT ROOM-2 (L3)	STERILE EXIT ROOM-2 (L3)	ASEPTIC EXIT ROOM-2 (L3) wrt EXIT ROOM-3 (L3)	STERILE EXIT ROOM-3 (L3)
Date Time	DP Pa	°C TEMP	DP Pa	°C TEMP	DP Pa	°C TEMP
21-10-2021 11:09	23	22.2	18	22.5	19	22.6
21-10-2021 11:10	28	22.2	20	22.5	21	22.6
21-10-2021 11:11	23	22.2	18	22.5	20	22.6
21-10-2021 11:12	23	22.2	18	22.5	19	22.6
21-10-2021 11:13	30	22.2	0	22.5	28	22.6
21-10-2021 11:14	24	22.3	18	22.5	16	22.6
21-10-2021 11:15	23	22.3	18	22.5	20	22.7
21-10-2021 11:16	24	22.3	15	22.6	18	22.7
21-10-2021 11:17	23	22.3	17	22.6	20	22.7
21-10-2021 11:18	23	22.3	18	22.6	19	22.7
21-10-2021 11:19	23	22.3	18	22.6	20	22.7
21-10-2021 11:20	25	22.3	18	22.6	20	22.7
21-10-2021 11:21	23	22.3	18	22.6	20	22.7
21-10-2021 11:22	25	22.3	19	22.6	21	22.7
21-10-2021 11:23	24	22.3	19	22.6	21	22.7
21-10-2021 11:24	24	22.3	19	22.6	20	22.7
21-10-2021 11:25	23	22.3	18	22.6	20	22.7
21-10-2021 11:26	23	22.3	19	22.6	20	22.7
21-10-2021 11:27	25	22.3	19	22.6	20	22.7
21-10-2021 11:28	25	22.3	19	22.6	20	22.7
21-10-2021 11:29	25	22.3	19	22.6	20	22.7
21-10-2021 11:30	25	22.3	19	22.6	20	22.7
21-10-2021 11:31	27	22.2	19	22.6	20	22.7
21-10-2021 11:32	24	22.2	18	22.6	21	22.7
21-10-2021 11:33	23	22.2	18	22.6	20	22.7
21-10-2021 11:34	27	22.2	20	22.5	20	22.7
21-10-2021 11:35	24	22.2	18	22.5	19	22.7
21-10-2021 11:36	24	22.1	18	22.5	20	22.7



# Environmental Monitoring System

## DATA REPORT

### STERILE EXIT CHANGE ROOMS (L3)

Date Time	STERILE PASSAGE (L3) wrt EXIT ROOM-1 (L3)	STERILE EXIT ROOM-1 (L3)	ASEPTIC EXIT ROOM-1 (L3) wrt EXIT ROOM-2 (L3)	STERILE EXIT ROOM-2 (L3)	ASEPTIC EXIT ROOM-2 (L3) wrt EXIT ROOM-3 (L3)	STERILE EXIT ROOM-3 (L3)
Date Time	DP Pa	°C TEMP	DP Pa	°C TEMP	DP Pa	°C TEMP
21-10-2021 11:37	24	22.1	18	22.5	20	22.7
21-10-2021 11:38	25	22.1	19	22.5	20	22.8
21-10-2021 11:39	26	22.1	18	22.5	21	22.8
21-10-2021 11:40	25	22.1	18	22.5	20	22.8
21-10-2021 11:41	25	22.0	20	22.5	21	22.8
21-10-2021 11:42	23	22.1	18	22.5	20	22.7
21-10-2021 11:43	25	22.0	18	22.4	20	22.7
21-10-2021 11:44	25	22.0	20	22.4	21	22.7
21-10-2021 11:45	25	22.0	19	22.4	20	22.7
21-10-2021 11:46	24	22.0	18	22.4	20	22.7
21-10-2021 11:47	25	22.0	18	22.4	20	22.8
21-10-2021 11:48	25	22.0	19	22.4	20	22.7
21-10-2021 11:49	25	22.0	19	22.4	21	22.7
21-10-2021 11:50	24	22.0	18	22.4	20	22.7
21-10-2021 11:51	25	22.0	20	22.4	21	22.7
21-10-2021 11:52	23	22.0	16	22.4	19	22.7
21-10-2021 11:53	23	22.0	18	22.4	20	22.7
21-10-2021 11:54	23	22.0	16	22.3	18	22.7
21-10-2021 11:55	23	22.0	20	22.3	20	22.7
21-10-2021 11:56	25	21.9	18	22.3	20	22.7
21-10-2021 11:57	24	21.9	18	22.3	20	22.6
21-10-2021 11:58	25	21.9	19	22.3	21	22.6
21-10-2021 11:59	26	21.9	19	22.3	20	22.6
21-10-2021 12:00	30	22.0	20	22.3	20	22.6
21-10-2021 12:01	25	22.0	20	22.4	21	22.6
21-10-2021 12:02	24	22.1	19	22.4	21	22.6
21-10-2021 12:03	28	22.1	20	22.4	21	22.6
21-10-2021 12:04	24	22.1	18	22.4	20	22.6



# Environmental Monitoring System

## DATA REPORT

### STERILE EXIT CHANGE ROOMS (L3)

Date Time	STERILE PASSAGE (L3) wrt EXIT ROOM-1 (L3)	STERILE EXIT ROOM-1 (L3)	ASEPTIC EXIT ROOM-1 (L3) wrt EXIT ROOM-2 (L3)	STERILE EXIT ROOM-2 (L3)	ASEPTIC EXIT ROOM-2 (L3) wrt EXIT ROOM-3 (L3)	STERILE EXIT ROOM-3 (L3)
Date Time	DP Pa	°C TEMP	DP Pa	°C TEMP	DP Pa	°C TEMP
21-10-2021 12:05	24	22.1	18	22.4	20	22.6
21-10-2021 12:06	23	22.1	16	22.4	14	22.6
21-10-2021 12:07	27	22.2	20	22.4	20	22.6
21-10-2021 12:08	23	22.2	17	22.4	20	22.6
21-10-2021 12:09	23	22.2	15	22.5	16	22.6
21-10-2021 12:10	23	22.2	17	22.5	20	22.6
21-10-2021 12:11	23	22.3	17	22.5	20	22.6
21-10-2021 12:12	23	22.3	18	22.5	20	22.6
21-10-2021 12:13	21	22.4	18	22.5	20	22.6
21-10-2021 12:14	23	22.4	18	22.6	19	22.6
21-10-2021 12:15	25	22.4	19	22.6	20	22.6
21-10-2021 12:16	24	22.4	18	22.6	20	22.6
21-10-2021 12:17	22	22.5	18	22.6	19	22.6
21-10-2021 12:18	22	22.5	17	22.6	20	22.6
21-10-2021 12:19	25	22.5	18	22.6	19	22.6
21-10-2021 12:20	23	22.5	17	22.7	20	22.6
21-10-2021 12:21	24	22.6	18	22.7	20	22.6
21-10-2021 12:22	25	22.6	19	22.7	20	22.6
21-10-2021 12:23	22	22.6	18	22.7	19	22.6
21-10-2021 12:24	23	22.6	18	22.7	20	22.6
21-10-2021 12:25	24	22.6	18	22.7	21	22.6
21-10-2021 12:26	25	22.6	19	22.7	20	22.6
21-10-2021 12:27	23	22.6	18	22.7	20	22.6
21-10-2021 12:28	24	22.6	19	22.7	20	22.6
21-10-2021 12:29	24	22.6	18	22.7	19	22.6
21-10-2021 12:30	23	22.6	18	22.7	20	22.6
21-10-2021 12:31	27	22.6	20	22.6	22	22.6
21-10-2021 12:32	24	22.5	18	22.6	20	22.6



# Environmental Monitoring System

## DATA REPORT

### STERILE EXIT CHANGE ROOMS (L3)

Date Time	STERILE PASSAGE (L3) wrt EXIT ROOM-1 (L3)	STERILE EXIT ROOM-1 (L3)	ASEPTIC EXIT ROOM-1 (L3) wrt EXIT ROOM-2 (L3)	STERILE EXIT ROOM-2 (L3)	ASEPTIC EXIT ROOM-2 (L3) wrt EXIT ROOM-3 (L3)	STERILE EXIT ROOM-3 (L3)
Date Time	DP Pa	°C TEMP	DP Pa	°C TEMP	DP Pa	°C TEMP
21-10-2021 12:33	23	22.5	17	22.6	20	22.6
21-10-2021 12:34	24	22.5	18	22.6	20	22.6
21-10-2021 12:35	28	22.4	20	22.6	20	22.6
21-10-2021 12:36	24	22.4	18	22.6	21	22.6
21-10-2021 12:37	24	22.4	18	22.6	20	22.6
21-10-2021 12:38	23	22.4	18	22.6	20	22.6
21-10-2021 12:39	24	22.4	18	22.5	20	22.6
21-10-2021 12:40	24	22.3	18	22.5	20	22.6
21-10-2021 12:41	24	22.3	17	22.5	20	22.6
21-10-2021 12:42	23	22.3	18	22.5	20	22.6
21-10-2021 12:43	25	22.2	18	22.5	20	22.6
21-10-2021 12:44	27	22.2	19	22.5	21	22.6
21-10-2021 12:45	27	22.2	20	22.5	21	22.6
21-10-2021 12:46	25	22.2	19	22.5	20	22.6
21-10-2021 12:47	30	22.1	21	22.5	21	22.5
21-10-2021 12:48	29	22.1	21	22.5	21	22.6
21-10-2021 12:49	30	22.1	22	22.4	22	22.6
21-10-2021 12:50	28	22.1	21	22.4	21	22.7
21-10-2021 12:51	23	22.0	19	22.4	20	22.7
21-10-2021 12:52	24	22.0	21	22.4	16	22.7
21-10-2021 12:53	24	22.0	19	22.4	21	22.7
21-10-2021 12:54	23	22.0	17	22.4	20	22.7
21-10-2021 12:55	23	22.0	18	22.4	20	22.7
21-10-2021 12:56	27	22.1	19	22.4	20	22.7
21-10-2021 12:57	23	22.1	18	22.4	20	22.7
21-10-2021 12:58	21	22.0	17	22.4	19	22.7
21-10-2021 12:59	23	22.0	18	22.3	20	22.7
21-10-2021 13:00	21	22.0	17	22.3	20	22.7



# Environmental Monitoring System

## DATA REPORT

### STERILE EXIT CHANGE ROOMS (L3)

Date Time	STERILE PASSAGE (L3) wrt EXIT ROOM-1 (L3)	STERILE EXIT ROOM-1 (L3)	ASEPTIC EXIT ROOM-1 (L3) wrt EXIT ROOM-2 (L3)	STERILE EXIT ROOM-2 (L3)	ASEPTIC EXIT ROOM-2 (L3) wrt EXIT ROOM-3 (L3)	STERILE EXIT ROOM-3 (L3)
Date Time	DP Pa	°C TEMP	DP Pa	°C TEMP	DP Pa	°C TEMP
21-10-2021 13:01	24	22.0	19	22.3	20	22.8
21-10-2021 13:02	21	22.1	18	22.3	18	22.8
21-10-2021 13:03	23	22.1	18	22.3	21	22.8
21-10-2021 13:04	22	22.1	18	22.3	20	22.8
21-10-2021 13:05	23	22.1	18	22.3	21	22.7
21-10-2021 13:06	21	22.1	17	22.3	20	22.7
21-10-2021 13:07	21	22.1	17	22.3	21	22.7
21-10-2021 13:08	25	22.1	19	22.4	21	22.7
21-10-2021 13:09	24	22.1	20	22.4	21	22.7
21-10-2021 13:10	32	22.0	0	22.4	32	22.7
21-10-2021 13:11	23	22.1	18	22.4	20	22.7
21-10-2021 13:12	23	22.1	19	22.4	21	22.7
21-10-2021 13:13	29	22.1	22	22.4	21	22.7
21-10-2021 13:14	25	22.1	20	22.4	21	22.7
21-10-2021 13:15	25	22.1	20	22.4	21	22.7
21-10-2021 13:16	27	22.1	16	22.5	17	22.7
21-10-2021 13:17	25	22.2	16	22.5	17	22.7
21-10-2021 13:18	25	22.2	18	22.5	18	22.8
21-10-2021 13:19	25	22.2	19	22.5	21	22.8
21-10-2021 13:20	26	22.2	20	22.5	22	22.8
21-10-2021 13:21	25	22.3	20	22.6	21	22.8
21-10-2021 13:22	25	22.3	20	22.6	21	22.8
21-10-2021 13:23	25	22.3	20	22.6	21	22.8
21-10-2021 13:24	25	22.4	20	22.6	21	22.8
21-10-2021 13:25	25	22.4	20	22.6	21	22.8
21-10-2021 13:26	30	22.4	20	22.7	22	22.8
21-10-2021 13:27	25	22.4	20	22.7	22	22.8
21-10-2021 13:28	25	22.4	20	22.7	21	22.8



# Environmental Monitoring System

## DATA REPORT

### STERILE EXIT CHANGE ROOMS (L3)

Date Time	STERILE PASSAGE (L3) wrt EXIT ROOM-1 (L3)	STERILE EXIT ROOM-1 (L3)	ASEPTIC EXIT ROOM-1 (L3) wrt EXIT ROOM-2 (L3)	STERILE EXIT ROOM-2 (L3)	ASEPTIC EXIT ROOM-2 (L3) wrt EXIT ROOM-3 (L3)	STERILE EXIT ROOM-3 (L3)
Date Time	DP Pa	°C TEMP	DP Pa	°C TEMP	DP Pa	°C TEMP
21-10-2021 13:29	25	22.4	20	22.7	21	22.8
21-10-2021 13:30	25	22.5	20	22.7	22	22.8
21-10-2021 13:31	25	22.5	20	22.7	22	22.8
21-10-2021 13:32	25	22.5	20	22.7	21	22.8
21-10-2021 13:33	7	22.5	29	22.7	27	22.8
21-10-2021 13:34	18	22.5	22	22.8	21	22.9
21-10-2021 13:35	24	22.5	20	22.8	23	22.9
21-10-2021 13:36	24	22.5	19	22.8	20	22.9
21-10-2021 13:37	27	22.5	20	22.8	21	22.9
21-10-2021 13:38	25	22.5	20	22.8	21	22.9
21-10-2021 13:39	25	22.5	20	22.8	21	22.8
21-10-2021 13:40	25	22.4	20	22.7	21	22.8
21-10-2021 13:41	25	22.4	20	22.7	22	22.8
21-10-2021 13:42	25	22.4	20	22.7	21	22.8
21-10-2021 13:43	26	22.4	21	22.7	22	22.8
21-10-2021 13:44	26	22.3	16	22.7	18	22.8
21-10-2021 13:45	25	22.3	16	22.6	18	22.8
21-10-2021 13:46	25	22.3	20	22.6	21	22.8
21-10-2021 13:47	26	22.3	19	22.6	21	22.8
21-10-2021 13:48	25	22.3	20	22.6	21	22.8
21-10-2021 13:49	25	22.2	20	22.6	21	22.8
21-10-2021 13:50	25	22.2	20	22.6	22	22.8
21-10-2021 13:51	26	22.2	20	22.5	21	22.8
21-10-2021 13:52	26	22.2	20	22.5	23	22.8
21-10-2021 13:53	25	22.1	20	22.5	21	22.8
21-10-2021 13:54	26	22.1	20	22.5	21	22.8
21-10-2021 13:55	25	22.1	19	22.5	21	22.8
21-10-2021 13:56	25	22.1	20	22.5	21	22.8



# Environmental Monitoring System

## DATA REPORT

### STERILE EXIT CHANGE ROOMS (L3)

Date Time	STERILE PASSAGE (L3) wrt EXIT ROOM-1 (L3)	STERILE EXIT ROOM-1 (L3)	ASEPTIC EXIT ROOM-1 (L3) wrt EXIT ROOM-2 (L3)	STERILE EXIT ROOM-2 (L3)	ASEPTIC EXIT ROOM-2 (L3) wrt EXIT ROOM-3 (L3)	STERILE EXIT ROOM-3 (L3)
Date Time	DP Pa	°C TEMP	DP Pa	°C TEMP	DP Pa	°C TEMP
21-10-2021 13:57	27	22.1	16	22.5	18	22.8
21-10-2021 13:58	25	22.1	20	22.5	21	22.8
21-10-2021 13:59	23	22.1	19	22.4	20	22.7
21-10-2021 14:00	25	22.0	20	22.4	21	22.7
21-10-2021 14:01	25	22.0	19	22.4	20	22.7
21-10-2021 14:02	25	22.0	20	22.4	22	22.7
21-10-2021 14:03	25	22.0	20	22.4	21	22.7
21-10-2021 14:04	26	22.0	20	22.4	21	22.7
21-10-2021 14:05	25	22.0	20	22.4	21	22.7
21-10-2021 14:06	27	22.0	20	22.4	20	22.7
21-10-2021 14:07	29	22.0	22	22.4	23	22.7
21-10-2021 14:08	23	21.9	16	22.4	17	22.7
21-10-2021 14:09	25	21.9	20	22.3	21	22.7
21-10-2021 14:10	25	21.9	20	22.3	21	22.7
21-10-2021 14:11	28	21.9	20	22.3	21	22.7
21-10-2021 14:12	30	21.9	21	22.3	23	22.7
21-10-2021 14:13	25	21.9	20	22.3	21	22.6
21-10-2021 14:14	23	21.9	20	22.4	21	22.6
21-10-2021 14:15	26	21.9	19	22.3	21	22.6
21-10-2021 14:16	25	21.9	20	22.4	21	22.6
21-10-2021 14:17	24	21.9	20	22.4	22	22.6
21-10-2021 14:18	25	22.0	21	22.4	22	22.6
21-10-2021 14:19	24	22.0	20	22.4	21	22.6
21-10-2021 14:20	25	22.0	20	22.4	21	22.6
21-10-2021 14:21	26	22.0	20	22.4	21	22.6
21-10-2021 14:22	24	22.0	20	22.4	21	22.6
21-10-2021 14:23	25	22.0	19	22.4	21	22.6
21-10-2021 14:24	26	22.1	20	22.5	21	22.6



# Environmental Monitoring System

## DATA REPORT

### STERILE EXIT CHANGE ROOMS (L3)

Date Time	STERILE PASSAGE (L3) wrt EXIT ROOM-1 (L3)	STERILE EXIT ROOM-1 (L3)	ASEPTIC EXIT ROOM-1 (L3) wrt EXIT ROOM-2 (L3)	STERILE EXIT ROOM-2 (L3)	ASEPTIC EXIT ROOM-2 (L3) wrt EXIT ROOM-3 (L3)	STERILE EXIT ROOM-3 (L3)
Date Time	DP Pa	°C TEMP	DP Pa	°C TEMP	DP Pa	°C TEMP
21-10-2021 14:25	27	22.1	20	22.5	22	22.6
21-10-2021 14:26	27	22.1	20	22.5	21	22.6
21-10-2021 14:27	26	22.1	20	22.5	21	22.6
21-10-2021 14:28	25	22.1	20	22.6	21	22.6
21-10-2021 14:29	25	22.2	19	22.6	21	22.6
21-10-2021 14:30	26	22.2	20	22.6	21	22.6
21-10-2021 14:31	25	22.2	18	22.6	20	22.6
21-10-2021 14:32	26	22.3	19	22.7	20	22.6
21-10-2021 14:33	27	22.3	19	22.7	21	22.7
21-10-2021 14:34	27	22.3	20	22.7	21	22.7
21-10-2021 14:35	25	22.3	20	22.7	21	22.7
21-10-2021 14:36	25	22.3	20	22.7	21	22.7
21-10-2021 14:37	26	22.4	21	22.7	21	22.7
21-10-2021 14:38	25	22.4	20	22.8	21	22.7
21-10-2021 14:39	23	22.5	19	22.8	20	22.7
21-10-2021 14:40	25	22.5	20	22.8	23	22.7
21-10-2021 14:41	25	22.6	19	22.8	21	22.7
21-10-2021 14:42	25	22.6	20	22.8	21	22.7
21-10-2021 14:43	25	22.6	20	22.8	20	22.7
21-10-2021 14:44	25	22.6	20	22.8	20	22.7
21-10-2021 14:45	29	22.6	22	22.9	21	22.7
21-10-2021 14:46	24	22.6	20	22.9	21	22.7
21-10-2021 14:47	16	22.7	21	22.9	24	22.7
21-10-2021 14:48	23	22.7	21	22.9	21	22.7
21-10-2021 14:49	25	22.7	20	22.9	21	22.8
21-10-2021 14:50	23	22.7	18	22.9	20	22.8
21-10-2021 14:51	20	22.6	17	22.9	20	22.8
21-10-2021 14:52	24	22.6	19	22.9	20	22.8





# Environmental Monitoring System

## DATA REPORT

### STERILE EXIT CHANGE ROOMS (L3)

Date Time	STERILE PASSAGE (L3) wrt EXIT ROOM-1 (L3)	STERILE EXIT ROOM-1 (L3)	ASEPTIC EXIT ROOM-1 (L3) wrt EXIT ROOM-2 (L3)	STERILE EXIT ROOM-2 (L3)	ASEPTIC EXIT ROOM-2 (L3) wrt EXIT ROOM-3 (L3)	STERILE EXIT ROOM-3 (L3)
Date Time	DP Pa	°C TEMP	DP Pa	°C TEMP	DP Pa	°C TEMP
21-10-2021 14:53	25	22.6	20	22.9	22	22.8
21-10-2021 14:54	24	22.7	19	22.9	20	22.8
21-10-2021 14:55	23	22.7	20	22.9	21	22.8
21-10-2021 14:56	25	22.6	20	22.9	21	22.8
21-10-2021 14:57	23	22.7	18	22.9	20	22.8
21-10-2021 14:58	26	22.7	20	22.9	21	22.8
21-10-2021 14:59	29	22.6	21	22.9	23	22.8
21-10-2021 15:00	28	22.6	21	22.9	22	22.7
21-10-2021 15:01	24	22.6	20	22.8	21	22.7
21-10-2021 15:02	24	22.6	20	22.8	21	22.7
21-10-2021 15:03	26	22.6	20	22.8	21	22.7
21-10-2021 15:04	23	22.5	19	22.8	21	22.7
21-10-2021 15:05	25	22.5	18	22.8	21	22.7
21-10-2021 15:06	28	22.5	21	22.8	21	22.7
21-10-2021 15:07	22	22.5	19	22.7	21	22.7
21-10-2021 15:08	25	22.4	20	22.7	20	22.7
21-10-2021 15:09	25	22.4	20	22.7	20	22.7
21-10-2021 15:10	24	22.4	18	22.7	19	22.7
21-10-2021 15:11	24	22.3	19	22.6	21	22.7
21-10-2021 15:12	23	22.3	18	22.6	21	22.7
21-10-2021 15:13	25	22.3	20	22.6	21	22.7
21-10-2021 15:14	27	22.3	18	22.6	20	22.7
21-10-2021 15:15	26	22.2	19	22.6	20	22.7
21-10-2021 15:16	26	22.2	18	22.5	20	22.6
21-10-2021 15:17	23	22.2	19	22.5	21	22.6
21-10-2021 15:18	23	22.2	16	22.5	18	22.6
21-10-2021 15:19	25	22.1	18	22.5	20	22.6
21-10-2021 15:20	24	22.1	20	22.5	20	22.6



# Environmental Monitoring System

## DATA REPORT

### STERILE EXIT CHANGE ROOMS (L3)

Date Time	STERILE PASSAGE (L3) wrt EXIT ROOM-1 (L3)	STERILE EXIT ROOM-1 (L3)	ASEPTIC EXIT ROOM-1 (L3) wrt EXIT ROOM-2 (L3)	STERILE EXIT ROOM-2 (L3)	ASEPTIC EXIT ROOM-2 (L3) wrt EXIT ROOM-3 (L3)	STERILE EXIT ROOM-3 (L3)
Date Time	DP Pa	°C TEMP	DP Pa	°C TEMP	DP Pa	°C TEMP
21-10-2021 15:21	26	22.1	20	22.4	21	22.6
21-10-2021 15:22	25	22.1	20	22.4	21	22.6
21-10-2021 15:23	25	22.1	19	22.4	20	22.6
21-10-2021 15:24	23	22.1	18	22.4	20	22.6
21-10-2021 15:25	23	22.1	19	22.4	20	22.6
21-10-2021 15:26	25	22.1	20	22.4	21	22.6
21-10-2021 15:27	23	22.2	19	22.4	20	22.6
21-10-2021 15:28	25	22.2	20	22.4	21	22.6
21-10-2021 15:29	22	22.3	19	22.5	22	22.6
21-10-2021 15:30	25	22.3	20	22.5	20	22.6
21-10-2021 15:31	23	22.3	19	22.5	22	22.5
21-10-2021 15:32	26	22.3	21	22.5	22	22.5
21-10-2021 15:33	24	22.3	20	22.5	21	22.5
21-10-2021 15:34	24	22.4	20	22.5	22	22.5
21-10-2021 15:35	23	22.4	19	22.5	21	22.5
21-10-2021 15:36	21	22.4	20	22.5	20	22.5
21-10-2021 15:37	28	22.4	22	22.5	23	22.5
21-10-2021 15:38	22	22.5	20	22.5	23	22.5
21-10-2021 15:39	27	22.5	23	22.6	23	22.5
21-10-2021 15:40	23	22.5	20	22.6	21	22.5
21-10-2021 15:41	27	22.5	21	22.6	21	22.5
21-10-2021 15:42	24	22.5	20	22.6	21	22.5
21-10-2021 15:43	25	22.5	20	22.6	21	22.5
21-10-2021 15:44	24	22.5	19	22.6	21	22.5
21-10-2021 15:45	24	22.5	20	22.6	21	22.5
21-10-2021 15:46	24	22.5	19	22.6	20	22.5
21-10-2021 15:47	23	22.5	20	22.6	20	22.5
21-10-2021 15:48	23	22.5	20	22.6	21	22.5



# Environmental Monitoring System

## DATA REPORT

### STERILE EXIT CHANGE ROOMS (L3)

Date Time	STERILE PASSAGE (L3) wrt EXIT ROOM-1 (L3)	STERILE EXIT ROOM-1 (L3)	ASEPTIC EXIT ROOM-1 (L3) wrt EXIT ROOM-2 (L3)	STERILE EXIT ROOM-2 (L3)	ASEPTIC EXIT ROOM-2 (L3) wrt EXIT ROOM-3 (L3)	STERILE EXIT ROOM-3 (L3)
Date Time	DP Pa	°C TEMP	DP Pa	°C TEMP	DP Pa	°C TEMP
21-10-2021 15:49	24	22.5	20	22.6	21	22.5
21-10-2021 15:50	23	22.5	18	22.6	21	22.6
21-10-2021 15:51	23	22.5	20	22.7	21	22.6
21-10-2021 15:52	23	22.6	20	22.6	20	22.7
21-10-2021 15:53	25	22.6	20	22.6	21	22.7
21-10-2021 15:54	23	22.6	19	22.6	21	22.7
21-10-2021 15:55	23	22.6	20	22.6	21	22.7
21-10-2021 15:56	28	22.6	21	22.6	22	22.6
21-10-2021 15:57	23	22.6	19	22.6	21	22.6
21-10-2021 15:58	22	22.5	20	22.6	20	22.6
21-10-2021 15:59	23	22.5	19	22.6	21	22.6
21-10-2021 16:00	23	22.5	18	22.6	20	22.6
21-10-2021 16:01	24	22.5	18	22.6	21	22.6
21-10-2021 16:02	24	22.5	18	22.6	21	22.6
21-10-2021 16:03	23	22.5	19	22.6	20	22.6
21-10-2021 16:04	27	22.5	21	22.6	22	22.6
21-10-2021 16:05	27	22.5	21	22.6	23	22.6
21-10-2021 16:06	24	22.5	20	22.5	21	22.5
21-10-2021 16:07	23	22.5	19	22.5	21	22.5
21-10-2021 16:08	23	22.5	20	22.5	21	22.5
21-10-2021 16:09	24	22.4	19	22.5	21	22.5
21-10-2021 16:10	27	22.4	21	22.5	23	22.5
21-10-2021 16:11	24	22.4	20	22.5	21	22.5
21-10-2021 16:12	23	22.4	20	22.5	20	22.5
21-10-2021 16:13	24	22.5	18	22.5	21	22.5
21-10-2021 16:14	24	22.5	20	22.5	21	22.5
21-10-2021 16:15	23	22.5	20	22.5	21	22.5
21-10-2021 16:16	26	22.5	20	22.6	21	22.5



# Environmental Monitoring System

## DATA REPORT

### STERILE EXIT CHANGE ROOMS (L3)

Date Time	STERILE PASSAGE (L3) wrt EXIT ROOM-1 (L3)	STERILE EXIT ROOM-1 (L3)	ASEPTIC EXIT ROOM-1 (L3) wrt EXIT ROOM-2 (L3)	STERILE EXIT ROOM-2 (L3)	ASEPTIC EXIT ROOM-2 (L3) wrt EXIT ROOM-3 (L3)	STERILE EXIT ROOM-3 (L3)
Date Time	DP Pa	°C TEMP	DP Pa	°C TEMP	DP Pa	°C TEMP
21-10-2021 16:17	25	22.5	20	22.6	21	22.5
21-10-2021 16:18	27	22.5	21	22.6	21	22.5
21-10-2021 16:19	25	22.5	21	22.6	21	22.5
21-10-2021 16:20	24	22.6	20	22.7	21	22.5
21-10-2021 16:21	23	22.6	19	22.7	20	22.5
21-10-2021 16:22	25	22.6	20	22.7	20	22.5
21-10-2021 16:23	24	22.6	20	22.7	20	22.5
21-10-2021 16:24	30	22.6	23	22.7	23	22.5
21-10-2021 16:25	23	22.7	20	22.8	20	22.5
21-10-2021 16:26	24	22.7	20	22.8	20	22.6
21-10-2021 16:27	23	22.8	20	22.8	21	22.6
21-10-2021 16:28	23	22.8	19	22.8	21	22.6
21-10-2021 16:29	24	22.8	19	22.8	20	22.6
21-10-2021 16:30	24	22.8	20	22.9	20	22.6
21-10-2021 16:31	24	22.8	21	22.9	21	22.6
21-10-2021 16:32	24	22.9	19	22.9	20	22.6
21-10-2021 16:33	23	22.9	20	22.9	20	22.6
21-10-2021 16:34	25	22.9	20	22.9	21	22.6
21-10-2021 16:35	28	22.9	21	22.9	22	22.6
21-10-2021 16:36	23	22.9	20	23.0	21	22.6
21-10-2021 16:37	23	22.9	20	23.0	20	22.7
21-10-2021 16:38	23	23.0	19	23.0	20	22.7
21-10-2021 16:39	21	23.0	18	23.0	20	22.7
21-10-2021 16:40	25	23.0	20	23.0	21	22.7
21-10-2021 16:41	23	23.0	20	23.0	20	22.7
21-10-2021 16:42	23	22.9	19	23.0	22	22.7
21-10-2021 16:43	24	23.0	20	23.0	22	22.7
21-10-2021 16:44	23	23.0	20	23.0	21	22.7



# Environmental Monitoring System

## DATA REPORT

### STERILE EXIT CHANGE ROOMS (L3)

Date Time	STERILE PASSAGE (L3) wrt EXIT ROOM-1 (L3)	STERILE EXIT ROOM-1 (L3)	ASEPTIC EXIT ROOM-1 (L3) wrt EXIT ROOM-2 (L3)	STERILE EXIT ROOM-2 (L3)	ASEPTIC EXIT ROOM-2 (L3) wrt EXIT ROOM-3 (L3)	STERILE EXIT ROOM-3 (L3)
Date Time	DP Pa	°C TEMP	DP Pa	°C TEMP	DP Pa	°C TEMP
21-10-2021 16:45	23	23.0	20	23.0	21	22.7
21-10-2021 16:46	24	23.0	19	23.0	20	22.7
21-10-2021 16:47	24	22.9	20	22.9	20	22.7
21-10-2021 16:48	23	22.9	19	22.9	21	22.7
21-10-2021 16:49	23	22.9	19	22.9	20	22.7
21-10-2021 16:50	23	22.9	19	22.9	21	22.7
21-10-2021 16:51	23	22.8	20	22.9	21	22.7
21-10-2021 16:52	22	22.9	19	22.9	21	22.7
21-10-2021 16:53	24	22.8	20	22.8	20	22.7
21-10-2021 16:54	24	22.8	20	22.8	21	22.7
21-10-2021 16:55	23	22.7	20	22.8	20	22.7
21-10-2021 16:56	25	22.7	20	22.8	20	22.7
21-10-2021 16:57	25	22.7	20	22.8	21	22.7
21-10-2021 16:58	23	22.7	20	22.7	20	22.7
21-10-2021 16:59	23	22.6	20	22.7	21	22.7
21-10-2021 17:00	27	22.6	21	22.7	21	22.7
21-10-2021 17:01	25	22.6	20	22.7	21	22.7
21-10-2021 17:02	23	22.6	20	22.6	21	22.8
21-10-2021 17:03	25	22.6	20	22.6	21	22.7
21-10-2021 17:04	21	22.5	20	22.6	21	22.7
21-10-2021 17:05	23	22.5	21	22.6	21	22.7
21-10-2021 17:06	23	22.5	20	22.6	21	22.7
21-10-2021 17:07	24	22.5	20	22.5	22	22.7
21-10-2021 17:08	23	22.5	19	22.5	21	22.7
21-10-2021 17:09	23	22.4	21	22.5	22	22.6
21-10-2021 17:10	23	22.4	20	22.5	20	22.6
21-10-2021 17:11	23	22.4	20	22.5	20	22.6
21-10-2021 17:12	23	22.4	20	22.5	20	22.6



# Environmental Monitoring System

## DATA REPORT

### STERILE EXIT CHANGE ROOMS (L3)

Date Time	STERILE PASSAGE (L3) wrt EXIT ROOM-1 (L3)	STERILE EXIT ROOM-1 (L3)	ASEPTIC EXIT ROOM-1 (L3) wrt EXIT ROOM-2 (L3)	STERILE EXIT ROOM-2 (L3)	ASEPTIC EXIT ROOM-2 (L3) wrt EXIT ROOM-3 (L3)	STERILE EXIT ROOM-3 (L3)
Date Time	DP Pa	°C TEMP	DP Pa	°C TEMP	DP Pa	°C TEMP
21-10-2021 17:13	23	22.4	20	22.5	21	22.6
21-10-2021 17:14	22	22.4	19	22.5	21	22.6
21-10-2021 17:15	23	22.4	20	22.5	21	22.6
21-10-2021 17:16	23	22.4	19	22.5	21	22.6
21-10-2021 17:17	24	22.4	20	22.5	22	22.6
21-10-2021 17:18	23	22.4	20	22.5	22	22.6
21-10-2021 17:19	25	22.4	20	22.5	22	22.5
21-10-2021 17:20	23	22.4	20	22.5	21	22.5
21-10-2021 17:21	23	22.4	20	22.5	21	22.5
21-10-2021 17:22	24	22.4	19	22.5	22	22.5
21-10-2021 17:23	23	22.4	20	22.5	23	22.5
21-10-2021 17:24	24	22.5	20	22.5	21	22.5
21-10-2021 17:25	24	22.5	20	22.6	21	22.5
21-10-2021 17:26	25	22.5	20	22.6	21	22.5
21-10-2021 17:27	23	22.5	20	22.6	21	22.5
21-10-2021 17:28	23	22.6	20	22.6	21	22.5
21-10-2021 17:29	25	22.6	20	22.6	23	22.5
21-10-2021 17:30	28	22.6	22	22.7	21	22.6
21-10-2021 17:31	25	22.6	20	22.7	21	22.6
21-10-2021 17:32	25	22.6	21	22.7	23	22.6
21-10-2021 17:33	25	22.6	21	22.7	21	22.6
21-10-2021 17:34	25	22.7	19	22.7	20	22.6
21-10-2021 17:35	25	22.7	20	22.8	22	22.6
21-10-2021 17:36	25	22.7	21	22.8	22	22.6
21-10-2021 17:37	23	22.7	20	22.8	21	22.6
21-10-2021 17:38	26	22.8	20	22.8	22	22.6
21-10-2021 17:39	24	22.8	20	22.8	21	22.6
21-10-2021 17:40	21	22.9	18	22.8	20	22.6



# Environmental Monitoring System

## DATA REPORT

### STERILE EXIT CHANGE ROOMS (L3)

Date Time	STERILE PASSAGE (L3) wrt EXIT ROOM-1 (L3)	STERILE EXIT ROOM-1 (L3)	ASEPTIC EXIT ROOM-1 (L3) wrt EXIT ROOM-2 (L3)	STERILE EXIT ROOM-2 (L3)	ASEPTIC EXIT ROOM-2 (L3) wrt EXIT ROOM-3 (L3)	STERILE EXIT ROOM-3 (L3)
Date Time	DP Pa	°C TEMP	DP Pa	°C TEMP	DP Pa	°C TEMP
21-10-2021 17:41	25	22.9	21	22.9	22	22.6
21-10-2021 17:42	26	22.9	21	22.9	22	22.6
21-10-2021 17:43	24	22.9	20	22.9	21	22.6
21-10-2021 17:44	28	22.9	22	22.9	21	22.6
21-10-2021 17:45	24	22.9	20	22.9	21	22.7
21-10-2021 17:46	23	23.0	19	22.9	21	22.7
21-10-2021 17:47	24	22.9	17	23.0	22	22.7
21-10-2021 17:48	23	23.0	18	23.0	20	22.7
21-10-2021 17:49	23	23.0	20	23.0	21	22.7
21-10-2021 17:50	23	23.0	20	23.0	21	22.8
21-10-2021 17:51	23	23.0	20	23.0	21	22.8
21-10-2021 17:52	23	23.0	20	23.0	21	22.8
21-10-2021 17:53	23	23.0	20	23.0	21	22.8
21-10-2021 17:54	23	23.0	20	23.0	22	22.8
21-10-2021 17:55	23	23.0	20	23.0	21	22.8
21-10-2021 17:56	24	23.0	20	23.0	21	22.8
21-10-2021 17:57	23	23.0	19	22.9	21	22.8
21-10-2021 17:58	23	22.9	20	22.9	21	22.8
21-10-2021 17:59	24	22.9	20	22.9	21	22.8
21-10-2021 18:00	25	22.9	20	22.9	21	22.8
21-10-2021 18:01	25	22.9	20	22.9	21	22.8
21-10-2021 18:02	25	22.8	20	22.9	22	22.7
21-10-2021 18:03	25	22.8	20	22.8	21	22.8
21-10-2021 18:04	24	22.7	18	22.8	20	22.8
21-10-2021 18:05	23	22.7	19	22.8	21	22.9
21-10-2021 18:06	27	22.7	20	22.8	21	22.9
21-10-2021 18:07	25	22.7	21	22.8	21	22.9
21-10-2021 18:08	24	22.7	20	22.7	21	23.0



# Environmental Monitoring System

## DATA REPORT

### STERILE EXIT CHANGE ROOMS (L3)

Date Time	STERILE PASSAGE (L3) wrt EXIT ROOM-1 (L3)	STERILE EXIT ROOM-1 (L3)	ASEPTIC EXIT ROOM-1 (L3) wrt EXIT ROOM-2 (L3)	STERILE EXIT ROOM-2 (L3)	ASEPTIC EXIT ROOM-2 (L3) wrt EXIT ROOM-3 (L3)	STERILE EXIT ROOM-3 (L3)
Date Time	DP Pa	°C TEMP	DP Pa	°C TEMP	DP Pa	°C TEMP
21-10-2021 18:09	23	22.7	20	22.7	21	22.9
21-10-2021 18:10	25	22.7	19	22.7	20	22.9
21-10-2021 18:11	23	22.6	20	22.7	21	22.9
21-10-2021 18:12	24	22.6	20	22.7	21	22.9
21-10-2021 18:13	22	22.6	18	22.7	21	22.9
21-10-2021 18:14	26	22.5	20	22.6	21	22.8
21-10-2021 18:15	24	22.5	20	22.6	20	22.8
21-10-2021 18:16	25	22.5	19	22.6	20	22.8
21-10-2021 18:17	24	22.5	19	22.6	20	22.8
21-10-2021 18:18	23	22.5	19	22.6	21	22.8
21-10-2021 18:19	25	22.5	20	22.6	22	22.8
21-10-2021 18:20	24	22.5	19	22.6	21	22.8
21-10-2021 18:21	24	22.5	19	22.6	21	22.8
21-10-2021 18:22	25	22.5	19	22.6	20	22.8
21-10-2021 18:23	26	22.5	20	22.6	21	22.8
21-10-2021 18:24	25	22.5	20	22.6	20	22.8
21-10-2021 18:25	23	22.5	18	22.6	19	22.8
21-10-2021 18:26	25	22.5	19	22.6	20	22.8
21-10-2021 18:27	25	22.5	19	22.7	21	22.8
21-10-2021 18:28	25	22.6	20	22.7	21	22.7
21-10-2021 18:29	23	22.6	20	22.7	21	22.7
21-10-2021 18:30	23	22.6	20	22.7	22	22.7
21-10-2021 18:31	24	22.7	20	22.7	21	22.7
21-10-2021 18:32	23	22.7	19	22.7	20	22.7
21-10-2021 18:33	23	22.7	20	22.7	21	22.7
21-10-2021 18:34	23	22.7	20	22.7	21	22.7
21-10-2021 18:35	23	22.7	19	22.8	21	22.7
21-10-2021 18:36	25	22.8	20	22.8	21	22.7





# Environmental Monitoring System

## DATA REPORT

### STERILE EXIT CHANGE ROOMS (L3)

Date Time	STERILE PASSAGE (L3) wrt EXIT ROOM-1 (L3)	STERILE EXIT ROOM-1 (L3)	ASEPTIC EXIT ROOM-1 (L3) wrt EXIT ROOM-2 (L3)	STERILE EXIT ROOM-2 (L3)	ASEPTIC EXIT ROOM-2 (L3) wrt EXIT ROOM-3 (L3)	STERILE EXIT ROOM-3 (L3)
Date Time	DP Pa	°C TEMP	DP Pa	°C TEMP	DP Pa	°C TEMP
21-10-2021 18:37	23	22.8	20	22.8	21	22.7
21-10-2021 18:38	23	22.8	20	22.8	21	22.7
21-10-2021 18:39	23	22.8	19	22.8	21	22.7
21-10-2021 18:40	23	22.8	20	22.8	22	22.7
21-10-2021 18:41	23	22.9	20	22.8	21	22.7
21-10-2021 18:42	24	22.9	20	22.9	21	22.7
21-10-2021 18:43	23	22.9	20	22.9	21	22.7
21-10-2021 18:44	23	22.9	20	22.9	21	22.7
21-10-2021 18:45	23	22.9	20	22.9	21	22.8
21-10-2021 18:46	24	22.9	19	22.9	21	22.8
21-10-2021 18:47	25	22.9	18	22.9	20	22.8
21-10-2021 18:48	25	22.9	19	22.9	20	22.8
21-10-2021 18:49	27	22.9	20	23.0	21	22.8
21-10-2021 18:50	24	22.9	20	23.0	21	22.8
21-10-2021 18:51	27	23.0	20	23.0	21	22.8
21-10-2021 18:52	23	23.0	19	23.0	21	22.8
21-10-2021 18:53	25	23.0	20	23.0	20	22.8
21-10-2021 18:54	26	23.0	21	23.0	20	22.8
21-10-2021 18:55	25	23.0	21	23.0	21	22.8
21-10-2021 18:56	24	23.0	20	23.0	21	22.8
21-10-2021 18:57	24	23.0	20	23.0	20	22.8
21-10-2021 18:58	24	23.0	20	23.0	21	22.8
21-10-2021 18:59	27	23.0	23	23.0	22	22.8
21-10-2021 19:00	25	23.0	20	23.0	22	22.8
21-10-2021 19:01	23	22.9	19	23.0	21	22.8
21-10-2021 19:02	25	22.9	20	22.9	21	22.8
21-10-2021 19:03	0	22.9	30	22.9	26	22.8
21-10-2021 19:04	28	22.8	21	22.9	21	22.9



# Environmental Monitoring System

## DATA REPORT

### STERILE EXIT CHANGE ROOMS (L3)

Date Time	STERILE PASSAGE (L3) wrt EXIT ROOM-1 (L3)	STERILE EXIT ROOM-1 (L3)	ASEPTIC EXIT ROOM-1 (L3) wrt EXIT ROOM-2 (L3)	STERILE EXIT ROOM-2 (L3)	ASEPTIC EXIT ROOM-2 (L3) wrt EXIT ROOM-3 (L3)	STERILE EXIT ROOM-3 (L3)
Date Time	DP Pa	°C TEMP	DP Pa	°C TEMP	DP Pa	°C TEMP
21-10-2021 19:05	23	22.8	20	22.9	21	22.9
21-10-2021 19:06	23	22.8	20	22.9	19	23.0
21-10-2021 19:07	22	22.8	19	22.9	22	23.0
21-10-2021 19:08	23	22.8	19	22.8	21	23.0
21-10-2021 19:09	23	22.8	20	22.8	22	23.0
21-10-2021 19:10	23	22.7	20	22.8	21	23.0
21-10-2021 19:11	24	22.7	21	22.8	22	23.0
21-10-2021 19:12	23	22.7	21	22.8	21	23.0
21-10-2021 19:13	25	22.7	20	22.7	21	22.9
21-10-2021 19:14	23	22.7	21	22.7	21	22.9
21-10-2021 19:15	25	22.6	21	22.7	22	22.9
21-10-2021 19:16	25	22.6	21	22.7	23	22.9
21-10-2021 19:17	23	22.6	20	22.7	22	22.9
21-10-2021 19:18	24	22.6	20	22.7	22	22.9
21-10-2021 19:19	25	22.6	20	22.7	21	22.9
21-10-2021 19:20	24	22.5	20	22.7	22	22.9
21-10-2021 19:21	25	22.5	21	22.7	22	22.9
21-10-2021 19:22	23	22.5	20	22.7	22	22.9
21-10-2021 19:23	23	22.6	20	22.7	21	22.9
21-10-2021 19:24	23	22.6	20	22.7	21	22.9
21-10-2021 19:25	23	22.6	20	22.7	21	22.9
21-10-2021 19:26	24	22.6	20	22.7	21	22.9
21-10-2021 19:27	23	22.6	20	22.7	21	22.8
21-10-2021 19:28	23	22.6	20	22.7	22	22.8
21-10-2021 19:29	23	22.6	20	22.7	21	22.8
21-10-2021 19:30	23	22.6	20	22.7	21	22.8
21-10-2021 19:31	24	22.6	20	22.7	23	22.8
21-10-2021 19:32	23	22.6	21	22.7	22	22.8



# Environmental Monitoring System

## DATA REPORT

### STERILE EXIT CHANGE ROOMS (L3)

Date Time	STERILE PASSAGE (L3) wrt EXIT ROOM-1 (L3)	STERILE EXIT ROOM-1 (L3)	ASEPTIC EXIT ROOM-1 (L3) wrt EXIT ROOM-2 (L3)	STERILE EXIT ROOM-2 (L3)	ASEPTIC EXIT ROOM-2 (L3) wrt EXIT ROOM-3 (L3)	STERILE EXIT ROOM-3 (L3)
Date Time	DP Pa	°C TEMP	DP Pa	°C TEMP	DP Pa	°C TEMP
21-10-2021 19:33	23	22.7	19	22.8	21	22.8
21-10-2021 19:34	23	22.7	20	22.8	21	22.8
21-10-2021 19:35	24	22.7	20	22.8	22	22.9
21-10-2021 19:36	23	22.7	20	22.8	21	22.9
21-10-2021 19:37	23	22.8	20	22.8	20	22.8
21-10-2021 19:38	25	22.8	21	22.8	23	22.8
21-10-2021 19:39	23	22.8	21	22.9	23	22.9
21-10-2021 19:40	24	22.8	21	22.9	21	22.9
21-10-2021 19:41	23	22.8	20	22.9	22	22.9
21-10-2021 19:42	24	22.9	20	22.9	21	22.9
21-10-2021 19:43	25	22.9	20	22.9	21	22.9
21-10-2021 19:44	24	22.9	21	22.9	21	22.9
21-10-2021 19:45	25	22.9	21	23.0	22	22.9
21-10-2021 19:46	24	23.0	20	23.0	22	22.9
21-10-2021 19:47	24	23.0	20	23.0	22	22.9
21-10-2021 19:48	24	23.0	21	23.0	21	22.9
21-10-2021 19:49	25	23.0	20	23.0	21	22.9
21-10-2021 19:50	24	23.0	20	23.0	21	22.9
21-10-2021 19:51	24	23.0	20	23.0	22	22.9
21-10-2021 19:52	25	23.0	21	23.0	23	22.9
21-10-2021 19:53	25	23.0	21	23.0	22	22.9
21-10-2021 19:54	23	23.0	19	23.0	21	22.9
21-10-2021 19:55	24	23.0	21	23.1	22	22.9
21-10-2021 19:56	25	23.0	20	23.1	21	22.9
21-10-2021 19:57	25	23.1	20	23.1	22	22.9
21-10-2021 19:58	24	23.1	21	23.0	21	22.9
21-10-2021 19:59	23	23.0	20	23.0	22	22.9
21-10-2021 20:00	23	23.0	20	23.0	21	22.9



# Environmental Monitoring System

## DATA REPORT

### STERILE EXIT CHANGE ROOMS (L3)

Date Time	STERILE PASSAGE (L3) wrt EXIT ROOM-1 (L3)	STERILE EXIT ROOM-1 (L3)	ASEPTIC EXIT ROOM-1 (L3) wrt EXIT ROOM-2 (L3)	STERILE EXIT ROOM-2 (L3)	ASEPTIC EXIT ROOM-2 (L3) wrt EXIT ROOM-3 (L3)	STERILE EXIT ROOM-3 (L3)
Date Time	DP Pa	°C TEMP	DP Pa	°C TEMP	DP Pa	°C TEMP
21-10-2021 20:01	24	23.0	20	23.0	22	22.9
21-10-2021 20:02	24	23.0	20	23.0	21	22.9
21-10-2021 20:03	26	23.0	20	23.0	21	22.9
21-10-2021 20:04	23	22.9	19	23.0	21	22.9
21-10-2021 20:05	25	22.9	20	23.0	22	22.9
21-10-2021 20:06	24	22.9	20	22.9	22	22.9
21-10-2021 20:07	24	22.9	20	22.9	21	22.9
21-10-2021 20:08	23	22.8	21	22.9	22	22.9
21-10-2021 20:09	23	22.8	20	22.9	22	22.9
21-10-2021 20:10	24	22.8	20	22.9	21	22.9
21-10-2021 20:11	23	22.8	20	22.9	21	22.9
21-10-2021 20:12	25	22.8	20	22.8	22	22.9
21-10-2021 20:13	25	22.7	20	22.8	20	22.9
21-10-2021 20:14	26	22.7	20	22.8	21	22.9
21-10-2021 20:15	23	22.7	20	22.8	22	22.9
21-10-2021 20:16	23	22.6	20	22.8	21	22.9
21-10-2021 20:17	25	22.5	18	22.7	20	22.9
21-10-2021 20:18	25	22.4	18	22.7	21	22.9
21-10-2021 20:19	25	22.4	18	22.7	21	22.9
21-10-2021 20:20	25	22.3	20	22.7	20	22.8
21-10-2021 20:21	23	22.3	20	22.7	21	22.8
21-10-2021 20:22	23	22.4	20	22.7	22	22.8
21-10-2021 20:23	23	22.4	21	22.7	22	22.8
21-10-2021 20:24	24	22.5	20	22.7	22	22.8
21-10-2021 20:25	23	22.5	20	22.7	21	22.8
21-10-2021 20:26	23	22.5	20	22.7	21	22.8
21-10-2021 20:27	23	22.5	20	22.7	21	22.8
21-10-2021 20:28	23	22.5	20	22.7	21	22.8



# Environmental Monitoring System

## DATA REPORT

### STERILE EXIT CHANGE ROOMS (L3)

Date Time	STERILE PASSAGE (L3) wrt EXIT ROOM-1 (L3)	STERILE EXIT ROOM-1 (L3)	ASEPTIC EXIT ROOM-1 (L3) wrt EXIT ROOM-2 (L3)	STERILE EXIT ROOM-2 (L3)	ASEPTIC EXIT ROOM-2 (L3) wrt EXIT ROOM-3 (L3)	STERILE EXIT ROOM-3 (L3)
Date Time	DP Pa	°C TEMP	DP Pa	°C TEMP	DP Pa	°C TEMP
21-10-2021 20:29	23	22.6	20	22.8	21	22.8
21-10-2021 20:30	25	22.6	20	22.8	21	22.8
21-10-2021 20:31	24	22.6	20	22.8	21	22.8
21-10-2021 20:32	23	22.7	20	22.8	21	22.8
21-10-2021 20:33	23	22.7	20	22.8	21	22.8
21-10-2021 20:34	23	22.7	20	22.8	21	22.8
21-10-2021 20:35	24	22.7	20	22.8	21	22.8
21-10-2021 20:36	24	22.8	20	22.9	21	22.8
21-10-2021 20:37	23	22.8	20	22.9	23	22.8
21-10-2021 20:38	23	22.8	20	22.9	21	22.9
21-10-2021 20:39	28	22.8	20	22.9	21	22.9
21-10-2021 20:40	24	22.8	20	22.9	22	22.9
21-10-2021 20:41	24	22.9	20	22.9	21	22.9
21-10-2021 20:42	23	22.9	20	23.0	21	22.9
21-10-2021 20:43	23	22.9	20	23.0	21	22.9
21-10-2021 20:44	22	22.9	20	23.0	22	22.9
21-10-2021 20:45	23	23.0	18	23.0	21	22.9
21-10-2021 20:46	23	22.9	20	23.0	22	22.9
21-10-2021 20:47	23	23.0	20	23.0	21	22.9
21-10-2021 20:48	24	23.0	20	23.0	21	22.9
21-10-2021 20:49	23	23.0	20	23.0	21	22.9
21-10-2021 20:50	24	23.0	21	23.0	22	22.9
21-10-2021 20:51	27	23.0	20	23.0	22	22.9
21-10-2021 20:52	23	23.0	20	23.1	22	22.9
21-10-2021 20:53	23	23.0	20	23.1	23	22.9
21-10-2021 20:54	25	23.0	20	23.1	22	22.9
21-10-2021 20:55	23	23.0	20	23.0	21	22.9
21-10-2021 20:56	23	23.0	20	23.0	21	22.9



# Environmental Monitoring System

## DATA REPORT

### STERILE EXIT CHANGE ROOMS (L3)

Date Time	STERILE PASSAGE (L3) wrt EXIT ROOM-1 (L3)	STERILE EXIT ROOM-1 (L3)	ASEPTIC EXIT ROOM-1 (L3) wrt EXIT ROOM-2 (L3)	STERILE EXIT ROOM-2 (L3)	ASEPTIC EXIT ROOM-2 (L3) wrt EXIT ROOM-3 (L3)	STERILE EXIT ROOM-3 (L3)
Date Time	DP Pa	°C TEMP	DP Pa	°C TEMP	DP Pa	°C TEMP
21-10-2021 20:57	24	23.0	21	23.0	21	22.9
21-10-2021 20:58	24	23.0	20	23.0	22	22.9
21-10-2021 20:59	23	23.0	20	23.0	20	22.9
21-10-2021 21:00	24	23.0	20	23.0	21	22.9
21-10-2021 21:01	24	22.9	20	23.0	22	22.9
21-10-2021 21:02	25	22.9	20	23.0	21	22.9
21-10-2021 21:03	23	22.9	20	23.0	23	22.9
21-10-2021 21:04	23	22.8	20	22.9	21	22.9
21-10-2021 21:05	23	22.8	21	22.9	21	22.9
21-10-2021 21:06	24	22.8	21	22.9	22	22.9
21-10-2021 21:07	25	22.8	20	22.9	22	22.9
21-10-2021 21:08	25	22.8	22	22.9	23	22.9
21-10-2021 21:09	24	22.7	20	22.9	21	22.9
21-10-2021 21:10	23	22.8	20	22.9	22	22.9
21-10-2021 21:11	25	22.7	21	22.8	22	22.9
21-10-2021 21:12	25	22.7	20	22.8	21	22.9
21-10-2021 21:13	27	22.7	22	22.8	23	22.9
21-10-2021 21:14	23	22.7	21	22.8	22	22.8
21-10-2021 21:15	25	22.7	20	22.8	21	22.8
21-10-2021 21:16	25	22.7	20	22.8	22	22.8
21-10-2021 21:17	24	22.7	19	22.8	22	22.8
21-10-2021 21:18	23	22.7	19	22.8	21	22.8
21-10-2021 21:19	27	22.6	21	22.8	22	22.8
21-10-2021 21:20	23	22.6	20	22.8	22	22.8
21-10-2021 21:21	24	22.6	21	22.8	23	22.8
21-10-2021 21:22	24	22.6	20	22.8	21	22.8
21-10-2021 21:23	24	22.6	21	22.8	23	22.8
21-10-2021 21:24	25	22.7	20	22.8	21	22.8



# Environmental Monitoring System

## DATA REPORT

### STERILE EXIT CHANGE ROOMS (L3)

Date Time	STERILE PASSAGE (L3) wrt EXIT ROOM-1 (L3)	STERILE EXIT ROOM-1 (L3)	ASEPTIC EXIT ROOM-1 (L3) wrt EXIT ROOM-2 (L3)	STERILE EXIT ROOM-2 (L3)	ASEPTIC EXIT ROOM-2 (L3) wrt EXIT ROOM-3 (L3)	STERILE EXIT ROOM-3 (L3)
Date Time	DP Pa	°C TEMP	DP Pa	°C TEMP	DP Pa	°C TEMP
21-10-2021 21:25	24	22.6	20	22.8	21	22.8
21-10-2021 21:26	23	22.6	20	22.8	22	22.8
21-10-2021 21:27	23	22.7	20	22.8	22	22.8
21-10-2021 21:28	25	22.7	20	22.8	21	22.8
21-10-2021 21:29	23	22.7	20	22.8	22	22.8
21-10-2021 21:30	23	22.7	20	22.8	21	22.8
21-10-2021 21:31	23	22.7	20	22.9	22	22.8
21-10-2021 21:32	21	22.8	19	22.9	22	22.8
21-10-2021 21:33	22	22.7	20	22.9	22	22.8
21-10-2021 21:34	21	22.8	18	22.9	20	22.8
21-10-2021 21:35	23	22.8	20	22.9	21	22.8
21-10-2021 21:36	23	22.8	19	22.9	21	22.8
21-10-2021 21:37	23	22.9	21	22.9	22	22.8
21-10-2021 21:38	23	22.9	20	23.0	22	22.8
21-10-2021 21:39	23	22.9	20	23.0	21	22.8
21-10-2021 21:40	24	22.9	20	23.0	21	22.8
21-10-2021 21:41	22	22.9	20	23.0	22	22.8
21-10-2021 21:42	22	22.9	20	23.0	22	22.8
21-10-2021 21:43	23	22.9	20	23.0	21	22.8
21-10-2021 21:44	21	23.0	19	23.0	21	22.8
21-10-2021 21:45	23	23.0	20	23.0	21	22.8
21-10-2021 21:46	23	23.0	21	23.1	21	22.8
21-10-2021 21:47	24	23.0	20	23.1	22	22.8
21-10-2021 21:48	24	23.0	20	23.1	23	22.8
21-10-2021 21:49	23	23.0	20	23.1	21	22.8
21-10-2021 21:50	23	23.0	20	23.1	21	22.8
21-10-2021 21:51	23	23.0	20	23.1	21	22.9
21-10-2021 21:52	23	23.0	19	23.1	21	22.9



# Environmental Monitoring System

## DATA REPORT

### STERILE EXIT CHANGE ROOMS (L3)

Date Time	STERILE PASSAGE (L3) wrt EXIT ROOM-1 (L3)	STERILE EXIT ROOM-1 (L3)	ASEPTIC EXIT ROOM-1 (L3) wrt EXIT ROOM-2 (L3)	STERILE EXIT ROOM-2 (L3)	ASEPTIC EXIT ROOM-2 (L3) wrt EXIT ROOM-3 (L3)	STERILE EXIT ROOM-3 (L3)
Date Time	DP Pa	°C TEMP	DP Pa	°C TEMP	DP Pa	°C TEMP
21-10-2021 21:53	23	23.1	20	23.1	22	22.9
21-10-2021 21:54	23	23.0	21	23.1	23	22.9
21-10-2021 21:55	22	23.1	20	23.1	23	22.9
21-10-2021 21:56	23	23.1	20	23.1	21	22.9
21-10-2021 21:57	23	23.1	20	23.1	21	22.9
21-10-2021 21:58	23	23.1	21	23.1	22	22.9
21-10-2021 21:59	25	23.1	20	23.1	21	22.9
21-10-2021 22:00	23	23.0	20	23.1	22	22.9
21-10-2021 22:01	22	23.0	20	23.1	21	22.9
21-10-2021 22:02	23	23.0	20	23.1	22	22.9
21-10-2021 22:03	24	23.0	20	23.1	22	22.9
21-10-2021 22:04	23	23.0	20	23.0	21	22.9
21-10-2021 22:05	24	22.9	21	23.0	22	22.9
21-10-2021 22:06	24	22.9	20	23.0	21	22.9
21-10-2021 22:07	24	22.9	20	23.0	21	22.8
21-10-2021 22:08	23	22.8	20	23.0	22	22.9
21-10-2021 22:09	11	22.8	25	22.9	25	22.8
21-10-2021 22:10	25	22.7	20	22.9	22	22.8
21-10-2021 22:11	24	22.7	21	22.9	22	22.9
21-10-2021 22:12	23	22.7	20	22.9	21	22.9
21-10-2021 22:13	24	22.7	20	22.9	22	22.9
21-10-2021 22:14	23	22.7	27	22.8	21	22.9
21-10-2021 22:15	22	22.7	20	22.8	21	22.9
21-10-2021 22:16	23	22.7	20	22.8	21	23.0
21-10-2021 22:17	21	22.7	19	22.8	20	23.0
21-10-2021 22:18	21	22.6	19	22.8	21	22.9
21-10-2021 22:19	23	22.6	20	22.8	22	22.9
21-10-2021 22:20	23	22.6	19	22.8	21	22.9





# Environmental Monitoring System

## DATA REPORT

### STERILE EXIT CHANGE ROOMS (L3)

Date Time	STERILE PASSAGE (L3) wrt EXIT ROOM-1 (L3)	STERILE EXIT ROOM-1 (L3)	ASEPTIC EXIT ROOM-1 (L3) wrt EXIT ROOM-2 (L3)	STERILE EXIT ROOM-2 (L3)	ASEPTIC EXIT ROOM-2 (L3) wrt EXIT ROOM-3 (L3)	STERILE EXIT ROOM-3 (L3)
Date Time	DP Pa	°C TEMP	DP Pa	°C TEMP	DP Pa	°C TEMP
21-10-2021 22:21	23	22.6	19	22.8	21	22.9
21-10-2021 22:22	23	22.6	20	22.7	21	22.8
21-10-2021 22:23	24	22.2	20	22.7	21	22.8
21-10-2021 22:24	24	22.2	19	22.7	21	22.8
21-10-2021 22:25	25	22.2	19	22.7	21	22.8
21-10-2021 22:26	24	22.3	20	22.7	21	22.8
21-10-2021 22:27	24	22.4	20	22.8	21	22.8
21-10-2021 22:28	24	22.4	19	22.8	22	22.8
21-10-2021 22:29	24	22.4	19	22.8	22	22.8
21-10-2021 22:30	23	22.5	20	22.8	22	22.8
21-10-2021 22:31	23	22.5	20	22.8	21	22.8
21-10-2021 22:32	24	22.5	20	22.8	21	22.8
21-10-2021 22:33	24	22.6	20	22.8	21	22.8
21-10-2021 22:34	24	22.6	20	22.8	21	22.8
21-10-2021 22:35	24	22.6	20	22.9	21	22.8
21-10-2021 22:36	25	22.6	20	22.9	21	22.8
21-10-2021 22:37	24	22.6	20	22.9	22	22.8
21-10-2021 22:38	23	22.7	20	22.9	21	22.8
21-10-2021 22:39	24	22.7	20	22.9	21	22.8
21-10-2021 22:40	23	22.7	20	22.9	22	22.8
21-10-2021 22:41	23	22.7	20	23.0	21	22.8
21-10-2021 22:42	24	22.7	20	23.0	21	22.8
21-10-2021 22:43	25	22.8	20	23.0	21	22.8
21-10-2021 22:44	23	22.8	20	23.0	21	22.8
21-10-2021 22:45	24	22.8	20	23.0	21	22.8
21-10-2021 22:46	25	22.8	20	23.0	21	22.8
21-10-2021 22:47	25	22.9	20	23.1	21	22.8
21-10-2021 22:48	23	22.9	20	23.1	21	22.8



# Environmental Monitoring System

## DATA REPORT

### STERILE EXIT CHANGE ROOMS (L3)

Date Time	STERILE PASSAGE (L3) wrt EXIT ROOM-1 (L3)	STERILE EXIT ROOM-1 (L3)	ASEPTIC EXIT ROOM-1 (L3) wrt EXIT ROOM-2 (L3)	STERILE EXIT ROOM-2 (L3)	ASEPTIC EXIT ROOM-2 (L3) wrt EXIT ROOM-3 (L3)	STERILE EXIT ROOM-3 (L3)
Date Time	DP Pa	°C TEMP	DP Pa	°C TEMP	DP Pa	°C TEMP
21-10-2021 22:49	23	22.9	20	23.1	22	22.8
21-10-2021 22:50	23	23.0	20	23.1	21	22.9
21-10-2021 22:51	24	23.0	19	23.1	21	22.9
21-10-2021 22:52	24	23.0	20	23.1	21	22.9
21-10-2021 22:53	24	22.9	20	23.2	21	22.9
21-10-2021 22:54	23	23.0	19	23.2	21	22.9
21-10-2021 22:55	24	23.0	20	23.2	21	22.9
21-10-2021 22:56	25	23.0	20	23.2	21	22.9
21-10-2021 22:57	26	23.0	19	23.2	22	22.9
21-10-2021 22:58	23	23.0	19	23.2	21	22.9
21-10-2021 22:59	22	23.0	20	23.2	22	22.9
21-10-2021 23:00	23	23.0	20	23.2	21	22.9
21-10-2021 23:01	24	23.0	20	23.2	22	22.9
21-10-2021 23:02	24	23.0	20	23.3	21	22.9
21-10-2021 23:03	23	23.1	20	23.3	21	22.9
21-10-2021 23:04	23	23.1	20	23.2	21	23.0
21-10-2021 23:05	24	23.0	20	23.3	22	23.0
21-10-2021 23:06	23	23.0	19	23.2	20	23.0
21-10-2021 23:07	23	23.0	18	23.2	20	23.1
21-10-2021 23:08	23	23.0	18	23.2	20	23.1
21-10-2021 23:09	23	23.0	22	23.2	20	23.1
21-10-2021 23:10	25	23.0	19	23.2	21	23.1
21-10-2021 23:11	25	23.0	19	23.2	21	23.1
21-10-2021 23:12	25	22.9	21	23.2	21	23.1
21-10-2021 23:13	23	22.8	20	23.2	21	23.1
21-10-2021 23:14	24	22.9	21	23.2	22	23.1
21-10-2021 23:15	24	22.9	20	23.1	22	23.1
21-10-2021 23:16	24	22.9	20	23.1	22	23.0



# Environmental Monitoring System

## DATA REPORT

### STERILE EXIT CHANGE ROOMS (L3)

Date Time	STERILE PASSAGE (L3) wrt EXIT ROOM-1 (L3)	STERILE EXIT ROOM-1 (L3)	ASEPTIC EXIT ROOM-1 (L3) wrt EXIT ROOM-2 (L3)	STERILE EXIT ROOM-2 (L3)	ASEPTIC EXIT ROOM-2 (L3) wrt EXIT ROOM-3 (L3)	STERILE EXIT ROOM-3 (L3)
Date Time	DP Pa	°C TEMP	DP Pa	°C TEMP	DP Pa	°C TEMP
21-10-2021 23:17	25	22.8	20	23.1	21	23.0
21-10-2021 23:18	24	22.8	20	23.1	22	23.0
21-10-2021 23:19	24	22.8	20	23.0	22	23.0
21-10-2021 23:20	24	22.8	20	23.0	22	23.0
21-10-2021 23:21	23	22.8	19	23.0	21	23.0
21-10-2021 23:22	24	22.7	19	23.0	21	23.0
21-10-2021 23:23	23	22.7	20	23.0	21	23.0
21-10-2021 23:24	25	22.7	20	23.0	22	23.0
21-10-2021 23:25	25	22.7	20	22.9	22	23.0
21-10-2021 23:26	23	22.7	20	22.9	22	23.0
21-10-2021 23:27	24	22.7	20	22.9	22	22.9
21-10-2021 23:28	23	22.7	20	22.9	22	22.9
21-10-2021 23:29	25	22.6	20	22.9	23	22.9
21-10-2021 23:30	24	22.6	20	22.9	23	22.9
21-10-2021 23:31	24	22.6	20	22.9	22	22.9
21-10-2021 23:32	25	22.6	20	22.9	22	22.9
21-10-2021 23:33	24	22.7	20	22.9	21	22.9
21-10-2021 23:34	24	22.7	20	22.9	22	22.9
21-10-2021 23:35	25	22.7	20	22.9	22	22.9
21-10-2021 23:36	24	22.7	20	22.9	22	22.9
21-10-2021 23:37	24	22.7	21	22.9	22	22.9
21-10-2021 23:38	23	22.7	20	22.9	21	22.9
21-10-2021 23:39	25	22.7	21	22.9	22	22.9
21-10-2021 23:40	23	22.7	20	22.9	21	22.9
21-10-2021 23:41	25	22.7	20	23.0	22	22.9
21-10-2021 23:42	24	22.7	20	23.0	22	22.9
21-10-2021 23:43	24	22.8	20	23.0	21	22.9
21-10-2021 23:44	25	22.8	20	23.0	22	22.9



## Environmental Monitoring System

### DATA REPORT

#### STERILE EXIT CHANGE ROOMS (L3)

Date Time	STERILE PASSAGE (L3) wrt EXIT ROOM-1 (L3)	STERILE EXIT ROOM-1 (L3)	ASEPTIC EXIT ROOM-1 (L3) wrt EXIT ROOM-2 (L3)	STERILE EXIT ROOM-2 (L3)	ASEPTIC EXIT ROOM-2 (L3) wrt EXIT ROOM-3 (L3)	STERILE EXIT ROOM-3 (L3)
Date Time	DP Pa	°C TEMP	DP Pa	°C TEMP	DP Pa	°C TEMP
21-10-2021 23:45	23	22.8	20	23.0	22	22.9
21-10-2021 23:46	23	22.8	20	23.0	21	22.9
21-10-2021 23:47	24	22.8	20	23.0	23	22.9
21-10-2021 23:48	24	22.9	20	23.0	21	22.9
21-10-2021 23:49	25	22.9	21	23.1	22	22.9
21-10-2021 23:50	24	22.9	20	23.1	21	22.9
21-10-2021 23:51	23	22.9	20	23.1	21	22.9
21-10-2021 23:52	24	22.9	20	23.1	21	22.9
21-10-2021 23:53	26	22.9	20	23.1	23	23.0
21-10-2021 23:54	25	23.0	20	23.1	21	23.0
21-10-2021 23:55	24	23.0	20	23.1	21	23.0
21-10-2021 23:56	24	23.0	20	23.1	23	23.0
21-10-2021 23:57	24	23.0	21	23.1	23	23.0
21-10-2021 23:58	24	23.0	20	23.1	21	23.0
21-10-2021 23:59	26	23.0	20	23.2	22	23.0
22-10-2021 00:00	24	23.0	21	23.2	21	23.0
Min Value	****	****	****	****	****	****
Max Value	****	****	****	****	****	****

End Of Report : From 21/10/2021 00:00:00 To 22/10/2021 00:00:00

ACTIVITY	NAME	SIGNATURE AND DATE
REVIEWED BY USER		
REVIEWED BY QA		