



SOMERSET THERAPEUTICS LIMITED

DATA REPORT - SVP1 AND AMPOULE LINE EMS

WASHING AND STERILIZATION AREA

Date Time	Temperature	RH	Diffrential Pressure	Diffrential Pressure	Diffrential Pressure
DD-MM-YYYY HH:MM:SS	Washing and Sterilization Area (NMT 30°C)	Washing and Sterilization Area (NMT 80%)	Washing and Sterilization Area w.r.t Unit Preparation Room (NLT 6 Pa)	Washing and Sterilization Area w.r.t Ampoule Decartoning Room (NLT 12 Pa)	Washing and Sterilization Area w.r.t Injectable main corridor (NLT 12 Pa)
25-05-2022 18:08:00	18	80.5	20	16	37
25-05-2022 18:13:00	18	78.9	22	16	37
25-05-2022 18:18:00	18	77	21	14	33
25-05-2022 18:23:00	17.9	76.5	22	16	37
25-05-2022 18:28:00	17.9	76.5	21	16	37
25-05-2022 18:33:00	17.9	76.5	21	16	37
25-05-2022 18:38:00	17.9	76.4	22	16	37
25-05-2022 18:43:00	17.8	76.3	23	16	37
25-05-2022 18:48:00	17.8	76.4	22	16	37
25-05-2022 18:53:00	17.8	76.2	22	16	37
25-05-2022 18:58:00	17.8	76.4	22	16	37
25-05-2022 19:03:00	17.8	76.4	22	15	34
25-05-2022 19:08:00	17.8	76.4	22	16	37
25-05-2022 19:13:00	17.8	76.5	21	15	33
25-05-2022 19:18:00	17.8	76.6	22	16	36
25-05-2022 19:23:00	17.8	76.6	22	16	36
25-05-2022 19:28:00	17.9	76.6	21	16	37
25-05-2022 19:33:00	17.9	76.4	21	16	36
25-05-2022 19:38:00	17.8	76.4	21	16	37
25-05-2022 19:43:00	17.8	76.3	20	15	36
25-05-2022 19:48:00	17.8	77	16	16	37
25-05-2022 19:53:00	17.8	77.3	21	14	35
25-05-2022 19:58:00	18	81	20	14	34
25-05-2022 20:03:00	18.3	81.4	19	17	40
25-05-2022 20:08:00	18.4	79.5	20	15	35
ACTIVITY		NAME		SIGNATURE AND DATE	
REVIEWED BY USER					
REVIEWED BY QA					



SOMERSET THERAPEUTICS LIMITED

DATA REPORT - SVP1 AND AMPOULE LINE EMS

WASHING AND STERILIZATION AREA

Date Time	Temperature	RH	Diffrential Pressure	Diffrential Pressure	Diffrential Pressure
DD-MM-YYYY HH:MM:SS	Washing and Sterilization Area (NMT 30°C)	Washing and Sterilization Area (NMT 80%)	Washing and Sterilization Area w.r.t Unit Preparation Room (NLT 6 Pa)	Washing and Sterilization Area w.r.t Ampoule Decartoning Room (NLT 12 Pa)	Washing and Sterilization Area w.r.t Injectable main corridor (NLT 12 Pa)
25-05-2022 20:28:00	18.2	77.6	21	16	37
25-05-2022 20:33:00	18.2	77.5	19	15	36
25-05-2022 20:38:00	18.1	77.3	19	15	38
25-05-2022 20:43:00	18.1	77.3	19	15	36
25-05-2022 20:48:00	18.1	77.4	19	16	37
25-05-2022 20:53:00	18.1	77.4	7	14	36
25-05-2022 20:58:00	18.1	77.2	0	13	34
25-05-2022 21:03:00	18.1	77	19	16	38
25-05-2022 21:08:00	18.2	76.3	20	17	40
25-05-2022 21:13:00	18.5	76	20	16	39
25-05-2022 21:18:00	18.3	76.6	19	18	39
25-05-2022 21:23:00	18.3	78	0	14	37
25-05-2022 21:28:00	18.3	77.3	0	15	39
25-05-2022 21:33:00	18.3	77	0	15	37
25-05-2022 21:38:00	18.3	76.7	0	15	37
25-05-2022 21:43:00	18.3	76.4	17	16	39
25-05-2022 21:48:00	18.2	76.4	19	16	39
25-05-2022 21:53:00	18.3	76.3	19	16	40
25-05-2022 21:58:00	18.3	76.3	19	16	39
25-05-2022 22:03:00	18.4	76.2	19	16	37
25-05-2022 22:08:00	18.4	76.1	19	15	36
25-05-2022 22:13:00	18.4	75.9	19	16	38
25-05-2022 22:18:00	18.4	76	18	16	39
25-05-2022 22:23:00	18.4	75.8	18	16	37
25-05-2022 22:28:00	18.5	75.7	18	16	39
ACTIVITY		NAME		SIGNATURE AND DATE	
REVIEWED BY USER					
REVIEWED BY QA					



SOMERSET THERAPEUTICS LIMITED

DATA REPORT - SVP1 AND AMPOULE LINE EMS

WASHING AND STERILIZATION AREA

Date Time	Temperature	RH	Diffrential Pressure	Diffrential Pressure	Diffrential Pressure
DD-MM-YYYY HH:MM:SS	Washing and Sterilization Area (NMT 30°C)	Washing and Sterilization Area (NMT 80%)	Washing and Sterilization Area w.r.t Unit Preparation Room (NLT 6 Pa)	Washing and Sterilization Area w.r.t Ampoule Decartoning Room (NLT 12 Pa)	Washing and Sterilization Area w.r.t Injectable main corridor (NLT 12 Pa)
25-05-2022 22:48:00	18.3	77.2	24	17	40
25-05-2022 22:53:00	18.7	77.1	18	17	40
25-05-2022 22:58:00	18.9	76	21	15	36
Min Value	17.8	75.7	0	13	33
Max Value	18.9	81.4	24	18	41

End Of Report : From 25-05-2022 17:58:24 To 25-05-2022 22:58:24

ACTIVITY	NAME	SIGNATURE AND DATE
REVIEWED BY USER		
REVIEWED BY QA		