



SOMERSET THERAPEUTICS LIMITED

DATA REPORT - SVP1 AND AMPOULE LINE EMS

WASHING AND STERILIZATION AREA

Date Time	Temperature	RH	Diffrential Pressure	Diffrential Pressure	Diffrential Pressure
DD-MM-YYYY HH:MM:SS	Washing and Sterilization Area (NMT 30°C)	Washing and Sterilization Area (NMT 80%)	Washing and Sterilization Area w.r.t Unit Preparation Room (NLT 6 Pa)	Washing and Sterilization Area w.r.t Ampoule Decartoning Room (NLT 12 Pa)	Washing and Sterilization Area w.r.t Injectable main corridor (NLT 12 Pa)
04/06/2022 15:34:00	18.1	77.1	21	13	38
04/06/2022 16:04:00	18.1	77.1	21	13	38
04/06/2022 16:34:00	18.1	77.1	21	13	38
04/06/2022 17:04:00	18.1	77.1	21	13	38
04/06/2022 17:34:00	18.1	77.1	21	13	38
04/06/2022 18:04:00	18.1	77.1	21	13	38
04/06/2022 18:34:00	18.1	77.1	21	13	38
04/06/2022 19:04:00	18.1	77.1	21	13	38
04/06/2022 19:34:00	18.1	77.1	21	13	38
04/06/2022 20:04:00	18.1	77.1	21	13	38
04/06/2022 20:34:00	18.1	77.1	21	13	38
04/06/2022 21:04:00	18.1	77.1	21	13	38
04/06/2022 21:34:00	18.1	77.1	21	13	38
04/06/2022 22:04:00	18.1	77.1	21	13	38
04/06/2022 22:34:00	18.1	77.1	21	13	38
04/06/2022 23:04:00	18.1	77.1	21	13	38
04/06/2022 23:34:00	18.1	77.1	21	13	38
05/06/2022 00:04:00	18.1	77.1	21	13	38
05/06/2022 00:34:00	18.1	77.1	21	13	38
05/06/2022 01:04:00	18.1	77.1	21	13	38
05/06/2022 01:34:00	18.1	77.1	21	13	38
05/06/2022 02:04:00	18.1	77.1	21	13	38
05/06/2022 02:34:00	18.1	77.1	21	13	38
05/06/2022 03:04:00	18.1	77.1	21	13	38

ACTIVITY	NAME	SIGNATURE AND DATE
REVIEWED BY USER		
REVIEWED BY QA		



SOMERSET THERAPEUTICS LIMITED

DATA REPORT - SVP1 AND AMPOULE LINE EMS

WASHING AND STERILIZATION AREA

Date Time	Temperature	RH	Diffrential Pressure	Diffrential Pressure	Diffrential Pressure
DD-MM-YYYY HH:MM:SS	Washing and Sterilization Area (NMT 30°C)	Washing and Sterilization Area (NMT 80%)	Washing and Sterilization Area w.r.t Unit Preparation Room (NLT 6 Pa)	Washing and Sterilization Area w.r.t Ampoule Decartoning Room (NLT 12 Pa)	Washing and Sterilization Area w.r.t Injectable main corridor (NLT 12 Pa)
05/06/2022 03:34:00	18.1	77.1	21	13	38
05/06/2022 04:04:00	18.1	77.1	21	13	38
05/06/2022 04:34:00	18.1	77.1	21	13	38
05/06/2022 05:04:00	18.1	77.1	21	13	38
05/06/2022 05:34:00	18.1	77.1	21	13	38
05/06/2022 06:04:00	18.1	77.1	21	13	38
05/06/2022 06:34:00	18.1	77.1	21	13	38
05/06/2022 07:04:00	18.1	77.1	21	13	38
05/06/2022 07:34:00	18.1	77.1	21	13	38
05/06/2022 08:04:00	18.1	77.1	21	13	38
05/06/2022 08:34:00	18.1	77.1	21	13	38
05/06/2022 09:04:00	18.1	77.1	21	13	38
05/06/2022 09:34:00	18.1	77.1	21	13	38
05/06/2022 10:04:00	18.1	77.1	21	13	38
05/06/2022 10:34:00	18.1	77.1	21	13	38
05/06/2022 11:04:00	18.1	77.1	21	13	38
05/06/2022 11:34:00	18.1	77.1	21	13	38
05/06/2022 12:04:00	18.1	77.1	21	13	38
05/06/2022 12:34:00	18.1	77.1	21	13	38
05/06/2022 13:04:00	18.1	77.1	21	13	38
05/06/2022 13:34:00	18.1	77.1	21	13	38
05/06/2022 14:04:00	18.1	77.1	21	13	38
05/06/2022 14:34:00	18.1	77.1	21	13	38
05/06/2022 15:04:00	18.1	77.1	21	13	38

ACTIVITY	NAME	SIGNATURE AND DATE
REVIEWED BY USER		
REVIEWED BY QA		



SOMERSET THERAPEUTICS LIMITED

DATA REPORT - SVP1 AND AMPOULE LINE EMS

WASHING AND STERILIZATION AREA

Date Time	Temperature	RH	Diffrential Pressure	Diffrential Pressure	Diffrential Pressure
DD-MM-YYYY HH:MM:SS	Washing and Sterilization Area (NMT 30°C)	Washing and Sterilization Area (NMT 80%)	Washing and Sterilization Area w.r.t Unit Preparation Room (NLT 6 Pa)	Washing and Sterilization Area w.r.t Ampoule Decartoning Room (NLT 12 Pa)	Washing and Sterilization Area w.r.t Injectable main corridor (NLT 12 Pa)
05/06/2022 15:34:00	18.1	77.1	21	13	38
Min Value	18.1	77.1	21	13	38
Max Value	18.1	77.1	21	13	38

End Of Report : From 04-06-2022 15:34:37 To 05-06-2022 15:34:37

ACTIVITY	NAME	SIGNATURE AND DATE
REVIEWED BY USER		
REVIEWED BY QA		