



Environmental Monitoring System

DATA REPORT

STERILE EXIT CHANGE ROOMS (L4)

Date Time	STERILE PASSAGE (L4) wrt EXIT ROOM-1 (L4)	STERILE EXIT ROOM-1 (L4)	ASEPTIC EXIT ROOM-1 (L4) wrt EXIT ROOM-2 (L4)	STERILE EXIT ROOM-2 (L4)	ASEPTIC EXIT ROOM-2 (L4) wrt EXIT ROOM-3 (L4)	STERILE EXIT ROOM-3 (L4)
Date Time	DP Pa	°C TEMP	DP Pa	°C TEMP	DP Pa	°C TEMP
Alarm Low Limit		0.00		0.00		0.00
Set Value						
Alarm High Limit	50	100.00	50	100.00	50	100.00
04-11-2021 00:00	8	22.46	21	23.42	41	23.00
04-11-2021 00:01	8	22.45	21	23.43	40	23.01
04-11-2021 00:02	8	22.45	22	23.43	42	23.01
04-11-2021 00:03	8	22.45	22	23.43	40	23.00
04-11-2021 00:04	12	22.44	28	23.44	42	22.99
04-11-2021 00:05	7	22.45	23	23.46	41	22.99
04-11-2021 00:06	6	22.45	23	23.46	41	23.01
04-11-2021 00:07	7	22.44	24	23.44	42	23.01
04-11-2021 00:08	8	22.44	23	23.47	41	23.01
04-11-2021 00:09	8	22.46	22	23.47	42	23.00
04-11-2021 00:10	8	22.47	22	23.48	40	22.99
04-11-2021 00:11	6	22.47	22	23.46	41	23.00
04-11-2021 00:12	6	22.47	21	23.47	42	23.00
04-11-2021 00:13	8	22.45	23	23.47	40	22.99
04-11-2021 00:14	6	22.47	23	23.47	42	23.01
04-11-2021 00:15	9	22.48	22	23.47	40	23.00
04-11-2021 00:16	7	22.48	22	23.49	41	22.99
04-11-2021 00:17	6	22.48	24	23.49	40	22.98
04-11-2021 00:18	5	22.50	23	23.47	40	22.98
04-11-2021 00:19	6	22.51	23	23.49	41	22.97
04-11-2021 00:20	6	22.50	23	23.48	40	22.97
04-11-2021 00:21	7	22.51	22	23.48	40	22.97
04-11-2021 00:22	5	22.50	22	23.50	40	22.98
04-11-2021 00:23	6	22.50	23	23.50	40	22.97
04-11-2021 00:24	6	22.50	23	23.52	42	22.97



Environmental Monitoring System

DATA REPORT

STERILE EXIT CHANGE ROOMS (L4)

Date Time	STERILE PASSAGE (L4) wrt EXIT ROOM-1 (L4)	STERILE EXIT ROOM-1 (L4)	ASEPTIC EXIT ROOM-1 (L4) wrt EXIT ROOM-2 (L4)	STERILE EXIT ROOM-2 (L4)	ASEPTIC EXIT ROOM-2 (L4) wrt EXIT ROOM-3 (L4)	STERILE EXIT ROOM-3 (L4)
Date Time	DP Pa	°C TEMP	DP Pa	°C TEMP	DP Pa	°C TEMP
04-11-2021 00:25	6	22.52	22	23.51	41	22.97
04-11-2021 00:26	5	22.50	23	23.52	41	22.97
04-11-2021 00:27	6	22.51	22	23.52	41	22.98
04-11-2021 00:28	6	22.51	23	23.50	42	22.96
04-11-2021 00:29	6	22.51	23	23.50	41	22.97
04-11-2021 00:30	6	22.51	23	23.51	41	22.97
04-11-2021 00:31	6	22.51	22	23.50	42	22.96
04-11-2021 00:32	6	22.51	23	23.50	40	22.98
04-11-2021 00:33	4	22.54	23	23.52	40	22.97
04-11-2021 00:34	5	22.53	23	23.53	41	22.97
04-11-2021 00:35	4	22.53	23	23.52	41	22.97
04-11-2021 00:36	5	22.53	22	23.52	41	22.96
04-11-2021 00:37	8	22.53	21	23.53	40	22.97
04-11-2021 00:38	7	22.53	22	23.53	40	22.96
04-11-2021 00:39	6	22.52	23	23.50	42	22.95
04-11-2021 00:40	6	22.53	22	23.52	41	22.94
04-11-2021 00:41	6	22.54	22	23.51	41	22.94
04-11-2021 00:42	6	22.55	23	23.54	41	22.94
04-11-2021 00:43	6	22.55	22	23.53	41	22.94
04-11-2021 00:44	5	22.55	23	23.53	40	22.94
04-11-2021 00:45	7	22.56	23	23.53	42	22.94
04-11-2021 00:46	7	22.57	22	23.54	41	22.96
04-11-2021 00:47	7	22.58	22	23.54	40	22.95
04-11-2021 00:48	6	22.58	23	23.58	41	22.94
04-11-2021 00:49	6	22.58	23	23.58	40	22.94
04-11-2021 00:50	6	22.60	23	23.57	40	22.95
04-11-2021 00:51	6	22.60	22	23.57	40	22.94
04-11-2021 00:52	6	22.61	22	23.57	40	22.95



Environmental Monitoring System

DATA REPORT

STERILE EXIT CHANGE ROOMS (L4)

Date Time	STERILE PASSAGE (L4) wrt EXIT ROOM-1 (L4)	STERILE EXIT ROOM-1 (L4)	ASEPTIC EXIT ROOM-1 (L4) wrt EXIT ROOM-2 (L4)	STERILE EXIT ROOM-2 (L4)	ASEPTIC EXIT ROOM-2 (L4) wrt EXIT ROOM-3 (L4)	STERILE EXIT ROOM-3 (L4)
Date Time	DP Pa	°C TEMP	DP Pa	°C TEMP	DP Pa	°C TEMP
04-11-2021 00:53	6	22.61	22	23.57	41	22.95
04-11-2021 00:54	5	22.61	23	23.59	41	22.95
04-11-2021 00:55	5	22.63	23	23.59	41	22.95
04-11-2021 00:56	6	22.64	23	23.60	41	22.95
04-11-2021 00:57	5	22.65	23	23.60	42	22.96
04-11-2021 00:58	7	22.65	22	23.61	40	22.97
04-11-2021 00:59	6	22.65	23	23.62	41	22.97
04-11-2021 01:00	4	22.67	23	23.62	42	22.97
04-11-2021 01:01	6	22.67	23	23.62	40	22.97
04-11-2021 01:02	6	22.69	23	23.61	41	22.97
04-11-2021 01:03	6	22.69	23	23.64	41	22.97
04-11-2021 01:04	6	22.69	21	23.64	41	22.98
04-11-2021 01:05	5	22.69	23	23.64	42	22.98
04-11-2021 01:06	6	22.68	23	23.64	41	22.98
04-11-2021 01:07	6	22.69	23	23.63	40	22.98
04-11-2021 01:08	6	22.70	22	23.61	41	22.98
04-11-2021 01:09	6	22.71	22	23.62	42	22.98
04-11-2021 01:10	6	22.70	23	23.63	40	22.98
04-11-2021 01:11	6	22.70	23	23.64	42	22.99
04-11-2021 01:12	6	22.70	21	23.65	41	22.99
04-11-2021 01:13	6	22.71	23	23.66	40	22.98
04-11-2021 01:14	5	22.70	23	23.63	40	22.99
04-11-2021 01:15	6	22.71	21	23.63	40	22.99
04-11-2021 01:16	5	22.69	23	23.61	42	22.99
04-11-2021 01:17	6	22.67	21	23.59	40	22.99
04-11-2021 01:18	7	22.67	24	23.59	41	22.98
04-11-2021 01:19	6	22.65	23	23.59	41	22.98
04-11-2021 01:20	6	22.64	23	23.55	40	22.99



Environmental Monitoring System

DATA REPORT

STERILE EXIT CHANGE ROOMS (L4)

Date Time	STERILE PASSAGE (L4) wrt EXIT ROOM-1 (L4)	STERILE EXIT ROOM-1 (L4)	ASEPTIC EXIT ROOM-1 (L4) wrt EXIT ROOM-2 (L4)	STERILE EXIT ROOM-2 (L4)	ASEPTIC EXIT ROOM-2 (L4) wrt EXIT ROOM-3 (L4)	STERILE EXIT ROOM-3 (L4)
Date Time	DP Pa	°C TEMP	DP Pa	°C TEMP	DP Pa	°C TEMP
04-11-2021 01:21	6	22.63	22	23.54	41	22.99
04-11-2021 01:22	6	22.63	21	23.53	41	22.98
04-11-2021 01:23	6	22.62	23	23.50	41	22.98
04-11-2021 01:24	6	22.58	21	23.50	40	22.98
04-11-2021 01:25	6	22.56	21	23.48	41	22.98
04-11-2021 01:26	5	22.56	23	23.48	42	22.95
04-11-2021 01:27	6	22.56	23	23.48	41	22.95
04-11-2021 01:28	7	22.53	22	23.46	40	22.94
04-11-2021 01:29	7	22.51	22	23.45	40	22.94
04-11-2021 01:30	6	22.51	23	23.43	41	22.93
04-11-2021 01:31	6	22.50	23	23.42	42	22.91
04-11-2021 01:32	4	22.50	21	23.40	42	22.91
04-11-2021 01:33	6	22.48	22	23.40	40	22.89
04-11-2021 01:34	6	22.45	23	23.40	40	22.89
04-11-2021 01:35	5	22.46	23	23.38	42	22.89
04-11-2021 01:36	6	22.45	21	23.39	41	22.89
04-11-2021 01:37	6	22.45	22	23.37	41	22.88
04-11-2021 01:38	5	22.44	23	23.41	42	22.87
04-11-2021 01:39	8	22.44	23	23.40	42	22.90
04-11-2021 01:40	6	22.44	22	23.40	42	22.90
04-11-2021 01:41	6	22.44	22	23.39	41	22.88
04-11-2021 01:42	9	22.43	24	23.40	43	22.88
04-11-2021 01:43	6	22.43	23	23.39	40	22.86
04-11-2021 01:44	7	22.42	23	23.37	41	22.86
04-11-2021 01:45	7	22.44	23	23.38	40	22.87
04-11-2021 01:46	8	22.43	23	23.37	40	22.85
04-11-2021 01:47	8	22.43	22	23.38	40	22.85
04-11-2021 01:48	8	22.43	24	23.40	42	22.86



Environmental Monitoring System

DATA REPORT

STERILE EXIT CHANGE ROOMS (L4)

Date Time	STERILE PASSAGE (L4) wrt EXIT ROOM-1 (L4)	STERILE EXIT ROOM-1 (L4)	ASEPTIC EXIT ROOM-1 (L4) wrt EXIT ROOM-2 (L4)	STERILE EXIT ROOM-2 (L4)	ASEPTIC EXIT ROOM-2 (L4) wrt EXIT ROOM-3 (L4)	STERILE EXIT ROOM-3 (L4)
Date Time	DP Pa	°C TEMP	DP Pa	°C TEMP	DP Pa	°C TEMP
04-11-2021 01:49	8	22.44	22	23.39	42	22.84
04-11-2021 01:50	7	22.44	23	23.36	42	22.85
04-11-2021 01:51	6	22.44	23	23.40	42	22.84
04-11-2021 01:52	6	22.44	23	23.41	41	22.84
04-11-2021 01:53	6	22.44	23	23.39	41	22.84
04-11-2021 01:54	6	22.44	22	23.40	41	22.84
04-11-2021 01:55	6	22.45	22	23.40	41	22.84
04-11-2021 01:56	6	22.46	23	23.40	42	22.83
04-11-2021 01:57	6	22.48	23	23.41	41	22.83
04-11-2021 01:58	6	22.48	22	23.42	41	22.83
04-11-2021 01:59	7	22.48	21	23.45	40	22.83
04-11-2021 02:00	6	22.48	22	23.46	42	22.83
04-11-2021 02:01	6	22.49	23	23.44	40	22.84
04-11-2021 02:02	6	22.48	23	23.46	40	22.83
04-11-2021 02:03	5	22.48	23	23.47	42	22.84
04-11-2021 02:04	5	22.50	23	23.48	41	22.83
04-11-2021 02:05	4	22.51	23	23.47	41	22.83
04-11-2021 02:06	5	22.50	22	23.47	43	22.82
04-11-2021 02:07	6	22.51	23	23.49	40	22.84
04-11-2021 02:08	6	22.52	22	23.48	42	22.84
04-11-2021 02:09	5	22.52	22	23.48	40	22.83
04-11-2021 02:10	6	22.52	23	23.49	40	22.84
04-11-2021 02:11	7	22.53	21	23.47	41	22.84
04-11-2021 02:12	5	22.54	23	23.48	41	22.85
04-11-2021 02:13	3	22.54	22	23.49	40	22.85
04-11-2021 02:14	5	22.54	23	23.50	40	22.86
04-11-2021 02:15	8	22.56	21	23.51	42	22.85
04-11-2021 02:16	8	22.57	23	23.51	42	22.86



Environmental Monitoring System

DATA REPORT

STERILE EXIT CHANGE ROOMS (L4)

Date Time	STERILE PASSAGE (L4) wrt EXIT ROOM-1 (L4)	STERILE EXIT ROOM-1 (L4)	ASEPTIC EXIT ROOM-1 (L4) wrt EXIT ROOM-2 (L4)	STERILE EXIT ROOM-2 (L4)	ASEPTIC EXIT ROOM-2 (L4) wrt EXIT ROOM-3 (L4)	STERILE EXIT ROOM-3 (L4)
Date Time	DP Pa	°C TEMP	DP Pa	°C TEMP	DP Pa	°C TEMP
04-11-2021 02:17	6	22.57	22	23.52	41	22.87
04-11-2021 02:18	5	22.57	20	23.53	40	22.89
04-11-2021 02:19	6	22.58	21	23.55	40	22.90
04-11-2021 02:20	4	22.58	22	23.55	42	22.90
04-11-2021 02:21	6	22.59	23	23.56	40	22.89
04-11-2021 02:22	6	22.58	22	23.54	42	22.92
04-11-2021 02:23	5	22.58	22	23.55	42	22.91
04-11-2021 02:24	6	22.58	22	23.55	42	22.90
04-11-2021 02:25	6	22.59	21	23.55	42	22.91
04-11-2021 02:26	6	22.59	21	23.58	41	22.90
04-11-2021 02:27	7	22.60	23	23.58	41	22.90
04-11-2021 02:28	6	22.60	21	23.56	42	22.92
04-11-2021 02:29	5	22.63	21	23.58	42	22.92
04-11-2021 02:30	6	22.61	22	23.58	41	22.92
04-11-2021 02:31	6	22.63	21	23.58	42	22.92
04-11-2021 02:32	8	22.63	22	23.58	40	22.92
04-11-2021 02:33	6	22.63	22	23.58	42	22.92
04-11-2021 02:34	8	22.64	23	23.57	42	22.92
04-11-2021 02:35	6	22.66	21	23.58	39	22.93
04-11-2021 02:36	7	22.65	21	23.60	40	22.92
04-11-2021 02:37	6	22.66	21	23.61	40	22.96
04-11-2021 02:38	6	22.67	21	23.61	39	22.99
04-11-2021 02:39	5	22.68	21	23.63	39	23.00
04-11-2021 02:40	5	22.69	21	23.63	42	23.03
04-11-2021 02:41	6	22.70	22	23.63	41	23.01
04-11-2021 02:42	6	22.69	21	23.63	39	23.01
04-11-2021 02:43	5	22.69	22	23.63	41	23.02
04-11-2021 02:44	5	22.70	22	23.63	40	23.02



Environmental Monitoring System

DATA REPORT

STERILE EXIT CHANGE ROOMS (L4)

Date Time	STERILE PASSAGE (L4) wrt EXIT ROOM-1 (L4)	STERILE EXIT ROOM-1 (L4)	ASEPTIC EXIT ROOM-1 (L4) wrt EXIT ROOM-2 (L4)	STERILE EXIT ROOM-2 (L4)	ASEPTIC EXIT ROOM-2 (L4) wrt EXIT ROOM-3 (L4)	STERILE EXIT ROOM-3 (L4)
Date Time	DP Pa	°C TEMP	DP Pa	°C TEMP	DP Pa	°C TEMP
04-11-2021 02:45	7	22.71	22	23.63	42	23.02
04-11-2021 02:46	0	22.70	25	23.62	42	23.02
04-11-2021 02:47	0	22.70	24	23.63	43	23.01
04-11-2021 02:48	7	22.73	21	23.63	40	23.03
04-11-2021 02:49	6	22.73	21	23.66	40	23.04
04-11-2021 02:50	6	22.75	21	23.67	40	23.03
04-11-2021 02:51	5	22.73	22	23.68	42	23.04
04-11-2021 02:52	7	22.74	22	23.67	40	23.04
04-11-2021 02:53	6	22.74	22	23.67	40	23.04
04-11-2021 02:54	6	22.74	22	23.70	40	23.05
04-11-2021 02:55	6	22.74	21	23.66	40	23.05
04-11-2021 02:56	6	22.74	22	23.66	40	23.05
04-11-2021 02:57	4	22.74	21	23.65	39	23.05
04-11-2021 02:58	6	22.74	23	23.66	40	23.05
04-11-2021 02:59	5	22.75	22	23.66	40	23.05
04-11-2021 03:00	6	22.73	21	23.64	40	23.04
04-11-2021 03:01	6	22.74	21	23.64	41	23.04
04-11-2021 03:02	6	22.73	23	23.65	40	23.06
04-11-2021 03:03	5	22.74	22	23.64	40	23.07
04-11-2021 03:04	6	22.73	22	23.64	42	23.08
04-11-2021 03:05	6	22.74	22	23.64	40	23.09
04-11-2021 03:06	10	22.75	0	23.62	57	23.06
04-11-2021 03:07	13	22.74	22	23.64	40	23.09
04-11-2021 03:08	6	22.72	22	23.63	40	23.09
04-11-2021 03:09	6	22.72	23	23.65	40	23.08
04-11-2021 03:10	7	22.70	21	23.62	40	23.09
04-11-2021 03:11	6	22.66	23	23.58	42	23.08
04-11-2021 03:12	5	22.65	23	23.63	42	23.09



Environmental Monitoring System

DATA REPORT

STERILE EXIT CHANGE ROOMS (L4)

Date Time	STERILE PASSAGE (L4) wrt EXIT ROOM-1 (L4)	STERILE EXIT ROOM-1 (L4)	ASEPTIC EXIT ROOM-1 (L4) wrt EXIT ROOM-2 (L4)	STERILE EXIT ROOM-2 (L4)	ASEPTIC EXIT ROOM-2 (L4) wrt EXIT ROOM-3 (L4)	STERILE EXIT ROOM-3 (L4)
Date Time	DP Pa	°C TEMP	DP Pa	°C TEMP	DP Pa	°C TEMP
04-11-2021 03:13	5	22.65	23	23.61	41	23.10
04-11-2021 03:14	6	22.67	22	23.57	40	23.10
04-11-2021 03:15	10	22.64	0	23.57	51	23.11
04-11-2021 03:16	6	22.61	23	23.58	42	23.10
04-11-2021 03:17	6	22.63	21	23.59	42	23.11
04-11-2021 03:18	6	22.59	22	23.56	42	23.10
04-11-2021 03:19	4	22.59	20	23.55	39	23.08
04-11-2021 03:20	5	22.59	21	23.53	41	23.09
04-11-2021 03:21	6	22.58	21	23.51	42	23.07
04-11-2021 03:22	5	22.56	20	23.51	40	23.07
04-11-2021 03:23	5	22.53	21	23.48	40	23.06
04-11-2021 03:24	6	22.51	20	23.49	40	23.06
04-11-2021 03:25	7	22.51	21	23.48	41	23.05
04-11-2021 03:26	5	22.50	20	23.50	40	23.05
04-11-2021 03:27	6	22.47	20	23.47	42	23.06
04-11-2021 03:28	6	22.47	21	23.46	40	23.04
04-11-2021 03:29	6	22.47	21	23.46	40	23.04
04-11-2021 03:30	4	22.47	21	23.46	41	23.04
04-11-2021 03:31	6	22.46	21	23.44	41	23.03
04-11-2021 03:32	6	22.46	22	23.45	42	23.03
04-11-2021 03:33	4	22.46	21	23.45	41	23.02
04-11-2021 03:34	4	22.46	21	23.44	41	23.02
04-11-2021 03:35	6	22.43	20	23.44	41	23.01
04-11-2021 03:36	5	22.47	20	23.44	40	23.01
04-11-2021 03:37	4	22.44	21	23.42	40	23.01
04-11-2021 03:38	8	22.43	20	23.46	40	23.01
04-11-2021 03:39	5	22.44	20	23.45	41	23.00
04-11-2021 03:40	4	22.45	21	23.44	40	23.00



Environmental Monitoring System

DATA REPORT

STERILE EXIT CHANGE ROOMS (L4)

Date Time	STERILE PASSAGE (L4) wrt EXIT ROOM-1 (L4)	STERILE EXIT ROOM-1 (L4)	ASEPTIC EXIT ROOM-1 (L4) wrt EXIT ROOM-2 (L4)	STERILE EXIT ROOM-2 (L4)	ASEPTIC EXIT ROOM-2 (L4) wrt EXIT ROOM-3 (L4)	STERILE EXIT ROOM-3 (L4)
Date Time	DP Pa	°C TEMP	DP Pa	°C TEMP	DP Pa	°C TEMP
04-11-2021 03:41	5	22.45	21	23.45	41	22.99
04-11-2021 03:42	5	22.45	20	23.46	40	23.00
04-11-2021 03:43	5	22.45	20	23.46	40	23.00
04-11-2021 03:44	4	22.46	21	23.46	40	22.99
04-11-2021 03:45	5	22.45	21	23.47	41	22.98
04-11-2021 03:46	5	22.45	21	23.46	40	22.98
04-11-2021 03:47	4	22.46	21	23.46	40	22.98
04-11-2021 03:48	6	22.47	20	23.46	40	22.98
04-11-2021 03:49	6	22.47	21	23.45	40	22.97
04-11-2021 03:50	4	22.48	20	23.45	40	22.98
04-11-2021 03:51	5	22.48	22	23.44	41	22.98
04-11-2021 03:52	6	22.48	20	23.46	41	22.97
04-11-2021 03:53	6	22.49	21	23.48	40	22.97
04-11-2021 03:54	5	22.49	21	23.48	42	22.98
04-11-2021 03:55	4	22.51	21	23.49	41	22.98
04-11-2021 03:56	4	22.51	20	23.49	40	22.99
04-11-2021 03:57	4	22.52	21	23.51	40	23.00
04-11-2021 03:58	4	22.53	21	23.53	40	22.99
04-11-2021 03:59	4	22.53	20	23.53	41	22.99
04-11-2021 04:00	8	22.55	21	23.54	40	22.98
04-11-2021 04:01	7	22.55	21	23.55	40	22.98
04-11-2021 04:02	7	22.57	20	23.56	40	23.00
04-11-2021 04:03	5	22.57	21	23.56	39	23.01
04-11-2021 04:04	6	22.59	21	23.58	42	23.02
04-11-2021 04:05	7	22.61	21	23.61	40	23.01
04-11-2021 04:06	6	22.61	20	23.60	40	23.01
04-11-2021 04:07	5	22.61	20	23.59	40	23.02
04-11-2021 04:08	6	22.62	21	23.60	40	23.02



Environmental Monitoring System

DATA REPORT

STERILE EXIT CHANGE ROOMS (L4)

Date Time	STERILE PASSAGE (L4) wrt EXIT ROOM-1 (L4)	STERILE EXIT ROOM-1 (L4)	ASEPTIC EXIT ROOM-1 (L4) wrt EXIT ROOM-2 (L4)	STERILE EXIT ROOM-2 (L4)	ASEPTIC EXIT ROOM-2 (L4) wrt EXIT ROOM-3 (L4)	STERILE EXIT ROOM-3 (L4)
Date Time	DP Pa	°C TEMP	DP Pa	°C TEMP	DP Pa	°C TEMP
04-11-2021 04:09	5	22.64	20	23.58	39	23.03
04-11-2021 04:10	6	22.65	21	23.58	41	23.03
04-11-2021 04:11	6	22.65	20	23.61	40	23.03
04-11-2021 04:12	7	22.68	21	23.62	41	23.03
04-11-2021 04:13	7	22.69	21	23.62	41	23.03
04-11-2021 04:14	6	22.67	22	23.62	40	23.04
04-11-2021 04:15	6	22.65	21	23.62	40	23.04
04-11-2021 04:16	7	22.67	21	23.62	40	23.05
04-11-2021 04:17	7	22.67	21	23.63	40	23.05
04-11-2021 04:18	7	22.69	20	23.63	41	23.06
04-11-2021 04:19	6	22.70	20	23.63	40	23.07
04-11-2021 04:20	6	22.70	21	23.67	40	23.07
04-11-2021 04:21	6	22.68	20	23.65	40	23.07
04-11-2021 04:22	6	22.69	22	23.62	40	23.07
04-11-2021 04:23	6	22.71	21	23.62	39	23.08
04-11-2021 04:24	7	22.71	22	23.64	41	23.09
04-11-2021 04:25	7	22.73	21	23.65	41	23.09
04-11-2021 04:26	6	22.71	20	23.64	41	23.09
04-11-2021 04:27	6	22.71	21	23.63	40	23.08
04-11-2021 04:28	6	22.72	21	23.62	40	23.08
04-11-2021 04:29	8	22.73	20	23.62	41	23.08
04-11-2021 04:30	6	22.72	21	23.63	41	23.09
04-11-2021 04:31	7	22.72	20	23.61	40	23.09
04-11-2021 04:32	6	22.71	22	23.62	40	23.09
04-11-2021 04:33	6	22.72	21	23.62	41	23.10
04-11-2021 04:34	8	22.70	21	23.62	41	23.10
04-11-2021 04:35	6	22.70	21	23.61	42	23.10
04-11-2021 04:36	7	22.70	21	23.62	40	23.10



Environmental Monitoring System

DATA REPORT

STERILE EXIT CHANGE ROOMS (L4)

Date Time	STERILE PASSAGE (L4) wrt EXIT ROOM-1 (L4)	STERILE EXIT ROOM-1 (L4)	ASEPTIC EXIT ROOM-1 (L4) wrt EXIT ROOM-2 (L4)	STERILE EXIT ROOM-2 (L4)	ASEPTIC EXIT ROOM-2 (L4) wrt EXIT ROOM-3 (L4)	STERILE EXIT ROOM-3 (L4)
Date Time	DP Pa	°C TEMP	DP Pa	°C TEMP	DP Pa	°C TEMP
04-11-2021 04:37	6	22.68	21	23.61	41	23.10
04-11-2021 04:38	6	22.70	21	23.62	41	23.10
04-11-2021 04:39	6	22.69	21	23.60	40	23.09
04-11-2021 04:40	7	22.67	21	23.58	40	23.10
04-11-2021 04:41	6	22.67	21	23.59	40	23.10
04-11-2021 04:42	6	22.67	21	23.60	41	23.11
04-11-2021 04:43	5	22.66	20	23.59	40	23.10
04-11-2021 04:44	6	22.65	20	23.58	39	23.10
04-11-2021 04:45	6	22.64	18	23.57	39	23.10
04-11-2021 04:46	7	22.65	21	23.55	40	23.11
04-11-2021 04:47	7	22.66	20	23.54	40	23.10
04-11-2021 04:48	8	22.64	21	23.55	41	23.10
04-11-2021 04:49	6	22.64	21	23.55	39	23.10
04-11-2021 04:50	6	22.64	21	23.54	40	23.11
04-11-2021 04:51	6	22.60	21	23.55	41	23.11
04-11-2021 04:52	6	22.60	20	23.51	39	23.10
04-11-2021 04:53	6	22.60	20	23.53	39	23.09
04-11-2021 04:54	6	22.58	20	23.49	40	23.09
04-11-2021 04:55	6	22.59	21	23.49	40	23.09
04-11-2021 04:56	6	22.57	20	23.50	39	23.09
04-11-2021 04:57	6	22.54	20	23.47	39	23.09
04-11-2021 04:58	6	22.53	20	23.47	39	23.09
04-11-2021 04:59	6	22.52	20	23.46	38	23.08
04-11-2021 05:00	6	22.52	20	23.44	39	23.07
04-11-2021 05:01	6	22.50	20	23.44	40	23.05
04-11-2021 05:02	6	22.51	20	23.43	39	23.05
04-11-2021 05:03	7	22.50	20	23.41	39	23.05
04-11-2021 05:04	7	22.50	21	23.40	38	23.04



Environmental Monitoring System

DATA REPORT

STERILE EXIT CHANGE ROOMS (L4)

Date Time	STERILE PASSAGE (L4) wrt EXIT ROOM-1 (L4)	STERILE EXIT ROOM-1 (L4)	ASEPTIC EXIT ROOM-1 (L4) wrt EXIT ROOM-2 (L4)	STERILE EXIT ROOM-2 (L4)	ASEPTIC EXIT ROOM-2 (L4) wrt EXIT ROOM-3 (L4)	STERILE EXIT ROOM-3 (L4)
Date Time	DP Pa	°C TEMP	DP Pa	°C TEMP	DP Pa	°C TEMP
04-11-2021 05:05	6	22.50	20	23.41	39	23.04
04-11-2021 05:06	6	22.49	20	23.41	39	23.03
04-11-2021 05:07	8	22.50	20	23.41	39	23.04
04-11-2021 05:08	6	22.48	20	23.42	39	23.03
04-11-2021 05:09	6	22.49	21	23.40	39	23.03
04-11-2021 05:10	6	22.48	20	23.39	38	23.02
04-11-2021 05:11	8	22.48	21	23.39	40	23.03
04-11-2021 05:12	6	22.48	20	23.40	39	23.03
04-11-2021 05:13	6	22.44	20	23.39	39	23.02
04-11-2021 05:14	6	22.47	20	23.44	37	23.02
04-11-2021 05:15	7	22.47	21	23.45	39	22.99
04-11-2021 05:16	8	22.46	21	23.45	40	23.00
04-11-2021 05:17	6	22.47	20	23.43	39	23.01
04-11-2021 05:18	8	22.45	22	23.46	39	23.01
04-11-2021 05:19	7	22.46	21	23.45	39	23.00
04-11-2021 05:20	6	22.46	21	23.44	40	23.00
04-11-2021 05:21	6	22.47	20	23.44	38	23.00
04-11-2021 05:22	6	22.45	20	23.45	39	23.01
04-11-2021 05:23	8	22.45	21	23.46	39	23.02
04-11-2021 05:24	6	22.45	21	23.45	39	23.01
04-11-2021 05:25	7	22.47	21	23.47	38	23.02
04-11-2021 05:26	6	22.47	21	23.44	39	23.01
04-11-2021 05:27	7	22.49	21	23.46	39	23.01
04-11-2021 05:28	6	22.50	21	23.45	40	23.00
04-11-2021 05:29	7	22.49	21	23.45	40	23.02
04-11-2021 05:30	8	22.52	20	23.45	39	23.02
04-11-2021 05:31	6	22.48	21	23.46	39	23.02
04-11-2021 05:32	6	22.49	21	23.48	40	23.01



Environmental Monitoring System

DATA REPORT

STERILE EXIT CHANGE ROOMS (L4)

Date Time	STERILE PASSAGE (L4) wrt EXIT ROOM-1 (L4)	STERILE EXIT ROOM-1 (L4)	ASEPTIC EXIT ROOM-1 (L4) wrt EXIT ROOM-2 (L4)	STERILE EXIT ROOM-2 (L4)	ASEPTIC EXIT ROOM-2 (L4) wrt EXIT ROOM-3 (L4)	STERILE EXIT ROOM-3 (L4)
Date Time	DP Pa	°C TEMP	DP Pa	°C TEMP	DP Pa	°C TEMP
04-11-2021 05:33	8	22.48	21	23.46	39	23.01
04-11-2021 05:34	6	22.51	21	23.45	40	23.01
04-11-2021 05:35	6	22.52	21	23.44	39	23.01
04-11-2021 05:36	8	22.53	21	23.45	39	23.02
04-11-2021 05:37	6	22.51	20	23.43	40	23.01
04-11-2021 05:38	6	22.53	20	23.44	40	23.01
04-11-2021 05:39	8	22.54	21	23.44	41	23.01
04-11-2021 05:40	8	22.54	21	23.44	40	23.01
04-11-2021 05:41	7	22.56	21	23.44	39	23.01
04-11-2021 05:42	4	22.54	20	23.46	40	23.02
04-11-2021 05:43	7	22.54	21	23.45	40	23.00
04-11-2021 05:44	6	22.54	21	23.45	40	23.00
04-11-2021 05:45	6	22.54	20	23.45	40	23.01
04-11-2021 05:46	8	22.52	21	23.46	40	23.01
04-11-2021 05:47	7	22.52	21	23.48	40	23.01
04-11-2021 05:48	6	22.52	21	23.46	40	23.01
04-11-2021 05:49	6	22.51	20	23.47	39	23.01
04-11-2021 05:50	6	22.52	21	23.47	40	23.01
04-11-2021 05:51	6	22.52	21	23.47	39	23.02
04-11-2021 05:52	7	22.53	21	23.47	40	23.02
04-11-2021 05:53	4	22.53	21	23.47	39	23.01
04-11-2021 05:54	6	22.54	21	23.46	39	22.98
04-11-2021 05:55	4	22.53	21	23.48	39	22.96
04-11-2021 05:56	6	22.54	21	23.48	40	22.97
04-11-2021 05:57	6	22.53	21	23.47	39	22.95
04-11-2021 05:58	6	22.55	21	23.47	40	22.94
04-11-2021 05:59	6	22.54	22	23.46	40	22.94
04-11-2021 06:00	7	22.55	23	23.47	40	22.92



Environmental Monitoring System

DATA REPORT

STERILE EXIT CHANGE ROOMS (L4)

Date Time	STERILE PASSAGE (L4) wrt EXIT ROOM-1 (L4)	STERILE EXIT ROOM-1 (L4)	ASEPTIC EXIT ROOM-1 (L4) wrt EXIT ROOM-2 (L4)	STERILE EXIT ROOM-2 (L4)	ASEPTIC EXIT ROOM-2 (L4) wrt EXIT ROOM-3 (L4)	STERILE EXIT ROOM-3 (L4)
Date Time	DP Pa	°C TEMP	DP Pa	°C TEMP	DP Pa	°C TEMP
04-11-2021 06:01	6	22.53	22	23.46	41	22.93
04-11-2021 06:02	6	22.54	22	23.48	39	22.94
04-11-2021 06:03	6	22.53	23	23.47	39	22.92
04-11-2021 06:04	6	22.54	21	23.48	40	22.91
04-11-2021 06:05	6	22.54	22	23.47	41	22.92
04-11-2021 06:06	6	22.55	22	23.48	40	22.90
04-11-2021 06:07	6	22.55	21	23.48	40	22.91
04-11-2021 06:08	6	22.54	22	23.48	39	22.91
04-11-2021 06:09	6	22.55	21	23.47	39	22.91
04-11-2021 06:10	0	22.53	25	23.47	44	22.91
04-11-2021 06:11	0	22.53	32	23.50	11	22.90
04-11-2021 06:12	5	22.56	22	23.49	40	22.92
04-11-2021 06:13	10	22.56	22	23.47	40	22.90
04-11-2021 06:14	6	22.57	21	23.49	40	22.90
04-11-2021 06:15	6	22.57	21	23.49	42	22.89
04-11-2021 06:16	4	22.57	21	23.50	41	22.90
04-11-2021 06:17	6	22.54	21	23.51	40	22.90
04-11-2021 06:18	6	22.57	22	23.50	41	22.90
04-11-2021 06:19	5	22.58	21	23.48	41	22.89
04-11-2021 06:20	6	22.57	21	23.49	42	22.89
04-11-2021 06:21	5	22.57	21	23.51	41	22.90
04-11-2021 06:22	6	22.57	21	23.50	41	22.88
04-11-2021 06:23	6	22.59	21	23.50	41	22.89
04-11-2021 06:24	7	22.58	21	23.50	40	22.88
04-11-2021 06:25	8	22.57	21	23.51	40	22.87
04-11-2021 06:26	6	22.58	21	23.51	40	22.89
04-11-2021 06:27	7	22.58	21	23.50	41	22.89
04-11-2021 06:28	5	22.57	21	23.49	42	22.90



Environmental Monitoring System

DATA REPORT

STERILE EXIT CHANGE ROOMS (L4)

Date Time	STERILE PASSAGE (L4) wrt EXIT ROOM-1 (L4)	STERILE EXIT ROOM-1 (L4)	ASEPTIC EXIT ROOM-1 (L4) wrt EXIT ROOM-2 (L4)	STERILE EXIT ROOM-2 (L4)	ASEPTIC EXIT ROOM-2 (L4) wrt EXIT ROOM-3 (L4)	STERILE EXIT ROOM-3 (L4)
Date Time	DP Pa	°C TEMP	DP Pa	°C TEMP	DP Pa	°C TEMP
04-11-2021 06:29	9	22.58	21	23.51	40	22.88
04-11-2021 06:30	6	22.57	21	23.51	41	22.87
04-11-2021 06:31	5	22.57	22	23.51	40	22.90
04-11-2021 06:32	8	22.58	21	23.52	40	22.88
04-11-2021 06:33	6	22.56	21	23.52	40	22.89
04-11-2021 06:34	6	22.57	21	23.53	40	22.88
04-11-2021 06:35	8	22.59	21	23.54	42	22.88
04-11-2021 06:36	7	22.58	22	23.54	43	22.89
04-11-2021 06:37	6	22.59	21	23.54	40	22.88
04-11-2021 06:38	6	22.57	21	23.54	40	22.89
04-11-2021 06:39	7	22.59	22	23.53	42	22.89
04-11-2021 06:40	6	22.61	21	23.56	40	22.92
04-11-2021 06:41	11	22.60	21	23.55	40	22.95
04-11-2021 06:42	7	22.61	22	23.56	41	22.96
04-11-2021 06:43	7	22.61	21	23.56	41	22.97
04-11-2021 06:44	8	22.59	22	23.56	42	22.98
04-11-2021 06:45	8	22.59	22	23.56	42	22.99
04-11-2021 06:46	9	22.60	21	23.57	42	23.00
04-11-2021 06:47	7	22.60	23	23.57	41	23.02
04-11-2021 06:48	7	22.61	21	23.56	42	23.01
04-11-2021 06:49	8	22.61	21	23.56	42	23.01
04-11-2021 06:50	8	22.62	22	23.57	40	23.03
04-11-2021 06:51	9	22.62	21	23.57	42	23.03
04-11-2021 06:52	8	22.63	21	23.59	42	23.03
04-11-2021 06:53	6	22.64	21	23.59	41	23.03
04-11-2021 06:54	8	22.63	21	23.61	41	23.05
04-11-2021 06:55	8	22.64	22	23.60	41	23.04
04-11-2021 06:56	9	22.64	21	23.61	42	23.05



Environmental Monitoring System

DATA REPORT

STERILE EXIT CHANGE ROOMS (L4)

Date Time	STERILE PASSAGE (L4) wrt EXIT ROOM-1 (L4)	STERILE EXIT ROOM-1 (L4)	ASEPTIC EXIT ROOM-1 (L4) wrt EXIT ROOM-2 (L4)	STERILE EXIT ROOM-2 (L4)	ASEPTIC EXIT ROOM-2 (L4) wrt EXIT ROOM-3 (L4)	STERILE EXIT ROOM-3 (L4)
Date Time	DP Pa	°C TEMP	DP Pa	°C TEMP	DP Pa	°C TEMP
04-11-2021 06:57	8	22.67	21	23.60	41	23.07
04-11-2021 06:58	8	22.67	21	23.60	41	23.07
04-11-2021 06:59	8	22.68	20	23.62	42	23.08
04-11-2021 07:00	6	22.66	21	23.61	42	23.08
04-11-2021 07:01	8	22.68	22	23.61	42	23.07
04-11-2021 07:02	8	22.70	23	23.63	42	23.08
04-11-2021 07:03	7	22.71	22	23.63	42	23.10
04-11-2021 07:04	7	22.69	21	23.63	41	23.09
04-11-2021 07:05	8	22.69	21	23.65	41	23.09
04-11-2021 07:06	7	22.71	22	23.65	41	23.10
04-11-2021 07:07	9	22.69	21	23.64	42	23.11
04-11-2021 07:08	8	22.71	21	23.64	40	23.11
04-11-2021 07:09	8	22.71	22	23.64	41	23.10
04-11-2021 07:10	7	22.72	22	23.64	41	23.12
04-11-2021 07:11	8	22.72	22	23.64	41	23.12
04-11-2021 07:12	8	22.70	21	23.63	41	23.12
04-11-2021 07:13	8	22.72	22	23.64	41	23.13
04-11-2021 07:14	7	22.73	21	23.66	40	23.13
04-11-2021 07:15	8	22.75	23	23.65	42	23.14
04-11-2021 07:16	7	22.73	21	23.64	42	23.13
04-11-2021 07:17	9	22.73	21	23.65	42	23.14
04-11-2021 07:18	8	22.74	21	23.63	42	23.14
04-11-2021 07:19	6	22.74	23	23.63	42	23.14
04-11-2021 07:20	8	22.72	21	23.64	42	23.15
04-11-2021 07:21	8	22.73	22	23.63	42	23.14
04-11-2021 07:22	8	22.70	22	23.62	42	23.15
04-11-2021 07:23	8	22.71	21	23.63	40	23.15
04-11-2021 07:24	6	22.72	22	23.65	42	23.15



Environmental Monitoring System

DATA REPORT

STERILE EXIT CHANGE ROOMS (L4)

Date Time	STERILE PASSAGE (L4) wrt EXIT ROOM-1 (L4)	STERILE EXIT ROOM-1 (L4)	ASEPTIC EXIT ROOM-1 (L4) wrt EXIT ROOM-2 (L4)	STERILE EXIT ROOM-2 (L4)	ASEPTIC EXIT ROOM-2 (L4) wrt EXIT ROOM-3 (L4)	STERILE EXIT ROOM-3 (L4)
Date Time	DP Pa	°C TEMP	DP Pa	°C TEMP	DP Pa	°C TEMP
04-11-2021 07:25	8	22.71	22	23.64	42	23.16
04-11-2021 07:26	8	22.73	22	23.63	42	23.15
04-11-2021 07:27	7	22.68	23	23.63	42	23.16
04-11-2021 07:28	8	22.69	23	23.64	42	23.16
04-11-2021 07:29	6	22.70	23	23.63	41	23.15
04-11-2021 07:30	7	22.68	22	23.62	42	23.15
04-11-2021 07:31	10	22.69	21	23.62	41	23.15
04-11-2021 07:32	7	22.70	23	23.61	41	23.15
04-11-2021 07:33	7	22.71	23	23.62	41	23.15
04-11-2021 07:34	10	22.68	21	23.60	40	23.15
04-11-2021 07:35	8	22.69	22	23.60	42	23.16
04-11-2021 07:36	8	22.66	22	23.60	41	23.16
04-11-2021 07:37	8	22.67	21	23.58	42	23.15
04-11-2021 07:38	8	22.63	22	23.58	41	23.15
04-11-2021 07:39	8	22.64	21	23.60	42	23.14
04-11-2021 07:40	6	22.66	23	23.58	42	23.16
04-11-2021 07:41	8	22.66	21	23.58	42	23.16
04-11-2021 07:42	8	22.66	21	23.57	40	23.16
04-11-2021 07:43	8	22.65	21	23.57	41	23.16
04-11-2021 07:44	9	22.63	22	23.57	42	23.17
04-11-2021 07:45	7	22.65	22	23.56	41	23.15
04-11-2021 07:46	7	22.62	21	23.56	42	23.15
04-11-2021 07:47	6	22.63	21	23.58	42	23.16
04-11-2021 07:48	9	22.63	21	23.55	42	23.15
04-11-2021 07:49	6	22.63	22	23.57	42	23.16
04-11-2021 07:50	7	22.61	21	23.56	42	23.16
04-11-2021 07:51	8	22.62	21	23.57	42	23.16
04-11-2021 07:52	8	22.62	21	23.55	42	23.16



Environmental Monitoring System

DATA REPORT

STERILE EXIT CHANGE ROOMS (L4)

Date Time	STERILE PASSAGE (L4) wrt EXIT ROOM-1 (L4)	STERILE EXIT ROOM-1 (L4)	ASEPTIC EXIT ROOM-1 (L4) wrt EXIT ROOM-2 (L4)	STERILE EXIT ROOM-2 (L4)	ASEPTIC EXIT ROOM-2 (L4) wrt EXIT ROOM-3 (L4)	STERILE EXIT ROOM-3 (L4)
Date Time	DP Pa	°C TEMP	DP Pa	°C TEMP	DP Pa	°C TEMP
04-11-2021 07:53	6	22.64	22	23.57	41	23.16
04-11-2021 07:54	7	22.63	22	23.55	42	23.16
04-11-2021 07:55	8	22.60	21	23.56	42	23.16
04-11-2021 07:56	9	22.60	22	23.57	42	23.15
04-11-2021 07:57	7	22.63	23	23.55	42	23.16
04-11-2021 07:58	8	22.61	22	23.56	42	23.15
04-11-2021 07:59	8	22.62	21	23.55	42	23.15
04-11-2021 08:00	8	22.61	21	23.55	42	23.15
04-11-2021 08:01	6	22.61	34	23.58	50	23.15
04-11-2021 08:02	8	22.62	22	23.60	39	23.16
04-11-2021 08:03	9	22.60	24	23.57	42	23.13
04-11-2021 08:04	9	22.60	23	23.56	41	23.14
04-11-2021 08:05	8	22.59	22	23.55	40	23.13
04-11-2021 08:06	9	22.60	21	23.55	41	23.14
04-11-2021 08:07	7	22.57	22	23.54	41	23.14
04-11-2021 08:08	6	22.59	23	23.52	42	23.14
04-11-2021 08:09	8	22.57	23	23.52	41	23.14
04-11-2021 08:10	8	22.57	23	23.50	40	23.12
04-11-2021 08:11	7	22.54	23	23.51	40	23.12
04-11-2021 08:12	8	22.54	23	23.49	41	23.10
04-11-2021 08:13	7	22.51	23	23.49	40	23.10
04-11-2021 08:14	8	22.52	23	23.47	40	23.09
04-11-2021 08:15	8	22.49	22	23.47	40	23.10
04-11-2021 08:16	9	22.47	22	23.46	41	23.10
04-11-2021 08:17	8	22.45	21	23.45	40	23.10
04-11-2021 08:18	8	22.46	23	23.45	41	23.09
04-11-2021 08:19	8	22.47	22	23.44	42	23.09
04-11-2021 08:20	7	22.45	23	23.44	42	23.09



Environmental Monitoring System

DATA REPORT

STERILE EXIT CHANGE ROOMS (L4)

Date Time	STERILE PASSAGE (L4) wrt EXIT ROOM-1 (L4)	STERILE EXIT ROOM-1 (L4)	ASEPTIC EXIT ROOM-1 (L4) wrt EXIT ROOM-2 (L4)	STERILE EXIT ROOM-2 (L4)	ASEPTIC EXIT ROOM-2 (L4) wrt EXIT ROOM-3 (L4)	STERILE EXIT ROOM-3 (L4)
Date Time	DP Pa	°C TEMP	DP Pa	°C TEMP	DP Pa	°C TEMP
04-11-2021 08:21	6	22.43	22	23.44	41	23.08
04-11-2021 08:22	8	22.44	23	23.43	40	23.09
04-11-2021 08:23	8	22.43	23	23.43	42	23.09
04-11-2021 08:24	9	22.43	22	23.44	41	23.08
04-11-2021 08:25	6	22.43	22	23.44	41	23.08
04-11-2021 08:26	6	22.44	22	23.44	40	23.07
04-11-2021 08:27	8	22.44	23	23.42	40	23.08
04-11-2021 08:28	7	22.43	23	23.42	40	23.07
04-11-2021 08:29	9	22.46	21	23.42	40	23.05
04-11-2021 08:30	5	22.44	23	23.42	40	23.05
04-11-2021 08:31	8	22.47	22	23.44	41	23.06
04-11-2021 08:32	6	22.45	23	23.47	40	23.06
04-11-2021 08:33	7	22.44	22	23.46	40	23.06
04-11-2021 08:34	7	22.44	23	23.48	40	23.06
04-11-2021 08:35	8	22.46	23	23.47	40	23.06
04-11-2021 08:36	6	22.47	21	23.47	40	23.04
04-11-2021 08:37	8	22.46	23	23.48	40	23.05
04-11-2021 08:38	6	22.47	21	23.49	41	23.05
04-11-2021 08:39	6	22.49	23	23.51	42	23.06
04-11-2021 08:40	8	22.47	22	23.51	41	23.06
04-11-2021 08:41	8	22.47	22	23.49	40	23.06
04-11-2021 08:42	8	22.48	23	23.51	40	23.06
04-11-2021 08:43	8	22.48	23	23.51	40	23.06
04-11-2021 08:44	8	22.47	23	23.52	42	23.06
04-11-2021 08:45	8	22.48	21	23.52	40	23.05
04-11-2021 08:46	8	22.49	22	23.51	40	23.06
04-11-2021 08:47	7	22.50	23	23.53	41	23.06
04-11-2021 08:48	8	22.51	21	23.53	40	23.05



Environmental Monitoring System

DATA REPORT

STERILE EXIT CHANGE ROOMS (L4)

Date Time	STERILE PASSAGE (L4) wrt EXIT ROOM-1 (L4)	STERILE EXIT ROOM-1 (L4)	ASEPTIC EXIT ROOM-1 (L4) wrt EXIT ROOM-2 (L4)	STERILE EXIT ROOM-2 (L4)	ASEPTIC EXIT ROOM-2 (L4) wrt EXIT ROOM-3 (L4)	STERILE EXIT ROOM-3 (L4)
Date Time	DP Pa	°C TEMP	DP Pa	°C TEMP	DP Pa	°C TEMP
04-11-2021 08:49	8	22.53	23	23.54	42	23.05
04-11-2021 08:50	8	22.50	23	23.54	41	23.06
04-11-2021 08:51	7	22.50	23	23.53	41	23.05
04-11-2021 08:52	7	22.50	23	23.52	42	23.06
04-11-2021 08:53	7	22.51	23	23.53	42	23.06
04-11-2021 08:54	8	22.52	23	23.53	40	23.06
04-11-2021 08:55	8	22.49	23	23.52	40	23.06
04-11-2021 08:56	8	22.52	22	23.51	42	23.07
04-11-2021 08:57	8	22.51	23	23.53	42	23.07
04-11-2021 08:58	8	22.51	23	23.52	42	23.06
04-11-2021 08:59	6	22.54	23	23.55	41	23.07
04-11-2021 09:00	8	22.57	23	23.56	40	23.07
04-11-2021 09:01	8	22.54	22	23.54	41	23.07
04-11-2021 09:02	9	22.55	22	23.56	40	23.07
04-11-2021 09:03	8	22.55	22	23.56	40	23.08
04-11-2021 09:04	8	22.56	23	23.55	42	23.08
04-11-2021 09:05	8	22.56	22	23.56	40	23.09
04-11-2021 09:06	8	22.57	23	23.55	42	23.08
04-11-2021 09:07	7	22.56	23	23.56	42	23.08
04-11-2021 09:08	6	22.57	23	23.55	41	23.10
04-11-2021 09:09	8	22.56	22	23.56	40	23.11
04-11-2021 09:10	8	22.57	21	23.55	42	23.10
04-11-2021 09:11	8	22.58	23	23.56	41	23.10
04-11-2021 09:12	8	22.59	23	23.58	40	23.10
04-11-2021 09:13	8	22.58	22	23.57	40	23.09
04-11-2021 09:14	6	22.58	23	23.60	40	23.09
04-11-2021 09:15	7	22.57	23	23.59	41	23.11
04-11-2021 09:16	7	22.56	23	23.56	42	23.08



Environmental Monitoring System

DATA REPORT

STERILE EXIT CHANGE ROOMS (L4)

Date Time	STERILE PASSAGE (L4) wrt EXIT ROOM-1 (L4)	STERILE EXIT ROOM-1 (L4)	ASEPTIC EXIT ROOM-1 (L4) wrt EXIT ROOM-2 (L4)	STERILE EXIT ROOM-2 (L4)	ASEPTIC EXIT ROOM-2 (L4) wrt EXIT ROOM-3 (L4)	STERILE EXIT ROOM-3 (L4)
Date Time	DP Pa	°C TEMP	DP Pa	°C TEMP	DP Pa	°C TEMP
04-11-2021 09:17	8	22.55	22	23.55	40	23.10
04-11-2021 09:18	8	22.56	22	23.54	41	23.11
04-11-2021 09:19	7	22.55	22	23.54	41	23.10
04-11-2021 09:20	8	22.57	23	23.53	40	23.09
04-11-2021 09:21	8	22.55	22	23.51	41	23.12
04-11-2021 09:22	7	22.53	21	23.50	41	23.11
04-11-2021 09:23	6	22.52	23	23.49	40	23.11
04-11-2021 09:24	6	22.52	23	23.47	41	23.09
04-11-2021 09:25	0	22.47	25	23.46	38	23.10
04-11-2021 09:26	8	22.45	23	23.45	40	23.10
04-11-2021 09:27	6	22.45	23	23.44	41	23.08
04-11-2021 09:28	8	22.46	23	23.42	40	23.09
04-11-2021 09:29	8	22.41	21	23.41	42	23.10
04-11-2021 09:30	6	22.42	23	23.41	40	23.09
04-11-2021 09:31	7	22.41	24	23.41	40	23.08
04-11-2021 09:32	8	22.40	23	23.39	41	23.07
04-11-2021 09:33	8	22.39	23	23.38	42	23.07
04-11-2021 09:34	7	22.37	23	23.37	42	23.06
04-11-2021 09:35	8	22.36	23	23.35	40	23.08
04-11-2021 09:36	8	22.36	23	23.35	40	23.06
04-11-2021 09:37	7	22.34	23	23.35	40	23.06
04-11-2021 09:38	7	22.32	22	23.34	40	23.06
04-11-2021 09:39	8	22.33	23	23.34	40	23.05
04-11-2021 09:40	7	22.34	22	23.32	40	23.06
04-11-2021 09:41	10	22.31	25	23.32	41	23.06
04-11-2021 09:42	8	22.31	25	23.33	43	23.05
04-11-2021 09:43	7	22.30	21	23.31	40	23.05
04-11-2021 09:44	8	22.27	24	23.31	40	23.03



Environmental Monitoring System

DATA REPORT

STERILE EXIT CHANGE ROOMS (L4)

Date Time	STERILE PASSAGE (L4) wrt EXIT ROOM-1 (L4)	STERILE EXIT ROOM-1 (L4)	ASEPTIC EXIT ROOM-1 (L4) wrt EXIT ROOM-2 (L4)	STERILE EXIT ROOM-2 (L4)	ASEPTIC EXIT ROOM-2 (L4) wrt EXIT ROOM-3 (L4)	STERILE EXIT ROOM-3 (L4)
Date Time	DP Pa	°C TEMP	DP Pa	°C TEMP	DP Pa	°C TEMP
04-11-2021 09:45	6	22.27	22	23.30	41	23.05
04-11-2021 09:46	6	22.28	22	23.31	40	23.03
04-11-2021 09:47	7	22.29	23	23.32	40	23.03
04-11-2021 09:48	8	22.30	22	23.31	40	23.02
04-11-2021 09:49	6	22.27	24	23.33	43	23.02
04-11-2021 09:50	11	22.30	23	23.33	41	23.03
04-11-2021 09:51	5	22.30	22	23.33	41	23.03
04-11-2021 09:52	7	22.31	22	23.32	40	23.02
04-11-2021 09:53	6	22.30	23	23.34	40	23.02
04-11-2021 09:54	7	22.31	23	23.33	40	23.02
04-11-2021 09:55	6	22.31	24	23.35	40	23.03
04-11-2021 09:56	6	22.32	22	23.34	40	23.02
04-11-2021 09:57	4	22.32	22	23.36	42	23.03
04-11-2021 09:58	8	22.34	24	23.35	42	23.02
04-11-2021 09:59	7	22.34	24	23.37	42	23.02
04-11-2021 10:00	8	22.33	22	23.40	41	23.03
04-11-2021 10:01	8	22.33	22	23.39	42	23.03
04-11-2021 10:02	8	22.36	22	23.39	40	23.03
04-11-2021 10:03	6	22.35	23	23.40	39	23.02
04-11-2021 10:04	8	22.38	23	23.40	40	23.02
04-11-2021 10:05	8	22.39	22	23.40	40	23.02
04-11-2021 10:06	6	22.37	23	23.41	40	23.02
04-11-2021 10:07	8	22.38	23	23.40	41	23.02
04-11-2021 10:08	7	22.40	24	23.40	42	23.04
04-11-2021 10:09	8	22.40	23	23.42	41	23.02
04-11-2021 10:10	8	22.43	23	23.42	42	23.02
04-11-2021 10:11	9	22.43	23	23.41	40	23.02
04-11-2021 10:12	8	22.43	23	23.43	42	23.02



Environmental Monitoring System

DATA REPORT

STERILE EXIT CHANGE ROOMS (L4)

Date Time	STERILE PASSAGE (L4) wrt EXIT ROOM-1 (L4)	STERILE EXIT ROOM-1 (L4)	ASEPTIC EXIT ROOM-1 (L4) wrt EXIT ROOM-2 (L4)	STERILE EXIT ROOM-2 (L4)	ASEPTIC EXIT ROOM-2 (L4) wrt EXIT ROOM-3 (L4)	STERILE EXIT ROOM-3 (L4)
Date Time	DP Pa	°C TEMP	DP Pa	°C TEMP	DP Pa	°C TEMP
04-11-2021 10:13	8	22.45	21	23.44	42	23.03
04-11-2021 10:14	8	22.43	23	23.45	41	23.04
04-11-2021 10:15	7	22.42	22	23.47	42	23.03
04-11-2021 10:16	9	22.43	23	23.47	42	23.03
04-11-2021 10:17	8	22.43	22	23.46	42	23.04
04-11-2021 10:18	8	22.45	23	23.48	41	23.06
04-11-2021 10:19	8	22.44	23	23.47	40	23.04
04-11-2021 10:20	9	22.46	25	23.49	42	23.05
04-11-2021 10:21	8	22.46	22	23.46	41	23.06
04-11-2021 10:22	8	22.47	23	23.45	42	23.05
04-11-2021 10:23	8	22.47	23	23.45	40	23.06
04-11-2021 10:24	8	22.47	23	23.45	41	23.06
04-11-2021 10:25	7	22.46	23	23.43	41	23.06
04-11-2021 10:26	7	22.46	23	23.43	40	23.05
04-11-2021 10:27	8	22.44	22	23.43	41	23.06
04-11-2021 10:28	8	22.47	22	23.43	42	23.07
04-11-2021 10:29	8	22.46	23	23.41	41	23.06
04-11-2021 10:30	8	22.44	23	23.39	40	23.06
04-11-2021 10:31	8	22.45	22	23.40	41	23.06
04-11-2021 10:32	7	22.42	22	23.40	40	23.06
04-11-2021 10:33	6	22.42	23	23.39	40	23.06
04-11-2021 10:34	8	22.44	23	23.40	40	23.07
04-11-2021 10:35	8	22.42	23	23.39	41	23.07
04-11-2021 10:36	8	22.43	21	23.40	42	23.07
04-11-2021 10:37	6	22.40	22	23.39	41	23.07
04-11-2021 10:38	0	22.39	27	23.37	44	23.07
04-11-2021 10:39	8	22.40	23	23.37	40	23.08
04-11-2021 10:40	8	22.37	22	23.36	41	23.07



Environmental Monitoring System

DATA REPORT

STERILE EXIT CHANGE ROOMS (L4)

Date Time	STERILE PASSAGE (L4) wrt EXIT ROOM-1 (L4)	STERILE EXIT ROOM-1 (L4)	ASEPTIC EXIT ROOM-1 (L4) wrt EXIT ROOM-2 (L4)	STERILE EXIT ROOM-2 (L4)	ASEPTIC EXIT ROOM-2 (L4) wrt EXIT ROOM-3 (L4)	STERILE EXIT ROOM-3 (L4)
Date Time	DP Pa	°C TEMP	DP Pa	°C TEMP	DP Pa	°C TEMP
04-11-2021 10:41	7	22.38	23	23.38	40	23.07
04-11-2021 10:42	7	22.39	22	23.37	40	23.03
04-11-2021 10:43	8	22.39	22	23.36	39	23.01
04-11-2021 10:44	8	22.37	22	23.34	39	22.99
04-11-2021 10:45	7	22.38	22	23.34	39	22.97
04-11-2021 10:46	6	22.36	23	23.34	39	22.95
04-11-2021 10:47	6	22.37	21	23.30	39	22.94
04-11-2021 10:48	8	22.34	22	23.31	39	22.91
04-11-2021 10:49	8	22.32	21	23.33	39	22.90
04-11-2021 10:50	8	22.32	22	23.32	40	22.88
04-11-2021 10:51	8	22.31	21	23.30	39	22.86
04-11-2021 10:52	8	22.32	23	23.28	39	22.86
04-11-2021 10:53	8	22.30	21	23.28	39	22.84
04-11-2021 10:54	8	22.26	21	23.28	39	22.82
04-11-2021 10:55	7	22.27	22	23.26	39	22.79
04-11-2021 10:56	8	22.26	21	23.25	40	22.80
04-11-2021 10:57	9	22.25	22	23.24	39	22.78
04-11-2021 10:58	9	22.24	21	23.23	40	22.79
04-11-2021 10:59	8	22.23	21	23.24	40	22.77
04-11-2021 11:00	8	22.24	21	23.21	39	22.75
04-11-2021 11:01	8	22.22	22	23.23	39	22.75
04-11-2021 11:02	8	22.22	23	23.23	38	22.74
04-11-2021 11:03	8	22.21	22	23.22	40	22.75
04-11-2021 11:04	8	22.22	22	23.24	39	22.75
04-11-2021 11:05	7	22.23	22	23.23	38	22.74
04-11-2021 11:06	8	22.24	21	23.24	39	22.73
04-11-2021 11:07	8	22.24	21	23.24	39	22.74
04-11-2021 11:08	8	22.24	21	23.24	39	22.73



Environmental Monitoring System

DATA REPORT

STERILE EXIT CHANGE ROOMS (L4)

Date Time	STERILE PASSAGE (L4) wrt EXIT ROOM-1 (L4)	STERILE EXIT ROOM-1 (L4)	ASEPTIC EXIT ROOM-1 (L4) wrt EXIT ROOM-2 (L4)	STERILE EXIT ROOM-2 (L4)	ASEPTIC EXIT ROOM-2 (L4) wrt EXIT ROOM-3 (L4)	STERILE EXIT ROOM-3 (L4)
Date Time	DP Pa	°C TEMP	DP Pa	°C TEMP	DP Pa	°C TEMP
04-11-2021 11:09	8	22.24	22	23.25	39	22.73
04-11-2021 11:10	6	22.23	22	23.24	39	22.73
04-11-2021 11:11	7	22.25	23	23.25	39	22.74
04-11-2021 11:12	9	22.24	22	23.26	40	22.74
04-11-2021 11:13	8	22.26	23	23.26	40	22.75
04-11-2021 11:14	8	22.28	21	23.28	39	22.73
04-11-2021 11:15	7	22.27	22	23.28	39	22.74
04-11-2021 11:16	9	22.26	22	23.29	39	22.74
04-11-2021 11:17	10	22.28	22	23.29	40	22.75
04-11-2021 11:18	8	22.29	21	23.33	39	22.74
04-11-2021 11:19	8	22.29	23	23.32	39	22.75
04-11-2021 11:20	8	22.32	21	23.32	39	22.75
04-11-2021 11:21	7	22.32	21	23.36	38	22.76
04-11-2021 11:22	8	22.33	23	23.34	40	22.76
04-11-2021 11:23	9	22.35	23	23.34	39	22.76
04-11-2021 11:24	7	22.36	22	23.37	39	22.76
04-11-2021 11:25	8	22.36	22	23.39	39	22.78
04-11-2021 11:26	7	22.37	21	23.38	40	22.78
04-11-2021 11:27	9	22.37	23	23.39	40	22.78
04-11-2021 11:28	8	22.37	22	23.41	39	22.80
04-11-2021 11:29	8	22.38	22	23.42	39	22.79
04-11-2021 11:30	6	22.39	22	23.42	40	22.81
04-11-2021 11:31	9	22.41	22	23.43	39	22.81
04-11-2021 11:32	8	22.40	22	23.46	40	22.82
04-11-2021 11:33	9	22.43	21	23.46	39	22.83
04-11-2021 11:34	8	22.43	22	23.45	39	22.81
04-11-2021 11:35	9	22.43	23	23.44	38	22.83
04-11-2021 11:36	8	22.43	22	23.44	39	22.84



Environmental Monitoring System

DATA REPORT

STERILE EXIT CHANGE ROOMS (L4)

Date Time	STERILE PASSAGE (L4) wrt EXIT ROOM-1 (L4)	STERILE EXIT ROOM-1 (L4)	ASEPTIC EXIT ROOM-1 (L4) wrt EXIT ROOM-2 (L4)	STERILE EXIT ROOM-2 (L4)	ASEPTIC EXIT ROOM-2 (L4) wrt EXIT ROOM-3 (L4)	STERILE EXIT ROOM-3 (L4)
Date Time	DP Pa	°C TEMP	DP Pa	°C TEMP	DP Pa	°C TEMP
04-11-2021 11:37	8	22.46	21	23.43	39	22.83
04-11-2021 11:38	8	22.45	23	23.45	40	22.84
04-11-2021 11:39	7	22.48	22	23.44	40	22.83
04-11-2021 11:40	8	22.47	22	23.45	40	22.84
04-11-2021 11:41	7	22.48	23	23.44	39	22.83
04-11-2021 11:42	8	22.47	23	23.43	40	22.82
04-11-2021 11:43	9	22.47	23	23.43	39	22.85
04-11-2021 11:44	8	22.46	23	23.44	39	22.86
04-11-2021 11:45	6	22.46	21	23.42	39	22.87
04-11-2021 11:46	8	22.46	22	23.41	39	22.84
04-11-2021 11:47	8	22.44	21	23.40	40	22.83
04-11-2021 11:48	8	22.43	23	23.43	39	22.82
04-11-2021 11:49	8	22.42	21	23.41	38	22.82
04-11-2021 11:50	8	22.40	22	23.41	39	22.82
04-11-2021 11:51	7	22.39	21	23.40	40	22.82
04-11-2021 11:52	9	22.37	23	23.37	39	22.81
04-11-2021 11:53	6	22.38	21	23.36	39	22.79
04-11-2021 11:54	8	22.37	21	23.38	39	22.79
04-11-2021 11:55	9	22.38	22	23.34	39	22.78
04-11-2021 11:56	8	22.33	22	23.32	39	22.78
04-11-2021 11:57	7	22.34	22	23.31	39	22.78
04-11-2021 11:58	7	22.32	21	23.32	40	22.75
04-11-2021 11:59	7	22.30	22	23.30	39	22.75
04-11-2021 12:00	9	22.32	21	23.28	39	22.75
04-11-2021 12:01	7	22.28	21	23.26	39	22.74
04-11-2021 12:02	8	22.29	23	23.25	38	22.74
04-11-2021 12:03	7	22.28	21	23.25	39	22.73
04-11-2021 12:04	8	22.26	21	23.23	39	22.73



Environmental Monitoring System

DATA REPORT

STERILE EXIT CHANGE ROOMS (L4)

Date Time	STERILE PASSAGE (L4) wrt EXIT ROOM-1 (L4)	STERILE EXIT ROOM-1 (L4)	ASEPTIC EXIT ROOM-1 (L4) wrt EXIT ROOM-2 (L4)	STERILE EXIT ROOM-2 (L4)	ASEPTIC EXIT ROOM-2 (L4) wrt EXIT ROOM-3 (L4)	STERILE EXIT ROOM-3 (L4)
Date Time	DP Pa	°C TEMP	DP Pa	°C TEMP	DP Pa	°C TEMP
04-11-2021 12:05	9	22.26	21	23.23	38	22.72
04-11-2021 12:06	6	22.25	22	23.23	38	22.72
04-11-2021 12:07	8	22.24	21	23.23	38	22.70
04-11-2021 12:08	8	22.23	21	23.21	39	22.71
04-11-2021 12:09	7	22.24	21	23.22	39	22.68
04-11-2021 12:10	8	22.25	21	23.24	39	22.70
04-11-2021 12:11	8	22.24	21	23.23	39	22.69
04-11-2021 12:12	8	22.22	21	23.24	39	22.70
04-11-2021 12:13	8	22.23	23	23.22	39	22.70
04-11-2021 12:14	8	22.25	22	23.23	39	22.69
04-11-2021 12:15	7	22.23	21	23.23	39	22.70
04-11-2021 12:16	7	22.25	22	23.25	39	22.70
04-11-2021 12:17	9	22.24	21	23.26	39	22.69
04-11-2021 12:18	7	22.24	21	23.27	39	22.70
04-11-2021 12:19	7	22.24	22	23.26	39	22.69
04-11-2021 12:20	8	22.24	21	23.27	37	22.70
04-11-2021 12:21	8	22.26	21	23.29	39	22.71
04-11-2021 12:22	8	22.27	21	23.27	39	22.71
04-11-2021 12:23	6	22.26	22	23.29	39	22.70
04-11-2021 12:24	7	22.26	21	23.29	39	22.71
04-11-2021 12:25	8	22.26	21	23.29	39	22.73
04-11-2021 12:26	7	22.28	21	23.29	39	22.73
04-11-2021 12:27	8	22.32	21	23.30	37	22.72
04-11-2021 12:28	8	22.31	21	23.31	39	22.73
04-11-2021 12:29	8	22.32	23	23.30	37	22.73
04-11-2021 12:30	6	22.33	23	23.32	39	22.72
04-11-2021 12:31	7	22.32	21	23.35	39	22.73
04-11-2021 12:32	6	22.34	22	23.37	39	22.74



Environmental Monitoring System

DATA REPORT

STERILE EXIT CHANGE ROOMS (L4)

Date Time	STERILE PASSAGE (L4) wrt EXIT ROOM-1 (L4)	STERILE EXIT ROOM-1 (L4)	ASEPTIC EXIT ROOM-1 (L4) wrt EXIT ROOM-2 (L4)	STERILE EXIT ROOM-2 (L4)	ASEPTIC EXIT ROOM-2 (L4) wrt EXIT ROOM-3 (L4)	STERILE EXIT ROOM-3 (L4)
Date Time	DP Pa	°C TEMP	DP Pa	°C TEMP	DP Pa	°C TEMP
04-11-2021 12:33	6	22.33	20	23.36	39	22.75
04-11-2021 12:34	6	22.33	21	23.35	39	22.76
04-11-2021 12:35	7	22.34	21	23.38	40	22.75
04-11-2021 12:36	8	22.34	21	23.37	39	22.76
04-11-2021 12:37	8	22.34	22	23.39	38	22.75
04-11-2021 12:38	8	22.36	22	23.39	39	22.76
04-11-2021 12:39	7	22.35	21	23.40	39	22.77
04-11-2021 12:40	8	22.37	23	23.39	40	22.78
04-11-2021 12:41	8	22.37	22	23.38	39	22.76
04-11-2021 12:42	8	22.38	22	23.39	39	22.76
04-11-2021 12:43	7	22.36	21	23.39	37	22.77
04-11-2021 12:44	7	22.38	21	23.40	39	22.78
04-11-2021 12:45	8	22.38	21	23.37	39	22.76
04-11-2021 12:46	7	22.39	22	23.36	39	22.76
04-11-2021 12:47	8	22.37	22	23.36	39	22.77
04-11-2021 12:48	7	22.37	22	23.34	39	22.76
04-11-2021 12:49	8	22.36	21	23.34	39	22.77
04-11-2021 12:50	13	22.37	13	23.32	46	22.77
04-11-2021 12:51	9	22.37	21	23.37	39	22.77
04-11-2021 12:52	8	22.38	21	23.34	39	22.79
04-11-2021 12:53	7	22.35	21	23.32	38	22.79
04-11-2021 12:54	8	22.33	22	23.31	37	22.79
04-11-2021 12:55	7	22.29	22	23.29	39	22.78
04-11-2021 12:56	8	22.30	21	23.29	38	22.76
04-11-2021 12:57	6	22.28	21	23.28	38	22.75
04-11-2021 12:58	6	22.28	22	23.27	38	22.75
04-11-2021 12:59	7	22.29	22	23.25	37	22.74
04-11-2021 13:00	6	22.27	21	23.26	39	22.73



Environmental Monitoring System

DATA REPORT

STERILE EXIT CHANGE ROOMS (L4)

Date Time	STERILE PASSAGE (L4) wrt EXIT ROOM-1 (L4)	STERILE EXIT ROOM-1 (L4)	ASEPTIC EXIT ROOM-1 (L4) wrt EXIT ROOM-2 (L4)	STERILE EXIT ROOM-2 (L4)	ASEPTIC EXIT ROOM-2 (L4) wrt EXIT ROOM-3 (L4)	STERILE EXIT ROOM-3 (L4)
Date Time	DP Pa	°C TEMP	DP Pa	°C TEMP	DP Pa	°C TEMP
04-11-2021 13:01	8	22.26	23	23.25	39	22.72
04-11-2021 13:02	7	22.25	21	23.23	39	22.71
04-11-2021 13:03	8	22.25	21	23.24	39	22.71
04-11-2021 13:04	8	22.23	22	23.25	40	22.70
04-11-2021 13:05	7	22.23	22	23.24	38	22.68
04-11-2021 13:06	6	22.20	22	23.23	37	22.68
04-11-2021 13:07	8	22.20	21	23.21	39	22.68
04-11-2021 13:08	7	22.20	21	23.20	38	22.66
04-11-2021 13:09	6	22.20	21	23.19	39	22.67
04-11-2021 13:10	8	22.17	21	23.20	39	22.66
04-11-2021 13:11	7	22.19	21	23.19	38	22.66
04-11-2021 13:12	7	22.17	22	23.18	39	22.66
04-11-2021 13:13	8	22.21	21	23.21	38	22.67
04-11-2021 13:14	8	22.21	21	23.21	39	22.66
04-11-2021 13:15	7	22.20	21	23.22	38	22.65
04-11-2021 13:16	7	22.20	22	23.20	38	22.65
04-11-2021 13:17	6	22.21	21	23.19	39	22.66
04-11-2021 13:18	7	22.22	22	23.23	39	22.66
04-11-2021 13:19	6	22.22	21	23.21	39	22.66
04-11-2021 13:20	7	22.21	21	23.21	38	22.66
04-11-2021 13:21	7	22.22	22	23.22	39	22.64
04-11-2021 13:22	7	22.22	22	23.22	39	22.65
04-11-2021 13:23	8	22.23	22	23.25	38	22.66
04-11-2021 13:24	8	22.24	21	23.24	39	22.67
04-11-2021 13:25	7	22.24	21	23.26	38	22.68
04-11-2021 13:26	8	22.25	21	23.27	39	22.68
04-11-2021 13:27	8	22.26	20	23.26	35	22.67
04-11-2021 13:28	8	22.28	22	23.28	39	22.68



Environmental Monitoring System

DATA REPORT

STERILE EXIT CHANGE ROOMS (L4)

Date Time	STERILE PASSAGE (L4) wrt EXIT ROOM-1 (L4)	STERILE EXIT ROOM-1 (L4)	ASEPTIC EXIT ROOM-1 (L4) wrt EXIT ROOM-2 (L4)	STERILE EXIT ROOM-2 (L4)	ASEPTIC EXIT ROOM-2 (L4) wrt EXIT ROOM-3 (L4)	STERILE EXIT ROOM-3 (L4)
Date Time	DP Pa	°C TEMP	DP Pa	°C TEMP	DP Pa	°C TEMP
04-11-2021 13:29	8	22.27	22	23.29	39	22.69
04-11-2021 13:30	7	22.28	21	23.30	38	22.68
04-11-2021 13:31	7	22.29	22	23.31	39	22.69
04-11-2021 13:32	7	22.31	21	23.31	39	22.69
04-11-2021 13:33	8	22.31	21	23.31	39	22.69
04-11-2021 13:34	9	22.30	21	23.32	39	22.71
04-11-2021 13:35	8	22.32	21	23.35	38	22.71
04-11-2021 13:36	8	22.33	21	23.34	38	22.72
04-11-2021 13:37	8	22.35	21	23.36	39	22.73
04-11-2021 13:38	7	22.36	21	23.37	38	22.73
04-11-2021 13:39	9	22.37	21	23.39	38	22.73
04-11-2021 13:40	7	22.35	22	23.39	39	22.73
04-11-2021 13:41	6	22.36	22	23.39	38	22.76
04-11-2021 13:42	6	22.37	21	23.39	39	22.75
04-11-2021 13:43	6	22.38	21	23.40	39	22.75
04-11-2021 13:44	8	22.36	21	23.40	38	22.77
04-11-2021 13:45	8	22.37	21	23.39	39	22.79
04-11-2021 13:46	8	22.38	21	23.38	38	22.82
04-11-2021 13:47	8	22.38	21	23.38	35	22.83
04-11-2021 13:48	7	22.36	20	23.38	36	22.78
04-11-2021 13:49	7	22.37	21	23.39	36	22.79
04-11-2021 13:50	7	22.37	20	23.36	36	22.76
04-11-2021 13:51	8	22.35	21	23.33	35	22.77
04-11-2021 13:52	8	22.37	21	23.35	38	22.77
04-11-2021 13:53	8	22.35	21	23.34	37	22.81
04-11-2021 13:54	9	22.35	22	23.33	39	22.82
04-11-2021 13:55	9	22.36	21	23.30	38	22.84
04-11-2021 13:56	8	22.33	20	23.33	36	22.80



Environmental Monitoring System

DATA REPORT

STERILE EXIT CHANGE ROOMS (L4)

Date Time	STERILE PASSAGE (L4) wrt EXIT ROOM-1 (L4)	STERILE EXIT ROOM-1 (L4)	ASEPTIC EXIT ROOM-1 (L4) wrt EXIT ROOM-2 (L4)	STERILE EXIT ROOM-2 (L4)	ASEPTIC EXIT ROOM-2 (L4) wrt EXIT ROOM-3 (L4)	STERILE EXIT ROOM-3 (L4)
Date Time	DP Pa	°C TEMP	DP Pa	°C TEMP	DP Pa	°C TEMP
04-11-2021 13:57	9	22.32	22	23.31	38	22.79
04-11-2021 13:58	8	22.33	21	23.29	36	22.79
04-11-2021 13:59	8	22.32	20	23.28	36	22.76
04-11-2021 14:00	8	22.28	20	23.27	36	22.74
04-11-2021 14:01	8	22.25	21	23.26	35	22.73
04-11-2021 14:02	8	22.25	21	23.24	39	22.76
04-11-2021 14:03	8	22.24	20	23.22	38	22.78
04-11-2021 14:04	7	22.24	21	23.21	39	22.79
04-11-2021 14:05	8	22.21	21	23.20	39	22.80
04-11-2021 14:06	8	22.20	21	23.20	39	22.80
04-11-2021 14:07	7	22.19	21	23.17	38	22.80
04-11-2021 14:08	8	22.19	21	23.18	38	22.80
04-11-2021 14:09	8	22.17	21	23.16	39	22.81
04-11-2021 14:10	8	22.17	21	23.15	39	22.81
04-11-2021 14:11	9	22.16	21	23.15	38	22.82
04-11-2021 14:12	6	22.13	21	23.14	39	22.82
04-11-2021 14:13	8	22.13	22	23.13	39	22.82
04-11-2021 14:14	8	22.12	21	23.13	37	22.82
04-11-2021 14:15	8	22.12	21	23.13	39	22.83
04-11-2021 14:16	8	22.12	22	23.13	39	22.84
04-11-2021 14:17	8	22.14	21	23.12	40	22.83
04-11-2021 14:18	8	22.11	21	23.14	37	22.84
04-11-2021 14:19	8	22.14	22	23.12	38	22.84
04-11-2021 14:20	9	22.11	21	23.13	38	22.85
04-11-2021 14:21	6	22.10	21	23.13	40	22.84
04-11-2021 14:22	7	22.11	20	23.13	39	22.84
04-11-2021 14:23	7	22.10	21	23.12	37	22.84
04-11-2021 14:24	7	22.12	21	23.12	38	22.84



Environmental Monitoring System

DATA REPORT

STERILE EXIT CHANGE ROOMS (L4)

Date Time	STERILE PASSAGE (L4) wrt EXIT ROOM-1 (L4)	STERILE EXIT ROOM-1 (L4)	ASEPTIC EXIT ROOM-1 (L4) wrt EXIT ROOM-2 (L4)	STERILE EXIT ROOM-2 (L4)	ASEPTIC EXIT ROOM-2 (L4) wrt EXIT ROOM-3 (L4)	STERILE EXIT ROOM-3 (L4)
Date Time	DP Pa	°C TEMP	DP Pa	°C TEMP	DP Pa	°C TEMP
04-11-2021 14:25	6	22.12	21	23.12	38	22.84
04-11-2021 14:26	8	22.12	21	23.11	37	22.83
04-11-2021 14:27	8	22.10	21	23.12	38	22.84
04-11-2021 14:28	8	22.10	21	23.13	38	22.85
04-11-2021 14:29	8	22.12	21	23.13	39	22.85
04-11-2021 14:30	7	22.10	21	23.13	37	22.85
04-11-2021 14:31	8	22.11	21	23.13	38	22.85
04-11-2021 14:32	9	22.12	21	23.14	37	22.85
04-11-2021 14:33	11	22.11	22	23.14	37	22.85
04-11-2021 14:34	8	22.11	21	23.16	39	22.85
04-11-2021 14:35	8	22.13	21	23.19	40	22.85
04-11-2021 14:36	8	22.14	22	23.17	39	22.86
04-11-2021 14:37	8	22.15	21	23.17	39	22.86
04-11-2021 14:38	8	22.15	21	23.18	39	22.86
04-11-2021 14:39	9	22.16	21	23.21	36	22.87
04-11-2021 14:40	9	22.19	21	23.20	39	22.86
04-11-2021 14:41	9	22.20	21	23.21	39	22.85
04-11-2021 14:42	7	22.21	20	23.23	36	22.81
04-11-2021 14:43	3	22.19	19	23.23	35	22.77
04-11-2021 14:44	8	22.21	19	23.23	35	22.75
04-11-2021 14:45	8	22.22	19	23.25	34	22.73
04-11-2021 14:46	13	22.22	7	23.23	47	22.72
04-11-2021 14:47	7	22.23	21	23.26	38	22.77
04-11-2021 14:48	8	22.25	20	23.29	37	22.80
04-11-2021 14:49	8	22.28	19	23.27	37	22.81
04-11-2021 14:50	8	22.27	20	23.27	36	22.82
04-11-2021 14:51	8	22.27	20	23.30	37	22.85
04-11-2021 14:52	8	22.28	20	23.30	36	22.86



Environmental Monitoring System

DATA REPORT

STERILE EXIT CHANGE ROOMS (L4)

Date Time	STERILE PASSAGE (L4) wrt EXIT ROOM-1 (L4)	STERILE EXIT ROOM-1 (L4)	ASEPTIC EXIT ROOM-1 (L4) wrt EXIT ROOM-2 (L4)	STERILE EXIT ROOM-2 (L4)	ASEPTIC EXIT ROOM-2 (L4) wrt EXIT ROOM-3 (L4)	STERILE EXIT ROOM-3 (L4)
Date Time	DP Pa	°C TEMP	DP Pa	°C TEMP	DP Pa	°C TEMP
04-11-2021 14:53	7	22.28	19	23.30	37	22.86
04-11-2021 14:54	6	22.30	20	23.31	36	22.87
04-11-2021 14:55	8	22.33	20	23.33	37	22.87
04-11-2021 14:56	6	22.32	19	23.33	37	22.88
04-11-2021 14:57	8	22.33	19	23.33	36	22.88
04-11-2021 14:58	6	22.35	20	23.35	35	22.90
04-11-2021 14:59	7	22.35	20	23.34	37	22.90
04-11-2021 15:00	7	22.34	20	23.36	37	22.91
04-11-2021 15:01	8	22.34	20	23.34	37	22.91
04-11-2021 15:02	8	22.34	20	23.34	37	22.91
04-11-2021 15:03	6	22.35	19	23.34	36	22.92
04-11-2021 15:04	8	22.34	20	23.34	36	22.91
04-11-2021 15:05	8	22.34	20	23.32	36	22.91
04-11-2021 15:06	7	22.33	20	23.36	37	22.92
04-11-2021 15:07	8	22.35	20	23.32	36	22.92
04-11-2021 15:08	7	22.34	20	23.33	37	22.91
04-11-2021 15:09	8	22.32	20	23.31	37	22.91
04-11-2021 15:10	7	22.33	20	23.31	37	22.89
04-11-2021 15:11	8	22.31	19	23.31	36	22.89
04-11-2021 15:12	7	22.32	20	23.30	36	22.88
04-11-2021 15:13	7	22.28	20	23.30	36	22.89
04-11-2021 15:14	8	22.28	19	23.27	36	22.90
04-11-2021 15:15	8	22.29	19	23.26	37	22.88
04-11-2021 15:16	7	22.27	20	23.25	36	22.87
04-11-2021 15:17	8	22.28	18	23.25	36	22.87
04-11-2021 15:18	7	22.28	20	23.24	37	22.86
04-11-2021 15:19	8	22.26	20	23.22	36	22.86
04-11-2021 15:20	8	22.26	20	23.21	37	22.85



Environmental Monitoring System

DATA REPORT

STERILE EXIT CHANGE ROOMS (L4)

Date Time	STERILE PASSAGE (L4) wrt EXIT ROOM-1 (L4)	STERILE EXIT ROOM-1 (L4)	ASEPTIC EXIT ROOM-1 (L4) wrt EXIT ROOM-2 (L4)	STERILE EXIT ROOM-2 (L4)	ASEPTIC EXIT ROOM-2 (L4) wrt EXIT ROOM-3 (L4)	STERILE EXIT ROOM-3 (L4)
Date Time	DP Pa	°C TEMP	DP Pa	°C TEMP	DP Pa	°C TEMP
04-11-2021 15:21	7	22.24	19	23.21	36	22.85
04-11-2021 15:22	6	22.24	20	23.21	36	22.85
04-11-2021 15:23	9	22.24	19	23.20	35	22.85
04-11-2021 15:24	8	22.23	20	23.19	35	22.85
04-11-2021 15:25	6	22.23	20	23.18	36	22.84
04-11-2021 15:26	9	22.22	20	23.18	37	22.84
04-11-2021 15:27	7	22.23	20	23.18	37	22.83
04-11-2021 15:28	7	22.21	19	23.20	37	22.84
04-11-2021 15:29	8	22.18	20	23.19	36	22.83
04-11-2021 15:30	8	22.19	18	23.18	37	22.82
04-11-2021 15:31	7	22.19	20	23.19	37	22.82
04-11-2021 15:32	8	22.20	19	23.20	37	22.82
04-11-2021 15:33	7	22.19	20	23.18	37	22.82
04-11-2021 15:34	6	22.17	18	23.19	37	22.82
04-11-2021 15:35	7	22.20	20	23.20	36	22.83
04-11-2021 15:36	8	22.22	19	23.19	37	22.82
04-11-2021 15:37	8	22.19	20	23.22	37	22.83
04-11-2021 15:38	8	22.21	19	23.21	36	22.83
04-11-2021 15:39	8	22.23	20	23.22	37	22.84
04-11-2021 15:40	8	22.22	19	23.22	37	22.83
04-11-2021 15:41	8	22.25	18	23.22	36	22.83
04-11-2021 15:42	7	22.24	20	23.22	37	22.84
04-11-2021 15:43	8	22.22	20	23.22	35	22.83
04-11-2021 15:44	7	22.22	20	23.21	37	22.84
04-11-2021 15:45	8	22.22	19	23.21	36	22.84
04-11-2021 15:46	9	22.22	20	23.21	37	22.85
04-11-2021 15:47	7	22.22	20	23.22	37	22.85
04-11-2021 15:48	8	22.22	20	23.23	37	22.85



Environmental Monitoring System

DATA REPORT

STERILE EXIT CHANGE ROOMS (L4)

Date Time	STERILE PASSAGE (L4) wrt EXIT ROOM-1 (L4)	STERILE EXIT ROOM-1 (L4)	ASEPTIC EXIT ROOM-1 (L4) wrt EXIT ROOM-2 (L4)	STERILE EXIT ROOM-2 (L4)	ASEPTIC EXIT ROOM-2 (L4) wrt EXIT ROOM-3 (L4)	STERILE EXIT ROOM-3 (L4)
Date Time	DP Pa	°C TEMP	DP Pa	°C TEMP	DP Pa	°C TEMP
04-11-2021 15:49	7	22.23	19	23.23	37	22.85
04-11-2021 15:50	8	22.24	21	23.24	37	22.85
04-11-2021 15:51	7	22.24	20	23.24	36	22.85
04-11-2021 15:52	6	22.24	20	23.25	37	22.85
04-11-2021 15:53	7	22.23	19	23.27	37	22.86
04-11-2021 15:54	8	22.24	20	23.28	37	22.86
04-11-2021 15:55	9	22.25	20	23.28	36	22.85
04-11-2021 15:56	9	22.25	20	23.28	37	22.86
04-11-2021 15:57	8	22.26	20	23.27	36	22.85
04-11-2021 15:58	8	22.26	20	23.27	36	22.86
04-11-2021 15:59	7	22.27	20	23.28	36	22.87
04-11-2021 16:00	8	22.27	19	23.28	36	22.85
04-11-2021 16:01	7	22.26	20	23.28	36	22.87
04-11-2021 16:02	7	22.27	19	23.29	36	22.85
04-11-2021 16:03	8	22.27	19	23.31	37	22.87
04-11-2021 16:04	8	22.28	20	23.30	36	22.87
04-11-2021 16:05	8	22.29	18	23.30	36	22.87
04-11-2021 16:06	8	22.28	20	23.30	36	22.87
04-11-2021 16:07	8	22.28	18	23.33	36	22.87
04-11-2021 16:08	7	22.31	20	23.33	36	22.87
04-11-2021 16:09	7	22.32	20	23.33	36	22.87
04-11-2021 16:10	8	22.32	20	23.32	36	22.88
04-11-2021 16:11	7	22.34	18	23.35	37	22.88
04-11-2021 16:12	9	22.34	18	23.35	35	22.89
04-11-2021 16:13	6	22.34	19	23.36	36	22.90
04-11-2021 16:14	7	22.35	20	23.37	37	22.90
04-11-2021 16:15	8	22.34	19	23.37	37	22.90
04-11-2021 16:16	7	22.37	19	23.36	36	22.90



Environmental Monitoring System

DATA REPORT

STERILE EXIT CHANGE ROOMS (L4)

Date Time	STERILE PASSAGE (L4) wrt EXIT ROOM-1 (L4)	STERILE EXIT ROOM-1 (L4)	ASEPTIC EXIT ROOM-1 (L4) wrt EXIT ROOM-2 (L4)	STERILE EXIT ROOM-2 (L4)	ASEPTIC EXIT ROOM-2 (L4) wrt EXIT ROOM-3 (L4)	STERILE EXIT ROOM-3 (L4)
Date Time	DP Pa	°C TEMP	DP Pa	°C TEMP	DP Pa	°C TEMP
04-11-2021 16:17	8	22.38	20	23.35	36	22.90
04-11-2021 16:18	8	22.37	18	23.35	37	22.91
04-11-2021 16:19	9	22.39	20	23.37	36	22.91
04-11-2021 16:20	6	22.36	20	23.36	37	22.91
04-11-2021 16:21	8	22.38	19	23.36	37	22.90
04-11-2021 16:22	8	22.39	19	23.38	36	22.91
04-11-2021 16:23	7	22.39	20	23.40	38	22.91
04-11-2021 16:24	6	22.40	20	23.40	37	22.92
04-11-2021 16:25	7	22.42	20	23.40	37	22.91
04-11-2021 16:26	8	22.43	20	23.40	37	22.91
04-11-2021 16:27	8	22.44	19	23.40	37	22.94
04-11-2021 16:28	7	22.43	20	23.41	36	22.93
04-11-2021 16:29	8	22.42	19	23.42	37	22.94
04-11-2021 16:30	8	22.43	20	23.42	37	22.93
04-11-2021 16:31	6	22.45	20	23.42	37	22.94
04-11-2021 16:32	8	22.44	20	23.43	36	22.95
04-11-2021 16:33	6	22.44	18	23.43	37	22.95
04-11-2021 16:34	7	22.45	19	23.41	36	22.95
04-11-2021 16:35	7	22.47	19	23.45	37	22.95
04-11-2021 16:36	8	22.47	20	23.44	36	22.95
04-11-2021 16:37	7	22.47	20	23.44	37	22.95
04-11-2021 16:38	7	22.46	19	23.45	37	22.96
04-11-2021 16:39	8	22.45	19	23.43	37	22.95
04-11-2021 16:40	8	22.45	20	23.43	37	22.95
04-11-2021 16:41	7	22.45	19	23.43	38	22.95
04-11-2021 16:42	8	22.42	18	23.40	37	22.95
04-11-2021 16:43	8	22.43	18	23.43	37	22.94
04-11-2021 16:44	8	22.44	19	23.42	35	22.94



Environmental Monitoring System

DATA REPORT

STERILE EXIT CHANGE ROOMS (L4)

Date Time	STERILE PASSAGE (L4) wrt EXIT ROOM-1 (L4)	STERILE EXIT ROOM-1 (L4)	ASEPTIC EXIT ROOM-1 (L4) wrt EXIT ROOM-2 (L4)	STERILE EXIT ROOM-2 (L4)	ASEPTIC EXIT ROOM-2 (L4) wrt EXIT ROOM-3 (L4)	STERILE EXIT ROOM-3 (L4)
Date Time	DP Pa	°C TEMP	DP Pa	°C TEMP	DP Pa	°C TEMP
04-11-2021 16:45	8	22.42	18	23.41	36	22.93
04-11-2021 16:46	7	22.42	20	23.40	37	22.93
04-11-2021 16:47	8	22.42	20	23.39	37	22.93
04-11-2021 16:48	6	22.42	20	23.39	36	22.92
04-11-2021 16:49	7	22.41	20	23.37	36	22.91
04-11-2021 16:50	7	22.40	20	23.38	37	22.92
04-11-2021 16:51	8	22.42	20	23.36	37	22.91
04-11-2021 16:52	7	22.40	20	23.35	37	22.91
04-11-2021 16:53	6	22.36	18	23.35	38	22.92
04-11-2021 16:54	7	22.38	19	23.36	37	22.91
04-11-2021 16:55	8	22.37	19	23.34	37	22.91
04-11-2021 16:56	7	22.36	19	23.34	37	22.91
04-11-2021 16:57	7	22.37	20	23.34	36	22.91
04-11-2021 16:58	9	22.37	20	23.35	36	22.90
04-11-2021 16:59	8	22.35	20	23.35	37	22.90
04-11-2021 17:00	8	22.37	20	23.32	37	22.91
04-11-2021 17:01	8	22.35	20	23.32	35	22.89
04-11-2021 17:02	9	22.36	18	23.33	37	22.90
04-11-2021 17:03	7	22.36	20	23.32	37	22.89
04-11-2021 17:04	8	22.37	18	23.32	37	22.89
04-11-2021 17:05	6	22.35	20	23.32	37	22.89
04-11-2021 17:06	6	22.35	19	23.33	37	22.89
04-11-2021 17:07	7	22.36	20	23.31	35	22.88
04-11-2021 17:08	6	22.35	19	23.31	37	22.89
04-11-2021 17:09	6	22.33	20	23.31	37	22.88
04-11-2021 17:10	8	22.33	20	23.31	35	22.88
04-11-2021 17:11	9	22.34	19	23.33	36	22.88
04-11-2021 17:12	6	22.32	19	23.33	37	22.88



Environmental Monitoring System

DATA REPORT

STERILE EXIT CHANGE ROOMS (L4)

Date Time	STERILE PASSAGE (L4) wrt EXIT ROOM-1 (L4)	STERILE EXIT ROOM-1 (L4)	ASEPTIC EXIT ROOM-1 (L4) wrt EXIT ROOM-2 (L4)	STERILE EXIT ROOM-2 (L4)	ASEPTIC EXIT ROOM-2 (L4) wrt EXIT ROOM-3 (L4)	STERILE EXIT ROOM-3 (L4)
Date Time	DP Pa	°C TEMP	DP Pa	°C TEMP	DP Pa	°C TEMP
04-11-2021 17:13	8	22.31	18	23.32	37	22.87
04-11-2021 17:14	6	22.31	20	23.32	37	22.86
04-11-2021 17:15	8	22.31	20	23.32	36	22.87
04-11-2021 17:16	8	22.32	20	23.33	37	22.86
04-11-2021 17:17	8	22.31	20	23.30	36	22.85
04-11-2021 17:18	8	22.32	20	23.31	37	22.86
04-11-2021 17:19	8	22.32	20	23.31	37	22.86
04-11-2021 17:20	7	22.32	20	23.31	37	22.86
04-11-2021 17:21	7	22.29	20	23.31	37	22.87
04-11-2021 17:22	7	22.31	19	23.31	37	22.85
04-11-2021 17:23	6	22.29	20	23.31	36	22.85
04-11-2021 17:24	9	22.28	20	23.32	37	22.84
04-11-2021 17:25	7	22.30	18	23.31	39	22.85
04-11-2021 17:26	8	22.31	20	23.31	36	22.85
04-11-2021 17:27	7	22.30	20	23.32	38	22.85
04-11-2021 17:28	8	22.30	20	23.32	37	22.86
04-11-2021 17:29	7	22.29	19	23.32	37	22.85
04-11-2021 17:30	8	22.29	20	23.34	36	22.85
04-11-2021 17:31	7	22.28	19	23.31	35	22.85
04-11-2021 17:32	7	22.28	20	23.31	37	22.85
04-11-2021 17:33	8	22.28	19	23.32	35	22.85
04-11-2021 17:34	6	22.30	20	23.34	36	22.84
04-11-2021 17:35	8	22.28	19	23.34	36	22.85
04-11-2021 17:36	7	22.31	19	23.32	38	22.85
04-11-2021 17:37	9	22.29	20	23.32	37	22.85
04-11-2021 17:38	8	22.28	19	23.33	37	22.85
04-11-2021 17:39	8	22.29	19	23.34	36	22.85
04-11-2021 17:40	8	22.29	19	23.33	37	22.85



Environmental Monitoring System

DATA REPORT

STERILE EXIT CHANGE ROOMS (L4)

Date Time	STERILE PASSAGE (L4) wrt EXIT ROOM-1 (L4)	STERILE EXIT ROOM-1 (L4)	ASEPTIC EXIT ROOM-1 (L4) wrt EXIT ROOM-2 (L4)	STERILE EXIT ROOM-2 (L4)	ASEPTIC EXIT ROOM-2 (L4) wrt EXIT ROOM-3 (L4)	STERILE EXIT ROOM-3 (L4)
Date Time	DP Pa	°C TEMP	DP Pa	°C TEMP	DP Pa	°C TEMP
04-11-2021 17:41	7	22.31	20	23.35	37	22.86
04-11-2021 17:42	6	22.31	20	23.34	37	22.85
04-11-2021 17:43	7	22.32	19	23.32	37	22.84
04-11-2021 17:44	8	22.34	20	23.32	34	22.85
04-11-2021 17:45	7	22.33	20	23.31	37	22.84
04-11-2021 17:46	8	22.32	18	23.31	35	22.85
04-11-2021 17:47	6	22.34	20	23.30	37	22.86
04-11-2021 17:48	7	22.33	19	23.33	37	22.85
04-11-2021 17:49	7	22.33	19	23.31	37	22.84
04-11-2021 17:50	8	22.34	20	23.32	35	22.84
04-11-2021 17:51	8	22.34	20	23.34	37	22.85
04-11-2021 17:52	6	22.33	18	23.34	36	22.85
04-11-2021 17:53	6	22.32	19	23.34	37	22.85
04-11-2021 17:54	8	22.33	19	23.34	37	22.84
04-11-2021 17:55	8	22.34	18	23.34	36	22.84
04-11-2021 17:56	8	22.35	19	23.35	36	22.85
04-11-2021 17:57	8	22.34	20	23.34	37	22.85
04-11-2021 17:58	7	22.33	20	23.35	35	22.85
04-11-2021 17:59	7	22.34	19	23.36	36	22.86
04-11-2021 18:00	7	22.35	20	23.35	36	22.86
04-11-2021 18:01	7	22.35	20	23.34	37	22.86
04-11-2021 18:02	6	22.33	20	23.35	37	22.87
04-11-2021 18:03	7	22.34	19	23.36	36	22.85
04-11-2021 18:04	9	22.35	20	23.38	37	22.85
04-11-2021 18:05	7	22.32	19	23.38	37	22.85
04-11-2021 18:06	8	22.35	19	23.37	37	22.86
04-11-2021 18:07	8	22.35	19	23.39	35	22.86
04-11-2021 18:08	7	22.36	19	23.39	36	22.85



Environmental Monitoring System

DATA REPORT

STERILE EXIT CHANGE ROOMS (L4)

Date Time	STERILE PASSAGE (L4) wrt EXIT ROOM-1 (L4)	STERILE EXIT ROOM-1 (L4)	ASEPTIC EXIT ROOM-1 (L4) wrt EXIT ROOM-2 (L4)	STERILE EXIT ROOM-2 (L4)	ASEPTIC EXIT ROOM-2 (L4) wrt EXIT ROOM-3 (L4)	STERILE EXIT ROOM-3 (L4)
Date Time	DP Pa	°C TEMP	DP Pa	°C TEMP	DP Pa	°C TEMP
04-11-2021 18:09	7	22.38	19	23.39	36	22.86
04-11-2021 18:10	6	22.37	20	23.41	37	22.86
04-11-2021 18:11	6	22.37	20	23.41	36	22.86
04-11-2021 18:12	7	22.38	20	23.40	37	22.86
04-11-2021 18:13	8	22.38	19	23.41	36	22.87
04-11-2021 18:14	6	22.38	19	23.40	37	22.87
04-11-2021 18:15	6	22.39	20	23.41	35	22.87
04-11-2021 18:16	6	22.38	19	23.41	37	22.87
04-11-2021 18:17	6	22.40	20	23.41	37	22.87
04-11-2021 18:18	7	22.39	19	23.40	36	22.87
04-11-2021 18:19	8	22.41	18	23.41	37	22.87
04-11-2021 18:20	7	22.42	20	23.42	36	22.87
04-11-2021 18:21	9	22.40	20	23.41	37	22.87
04-11-2021 18:22	8	22.42	20	23.42	37	22.87
04-11-2021 18:23	8	22.42	20	23.43	36	22.88
04-11-2021 18:24	7	22.42	19	23.42	36	22.87
04-11-2021 18:25	8	22.41	19	23.42	37	22.88
04-11-2021 18:26	6	22.41	20	23.42	35	22.89
04-11-2021 18:27	7	22.42	20	23.42	36	22.89
04-11-2021 18:28	8	22.43	20	23.44	35	22.88
04-11-2021 18:29	8	22.41	20	23.43	37	22.88
04-11-2021 18:30	8	22.41	19	23.43	37	22.88
04-11-2021 18:31	8	22.41	20	23.43	37	22.89
04-11-2021 18:32	7	22.41	20	23.41	37	22.88
04-11-2021 18:33	9	22.42	20	23.41	37	22.89
04-11-2021 18:34	7	22.41	20	23.40	36	22.88
04-11-2021 18:35	7	22.40	20	23.43	36	22.88
04-11-2021 18:36	8	22.38	20	23.41	36	22.88



Environmental Monitoring System

DATA REPORT

STERILE EXIT CHANGE ROOMS (L4)

Date Time	STERILE PASSAGE (L4) wrt EXIT ROOM-1 (L4)	STERILE EXIT ROOM-1 (L4)	ASEPTIC EXIT ROOM-1 (L4) wrt EXIT ROOM-2 (L4)	STERILE EXIT ROOM-2 (L4)	ASEPTIC EXIT ROOM-2 (L4) wrt EXIT ROOM-3 (L4)	STERILE EXIT ROOM-3 (L4)
Date Time	DP Pa	°C TEMP	DP Pa	°C TEMP	DP Pa	°C TEMP
04-11-2021 18:37	8	22.38	19	23.40	36	22.87
04-11-2021 18:38	7	22.36	20	23.41	36	22.88
04-11-2021 18:39	8	22.37	19	23.38	36	22.87
04-11-2021 18:40	7	22.36	19	23.38	37	22.87
04-11-2021 18:41	8	22.34	20	23.38	37	22.86
04-11-2021 18:42	6	22.35	20	23.37	37	22.86
04-11-2021 18:43	7	22.35	19	23.36	37	22.86
04-11-2021 18:44	8	22.36	19	23.37	37	22.85
04-11-2021 18:45	6	22.33	19	23.35	36	22.85
04-11-2021 18:46	7	22.34	20	23.36	37	22.86
04-11-2021 18:47	8	22.35	20	23.35	37	22.87
04-11-2021 18:48	8	22.34	20	23.33	36	22.87
04-11-2021 18:49	8	22.34	19	23.33	37	22.87
04-11-2021 18:50	7	22.33	20	23.34	37	22.88
04-11-2021 18:51	6	22.36	20	23.32	37	22.87
04-11-2021 18:52	8	22.35	20	23.34	37	22.86
04-11-2021 18:53	7	22.35	20	23.34	37	22.87
04-11-2021 18:54	7	22.34	20	23.35	37	22.88
04-11-2021 18:55	7	22.34	19	23.36	37	22.88
04-11-2021 18:56	8	22.34	19	23.34	37	22.89
04-11-2021 18:57	7	22.34	20	23.35	37	22.90
04-11-2021 18:58	8	22.36	18	23.36	36	22.90
04-11-2021 18:59	8	22.37	20	23.36	37	22.90
04-11-2021 19:00	7	22.36	19	23.39	36	22.90
04-11-2021 19:01	8	22.39	19	23.38	36	22.91
04-11-2021 19:02	7	22.37	19	23.38	37	22.92
04-11-2021 19:03	8	22.40	20	23.36	37	22.93
04-11-2021 19:04	7	22.40	19	23.39	37	22.94



Environmental Monitoring System

DATA REPORT

STERILE EXIT CHANGE ROOMS (L4)

Date Time	STERILE PASSAGE (L4) wrt EXIT ROOM-1 (L4)	STERILE EXIT ROOM-1 (L4)	ASEPTIC EXIT ROOM-1 (L4) wrt EXIT ROOM-2 (L4)	STERILE EXIT ROOM-2 (L4)	ASEPTIC EXIT ROOM-2 (L4) wrt EXIT ROOM-3 (L4)	STERILE EXIT ROOM-3 (L4)
Date Time	DP Pa	°C TEMP	DP Pa	°C TEMP	DP Pa	°C TEMP
04-11-2021 19:05	7	22.41	20	23.41	37	22.95
04-11-2021 19:06	7	22.41	20	23.41	36	22.95
04-11-2021 19:07	8	22.41	20	23.43	37	22.95
04-11-2021 19:08	7	22.42	20	23.42	37	22.97
04-11-2021 19:09	7	22.42	20	23.43	35	22.96
04-11-2021 19:10	9	22.44	20	23.47	36	22.98
04-11-2021 19:11	7	22.43	20	23.45	37	22.98
04-11-2021 19:12	6	22.44	20	23.44	35	22.97
04-11-2021 19:13	7	22.45	19	23.47	37	22.98
04-11-2021 19:14	7	22.45	20	23.46	37	22.99
04-11-2021 19:15	7	22.46	20	23.46	36	23.00
04-11-2021 19:16	6	22.47	20	23.47	37	23.00
04-11-2021 19:17	6	22.48	19	23.47	37	23.00
04-11-2021 19:18	6	22.48	19	23.47	36	23.00
04-11-2021 19:19	6	22.48	19	23.47	35	23.01
04-11-2021 19:20	7	22.50	19	23.47	35	23.02
04-11-2021 19:21	6	22.50	19	23.49	36	23.03
04-11-2021 19:22	8	22.51	19	23.46	36	23.04
04-11-2021 19:23	6	22.50	20	23.47	36	23.04
04-11-2021 19:24	8	22.52	19	23.50	37	23.04
04-11-2021 19:25	7	22.53	20	23.49	36	23.05
04-11-2021 19:26	6	22.53	20	23.48	36	23.04
04-11-2021 19:27	6	22.52	18	23.50	37	23.06
04-11-2021 19:28	8	22.52	19	23.49	36	23.04
04-11-2021 19:29	8	22.53	20	23.48	37	23.05
04-11-2021 19:30	7	22.51	20	23.47	36	23.05
04-11-2021 19:31	6	22.50	20	23.47	37	23.06
04-11-2021 19:32	8	22.51	20	23.47	37	23.06



Environmental Monitoring System

DATA REPORT

STERILE EXIT CHANGE ROOMS (L4)

Date Time	STERILE PASSAGE (L4) wrt EXIT ROOM-1 (L4)	STERILE EXIT ROOM-1 (L4)	ASEPTIC EXIT ROOM-1 (L4) wrt EXIT ROOM-2 (L4)	STERILE EXIT ROOM-2 (L4)	ASEPTIC EXIT ROOM-2 (L4) wrt EXIT ROOM-3 (L4)	STERILE EXIT ROOM-3 (L4)
Date Time	DP Pa	°C TEMP	DP Pa	°C TEMP	DP Pa	°C TEMP
04-11-2021 19:33	8	22.48	19	23.46	37	23.05
04-11-2021 19:34	6	22.48	19	23.46	35	23.06
04-11-2021 19:35	6	22.50	20	23.46	36	23.06
04-11-2021 19:36	8	22.47	20	23.44	37	23.06
04-11-2021 19:37	8	22.48	20	23.44	37	23.05
04-11-2021 19:38	6	22.49	20	23.46	37	23.05
04-11-2021 19:39	6	22.48	20	23.44	37	23.05
04-11-2021 19:40	6	22.50	19	23.42	37	23.06
04-11-2021 19:41	7	22.47	21	23.42	36	23.04
04-11-2021 19:42	8	22.47	20	23.43	35	23.03
04-11-2021 19:43	8	22.49	19	23.42	37	23.04
04-11-2021 19:44	7	22.47	18	23.43	37	23.04
04-11-2021 19:45	7	22.49	20	23.42	37	23.04
04-11-2021 19:46	6	22.47	19	23.43	36	23.05
04-11-2021 19:47	8	22.49	20	23.41	39	23.04
04-11-2021 19:48	7	22.47	20	23.43	37	23.05
04-11-2021 19:49	7	22.47	20	23.43	37	23.05
04-11-2021 19:50	7	22.45	20	23.42	40	23.06
04-11-2021 19:51	7	22.46	21	23.42	39	23.05
04-11-2021 19:52	8	22.45	20	23.41	39	23.04
04-11-2021 19:53	6	22.46	21	23.41	39	23.05
04-11-2021 19:54	8	22.45	21	23.41	40	23.05
04-11-2021 19:55	8	22.43	21	23.40	40	23.04
04-11-2021 19:56	7	22.43	21	23.40	39	23.05
04-11-2021 19:57	8	22.43	20	23.40	40	23.04
04-11-2021 19:58	6	22.43	21	23.39	40	23.04
04-11-2021 19:59	7	22.42	21	23.41	40	23.04
04-11-2021 20:00	8	22.44	21	23.41	39	23.04



Environmental Monitoring System

DATA REPORT

STERILE EXIT CHANGE ROOMS (L4)

Date Time	STERILE PASSAGE (L4) wrt EXIT ROOM-1 (L4)	STERILE EXIT ROOM-1 (L4)	ASEPTIC EXIT ROOM-1 (L4) wrt EXIT ROOM-2 (L4)	STERILE EXIT ROOM-2 (L4)	ASEPTIC EXIT ROOM-2 (L4) wrt EXIT ROOM-3 (L4)	STERILE EXIT ROOM-3 (L4)
Date Time	DP Pa	°C TEMP	DP Pa	°C TEMP	DP Pa	°C TEMP
04-11-2021 20:01	6	22.44	21	23.42	40	23.04
04-11-2021 20:02	8	22.44	21	23.40	40	23.05
04-11-2021 20:03	7	22.44	20	23.39	40	23.04
04-11-2021 20:04	8	22.44	21	23.41	40	23.03
04-11-2021 20:05	7	22.43	21	23.40	40	23.04
04-11-2021 20:06	8	22.45	21	23.41	39	23.03
04-11-2021 20:07	8	22.43	22	23.41	41	23.03
04-11-2021 20:08	7	22.42	21	23.40	39	23.04
04-11-2021 20:09	10	22.42	21	23.38	41	23.04
04-11-2021 20:10	9	22.40	20	23.39	40	23.04
04-11-2021 20:11	8	22.41	23	23.40	44	23.03
04-11-2021 20:12	8	22.43	21	23.39	40	23.03
04-11-2021 20:13	6	22.41	21	23.41	40	23.03
04-11-2021 20:14	8	22.41	21	23.40	39	23.02
04-11-2021 20:15	9	22.40	21	23.39	40	23.01
04-11-2021 20:16	8	22.41	20	23.37	40	23.01
04-11-2021 20:17	8	22.42	21	23.38	40	23.02
04-11-2021 20:18	8	22.42	21	23.38	40	23.02
04-11-2021 20:19	7	22.41	21	23.36	40	23.02
04-11-2021 20:20	6	22.40	21	23.38	40	23.02
04-11-2021 20:21	7	22.42	21	23.39	40	23.02
04-11-2021 20:22	8	22.40	20	23.39	40	23.01
04-11-2021 20:23	9	22.39	21	23.38	40	23.01
04-11-2021 20:24	7	22.39	21	23.39	40	23.01
04-11-2021 20:25	6	22.39	20	23.37	40	23.02
04-11-2021 20:26	7	22.39	21	23.36	39	23.01
04-11-2021 20:27	6	22.38	20	23.38	40	23.01
04-11-2021 20:28	8	22.38	20	23.39	40	23.01



Environmental Monitoring System

DATA REPORT

STERILE EXIT CHANGE ROOMS (L4)

Date Time	STERILE PASSAGE (L4) wrt EXIT ROOM-1 (L4)	STERILE EXIT ROOM-1 (L4)	ASEPTIC EXIT ROOM-1 (L4) wrt EXIT ROOM-2 (L4)	STERILE EXIT ROOM-2 (L4)	ASEPTIC EXIT ROOM-2 (L4) wrt EXIT ROOM-3 (L4)	STERILE EXIT ROOM-3 (L4)
Date Time	DP Pa	°C TEMP	DP Pa	°C TEMP	DP Pa	°C TEMP
04-11-2021 20:29	6	22.39	22	23.38	40	23.01
04-11-2021 20:30	8	22.38	21	23.38	39	23.00
04-11-2021 20:31	8	22.38	21	23.38	39	23.01
04-11-2021 20:32	8	22.38	21	23.41	39	23.01
04-11-2021 20:33	8	22.36	20	23.40	40	23.00
04-11-2021 20:34	7	22.39	20	23.41	40	23.00
04-11-2021 20:35	8	22.40	21	23.41	40	23.00
04-11-2021 20:36	8	22.38	21	23.39	40	23.00
04-11-2021 20:37	6	22.39	21	23.40	40	23.00
04-11-2021 20:38	6	22.40	21	23.40	40	23.00
04-11-2021 20:39	7	22.41	21	23.39	41	23.00
04-11-2021 20:40	7	22.39	20	23.39	40	23.00
04-11-2021 20:41	8	22.40	20	23.41	40	22.98
04-11-2021 20:42	6	22.40	21	23.40	39	23.00
04-11-2021 20:43	7	22.39	21	23.38	39	22.99
04-11-2021 20:44	8	22.40	20	23.39	40	22.99
04-11-2021 20:45	8	22.41	20	23.41	40	22.99
04-11-2021 20:46	8	22.42	20	23.38	40	22.99
04-11-2021 20:47	8	22.42	21	23.40	40	22.98
04-11-2021 20:48	6	22.41	21	23.39	40	22.98
04-11-2021 20:49	6	22.40	21	23.39	39	22.99
04-11-2021 20:50	6	22.42	21	23.40	40	23.00
04-11-2021 20:51	8	22.42	21	23.39	40	22.99
04-11-2021 20:52	6	22.40	20	23.38	39	22.99
04-11-2021 20:53	6	22.40	21	23.38	39	22.98
04-11-2021 20:54	6	22.40	21	23.40	41	22.99
04-11-2021 20:55	6	22.39	21	23.38	40	22.99
04-11-2021 20:56	9	22.37	20	23.38	40	22.98



Environmental Monitoring System

DATA REPORT

STERILE EXIT CHANGE ROOMS (L4)

Date Time	STERILE PASSAGE (L4) wrt EXIT ROOM-1 (L4)	STERILE EXIT ROOM-1 (L4)	ASEPTIC EXIT ROOM-1 (L4) wrt EXIT ROOM-2 (L4)	STERILE EXIT ROOM-2 (L4)	ASEPTIC EXIT ROOM-2 (L4) wrt EXIT ROOM-3 (L4)	STERILE EXIT ROOM-3 (L4)
Date Time	DP Pa	°C TEMP	DP Pa	°C TEMP	DP Pa	°C TEMP
04-11-2021 20:57	8	22.39	21	23.38	40	22.99
04-11-2021 20:58	8	22.36	21	23.37	40	22.99
04-11-2021 20:59	9	22.37	21	23.36	40	23.00
04-11-2021 21:00	8	22.36	21	23.35	41	22.99
04-11-2021 21:01	7	22.38	21	23.35	40	22.99
04-11-2021 21:02	7	22.36	21	23.34	40	22.98
04-11-2021 21:03	8	22.35	21	23.34	41	22.98
04-11-2021 21:04	7	22.34	21	23.33	39	22.99
04-11-2021 21:05	8	22.33	21	23.33	42	22.98
04-11-2021 21:06	5	22.34	21	23.32	40	22.98
04-11-2021 21:07	7	22.34	21	23.32	40	22.98
04-11-2021 21:08	7	22.35	21	23.32	39	22.97
04-11-2021 21:09	7	22.31	21	23.31	40	22.97
04-11-2021 21:10	8	22.30	21	23.32	40	22.96
04-11-2021 21:11	7	22.32	21	23.31	40	22.97
04-11-2021 21:12	7	22.32	20	23.31	40	22.96
04-11-2021 21:13	7	22.29	21	23.30	40	22.96
04-11-2021 21:14	7	22.30	21	23.31	40	22.95
04-11-2021 21:15	8	22.32	21	23.30	40	22.95
04-11-2021 21:16	8	22.33	21	23.30	40	22.94
04-11-2021 21:17	6	22.32	21	23.30	40	22.94
04-11-2021 21:18	6	22.30	21	23.30	40	22.94
04-11-2021 21:19	9	22.32	21	23.30	41	22.94
04-11-2021 21:20	7	22.33	21	23.31	40	22.94
04-11-2021 21:21	8	22.32	21	23.34	40	22.93
04-11-2021 21:22	6	22.33	21	23.32	40	22.94
04-11-2021 21:23	6	22.33	21	23.32	40	22.94
04-11-2021 21:24	6	22.32	21	23.33	40	22.94



Environmental Monitoring System

DATA REPORT

STERILE EXIT CHANGE ROOMS (L4)

Date Time	STERILE PASSAGE (L4) wrt EXIT ROOM-1 (L4)	STERILE EXIT ROOM-1 (L4)	ASEPTIC EXIT ROOM-1 (L4) wrt EXIT ROOM-2 (L4)	STERILE EXIT ROOM-2 (L4)	ASEPTIC EXIT ROOM-2 (L4) wrt EXIT ROOM-3 (L4)	STERILE EXIT ROOM-3 (L4)
Date Time	DP Pa	°C TEMP	DP Pa	°C TEMP	DP Pa	°C TEMP
04-11-2021 21:25	7	22.30	20	23.35	39	22.95
04-11-2021 21:26	8	22.32	20	23.36	40	22.94
04-11-2021 21:27	8	22.34	21	23.35	40	22.94
04-11-2021 21:28	8	22.35	20	23.35	40	22.94
04-11-2021 21:29	8	22.35	21	23.36	39	22.93
04-11-2021 21:30	8	22.36	21	23.37	40	22.94
04-11-2021 21:31	7	22.36	21	23.37	40	22.96
04-11-2021 21:32	7	22.37	21	23.38	40	22.96
04-11-2021 21:33	8	22.38	21	23.40	40	22.95
04-11-2021 21:34	8	22.38	21	23.38	39	22.96
04-11-2021 21:35	7	22.39	20	23.40	40	22.96
04-11-2021 21:36	8	22.38	20	23.40	40	22.96
04-11-2021 21:37	7	22.38	21	23.39	40	22.95
04-11-2021 21:38	7	22.39	21	23.40	40	22.95
04-11-2021 21:39	6	22.38	21	23.40	39	22.96
04-11-2021 21:40	8	22.38	20	23.40	39	22.95
04-11-2021 21:41	9	22.38	20	23.40	40	22.95
04-11-2021 21:42	7	22.39	21	23.41	40	22.96
04-11-2021 21:43	8	22.41	20	23.41	40	22.95
04-11-2021 21:44	6	22.43	21	23.43	40	22.97
04-11-2021 21:45	6	22.43	21	23.40	40	22.97
04-11-2021 21:46	7	22.42	21	23.43	40	22.97
04-11-2021 21:47	8	22.43	21	23.44	40	22.97
04-11-2021 21:48	7	22.43	21	23.46	39	22.97
04-11-2021 21:49	9	22.45	21	23.47	40	22.98
04-11-2021 21:50	8	22.44	21	23.46	39	22.98
04-11-2021 21:51	7	22.45	21	23.46	39	22.98
04-11-2021 21:52	6	22.46	21	23.47	40	22.99



Environmental Monitoring System

DATA REPORT

STERILE EXIT CHANGE ROOMS (L4)

Date Time	STERILE PASSAGE (L4) wrt EXIT ROOM-1 (L4)	STERILE EXIT ROOM-1 (L4)	ASEPTIC EXIT ROOM-1 (L4) wrt EXIT ROOM-2 (L4)	STERILE EXIT ROOM-2 (L4)	ASEPTIC EXIT ROOM-2 (L4) wrt EXIT ROOM-3 (L4)	STERILE EXIT ROOM-3 (L4)
Date Time	DP Pa	°C TEMP	DP Pa	°C TEMP	DP Pa	°C TEMP
04-11-2021 21:53	7	22.47	21	23.48	39	22.99
04-11-2021 21:54	8	22.48	21	23.49	39	23.00
04-11-2021 21:55	8	22.51	21	23.50	40	23.00
04-11-2021 21:56	7	22.51	21	23.52	40	23.00
04-11-2021 21:57	8	22.51	21	23.53	40	23.00
04-11-2021 21:58	7	22.53	21	23.55	40	23.01
04-11-2021 21:59	8	22.53	21	23.53	40	23.02
04-11-2021 22:00	8	22.54	21	23.55	40	23.01
04-11-2021 22:01	6	22.55	21	23.56	40	23.01
04-11-2021 22:02	6	22.57	21	23.58	40	23.04
04-11-2021 22:03	8	22.58	22	23.58	40	23.03
04-11-2021 22:04	7	22.61	21	23.59	40	23.04
04-11-2021 22:05	8	22.61	22	23.61	40	23.04
04-11-2021 22:06	9	22.63	20	23.63	39	23.05
04-11-2021 22:07	9	22.66	23	23.65	40	23.05
04-11-2021 22:08	6	22.67	21	23.66	40	23.06
04-11-2021 22:09	5	22.68	21	23.66	40	23.06
04-11-2021 22:10	6	22.70	21	23.68	40	23.07
04-11-2021 22:11	8	22.71	20	23.68	40	23.07
04-11-2021 22:12	8	22.73	21	23.70	39	23.08
04-11-2021 22:13	6	22.74	21	23.70	40	23.09
04-11-2021 22:14	6	22.76	21	23.71	41	23.10
04-11-2021 22:15	8	22.77	20	23.70	40	23.11
04-11-2021 22:16	6	22.77	21	23.69	40	23.12
04-11-2021 22:17	7	22.78	21	23.70	40	23.13
04-11-2021 22:18	6	22.78	21	23.71	40	23.13
04-11-2021 22:19	8	22.80	21	23.70	40	23.14
04-11-2021 22:20	7	22.80	22	23.70	39	23.14



Environmental Monitoring System

DATA REPORT

STERILE EXIT CHANGE ROOMS (L4)

Date Time	STERILE PASSAGE (L4) wrt EXIT ROOM-1 (L4)	STERILE EXIT ROOM-1 (L4)	ASEPTIC EXIT ROOM-1 (L4) wrt EXIT ROOM-2 (L4)	STERILE EXIT ROOM-2 (L4)	ASEPTIC EXIT ROOM-2 (L4) wrt EXIT ROOM-3 (L4)	STERILE EXIT ROOM-3 (L4)
Date Time	DP Pa	°C TEMP	DP Pa	°C TEMP	DP Pa	°C TEMP
04-11-2021 22:21	7	22.79	21	23.71	40	23.15
04-11-2021 22:22	6	22.80	21	23.72	41	23.14
04-11-2021 22:23	9	22.80	22	23.72	40	23.16
04-11-2021 22:24	9	22.79	21	23.71	40	23.16
04-11-2021 22:25	8	22.80	20	23.71	40	23.16
04-11-2021 22:26	8	22.80	20	23.72	40	23.17
04-11-2021 22:27	8	22.80	22	23.72	40	23.18
04-11-2021 22:28	8	22.81	21	23.72	40	23.18
04-11-2021 22:29	8	22.79	21	23.71	40	23.18
04-11-2021 22:30	8	22.79	21	23.69	39	23.18
04-11-2021 22:31	7	22.82	21	23.73	40	23.18
04-11-2021 22:32	7	22.82	21	23.72	40	23.18
04-11-2021 22:33	8	22.79	21	23.72	40	23.17
04-11-2021 22:34	8	22.80	21	23.71	40	23.19
04-11-2021 22:35	8	22.78	22	23.71	40	23.17
04-11-2021 22:36	7	22.78	21	23.69	40	23.18
04-11-2021 22:37	8	22.78	21	23.70	40	23.19
04-11-2021 22:38	8	22.79	21	23.71	39	23.19
04-11-2021 22:39	8	22.79	23	23.68	42	23.19
04-11-2021 22:40	5	22.80	21	23.67	40	23.19
04-11-2021 22:41	8	22.80	21	23.69	39	23.20
04-11-2021 22:42	7	22.79	21	23.66	40	23.19
04-11-2021 22:43	6	22.80	44	23.65	8	23.19
04-11-2021 22:44	6	22.79	21	23.68	39	23.21
04-11-2021 22:45	7	22.77	21	23.68	40	23.21
04-11-2021 22:46	8	22.76	23	23.66	43	23.21
04-11-2021 22:47	8	22.78	21	23.66	41	23.22
04-11-2021 22:48	8	22.77	22	23.66	40	23.23



Environmental Monitoring System

DATA REPORT

STERILE EXIT CHANGE ROOMS (L4)

Date Time	STERILE PASSAGE (L4) wrt EXIT ROOM-1 (L4)	STERILE EXIT ROOM-1 (L4)	ASEPTIC EXIT ROOM-1 (L4) wrt EXIT ROOM-2 (L4)	STERILE EXIT ROOM-2 (L4)	ASEPTIC EXIT ROOM-2 (L4) wrt EXIT ROOM-3 (L4)	STERILE EXIT ROOM-3 (L4)
Date Time	DP Pa	°C TEMP	DP Pa	°C TEMP	DP Pa	°C TEMP
04-11-2021 22:49	8	22.79	23	23.64	40	23.22
04-11-2021 22:50	8	22.77	22	23.67	40	23.22
04-11-2021 22:51	7	22.76	22	23.67	41	23.23
04-11-2021 22:52	6	22.77	22	23.67	40	23.23
04-11-2021 22:53	8	22.76	22	23.67	40	23.22
04-11-2021 22:54	8	22.76	23	23.65	41	23.23
04-11-2021 22:55	8	22.75	22	23.66	40	23.23
04-11-2021 22:56	6	22.75	22	23.65	40	23.22
04-11-2021 22:57	8	22.74	23	23.64	40	23.23
04-11-2021 22:58	6	22.75	21	23.63	40	23.23
04-11-2021 22:59	6	22.74	21	23.63	41	23.22
04-11-2021 23:00	8	22.74	21	23.65	39	23.22
04-11-2021 23:01	6	22.76	21	23.63	42	23.22
04-11-2021 23:02	8	22.76	21	23.62	39	23.22
04-11-2021 23:03	5	22.73	22	23.60	42	23.22
04-11-2021 23:04	6	22.73	21	23.61	39	23.20
04-11-2021 23:05	8	22.72	23	23.59	40	23.21
04-11-2021 23:06	8	22.71	21	23.58	40	23.21
04-11-2021 23:07	8	22.72	21	23.57	39	23.21
04-11-2021 23:08	7	22.72	21	23.57	39	23.20
04-11-2021 23:09	8	22.71	21	23.59	41	23.20
04-11-2021 23:10	6	22.73	22	23.57	40	23.19
04-11-2021 23:11	9	22.72	21	23.59	40	23.21
04-11-2021 23:12	8	22.73	22	23.59	41	23.20
04-11-2021 23:13	7	22.72	22	23.59	41	23.22
04-11-2021 23:14	7	22.74	21	23.60	40	23.19
04-11-2021 23:15	6	22.71	21	23.59	40	23.19
04-11-2021 23:16	7	22.73	22	23.60	41	23.19



Environmental Monitoring System

DATA REPORT

STERILE EXIT CHANGE ROOMS (L4)

Date Time	STERILE PASSAGE (L4) wrt EXIT ROOM-1 (L4)	STERILE EXIT ROOM-1 (L4)	ASEPTIC EXIT ROOM-1 (L4) wrt EXIT ROOM-2 (L4)	STERILE EXIT ROOM-2 (L4)	ASEPTIC EXIT ROOM-2 (L4) wrt EXIT ROOM-3 (L4)	STERILE EXIT ROOM-3 (L4)
Date Time	DP Pa	°C TEMP	DP Pa	°C TEMP	DP Pa	°C TEMP
04-11-2021 23:17	8	22.69	21	23.60	40	23.19
04-11-2021 23:18	6	22.68	22	23.59	40	23.19
04-11-2021 23:19	7	22.67	22	23.58	40	23.17
04-11-2021 23:20	7	22.68	22	23.56	39	23.18
04-11-2021 23:21	7	22.68	22	23.58	42	23.18
04-11-2021 23:22	7	22.65	22	23.56	41	23.17
04-11-2021 23:23	7	22.66	22	23.57	41	23.16
04-11-2021 23:24	8	22.68	21	23.56	40	23.17
04-11-2021 23:25	5	22.67	23	23.55	40	23.16
04-11-2021 23:26	8	22.68	21	23.55	41	23.17
04-11-2021 23:27	7	22.66	23	23.54	40	23.16
04-11-2021 23:28	7	22.67	23	23.51	41	23.16
04-11-2021 23:29	7	22.70	21	23.52	40	23.16
04-11-2021 23:30	6	22.64	23	23.52	41	23.15
04-11-2021 23:31	8	22.66	21	23.52	40	23.14
04-11-2021 23:32	6	22.66	21	23.54	40	23.15
04-11-2021 23:33	8	22.66	21	23.56	40	23.15
04-11-2021 23:34	7	22.67	22	23.55	40	23.16
04-11-2021 23:35	7	22.69	21	23.55	42	23.15
04-11-2021 23:36	7	22.67	21	23.57	40	23.15
04-11-2021 23:37	8	22.69	21	23.57	40	23.15
04-11-2021 23:38	7	22.70	22	23.59	41	23.15
04-11-2021 23:39	9	22.71	22	23.59	40	23.15
04-11-2021 23:40	6	22.72	23	23.60	41	23.16
04-11-2021 23:41	7	22.73	21	23.62	40	23.16
04-11-2021 23:42	7	22.74	22	23.62	40	23.17
04-11-2021 23:43	8	22.76	21	23.63	41	23.16
04-11-2021 23:44	7	22.75	23	23.62	41	23.16



Environmental Monitoring System

DATA REPORT

STERILE EXIT CHANGE ROOMS (L4)

Date Time	STERILE PASSAGE (L4) wrt EXIT ROOM-1 (L4)	STERILE EXIT ROOM-1 (L4)	ASEPTIC EXIT ROOM-1 (L4) wrt EXIT ROOM-2 (L4)	STERILE EXIT ROOM-2 (L4)	ASEPTIC EXIT ROOM-2 (L4) wrt EXIT ROOM-3 (L4)	STERILE EXIT ROOM-3 (L4)
Date Time	DP Pa	°C TEMP	DP Pa	°C TEMP	DP Pa	°C TEMP
04-11-2021 23:45	7	22.75	22	23.64	41	23.15
04-11-2021 23:46	7	22.77	22	23.64	40	23.16
04-11-2021 23:47	8	22.78	23	23.67	40	23.16
04-11-2021 23:48	8	22.81	23	23.66	42	23.16
04-11-2021 23:49	9	22.80	21	23.66	40	23.16
04-11-2021 23:50	6	22.82	23	23.67	40	23.17
04-11-2021 23:51	8	22.81	21	23.68	40	23.18
04-11-2021 23:52	8	22.81	22	23.68	39	23.18
04-11-2021 23:53	6	22.83	23	23.70	40	23.17
04-11-2021 23:54	8	22.84	23	23.70	42	23.18
04-11-2021 23:55	7	22.84	21	23.71	40	23.19
04-11-2021 23:56	6	22.87	21	23.71	40	23.19
04-11-2021 23:57	5	22.87	22	23.74	40	23.19
04-11-2021 23:58	7	22.87	22	23.74	41	23.19
04-11-2021 23:59	6	22.88	21	23.74	41	23.19
05-11-2021 00:00	7	22.89	22	23.75	41	23.19
Min Value	****	****	****	****	****	****
Max Value	****	****	****	****	****	****

End Of Report : From 04/11/2021 00:00:00 To 05/11/2021 00:00:00

ACTIVITY	NAME	SIGNATURE AND DATE
REVIEWED BY USER		
REVIEWED BY QA		