



SOMERSET THERAPEUTICS LIMITED

DATA REPORT - SVP1 AND AMPOULE LINE EMS

AMPOULE TUNNEL FILLING

Date Time	Temperature	RH	Diffrential Pressure	Diffrential Pressure	Diffrential Pressure
DD-MM-YYYY HH:MM:SS	Ampoule tunnel filling (NMT 25°C)	Ampoule tunnel filling (NMT 65%)	Ampoule tunnel filling w.r.t Sterile corridor (NLT 6 Pa)	Ampoule tunnel filling w.r.t. Ampoule tunnel washing (NLT 12 Pa)	Ampoule tunnel filling w.r.t. Ampoule tunnel receipt (NLT 12 Pa)
10-07-2022 13:30:00	20.8	64.9	0	-1	2
10-07-2022 13:31:00	20.8	64.9	0	0	1
10-07-2022 13:32:00	20.8	64.9	0	0	0
10-07-2022 13:33:00	20.8	65.1	0	0	1
10-07-2022 13:34:00	20.8	65.1	0	0	0
10-07-2022 13:35:00	20.8	65.1	0	0	1
10-07-2022 13:36:00	20.8	65.1	0	0	1
10-07-2022 13:37:00	20.8	65	0	0	0
10-07-2022 13:38:00	20.9	65	0	0	0
10-07-2022 13:39:00	20.8	65	0	0	1
10-07-2022 13:40:00	20.9	64.9	0	0	1
10-07-2022 13:41:00	20.9	65	0	0	1
10-07-2022 13:42:00	20.9	65	0	0	1
10-07-2022 13:43:00	20.9	65	0	0	1
10-07-2022 13:44:00	20.9	65	0	0	1
10-07-2022 13:45:00	20.9	65	0	0	1
10-07-2022 13:46:00	20.9	65	0	0	1
10-07-2022 13:47:00	20.9	65.2	0	0	1
10-07-2022 13:48:00	20.9	65.1	0	0	1
10-07-2022 13:49:00	20.9	65.1	0	0	0
10-07-2022 13:50:00	21	65.1	0	0	1
10-07-2022 13:51:00	21	65	0	0	1
10-07-2022 13:52:00	21	65	0	0	1
10-07-2022 13:53:00	21	64.9	0	0	1

ACTIVITY	NAME	SIGNATURE AND DATE
REVIEWED BY USER		
REVIEWED BY QA		



SOMERSET THERAPEUTICS LIMITED

DATA REPORT - SVP1 AND AMPOULE LINE EMS

AMPOULE TUNNEL FILLING

Date Time	Temperature	RH	Diffrential Pressure	Diffrential Pressure	Diffrential Pressure
DD-MM-YYYY HH:MM:SS	Ampoule tunnel filling (NMT 25°C)	Ampoule tunnel filling (NMT 65%)	Ampoule tunnel filling w.r.t Sterile corridor (NLT 6 Pa)	Ampoule tunnel filling w.r.t. Ampoule tunnel washing (NLT 12 Pa)	Ampoule tunnel receipt (NLT 12 Pa)
10-07-2022 13:54:00	21	64.9	0	-1	0
10-07-2022 13:55:00	21	64.9	0	0	1
10-07-2022 13:56:00	21	64.9	0	0	0
10-07-2022 13:57:00	21	64.9	0	0	1
10-07-2022 13:58:00	21	64.9	0	0	1
10-07-2022 13:59:00	21	64.9	0	0	1
10-07-2022 14:00:00	21	65	0	0	1
10-07-2022 14:01:00	21	65	0	0	0
10-07-2022 14:02:00	21	65	0	0	1
10-07-2022 14:03:00	21	65	0	0	0
10-07-2022 14:04:00	21	65	0	0	1
10-07-2022 14:05:00	21	65	0	0	2
10-07-2022 14:06:00	21	65	0	0	1
10-07-2022 14:07:00	21	65	0	0	1
10-07-2022 14:08:00	21	65	0	0	1
10-07-2022 14:09:00	21	65	1	1	1
10-07-2022 14:10:00	21	65.2	0	0	1
10-07-2022 14:11:00	21.1	65.3	0	0	1
10-07-2022 14:12:00	21.1	65.2	0	0	0
10-07-2022 14:13:00	21.1	65.2	0	0	0
10-07-2022 14:14:00	21.1	65.1	0	0	0
10-07-2022 14:15:00	21.1	65.1	0	0	0
10-07-2022 14:16:00	21.1	65.1	0	0	1
10-07-2022 14:17:00	21.1	65.1	0	0	1

ACTIVITY	NAME	SIGNATURE AND DATE
REVIEWED BY USER		
REVIEWED BY QA		



SOMERSET THERAPEUTICS LIMITED

DATA REPORT - SVP1 AND AMPOULE LINE EMS

AMPOULE TUNNEL FILLING

Date Time	Temperature	RH	Diffrential Pressure	Diffrential Pressure	Diffrential Pressure
DD-MM-YYYY HH:MM:SS	Ampoule tunnel filling (NMT 25°C)	Ampoule tunnel filling (NMT 65%)	Ampoule tunnel filling w.r.t Sterile corridor (NLT 6 Pa)	Ampoule tunnel filling w.r.t. Ampoule tunnel washing (NLT 12 Pa)	Ampoule tunnel filling w.r.t. Ampoule tunnel receipt (NLT 12 Pa)
10-07-2022 14:18:00	21.1	65.1	0	0	1
10-07-2022 14:19:00	21.1	65.1	0	0	1
10-07-2022 14:20:00	21.1	65.1	0	0	1
10-07-2022 14:21:00	21.1	65.1	0	0	0
10-07-2022 14:22:00	21.1	65	0	0	0
10-07-2022 14:23:00	21.1	65	0	0	0
10-07-2022 14:24:00	21.1	65	0	0	0
10-07-2022 14:25:00	21.1	65	0	0	0
10-07-2022 14:26:00	21.1	65	0	0	1
10-07-2022 14:27:00	21.1	65	0	0	1
10-07-2022 14:28:00	21.1	65	0	0	1
10-07-2022 14:29:00	21.1	65	0	0	1
10-07-2022 14:30:00	21.1	65	0	0	1
10-07-2022 14:31:00	21.1	65	0	0	1
10-07-2022 14:32:00	21.1	65	0	0	1
10-07-2022 14:33:00	21.1	65	0	0	1
10-07-2022 14:34:00	21.1	64.9	0	0	1
10-07-2022 14:35:00	21.1	64.9	0	0	1
10-07-2022 14:36:00	21.1	64.9	0	0	1
10-07-2022 14:37:00	21.1	64.9	0	0	0
10-07-2022 14:38:00	21.1	64.9	0	0	1
10-07-2022 14:39:00	21.1	64.9	0	0	2
10-07-2022 14:40:00	21.1	64.9	0	0	1
10-07-2022 14:41:00	21.1	64.9	0	0	0

ACTIVITY	NAME	SIGNATURE AND DATE
REVIEWED BY USER		
REVIEWED BY QA		



SOMERSET THERAPEUTICS LIMITED

DATA REPORT - SVP1 AND AMPOULE LINE EMS

AMPOULE TUNNEL FILLING

Date Time	Temperature	RH	Diffrential Pressure	Diffrential Pressure	Diffrential Pressure
DD-MM-YYYY HH:MM:SS	Ampoule tunnel filling (NMT 25°C)	Ampoule tunnel filling (NMT 65%)	Ampoule tunnel filling w.r.t Sterile corridor (NLT 6 Pa)	Ampoule tunnel filling w.r.t. Ampoule tunnel washing (NLT 12 Pa)	Ampoule tunnel receipt (NLT 12 Pa)
10-07-2022 14:42:00	21.1	64.9	0	0	2
10-07-2022 14:43:00	21.1	64.9	0	0	1
10-07-2022 14:44:00	21.1	64.9	0	0	1
10-07-2022 14:45:00	21.1	64.9	0	0	1
10-07-2022 14:46:00	21.1	64.9	0	0	0
10-07-2022 14:47:00	21.1	64.9	0	0	0
10-07-2022 14:48:00	21.1	64.8	0	0	0
10-07-2022 14:49:00	21.1	64.8	0	0	1
10-07-2022 14:50:00	21.2	64.8	0	0	1
10-07-2022 14:51:00	21.2	64.8	0	0	0
10-07-2022 14:52:00	21.2	64.8	0	0	2
10-07-2022 14:53:00	21.2	64.7	0	0	0
10-07-2022 14:54:00	21.2	64.7	0	0	1
10-07-2022 14:55:00	21.2	64.8	0	0	0
10-07-2022 14:56:00	21.2	65.5	0	0	0
10-07-2022 14:57:00	21.2	67.5	0	0	1
10-07-2022 14:58:00	21.2	68.5	0	0	1
10-07-2022 14:59:00	21.3	69.4	0	0	0
10-07-2022 15:00:00	21.3	69.7	0	0	1
10-07-2022 15:01:00	21.4	69.9	0	0	1
10-07-2022 15:02:00	21.4	69.6	0	0	1
10-07-2022 15:03:00	21.4	69.3	0	0	1
10-07-2022 15:04:00	21.4	69	0	0	1
10-07-2022 15:05:00	21.4	68.9	0	0	1

ACTIVITY	NAME	SIGNATURE AND DATE
REVIEWED BY USER		
REVIEWED BY QA		



SOMERSET THERAPEUTICS LIMITED

DATA REPORT - SVP1 AND AMPOULE LINE EMS

AMPOULE TUNNEL FILLING

Date Time	Temperature	RH	Diffrential Pressure	Diffrential Pressure	Diffrential Pressure
DD-MM-YYYY HH:MM:SS	Ampoule tunnel filling (NMT 25°C)	Ampoule tunnel filling (NMT 65%)	Ampoule tunnel filling w.r.t Sterile corridor (NLT 6 Pa)	Ampoule tunnel filling w.r.t. Ampoule tunnel washing (NLT 12 Pa)	Ampoule tunnel filling w.r.t. Ampoule tunnel receipt (NLT 12 Pa)
10-07-2022 15:06:00	21.4	68.8	0	0	1
10-07-2022 15:07:00	21.4	68.7	0	0	1
10-07-2022 15:08:00	21.4	68.7	0	0	1
10-07-2022 15:09:00	21.4	68.5	0	0	1
10-07-2022 15:10:00	21.4	68.5	0	0	0
10-07-2022 15:11:00	21.4	68.5	0	0	1
10-07-2022 15:12:00	21.4	68.4	0	0	1
10-07-2022 15:13:00	21.4	68.4	0	0	0
10-07-2022 15:14:00	21.4	68.4	0	0	0
10-07-2022 15:15:00	21.4	68.3	0	0	1
10-07-2022 15:16:00	21.4	68.3	0	0	1
10-07-2022 15:17:00	21.4	72.2	0	0	1
10-07-2022 15:18:00	21.2	75	0	0	1
10-07-2022 15:19:00	20.9	77.9	0	0	1
10-07-2022 15:20:00	20.8	80.8	0	0	1
10-07-2022 15:21:00	20.8	82.4	0	0	1
10-07-2022 15:22:00	20.8	83.9	0	0	1
10-07-2022 15:23:00	20.9	85.3	0	0	1
10-07-2022 15:24:00	20.9	86.1	0	0	1
10-07-2022 15:25:00	21	86.8	0	0	1
10-07-2022 15:26:00	21.1	87.1	0	0	1
10-07-2022 15:27:00	21.2	87.8	0	0	1
10-07-2022 15:28:00	21.3	88.2	0	0	2
10-07-2022 15:29:00	21.3	88.8	0	0	2

ACTIVITY	NAME	SIGNATURE AND DATE
REVIEWED BY USER		
REVIEWED BY QA		



SOMERSET THERAPEUTICS LIMITED

DATA REPORT - SVP1 AND AMPOULE LINE EMS

AMPOULE TUNNEL FILLING

Date Time	Temperature	RH	Diffrential Pressure	Diffrential Pressure	Diffrential Pressure
DD-MM-YYYY HH:MM:SS	Ampoule tunnel filling (NMT 25°C)	Ampoule tunnel filling (NMT 65%)	Ampoule tunnel filling w.r.t Sterile corridor (NLT 6 Pa)	Ampoule tunnel filling w.r.t. Ampoule tunnel washing (NLT 12 Pa)	Ampoule tunnel filling w.r.t. Ampoule tunnel receipt (NLT 12 Pa)
10-07-2022 15:30:00	21.4	88.9	0	0	1
10-07-2022 15:31:00	21.5	89	0	0	1
10-07-2022 15:32:00	21.6	89.5	0	0	1
10-07-2022 15:33:00	21.6	89.9	0	0	1
10-07-2022 15:34:00	21.7	90.2	0	0	1
10-07-2022 15:35:00	21.7	90.6	0	0	1
10-07-2022 15:36:00	21.7	91	0	-1	2
10-07-2022 15:37:00	21.7	91.1	0	0	1
10-07-2022 15:38:00	21.8	91.6	0	-1	0
10-07-2022 15:39:00	21.8	91.7	0	0	1
10-07-2022 15:40:00	21.9	91.7	0	0	1
10-07-2022 15:41:00	21.9	91.9	0	0	0
10-07-2022 15:42:00	22	92.4	0	0	0
10-07-2022 15:43:00	22	92.6	0	0	0
10-07-2022 15:44:00	22	92.9	0	0	0
10-07-2022 15:45:00	22.1	93.3	0	0	1
10-07-2022 15:46:00	22.1	93.5	0	0	0
10-07-2022 15:47:00	22.1	93.9	0	0	0
10-07-2022 15:48:00	22.1	94.5	0	0	0
10-07-2022 15:49:00	22.1	95	0	0	0
10-07-2022 15:50:00	22.1	95.2	0	0	0
10-07-2022 15:51:00	22.1	95.5	0	0	0
10-07-2022 15:52:00	22.1	95.7	0	0	0
10-07-2022 15:53:00	22.2	95.8	0	0	0

ACTIVITY	NAME	SIGNATURE AND DATE
REVIEWED BY USER		
REVIEWED BY QA		



SOMERSET THERAPEUTICS LIMITED

DATA REPORT - SVP1 AND AMPOULE LINE EMS

AMPOULE TUNNEL FILLING

Date Time	Temperature	RH	Diffrential Pressure	Diffrential Pressure	Diffrential Pressure
DD-MM-YYYY HH:MM:SS	Ampoule tunnel filling (NMT 25°C)	Ampoule tunnel filling (NMT 65%)	Ampoule tunnel filling w.r.t Sterile corridor (NLT 6 Pa)	Ampoule tunnel filling w.r.t. Ampoule tunnel washing (NLT 12 Pa)	Ampoule tunnel filling w.r.t. Ampoule tunnel receipt (NLT 12 Pa)
10-07-2022 15:54:00	22.1	95.1	0	0	1
10-07-2022 15:55:00	22.1	94.6	0	0	1
10-07-2022 15:56:00	22.1	94.3	0	0	0
10-07-2022 15:57:00	22.1	94	0	0	1
10-07-2022 15:58:00	22.1	93.6	0	0	1
10-07-2022 15:59:00	22	93.3	0	0	1
10-07-2022 16:00:00	22	92.9	0	0	0
10-07-2022 16:01:00	22	92.5	0	0	0
10-07-2022 16:02:00	22	92.2	0	0	1
10-07-2022 16:03:00	22	91.8	0	0	1
10-07-2022 16:04:00	22.1	91.5	0	0	0
10-07-2022 16:05:00	22	91.1	0	0	1
10-07-2022 16:06:00	22	90.9	0	0	1
10-07-2022 16:07:00	22	90.6	0	0	0
10-07-2022 16:08:00	22	90.4	0	0	0
10-07-2022 16:09:00	22	90.2	0	0	0
10-07-2022 16:10:00	22	90	0	0	0
10-07-2022 16:11:00	22	89.9	0	0	1
10-07-2022 16:12:00	22	89.8	0	0	0
10-07-2022 16:13:00	22	89.6	0	0	0
10-07-2022 16:14:00	22	89.5	0	0	0
10-07-2022 16:15:00	22	89.4	0	0	0
10-07-2022 16:16:00	22	89.3	0	0	0
10-07-2022 16:17:00	22	89.2	0	0	1

ACTIVITY	NAME	SIGNATURE AND DATE
REVIEWED BY USER		
REVIEWED BY QA		



SOMERSET THERAPEUTICS LIMITED

DATA REPORT - SVP1 AND AMPOULE LINE EMS

AMPOULE TUNNEL FILLING

Date Time	Temperature	RH	Diffrential Pressure	Diffrential Pressure	Diffrential Pressure
DD-MM-YYYY HH:MM:SS	Ampoule tunnel filling (NMT 25°C)	Ampoule tunnel filling (NMT 65%)	Ampoule tunnel filling w.r.t Sterile corridor (NLT 6 Pa)	Ampoule tunnel filling w.r.t. Ampoule tunnel washing (NLT 12 Pa)	Ampoule tunnel filling w.r.t. Ampoule tunnel receipt (NLT 12 Pa)
10-07-2022 16:18:00	22	89.1	0	0	0
10-07-2022 16:19:00	22	89.1	0	0	0
10-07-2022 16:20:00	22	89.1	0	0	1
10-07-2022 16:21:00	22	88.9	0	0	0
10-07-2022 16:22:00	22	89	0	0	0
10-07-2022 16:23:00	22	89	0	0	0
10-07-2022 16:24:00	22	88.9	0	0	0
10-07-2022 16:25:00	22	88.9	0	0	0
10-07-2022 16:26:00	22	88.8	0	0	0
10-07-2022 16:27:00	22	88.8	0	0	1
10-07-2022 16:28:00	22	88.7	0	0	0
10-07-2022 16:29:00	22	88.7	0	0	0
10-07-2022 16:30:00	22	88.7	0	0	1
10-07-2022 16:31:00	22	88.6	0	0	0
10-07-2022 16:32:00	22	88.6	0	0	0
10-07-2022 16:33:00	22	88.6	0	0	0
10-07-2022 16:34:00	22	88.6	0	0	0
10-07-2022 16:35:00	22	88.6	0	0	0
10-07-2022 16:36:00	22	88.5	0	0	0
10-07-2022 16:37:00	22	88.5	0	0	0
10-07-2022 16:38:00	22	88.5	0	0	0
10-07-2022 16:39:00	22	88.4	0	0	0
10-07-2022 16:40:00	22	88.4	0	0	0
10-07-2022 16:41:00	22	88.4	0	0	0

ACTIVITY	NAME	SIGNATURE AND DATE
REVIEWED BY USER		
REVIEWED BY QA		



SOMERSET THERAPEUTICS LIMITED

DATA REPORT - SVP1 AND AMPOULE LINE EMS

AMPOULE TUNNEL FILLING

Date Time	Temperature	RH	Diffrential Pressure	Diffrential Pressure	Diffrential Pressure
DD-MM-YYYY HH:MM:SS	Ampoule tunnel filling (NMT 25°C)	Ampoule tunnel filling (NMT 65%)	Ampoule tunnel filling w.r.t Sterile corridor (NLT 6 Pa)	Ampoule tunnel filling w.r.t. Ampoule tunnel washing (NLT 12 Pa)	Ampoule tunnel receipt (NLT 12 Pa)
10-07-2022 16:42:00	22	88.4	0	0	0
10-07-2022 16:43:00	22	88.5	0	0	0
10-07-2022 16:44:00	22	88.5	0	0	0
10-07-2022 16:45:00	22	88.4	0	0	0
10-07-2022 16:46:00	22	88.5	0	0	0
10-07-2022 16:47:00	22	88.5	0	0	0
10-07-2022 16:48:00	22	88.5	0	0	0
10-07-2022 16:49:00	22	88.5	0	0	0
10-07-2022 16:50:00	22	88.4	0	0	0
10-07-2022 16:51:00	22	88.4	0	0	0
10-07-2022 16:52:00	22	88.4	0	0	0
10-07-2022 16:53:00	22	88.4	0	0	1
10-07-2022 16:54:00	22	88.5	0	0	1
10-07-2022 16:55:00	22	88.4	0	0	1
10-07-2022 16:56:00	22	88.4	0	0	0
10-07-2022 16:57:00	22	88.4	0	0	0
10-07-2022 16:58:00	22	88.4	0	0	0
10-07-2022 16:59:00	22	88.4	0	0	1
10-07-2022 17:00:00	22	88.4	0	0	0
10-07-2022 17:01:00	22	88.4	0	0	0
10-07-2022 17:02:00	22.1	88.3	0	0	0
10-07-2022 17:03:00	22	88.3	0	0	1
10-07-2022 17:04:00	22	88.3	0	0	0
10-07-2022 17:05:00	22	88.3	0	0	0

ACTIVITY	NAME	SIGNATURE AND DATE
REVIEWED BY USER		
REVIEWED BY QA		



SOMERSET THERAPEUTICS LIMITED

DATA REPORT - SVP1 AND AMPOULE LINE EMS

AMPOULE TUNNEL FILLING

Date Time	Temperature	RH	Diffrential Pressure	Diffrential Pressure	Diffrential Pressure
DD-MM-YYYY HH:MM:SS	Ampoule tunnel filling (NMT 25°C)	Ampoule tunnel filling (NMT 65%)	Ampoule tunnel filling w.r.t Sterile corridor (NLT 6 Pa)	Ampoule tunnel filling w.r.t. Ampoule tunnel washing (NLT 12 Pa)	Ampoule tunnel filling w.r.t. Ampoule tunnel receipt (NLT 12 Pa)
10-07-2022 17:06:00	22.1	88.3	0	0	0
10-07-2022 17:07:00	22.1	88.3	0	0	0
10-07-2022 17:08:00	22.1	88.3	0	0	0
10-07-2022 17:09:00	22.1	88.3	0	0	0
10-07-2022 17:10:00	22.1	88.3	0	0	0
10-07-2022 17:11:00	22.1	88.3	0	0	1
10-07-2022 17:12:00	22.1	88.2	0	0	1
10-07-2022 17:13:00	22.1	88.2	0	0	0
10-07-2022 17:14:00	22.1	88.2	0	0	1
10-07-2022 17:15:00	22.1	88.2	0	0	1
10-07-2022 17:16:00	22.1	88.2	0	0	0
10-07-2022 17:17:00	22.1	88.2	0	0	1
10-07-2022 17:18:00	22.1	88.2	0	0	0
10-07-2022 17:19:00	22.1	88.2	0	0	0
10-07-2022 17:20:00	22.1	88.2	0	0	0
10-07-2022 17:21:00	22.1	88.2	0	0	1
10-07-2022 17:22:00	22.1	88.2	0	0	0
10-07-2022 17:23:00	22.1	88.1	0	0	1
10-07-2022 17:24:00	22.1	88.1	0	0	1
10-07-2022 17:25:00	22.1	88.1	0	0	1
10-07-2022 17:26:00	22.1	88.1	0	0	0
10-07-2022 17:27:00	22.1	88.1	0	0	0
10-07-2022 17:28:00	22.1	88.2	0	0	0
10-07-2022 17:29:00	22.1	88.1	0	0	0

ACTIVITY	NAME	SIGNATURE AND DATE
REVIEWED BY USER		
REVIEWED BY QA		



SOMERSET THERAPEUTICS LIMITED

DATA REPORT - SVP1 AND AMPOULE LINE EMS

AMPOULE TUNNEL FILLING

Date Time	Temperature	RH	Diffrential Pressure	Diffrential Pressure	Diffrential Pressure
DD-MM-YYYY HH:MM:SS	Ampoule tunnel filling (NMT 25°C)	Ampoule tunnel filling (NMT 65%)	Ampoule tunnel filling w.r.t Sterile corridor (NLT 6 Pa)	Ampoule tunnel filling w.r.t. Ampoule tunnel washing (NLT 12 Pa)	Ampoule tunnel filling w.r.t. Ampoule tunnel receipt (NLT 12 Pa)
10-07-2022 17:30:00	22.1	88.1	0	0	0
10-07-2022 17:31:00	22.2	88.1	0	0	0
10-07-2022 17:32:00	22.2	88.1	0	0	1
10-07-2022 17:33:00	22.2	88.1	0	0	0
10-07-2022 17:34:00	22.2	88.1	0	0	0
10-07-2022 17:35:00	22.2	88.2	0	0	0
10-07-2022 17:36:00	22.2	88.1	0	0	1
10-07-2022 17:37:00	22.2	88.1	0	0	0
10-07-2022 17:38:00	22.2	88.1	0	0	0
10-07-2022 17:39:00	22.2	88.1	0	0	0
10-07-2022 17:40:00	22.2	88.1	0	0	0
10-07-2022 17:41:00	22.2	88.1	0	0	1
10-07-2022 17:42:00	22.2	88	0	0	0
10-07-2022 17:43:00	22.2	88	0	0	0
10-07-2022 17:44:00	22.2	88	0	0	0
10-07-2022 17:45:00	22.2	88	0	0	0
10-07-2022 17:46:00	22.2	88	0	0	0
10-07-2022 17:47:00	22.2	87.9	0	0	0
10-07-2022 17:48:00	22.2	88	0	0	0
10-07-2022 17:49:00	22.2	88	0	0	0
10-07-2022 17:50:00	22.2	88	0	0	0
10-07-2022 17:51:00	22.2	88	0	0	1
10-07-2022 17:52:00	22.2	88	0	0	0
10-07-2022 17:53:00	22.3	88	0	0	0

ACTIVITY	NAME	SIGNATURE AND DATE
REVIEWED BY USER		
REVIEWED BY QA		



SOMERSET THERAPEUTICS LIMITED

DATA REPORT - SVP1 AND AMPOULE LINE EMS

AMPOULE TUNNEL FILLING

Date Time	Temperature	RH	Diffrential Pressure	Diffrential Pressure	Diffrential Pressure
DD-MM-YYYY HH:MM:SS	Ampoule tunnel filling (NMT 25°C)	Ampoule tunnel filling (NMT 65%)	Ampoule tunnel filling w.r.t Sterile corridor (NLT 6 Pa)	Ampoule tunnel filling w.r.t. Ampoule tunnel washing (NLT 12 Pa)	Ampoule tunnel filling w.r.t. Ampoule tunnel receipt (NLT 12 Pa)
10-07-2022 17:54:00	22.3	87.9	0	0	0
10-07-2022 17:55:00	22.3	87.9	0	0	0
10-07-2022 17:56:00	22.3	88	0	0	0
10-07-2022 17:57:00	22.3	88	0	0	0
10-07-2022 17:58:00	22.3	88	0	0	0
10-07-2022 17:59:00	22.3	88	0	0	0
10-07-2022 18:00:00	22.3	87.9	0	0	1
10-07-2022 18:01:00	22.3	88	0	0	0
10-07-2022 18:02:00	22.3	87.9	0	0	0
10-07-2022 18:03:00	22.3	87.9	0	0	1
10-07-2022 18:04:00	22.3	87.9	0	0	1
10-07-2022 18:05:00	22.3	87.9	0	0	1
10-07-2022 18:06:00	22.3	87.9	0	0	0
10-07-2022 18:07:00	22.3	88	0	0	0
10-07-2022 18:08:00	22.3	87.9	0	0	0
10-07-2022 18:09:00	22.3	87.9	0	0	0
10-07-2022 18:10:00	22.3	87.9	0	0	0
10-07-2022 18:11:00	22.3	88	0	0	0
10-07-2022 18:12:00	22.3	88	0	0	0
10-07-2022 18:13:00	22.3	88	0	0	0
10-07-2022 18:14:00	22.3	88	0	0	0
10-07-2022 18:15:00	22.3	88	0	0	0
10-07-2022 18:16:00	22.3	88	0	0	0
10-07-2022 18:17:00	22.3	88	0	0	5

ACTIVITY	NAME	SIGNATURE AND DATE
REVIEWED BY USER		
REVIEWED BY QA		



SOMERSET THERAPEUTICS LIMITED

DATA REPORT - SVP1 AND AMPOULE LINE EMS

AMPOULE TUNNEL FILLING

Date Time	Temperature	RH	Diffrential Pressure	Diffrential Pressure	Diffrential Pressure
DD-MM-YYYY HH:MM:SS	Ampoule tunnel filling (NMT 25°C)	Ampoule tunnel filling (NMT 65%)	Ampoule tunnel filling w.r.t Sterile corridor (NLT 6 Pa)	Ampoule tunnel filling w.r.t. Ampoule tunnel washing (NLT 12 Pa)	Ampoule tunnel filling w.r.t. Ampoule tunnel receipt (NLT 12 Pa)
10-07-2022 18:18:00	22.3	88	0	0	0
10-07-2022 18:19:00	22.3	88	0	0	0
10-07-2022 18:20:00	22.3	88	0	0	0
10-07-2022 18:21:00	22.3	88	0	0	0
10-07-2022 18:22:00	22.3	88	0	0	0
10-07-2022 18:23:00	22.4	88	0	0	0
10-07-2022 18:24:00	22.3	88	0	0	0
10-07-2022 18:25:00	22.4	88	0	0	0
10-07-2022 18:26:00	22.4	87.9	0	0	1
10-07-2022 18:27:00	22.4	87.9	0	0	0
10-07-2022 18:28:00	22.4	87.9	0	0	0
10-07-2022 18:29:00	22.4	87.9	0	0	0
10-07-2022 18:30:00	22.4	87.9	0	0	0
10-07-2022 18:31:00	22.4	87.8	0	0	0
10-07-2022 18:32:00	22.4	87.8	0	0	0
10-07-2022 18:33:00	22.4	87.8	0	0	0
10-07-2022 18:34:00	22.4	87.8	0	0	0
10-07-2022 18:35:00	22.4	87.8	0	0	0
10-07-2022 18:36:00	22.4	87.8	-4	2	1
10-07-2022 18:37:00	22.4	87.6	-5	34	58
10-07-2022 18:38:00	22.3	82.9	7	81	89
10-07-2022 18:39:00	22.3	74.5	6	81	91
10-07-2022 18:40:00	22.2	71.2	7	81	90
10-07-2022 18:41:00	22.1	68.3	7	81	90

ACTIVITY	NAME	SIGNATURE AND DATE
REVIEWED BY USER		
REVIEWED BY QA		



SOMERSET THERAPEUTICS LIMITED

DATA REPORT - SVP1 AND AMPOULE LINE EMS

AMPOULE TUNNEL FILLING

Date Time	Temperature	RH	Diffrential Pressure	Diffrential Pressure	Diffrential Pressure
DD-MM-YYYY HH:MM:SS	Ampoule tunnel filling (NMT 25°C)	Ampoule tunnel filling (NMT 65%)	Ampoule tunnel filling w.r.t Sterile corridor (NLT 6 Pa)	Ampoule tunnel filling w.r.t. Ampoule tunnel washing (NLT 12 Pa)	Ampoule tunnel filling w.r.t. Ampoule tunnel receipt (NLT 12 Pa)
10-07-2022 18:42:00	22.1	66.7	7	82	90
10-07-2022 18:43:00	22	64.7	7	82	91
10-07-2022 18:44:00	22	63.2	7	82	91
10-07-2022 18:45:00	21.9	62.8	7	82	90
10-07-2022 18:46:00	21.8	62.2	7	82	91
10-07-2022 18:47:00	21.7	61.8	7	82	91
10-07-2022 18:48:00	21.6	61.7	7	82	92
10-07-2022 18:49:00	21.6	61.6	7	82	90
10-07-2022 18:50:00	21.5	61.5	7	80	90
10-07-2022 18:51:00	21.4	61.5	6	81	90
10-07-2022 18:52:00	21.4	61.6	7	81	91
10-07-2022 18:53:00	21.3	61.6	6	81	91
10-07-2022 18:54:00	21.3	61.6	6	82	91
10-07-2022 18:55:00	21.2	61.6	7	82	91
10-07-2022 18:56:00	21.1	61.5	7	81	90
10-07-2022 18:57:00	21.1	61.6	6	81	91
10-07-2022 18:58:00	21	61.5	7	81	90
10-07-2022 18:59:00	21	61.6	6	82	91
10-07-2022 19:00:00	20.9	61.6	6	81	91
Min Value	20.8	61.5	-5	-1	0
Max Value	22.4	95.8	7	82	92

End Of Report : From 10-07-2022 13:30:00 To 10-07-2022 19:00:00

ACTIVITY	NAME	SIGNATURE AND DATE
REVIEWED BY USER		
REVIEWED BY QA		