



# Environmental Monitoring System

## DATA REPORT

### STERILE EXIT CHANGE ROOMS (L3)

Date Time	STERILE PASSAGE (L3) wrt EXIT ROOM-1 (L3)	STERILE EXIT ROOM-1 (L3)	ASEPTIC EXIT ROOM-1 (L3) wrt EXIT ROOM-2 (L3)	STERILE EXIT ROOM-2 (L3)	ASEPTIC EXIT ROOM-2 (L3) wrt EXIT ROOM-3 (L3)	STERILE EXIT ROOM-3 (L3)
Date Time	DP Pa	°C TEMP	DP Pa	°C TEMP	DP Pa	°C TEMP
Alarm Low Limit		21.0		21.0		21.0
Set Value						
Alarm High Limit	50	25.0	50	100.0	50	100.0
04-11-2021 00:00	15	22.2	13	22.7	20	22.8
04-11-2021 00:01	17	22.2	13	22.7	19	22.8
04-11-2021 00:02	19	22.2	14	22.7	20	22.8
04-11-2021 00:03	18	22.3	15	22.8	20	22.8
04-11-2021 00:04	18	22.3	15	22.8	20	22.8
04-11-2021 00:05	20	22.3	16	22.8	20	22.8
04-11-2021 00:06	20	22.3	15	22.8	20	22.8
04-11-2021 00:07	20	22.3	16	22.8	21	22.8
04-11-2021 00:08	20	22.4	16	22.8	20	22.8
04-11-2021 00:09	18	22.4	16	22.8	20	22.8
04-11-2021 00:10	21	22.4	16	22.8	21	22.8
04-11-2021 00:11	21	22.4	16	22.8	20	22.8
04-11-2021 00:12	20	22.4	16	22.8	20	22.8
04-11-2021 00:13	22	22.4	18	22.8	14	22.8
04-11-2021 00:14	21	22.4	16	22.9	20	22.9
04-11-2021 00:15	20	22.4	15	22.9	20	23.0
04-11-2021 00:16	21	22.4	22	22.9	27	23.0
04-11-2021 00:17	20	22.5	21	22.9	26	23.0
04-11-2021 00:18	21	22.6	22	22.9	27	23.0
04-11-2021 00:19	20	22.6	22	22.9	27	23.0
04-11-2021 00:20	20	22.6	22	22.9	27	23.0
04-11-2021 00:21	20	22.6	22	22.9	27	23.0
04-11-2021 00:22	21	22.6	22	22.9	27	23.0
04-11-2021 00:23	20	22.6	22	22.9	27	23.0
04-11-2021 00:24	20	22.6	22	22.9	27	23.0



# Environmental Monitoring System

## DATA REPORT

### STERILE EXIT CHANGE ROOMS (L3)

Date Time	STERILE PASSAGE (L3) wrt EXIT ROOM-1 (L3)	STERILE EXIT ROOM-1 (L3)	ASEPTIC EXIT ROOM-1 (L3) wrt EXIT ROOM-2 (L3)	STERILE EXIT ROOM-2 (L3)	ASEPTIC EXIT ROOM-2 (L3) wrt EXIT ROOM-3 (L3)	STERILE EXIT ROOM-3 (L3)
Date Time	DP Pa	°C TEMP	DP Pa	°C TEMP	DP Pa	°C TEMP
04-11-2021 00:25	21	22.6	23	22.9	27	23.0
04-11-2021 00:26	21	22.7	23	22.9	27	23.0
04-11-2021 00:27	21	22.7	21	23.0	27	23.0
04-11-2021 00:28	21	22.7	22	23.0	27	23.0
04-11-2021 00:29	20	22.7	21	23.0	27	23.0
04-11-2021 00:30	20	22.7	23	23.0	27	23.0
04-11-2021 00:31	21	22.7	23	23.0	26	23.0
04-11-2021 00:32	20	22.7	22	23.0	27	23.0
04-11-2021 00:33	19	22.7	23	23.0	27	23.0
04-11-2021 00:34	21	22.7	22	23.0	27	23.0
04-11-2021 00:35	21	22.7	22	23.0	27	23.0
04-11-2021 00:36	20	22.7	22	23.0	26	23.0
04-11-2021 00:37	20	22.7	22	23.0	26	23.0
04-11-2021 00:38	21	22.7	23	23.0	27	23.0
04-11-2021 00:39	21	22.8	23	23.0	28	23.0
04-11-2021 00:40	21	22.8	21	23.0	27	23.0
04-11-2021 00:41	19	22.8	21	23.0	25	23.0
04-11-2021 00:42	20	22.8	22	23.0	26	23.0
04-11-2021 00:43	19	22.7	21	23.0	25	23.0
04-11-2021 00:44	20	22.7	22	23.1	27	23.0
04-11-2021 00:45	22	22.7	21	23.1	27	23.0
04-11-2021 00:46	20	22.8	23	23.1	28	23.0
04-11-2021 00:47	21	22.8	23	23.1	27	23.0
04-11-2021 00:48	21	22.8	22	23.1	27	23.0
04-11-2021 00:49	21	22.8	21	23.1	27	23.0
04-11-2021 00:50	21	22.8	23	23.1	27	23.0
04-11-2021 00:51	20	22.9	22	23.1	27	23.0
04-11-2021 00:52	21	22.9	23	23.1	27	23.0



# Environmental Monitoring System

## DATA REPORT

### STERILE EXIT CHANGE ROOMS (L3)

Date Time	STERILE PASSAGE (L3) wrt EXIT ROOM-1 (L3)	STERILE EXIT ROOM-1 (L3)	ASEPTIC EXIT ROOM-1 (L3) wrt EXIT ROOM-2 (L3)	STERILE EXIT ROOM-2 (L3)	ASEPTIC EXIT ROOM-2 (L3) wrt EXIT ROOM-3 (L3)	STERILE EXIT ROOM-3 (L3)
Date Time	DP Pa	°C TEMP	DP Pa	°C TEMP	DP Pa	°C TEMP
04-11-2021 00:53	21	22.9	21	23.1	27	23.0
04-11-2021 00:54	20	22.9	21	23.1	27	23.0
04-11-2021 00:55	21	23.0	22	23.2	27	23.1
04-11-2021 00:56	20	22.9	21	23.2	27	23.1
04-11-2021 00:57	20	23.0	24	23.2	28	23.1
04-11-2021 00:58	21	23.0	23	23.2	27	23.1
04-11-2021 00:59	18	23.0	22	23.2	27	23.1
04-11-2021 01:00	21	23.0	23	23.2	27	23.1
04-11-2021 01:01	21	23.0	22	23.2	26	23.1
04-11-2021 01:02	20	23.0	23	23.2	27	23.1
04-11-2021 01:03	20	23.1	21	23.2	27	23.1
04-11-2021 01:04	20	23.1	22	23.2	27	23.1
04-11-2021 01:05	20	23.0	22	23.2	27	23.1
04-11-2021 01:06	19	23.0	22	23.2	27	23.1
04-11-2021 01:07	20	23.0	23	23.2	27	23.1
04-11-2021 01:08	21	23.0	22	23.2	27	23.1
04-11-2021 01:09	20	22.9	22	23.2	27	23.1
04-11-2021 01:10	20	22.9	22	23.2	27	23.1
04-11-2021 01:11	20	22.9	23	23.2	27	23.1
04-11-2021 01:12	19	22.9	23	23.1	27	23.1
04-11-2021 01:13	19	22.9	23	23.1	27	23.1
04-11-2021 01:14	20	22.9	23	23.1	27	23.1
04-11-2021 01:15	20	22.9	22	23.1	27	23.1
04-11-2021 01:16	21	22.9	24	23.1	28	23.1
04-11-2021 01:17	20	22.8	22	23.1	27	23.1
04-11-2021 01:18	20	22.8	21	23.1	27	23.1
04-11-2021 01:19	20	22.8	21	23.0	27	23.1
04-11-2021 01:20	19	22.7	21	23.0	25	23.1



# Environmental Monitoring System

## DATA REPORT

### STERILE EXIT CHANGE ROOMS (L3)

Date Time	STERILE PASSAGE (L3) wrt EXIT ROOM-1 (L3)	STERILE EXIT ROOM-1 (L3)	ASEPTIC EXIT ROOM-1 (L3) wrt EXIT ROOM-2 (L3)	STERILE EXIT ROOM-2 (L3)	ASEPTIC EXIT ROOM-2 (L3) wrt EXIT ROOM-3 (L3)	STERILE EXIT ROOM-3 (L3)
Date Time	DP Pa	°C TEMP	DP Pa	°C TEMP	DP Pa	°C TEMP
04-11-2021 01:21	20	22.7	23	23.0	27	23.0
04-11-2021 01:22	20	22.7	22	23.0	27	23.0
04-11-2021 01:23	21	22.7	22	22.9	27	23.0
04-11-2021 01:24	25	22.6	24	22.9	27	23.0
04-11-2021 01:25	20	22.6	23	22.9	26	23.0
04-11-2021 01:26	21	22.6	23	22.9	27	23.0
04-11-2021 01:27	21	22.6	23	22.8	28	23.0
04-11-2021 01:28	20	22.6	22	22.8	27	22.9
04-11-2021 01:29	21	22.5	21	22.8	28	22.9
04-11-2021 01:30	21	22.5	22	22.8	27	22.9
04-11-2021 01:31	21	22.5	21	22.8	27	22.9
04-11-2021 01:32	20	22.4	23	22.7	26	22.9
04-11-2021 01:33	20	22.4	22	22.7	27	22.9
04-11-2021 01:34	20	22.4	23	22.7	28	22.9
04-11-2021 01:35	21	22.5	23	22.7	27	22.9
04-11-2021 01:36	21	22.4	23	22.7	26	22.9
04-11-2021 01:37	20	22.4	21	22.7	25	22.9
04-11-2021 01:38	21	22.4	22	22.7	27	22.9
04-11-2021 01:39	19	22.4	21	22.7	26	22.9
04-11-2021 01:40	20	22.4	22	22.7	26	22.8
04-11-2021 01:41	20	22.5	22	22.7	26	22.8
04-11-2021 01:42	20	22.4	22	22.7	27	22.8
04-11-2021 01:43	21	22.5	21	22.7	27	22.8
04-11-2021 01:44	18	22.5	21	22.8	26	22.8
04-11-2021 01:45	19	22.5	21	22.8	27	22.8
04-11-2021 01:46	18	22.4	21	22.8	27	22.8
04-11-2021 01:47	21	22.5	22	22.8	27	22.8
04-11-2021 01:48	20	22.5	21	22.8	27	22.9



# Environmental Monitoring System

## DATA REPORT

### STERILE EXIT CHANGE ROOMS (L3)

Date Time	STERILE PASSAGE (L3) wrt EXIT ROOM-1 (L3)	STERILE EXIT ROOM-1 (L3)	ASEPTIC EXIT ROOM-1 (L3) wrt EXIT ROOM-2 (L3)	STERILE EXIT ROOM-2 (L3)	ASEPTIC EXIT ROOM-2 (L3) wrt EXIT ROOM-3 (L3)	STERILE EXIT ROOM-3 (L3)
Date Time	DP Pa	°C TEMP	DP Pa	°C TEMP	DP Pa	°C TEMP
04-11-2021 01:49	21	22.5	21	22.8	26	22.9
04-11-2021 01:50	19	22.5	22	22.8	27	22.9
04-11-2021 01:51	18	22.6	22	22.9	27	22.9
04-11-2021 01:52	20	22.6	21	22.9	26	22.9
04-11-2021 01:53	19	22.6	21	22.9	26	22.9
04-11-2021 01:54	19	22.6	21	22.9	27	22.9
04-11-2021 01:55	21	22.7	21	22.9	26	22.9
04-11-2021 01:56	22	22.6	23	22.9	28	22.9
04-11-2021 01:57	20	22.6	22	22.9	27	22.9
04-11-2021 01:58	20	22.6	22	22.9	26	22.9
04-11-2021 01:59	23	22.7	23	22.9	27	22.9
04-11-2021 02:00	20	22.7	21	22.9	27	22.9
04-11-2021 02:01	20	22.7	22	23.0	27	22.9
04-11-2021 02:02	20	22.7	22	23.0	28	22.9
04-11-2021 02:03	20	22.7	22	23.0	27	22.9
04-11-2021 02:04	21	22.7	21	23.0	27	23.0
04-11-2021 02:05	19	22.7	23	23.0	27	23.0
04-11-2021 02:06	19	22.8	22	23.0	28	23.0
04-11-2021 02:07	20	22.8	22	23.0	27	23.0
04-11-2021 02:08	20	22.8	22	23.0	27	23.0
04-11-2021 02:09	20	22.8	23	23.0	27	23.0
04-11-2021 02:10	19	22.7	21	23.0	27	23.0
04-11-2021 02:11	21	22.7	22	23.0	27	23.0
04-11-2021 02:12	23	22.7	24	23.0	28	23.0
04-11-2021 02:13	21	22.7	22	23.0	27	23.0
04-11-2021 02:14	20	22.8	23	23.0	27	23.0
04-11-2021 02:15	20	22.8	21	23.0	27	23.0
04-11-2021 02:16	20	22.7	22	23.0	27	23.0



# Environmental Monitoring System

## DATA REPORT

### STERILE EXIT CHANGE ROOMS (L3)

Date Time	STERILE PASSAGE (L3) wrt EXIT ROOM-1 (L3)	STERILE EXIT ROOM-1 (L3)	ASEPTIC EXIT ROOM-1 (L3) wrt EXIT ROOM-2 (L3)	STERILE EXIT ROOM-2 (L3)	ASEPTIC EXIT ROOM-2 (L3) wrt EXIT ROOM-3 (L3)	STERILE EXIT ROOM-3 (L3)
Date Time	DP Pa	°C TEMP	DP Pa	°C TEMP	DP Pa	°C TEMP
04-11-2021 02:17	23	22.7	23	23.0	27	23.0
04-11-2021 02:18	21	22.7	21	23.0	27	23.0
04-11-2021 02:19	19	22.7	23	23.0	27	23.0
04-11-2021 02:20	21	22.7	21	23.0	27	23.0
04-11-2021 02:21	20	22.7	22	23.1	27	23.0
04-11-2021 02:22	20	22.7	21	23.1	27	23.0
04-11-2021 02:23	20	22.7	22	23.1	27	23.0
04-11-2021 02:24	21	22.8	21	23.1	27	23.0
04-11-2021 02:25	20	22.8	22	23.1	27	23.0
04-11-2021 02:26	20	22.8	21	23.1	27	23.0
04-11-2021 02:27	20	22.8	22	23.1	27	23.0
04-11-2021 02:28	20	22.8	21	23.1	27	23.0
04-11-2021 02:29	20	22.8	22	23.1	28	23.0
04-11-2021 02:30	16	22.8	20	23.1	25	23.0
04-11-2021 02:31	17	22.8	20	23.1	26	23.0
04-11-2021 02:32	16	22.8	20	23.1	26	23.0
04-11-2021 02:33	16	22.8	20	23.1	27	23.0
04-11-2021 02:34	18	22.8	20	23.1	27	23.0
04-11-2021 02:35	17	22.8	20	23.1	25	23.0
04-11-2021 02:36	17	22.7	20	23.1	27	23.0
04-11-2021 02:37	18	22.7	21	23.1	27	23.0
04-11-2021 02:38	18	22.7	20	23.1	27	23.0
04-11-2021 02:39	16	22.8	20	23.1	25	23.0
04-11-2021 02:40	20	22.8	21	23.1	27	23.0
04-11-2021 02:41	17	22.9	20	23.2	24	23.0
04-11-2021 02:42	16	22.8	20	23.1	26	23.0
04-11-2021 02:43	16	22.7	20	23.2	27	23.0
04-11-2021 02:44	17	22.7	20	23.2	26	23.0



# Environmental Monitoring System

## DATA REPORT

### STERILE EXIT CHANGE ROOMS (L3)

Date Time	STERILE PASSAGE (L3) wrt EXIT ROOM-1 (L3)	STERILE EXIT ROOM-1 (L3)	ASEPTIC EXIT ROOM-1 (L3) wrt EXIT ROOM-2 (L3)	STERILE EXIT ROOM-2 (L3)	ASEPTIC EXIT ROOM-2 (L3) wrt EXIT ROOM-3 (L3)	STERILE EXIT ROOM-3 (L3)
Date Time	DP Pa	°C TEMP	DP Pa	°C TEMP	DP Pa	°C TEMP
04-11-2021 02:45	16	22.7	20	23.2	27	23.0
04-11-2021 02:46	16	22.7	20	23.2	26	23.0
04-11-2021 02:47	16	22.7	21	23.2	26	23.0
04-11-2021 02:48	17	22.8	20	23.2	26	23.0
04-11-2021 02:49	16	22.7	19	23.2	26	23.0
04-11-2021 02:50	17	22.8	20	23.2	26	23.1
04-11-2021 02:51	21	22.7	24	23.2	28	23.1
04-11-2021 02:52	17	22.8	21	23.2	25	23.0
04-11-2021 02:53	17	22.8	20	23.2	26	23.1
04-11-2021 02:54	18	22.7	20	23.2	25	23.1
04-11-2021 02:55	17	22.7	20	23.2	27	23.1
04-11-2021 02:56	16	22.7	19	23.2	27	23.1
04-11-2021 02:57	15	22.6	18	23.2	25	23.1
04-11-2021 02:58	19	22.7	21	23.2	27	23.1
04-11-2021 02:59	19	22.7	21	23.2	27	23.1
04-11-2021 03:00	20	22.7	21	23.2	27	23.0
04-11-2021 03:01	18	22.7	21	23.2	26	23.0
04-11-2021 03:02	18	22.7	21	23.1	26	23.0
04-11-2021 03:03	19	22.8	21	23.1	27	23.0
04-11-2021 03:04	20	22.8	23	23.1	28	23.0
04-11-2021 03:05	19	22.8	22	23.1	27	23.0
04-11-2021 03:06	20	22.7	21	23.1	27	23.0
04-11-2021 03:07	20	22.7	21	23.1	26	23.0
04-11-2021 03:08	21	22.7	21	23.1	27	23.0
04-11-2021 03:09	20	22.7	22	23.1	27	23.0
04-11-2021 03:10	20	22.7	21	23.1	27	23.0
04-11-2021 03:11	20	22.7	22	23.0	27	23.0
04-11-2021 03:12	23	22.7	23	23.0	28	23.0



# Environmental Monitoring System

## DATA REPORT

### STERILE EXIT CHANGE ROOMS (L3)

Date Time	STERILE PASSAGE (L3) wrt EXIT ROOM-1 (L3)	STERILE EXIT ROOM-1 (L3)	ASEPTIC EXIT ROOM-1 (L3) wrt EXIT ROOM-2 (L3)	STERILE EXIT ROOM-2 (L3)	ASEPTIC EXIT ROOM-2 (L3) wrt EXIT ROOM-3 (L3)	STERILE EXIT ROOM-3 (L3)
Date Time	DP Pa	°C TEMP	DP Pa	°C TEMP	DP Pa	°C TEMP
04-11-2021 03:13	21	22.7	22	23.0	27	23.0
04-11-2021 03:14	21	22.7	21	23.0	27	23.0
04-11-2021 03:15	20	22.7	22	23.0	27	23.0
04-11-2021 03:16	20	22.7	22	23.0	27	22.9
04-11-2021 03:17	19	22.7	21	22.9	28	22.9
04-11-2021 03:18	23	22.6	23	22.9	27	22.9
04-11-2021 03:19	23	22.6	23	22.9	27	22.9
04-11-2021 03:20	20	22.5	23	22.9	28	22.9
04-11-2021 03:21	18	22.6	21	22.9	27	22.9
04-11-2021 03:22	19	22.6	20	22.8	25	22.9
04-11-2021 03:23	19	22.5	21	22.8	27	22.9
04-11-2021 03:24	20	22.4	21	22.8	26	22.9
04-11-2021 03:25	21	22.5	20	22.8	27	22.9
04-11-2021 03:26	19	22.5	21	22.8	27	22.9
04-11-2021 03:27	19	22.5	21	22.8	27	22.9
04-11-2021 03:28	19	22.4	21	22.8	27	22.8
04-11-2021 03:29	18	22.5	21	22.8	27	22.8
04-11-2021 03:30	19	22.5	20	22.8	26	22.8
04-11-2021 03:31	20	22.4	21	22.8	27	22.8
04-11-2021 03:32	18	22.4	21	22.8	27	22.8
04-11-2021 03:33	19	22.5	21	22.8	27	22.8
04-11-2021 03:34	20	22.5	21	22.8	27	22.8
04-11-2021 03:35	19	22.5	21	22.8	27	22.8
04-11-2021 03:36	26	22.5	0	22.8	39	22.8
04-11-2021 03:37	27	22.6	0	22.8	39	22.9
04-11-2021 03:38	22	22.6	36	22.9	0	22.9
04-11-2021 03:39	19	22.5	21	22.9	26	22.9
04-11-2021 03:40	19	22.5	21	22.9	26	22.9





# Environmental Monitoring System

## DATA REPORT

### STERILE EXIT CHANGE ROOMS (L3)

Date Time	STERILE PASSAGE (L3) wrt EXIT ROOM-1 (L3)	STERILE EXIT ROOM-1 (L3)	ASEPTIC EXIT ROOM-1 (L3) wrt EXIT ROOM-2 (L3)	STERILE EXIT ROOM-2 (L3)	ASEPTIC EXIT ROOM-2 (L3) wrt EXIT ROOM-3 (L3)	STERILE EXIT ROOM-3 (L3)
Date Time	DP Pa	°C TEMP	DP Pa	°C TEMP	DP Pa	°C TEMP
04-11-2021 03:41	20	22.5	21	22.8	26	22.9
04-11-2021 03:42	18	22.4	21	22.8	26	22.9
04-11-2021 03:43	19	22.4	20	22.8	26	22.9
04-11-2021 03:44	19	22.4	20	22.8	25	22.8
04-11-2021 03:45	20	22.5	21	22.8	27	22.8
04-11-2021 03:46	19	22.4	21	22.8	27	22.8
04-11-2021 03:47	20	22.4	20	22.9	26	22.8
04-11-2021 03:48	19	22.4	21	22.9	26	22.8
04-11-2021 03:49	20	22.4	21	22.9	27	22.8
04-11-2021 03:50	19	22.5	21	22.9	27	22.8
04-11-2021 03:51	19	22.5	22	22.9	27	22.8
04-11-2021 03:52	19	22.4	21	22.9	27	22.8
04-11-2021 03:53	20	22.4	21	22.9	27	22.8
04-11-2021 03:54	18	22.4	20	23.0	27	22.8
04-11-2021 03:55	19	22.5	20	23.0	26	22.9
04-11-2021 03:56	20	22.4	21	23.0	27	22.9
04-11-2021 03:57	21	22.4	22	23.0	27	22.9
04-11-2021 03:58	19	22.5	20	23.0	27	22.9
04-11-2021 03:59	19	22.5	21	23.0	27	22.9
04-11-2021 04:00	19	22.5	20	23.0	26	22.9
04-11-2021 04:01	19	22.6	15	23.1	19	22.9
04-11-2021 04:02	20	22.6	15	23.1	20	23.0
04-11-2021 04:03	18	22.6	15	23.1	20	23.0
04-11-2021 04:04	20	22.6	15	23.1	20	23.0
04-11-2021 04:05	19	22.6	15	23.1	21	23.0
04-11-2021 04:06	20	22.6	15	23.1	20	23.1
04-11-2021 04:07	18	22.6	15	23.1	20	23.1
04-11-2021 04:08	20	22.6	16	23.1	20	23.1



# Environmental Monitoring System

## DATA REPORT

### STERILE EXIT CHANGE ROOMS (L3)

Date Time	STERILE PASSAGE (L3) wrt EXIT ROOM-1 (L3)	STERILE EXIT ROOM-1 (L3)	ASEPTIC EXIT ROOM-1 (L3) wrt EXIT ROOM-2 (L3)	STERILE EXIT ROOM-2 (L3)	ASEPTIC EXIT ROOM-2 (L3) wrt EXIT ROOM-3 (L3)	STERILE EXIT ROOM-3 (L3)
Date Time	DP Pa	°C TEMP	DP Pa	°C TEMP	DP Pa	°C TEMP
04-11-2021 04:09	19	22.6	16	23.1	20	23.1
04-11-2021 04:10	19	22.6	15	23.1	20	23.1
04-11-2021 04:11	18	22.6	14	23.1	20	23.1
04-11-2021 04:12	19	22.6	16	23.1	20	23.1
04-11-2021 04:13	20	22.6	15	23.1	20	23.1
04-11-2021 04:14	18	22.6	15	23.1	19	23.2
04-11-2021 04:15	19	22.6	15	23.1	20	23.1
04-11-2021 04:16	19	22.7	15	23.1	20	23.2
04-11-2021 04:17	18	22.7	15	23.1	20	23.2
04-11-2021 04:18	18	22.7	14	23.1	19	23.2
04-11-2021 04:19	18	22.7	15	23.1	20	23.2
04-11-2021 04:20	18	22.6	15	23.1	19	23.2
04-11-2021 04:21	19	22.7	15	23.1	20	23.2
04-11-2021 04:22	20	22.6	15	23.1	19	23.2
04-11-2021 04:23	19	22.6	15	23.1	20	23.2
04-11-2021 04:24	20	22.6	16	23.1	20	23.2
04-11-2021 04:25	20	22.6	15	23.1	20	23.2
04-11-2021 04:26	19	22.6	15	23.1	19	23.2
04-11-2021 04:27	20	22.6	15	23.1	19	23.2
04-11-2021 04:28	18	22.6	15	23.1	19	23.2
04-11-2021 04:29	20	22.6	16	23.1	20	23.2
04-11-2021 04:30	18	22.6	16	23.1	19	23.2
04-11-2021 04:31	20	22.6	15	23.1	20	23.2
04-11-2021 04:32	20	22.6	15	23.1	20	23.2
04-11-2021 04:33	21	22.5	16	23.0	21	23.2
04-11-2021 04:34	21	22.6	15	23.0	21	23.2
04-11-2021 04:35	23	22.5	16	23.0	19	23.2
04-11-2021 04:36	21	22.5	16	23.0	20	23.1



# Environmental Monitoring System

## DATA REPORT

### STERILE EXIT CHANGE ROOMS (L3)

Date Time	STERILE PASSAGE (L3) wrt EXIT ROOM-1 (L3)	STERILE EXIT ROOM-1 (L3)	ASEPTIC EXIT ROOM-1 (L3) wrt EXIT ROOM-2 (L3)	STERILE EXIT ROOM-2 (L3)	ASEPTIC EXIT ROOM-2 (L3) wrt EXIT ROOM-3 (L3)	STERILE EXIT ROOM-3 (L3)
Date Time	DP Pa	°C TEMP	DP Pa	°C TEMP	DP Pa	°C TEMP
04-11-2021 04:37	21	22.5	15	23.0	21	23.1
04-11-2021 04:38	20	22.5	16	23.0	20	23.1
04-11-2021 04:39	20	22.5	15	23.0	20	23.1
04-11-2021 04:40	18	22.5	14	23.0	20	23.1
04-11-2021 04:41	18	22.4	14	23.0	19	23.1
04-11-2021 04:42	18	22.4	14	23.0	19	23.1
04-11-2021 04:43	17	22.4	14	23.0	19	23.1
04-11-2021 04:44	23	22.4	16	23.0	18	23.1
04-11-2021 04:45	20	22.4	15	23.0	20	23.1
04-11-2021 04:46	17	22.4	15	23.0	19	23.1
04-11-2021 04:47	18	22.4	13	23.0	20	23.1
04-11-2021 04:48	16	22.4	15	22.9	20	23.1
04-11-2021 04:49	18	22.4	13	22.9	19	23.1
04-11-2021 04:50	17	22.4	14	22.9	20	23.1
04-11-2021 04:51	16	22.4	13	22.9	19	23.1
04-11-2021 04:52	21	22.3	15	22.9	19	23.1
04-11-2021 04:53	18	22.3	13	22.9	20	23.1
04-11-2021 04:54	16	22.4	14	22.9	19	23.1
04-11-2021 04:55	18	22.4	13	22.8	19	23.1
04-11-2021 04:56	18	22.3	15	22.8	20	23.1
04-11-2021 04:57	18	22.3	15	22.8	20	23.1
04-11-2021 04:58	19	22.3	15	22.8	20	23.1
04-11-2021 04:59	17	22.4	15	22.8	20	23.0
04-11-2021 05:00	18	22.3	15	22.8	20	23.0
04-11-2021 05:01	17	22.3	15	22.7	21	23.0
04-11-2021 05:02	17	22.3	15	22.7	20	23.0
04-11-2021 05:03	16	22.3	15	22.7	20	23.0
04-11-2021 05:04	18	22.3	15	22.7	20	23.0



# Environmental Monitoring System

## DATA REPORT

### STERILE EXIT CHANGE ROOMS (L3)

Date Time	STERILE PASSAGE (L3) wrt EXIT ROOM-1 (L3)	STERILE EXIT ROOM-1 (L3)	ASEPTIC EXIT ROOM-1 (L3) wrt EXIT ROOM-2 (L3)	STERILE EXIT ROOM-2 (L3)	ASEPTIC EXIT ROOM-2 (L3) wrt EXIT ROOM-3 (L3)	STERILE EXIT ROOM-3 (L3)
Date Time	DP Pa	°C TEMP	DP Pa	°C TEMP	DP Pa	°C TEMP
04-11-2021 05:05	18	22.3	15	22.7	21	23.0
04-11-2021 05:06	18	22.2	15	22.7	20	23.0
04-11-2021 05:07	18	22.2	14	22.7	21	23.0
04-11-2021 05:08	18	22.2	15	22.7	20	23.0
04-11-2021 05:09	18	22.3	15	22.7	21	23.0
04-11-2021 05:10	17	22.2	14	22.7	20	23.0
04-11-2021 05:11	20	22.2	16	22.7	21	23.0
04-11-2021 05:12	18	22.2	16	22.7	21	23.0
04-11-2021 05:13	19	22.3	15	22.7	20	23.0
04-11-2021 05:14	17	22.3	15	22.8	21	23.0
04-11-2021 05:15	18	22.3	15	22.8	20	23.0
04-11-2021 05:16	18	22.3	14	22.8	20	23.0
04-11-2021 05:17	16	22.3	14	22.8	20	23.0
04-11-2021 05:18	18	22.3	14	22.8	20	23.0
04-11-2021 05:19	18	22.3	15	22.8	19	23.0
04-11-2021 05:20	17	22.3	13	22.8	19	23.0
04-11-2021 05:21	17	22.4	14	22.8	19	23.0
04-11-2021 05:22	18	22.4	14	22.8	20	23.0
04-11-2021 05:23	18	22.4	15	22.8	18	23.0
04-11-2021 05:24	18	22.5	13	22.9	20	23.0
04-11-2021 05:25	18	22.4	14	22.9	19	23.0
04-11-2021 05:26	18	22.5	15	22.9	20	23.0
04-11-2021 05:27	17	22.4	14	22.9	18	23.0
04-11-2021 05:28	18	22.4	15	22.9	20	23.0
04-11-2021 05:29	17	22.4	15	22.9	19	23.0
04-11-2021 05:30	17	22.5	14	22.9	20	23.0
04-11-2021 05:31	17	22.4	14	22.9	18	23.0
04-11-2021 05:32	18	22.5	14	22.9	19	23.0



# Environmental Monitoring System

## DATA REPORT

### STERILE EXIT CHANGE ROOMS (L3)

Date Time	STERILE PASSAGE (L3) wrt EXIT ROOM-1 (L3)	STERILE EXIT ROOM-1 (L3)	ASEPTIC EXIT ROOM-1 (L3) wrt EXIT ROOM-2 (L3)	STERILE EXIT ROOM-2 (L3)	ASEPTIC EXIT ROOM-2 (L3) wrt EXIT ROOM-3 (L3)	STERILE EXIT ROOM-3 (L3)
Date Time	DP Pa	°C TEMP	DP Pa	°C TEMP	DP Pa	°C TEMP
04-11-2021 05:33	18	22.5	15	22.9	20	23.0
04-11-2021 05:34	18	22.5	14	22.9	20	23.0
04-11-2021 05:35	16	22.5	14	22.9	20	23.0
04-11-2021 05:36	17	22.5	14	22.9	18	23.0
04-11-2021 05:37	17	22.5	15	22.9	18	23.0
04-11-2021 05:38	18	22.5	14	22.9	19	23.0
04-11-2021 05:39	18	22.5	14	22.9	21	23.0
04-11-2021 05:40	18	22.5	15	22.9	19	23.1
04-11-2021 05:41	20	22.5	15	23.0	20	23.1
04-11-2021 05:42	27	22.5	16	22.9	23	23.1
04-11-2021 05:43	26	22.6	0	23.0	30	23.0
04-11-2021 05:44	25	22.6	0	23.0	36	23.0
04-11-2021 05:45	27	22.7	0	23.1	33	23.0
04-11-2021 05:46	27	22.8	0	23.2	33	23.0
04-11-2021 05:47	25	22.9	0	23.3	30	23.0
04-11-2021 05:48	27	22.9	0	23.3	29	23.0
04-11-2021 05:49	26	22.9	0	23.3	30	23.0
04-11-2021 05:50	18	22.8	16	23.2	20	23.0
04-11-2021 05:51	20	22.8	16	23.2	21	23.0
04-11-2021 05:52	20	22.8	15	23.1	20	23.0
04-11-2021 05:53	20	22.7	21	23.1	27	23.0
04-11-2021 05:54	21	22.7	21	23.1	27	23.0
04-11-2021 05:55	21	22.7	20	23.1	27	23.0
04-11-2021 05:56	21	22.8	21	23.1	27	23.0
04-11-2021 05:57	20	22.8	21	23.1	28	23.0
04-11-2021 05:58	20	22.7	21	23.1	27	23.0
04-11-2021 05:59	21	22.8	21	23.1	27	23.0
04-11-2021 06:00	20	22.7	22	23.1	27	23.0



# Environmental Monitoring System

## DATA REPORT

### STERILE EXIT CHANGE ROOMS (L3)

Date Time	STERILE PASSAGE (L3) wrt EXIT ROOM-1 (L3)	STERILE EXIT ROOM-1 (L3)	ASEPTIC EXIT ROOM-1 (L3) wrt EXIT ROOM-2 (L3)	STERILE EXIT ROOM-2 (L3)	ASEPTIC EXIT ROOM-2 (L3) wrt EXIT ROOM-3 (L3)	STERILE EXIT ROOM-3 (L3)
Date Time	DP Pa	°C TEMP	DP Pa	°C TEMP	DP Pa	°C TEMP
04-11-2021 06:01	21	22.7	21	23.0	27	23.0
04-11-2021 06:02	20	22.7	21	23.0	27	23.0
04-11-2021 06:03	21	22.7	21	23.0	27	23.0
04-11-2021 06:04	20	22.7	21	23.0	28	23.0
04-11-2021 06:05	21	22.7	21	23.0	28	23.0
04-11-2021 06:06	20	22.7	21	23.0	27	22.9
04-11-2021 06:07	20	22.8	21	23.0	27	23.0
04-11-2021 06:08	21	22.7	21	23.0	27	22.9
04-11-2021 06:09	24	22.7	21	23.0	27	22.9
04-11-2021 06:10	19	22.7	21	23.0	27	22.9
04-11-2021 06:11	21	22.7	20	23.0	23	22.9
04-11-2021 06:12	20	22.7	21	23.0	26	22.9
04-11-2021 06:13	19	22.6	20	23.0	27	22.9
04-11-2021 06:14	20	22.7	21	23.0	27	22.9
04-11-2021 06:15	21	22.7	21	23.0	27	22.9
04-11-2021 06:16	19	22.7	21	23.0	27	22.9
04-11-2021 06:17	21	22.7	21	23.0	27	22.9
04-11-2021 06:18	20	22.7	21	23.0	27	22.9
04-11-2021 06:19	20	22.7	21	23.0	28	22.9
04-11-2021 06:20	19	22.7	21	23.0	27	22.9
04-11-2021 06:21	20	22.7	21	23.0	26	22.9
04-11-2021 06:22	21	22.7	21	23.0	27	22.9
04-11-2021 06:23	21	22.8	22	23.0	27	22.9
04-11-2021 06:24	20	22.8	21	23.0	27	22.9
04-11-2021 06:25	20	22.7	21	23.0	27	22.9
04-11-2021 06:26	20	22.7	21	23.0	27	22.9
04-11-2021 06:27	20	22.7	21	23.0	27	22.9
04-11-2021 06:28	21	22.7	22	23.0	28	22.9



# Environmental Monitoring System

## DATA REPORT

### STERILE EXIT CHANGE ROOMS (L3)

Date Time	STERILE PASSAGE (L3) wrt EXIT ROOM-1 (L3)	STERILE EXIT ROOM-1 (L3)	ASEPTIC EXIT ROOM-1 (L3) wrt EXIT ROOM-2 (L3)	STERILE EXIT ROOM-2 (L3)	ASEPTIC EXIT ROOM-2 (L3) wrt EXIT ROOM-3 (L3)	STERILE EXIT ROOM-3 (L3)
Date Time	DP Pa	°C TEMP	DP Pa	°C TEMP	DP Pa	°C TEMP
04-11-2021 06:29	21	22.7	21	23.0	27	22.9
04-11-2021 06:30	20	22.7	21	23.0	27	22.9
04-11-2021 06:31	22	22.8	21	23.0	28	22.9
04-11-2021 06:32	20	22.7	21	23.0	27	22.9
04-11-2021 06:33	20	22.8	21	23.0	26	22.9
04-11-2021 06:34	20	22.8	22	23.0	26	22.9
04-11-2021 06:35	21	22.8	21	23.0	27	23.0
04-11-2021 06:36	21	22.8	23	23.0	28	23.0
04-11-2021 06:37	20	22.7	22	23.0	27	22.9
04-11-2021 06:38	21	22.8	21	23.0	27	23.0
04-11-2021 06:39	21	22.8	15	23.0	19	23.0
04-11-2021 06:40	21	22.8	16	23.0	21	23.1
04-11-2021 06:41	23	22.8	20	23.0	25	23.1
04-11-2021 06:42	20	22.7	15	23.0	21	23.1
04-11-2021 06:43	20	22.8	16	23.0	20	23.2
04-11-2021 06:44	20	22.7	16	23.1	20	23.2
04-11-2021 06:45	20	22.7	15	23.1	19	23.2
04-11-2021 06:46	21	22.7	16	23.1	21	23.2
04-11-2021 06:47	20	22.7	16	23.1	20	23.2
04-11-2021 06:48	20	22.7	15	23.1	20	23.2
04-11-2021 06:49	21	22.7	16	23.1	21	23.2
04-11-2021 06:50	20	22.7	15	23.1	20	23.2
04-11-2021 06:51	20	22.7	15	23.1	20	23.2
04-11-2021 06:52	20	22.7	16	23.1	20	23.2
04-11-2021 06:53	21	22.7	15	23.1	21	23.2
04-11-2021 06:54	20	22.7	16	23.1	21	23.2
04-11-2021 06:55	20	22.7	16	23.1	19	23.2
04-11-2021 06:56	20	22.7	16	23.1	21	23.2



# Environmental Monitoring System

## DATA REPORT

### STERILE EXIT CHANGE ROOMS (L3)

Date Time	STERILE PASSAGE (L3) wrt EXIT ROOM-1 (L3)	STERILE EXIT ROOM-1 (L3)	ASEPTIC EXIT ROOM-1 (L3) wrt EXIT ROOM-2 (L3)	STERILE EXIT ROOM-2 (L3)	ASEPTIC EXIT ROOM-2 (L3) wrt EXIT ROOM-3 (L3)	STERILE EXIT ROOM-3 (L3)
Date Time	DP Pa	°C TEMP	DP Pa	°C TEMP	DP Pa	°C TEMP
04-11-2021 06:57	19	22.7	16	23.1	20	23.2
04-11-2021 06:58	21	22.7	15	23.1	20	23.2
04-11-2021 06:59	20	22.7	15	23.1	20	23.2
04-11-2021 07:00	20	22.7	16	23.1	19	23.2
04-11-2021 07:01	21	22.7	16	23.1	20	23.2
04-11-2021 07:02	20	22.7	16	23.1	21	23.2
04-11-2021 07:03	20	22.7	16	23.1	20	23.2
04-11-2021 07:04	20	22.7	16	23.2	20	23.2
04-11-2021 07:05	20	22.7	15	23.2	20	23.2
04-11-2021 07:06	21	22.7	16	23.2	20	23.2
04-11-2021 07:07	20	22.7	15	23.2	20	23.2
04-11-2021 07:08	20	22.7	15	23.2	21	23.2
04-11-2021 07:09	20	22.7	16	23.2	20	23.2
04-11-2021 07:10	20	22.7	15	23.2	21	23.2
04-11-2021 07:11	20	22.7	15	23.2	20	23.2
04-11-2021 07:12	20	22.7	16	23.2	20	23.3
04-11-2021 07:13	20	22.7	16	23.2	20	23.3
04-11-2021 07:14	20	22.7	16	23.2	19	23.3
04-11-2021 07:15	20	22.7	16	23.1	20	23.3
04-11-2021 07:16	20	22.7	16	23.2	21	23.3
04-11-2021 07:17	20	22.7	16	23.1	20	23.3
04-11-2021 07:18	20	22.7	16	23.1	21	23.3
04-11-2021 07:19	21	22.7	16	23.1	20	23.3
04-11-2021 07:20	21	22.7	15	23.1	20	23.3
04-11-2021 07:21	20	22.7	16	23.1	21	23.3
04-11-2021 07:22	20	22.7	16	23.1	20	23.3
04-11-2021 07:23	20	22.7	16	23.1	20	23.3
04-11-2021 07:24	20	22.6	15	23.1	20	23.3





# Environmental Monitoring System

## DATA REPORT

### STERILE EXIT CHANGE ROOMS (L3)

Date Time	STERILE PASSAGE (L3) wrt EXIT ROOM-1 (L3)	STERILE EXIT ROOM-1 (L3)	ASEPTIC EXIT ROOM-1 (L3) wrt EXIT ROOM-2 (L3)	STERILE EXIT ROOM-2 (L3)	ASEPTIC EXIT ROOM-2 (L3) wrt EXIT ROOM-3 (L3)	STERILE EXIT ROOM-3 (L3)
Date Time	DP Pa	°C TEMP	DP Pa	°C TEMP	DP Pa	°C TEMP
04-11-2021 07:25	19	22.6	16	23.1	21	23.2
04-11-2021 07:26	21	22.6	15	23.1	20	23.2
04-11-2021 07:27	21	22.7	16	23.1	21	23.3
04-11-2021 07:28	20	22.6	16	23.1	20	23.2
04-11-2021 07:29	21	22.6	15	23.0	21	23.2
04-11-2021 07:30	20	22.6	16	23.0	20	23.2
04-11-2021 07:31	20	22.6	16	23.0	21	23.2
04-11-2021 07:32	21	22.6	16	23.0	21	23.2
04-11-2021 07:33	21	22.6	16	23.0	20	23.2
04-11-2021 07:34	21	22.5	16	23.0	20	23.2
04-11-2021 07:35	21	22.5	16	23.0	21	23.2
04-11-2021 07:36	20	22.5	16	23.0	21	23.2
04-11-2021 07:37	20	22.5	15	23.0	20	23.2
04-11-2021 07:38	20	22.5	15	23.0	20	23.2
04-11-2021 07:39	21	22.5	15	23.0	20	23.2
04-11-2021 07:40	20	22.5	16	23.0	21	23.2
04-11-2021 07:41	21	22.5	16	23.0	20	23.1
04-11-2021 07:42	20	22.5	16	22.9	20	23.1
04-11-2021 07:43	20	22.5	15	22.9	21	23.1
04-11-2021 07:44	21	22.5	16	22.9	21	23.1
04-11-2021 07:45	20	22.5	16	22.9	21	23.1
04-11-2021 07:46	20	22.5	16	22.9	20	23.1
04-11-2021 07:47	21	22.5	16	22.9	20	23.1
04-11-2021 07:48	20	22.5	15	22.9	20	23.1
04-11-2021 07:49	20	22.5	15	22.9	20	23.1
04-11-2021 07:50	20	22.5	15	22.9	21	23.1
04-11-2021 07:51	20	22.5	16	22.9	20	23.1
04-11-2021 07:52	20	22.5	16	22.9	21	23.1



# Environmental Monitoring System

## DATA REPORT

### STERILE EXIT CHANGE ROOMS (L3)

Date Time	STERILE PASSAGE (L3) wrt EXIT ROOM-1 (L3)	STERILE EXIT ROOM-1 (L3)	ASEPTIC EXIT ROOM-1 (L3) wrt EXIT ROOM-2 (L3)	STERILE EXIT ROOM-2 (L3)	ASEPTIC EXIT ROOM-2 (L3) wrt EXIT ROOM-3 (L3)	STERILE EXIT ROOM-3 (L3)
Date Time	DP Pa	°C TEMP	DP Pa	°C TEMP	DP Pa	°C TEMP
04-11-2021 07:53	20	22.4	16	22.9	20	23.1
04-11-2021 07:54	20	22.4	16	22.9	20	23.1
04-11-2021 07:55	21	22.5	15	22.9	20	23.1
04-11-2021 07:56	21	22.4	15	22.9	20	23.1
04-11-2021 07:57	20	22.5	16	22.9	20	23.1
04-11-2021 07:58	21	22.4	16	22.9	20	23.1
04-11-2021 07:59	20	22.5	15	22.9	20	23.1
04-11-2021 08:00	20	22.4	16	22.9	20	23.1
04-11-2021 08:01	21	22.5	15	22.9	20	23.1
04-11-2021 08:02	21	22.4	16	22.9	22	23.1
04-11-2021 08:03	21	22.4	16	22.9	21	23.1
04-11-2021 08:04	20	22.4	16	22.9	20	23.1
04-11-2021 08:05	20	22.4	15	22.9	20	23.1
04-11-2021 08:06	20	22.4	15	22.9	20	23.1
04-11-2021 08:07	20	22.4	16	22.8	20	23.1
04-11-2021 08:08	20	22.4	15	22.8	20	23.1
04-11-2021 08:09	20	22.4	15	22.8	20	23.0
04-11-2021 08:10	20	22.4	15	22.8	20	23.0
04-11-2021 08:11	20	22.3	15	22.8	20	23.0
04-11-2021 08:12	20	22.3	15	22.8	20	23.0
04-11-2021 08:13	20	22.3	15	22.8	20	23.0
04-11-2021 08:14	20	22.3	15	22.8	20	23.0
04-11-2021 08:15	20	22.3	16	22.7	21	23.0
04-11-2021 08:16	20	22.2	15	22.7	20	23.0
04-11-2021 08:17	20	22.2	16	22.7	21	23.0
04-11-2021 08:18	20	22.2	15	22.7	20	23.0
04-11-2021 08:19	21	22.2	15	22.7	20	23.0
04-11-2021 08:20	22	22.2	15	22.7	21	23.0



# Environmental Monitoring System

## DATA REPORT

### STERILE EXIT CHANGE ROOMS (L3)

Date Time	STERILE PASSAGE (L3) wrt EXIT ROOM-1 (L3)	STERILE EXIT ROOM-1 (L3)	ASEPTIC EXIT ROOM-1 (L3) wrt EXIT ROOM-2 (L3)	STERILE EXIT ROOM-2 (L3)	ASEPTIC EXIT ROOM-2 (L3) wrt EXIT ROOM-3 (L3)	STERILE EXIT ROOM-3 (L3)
Date Time	DP Pa	°C TEMP	DP Pa	°C TEMP	DP Pa	°C TEMP
04-11-2021 08:21	20	22.2	15	22.7	20	23.0
04-11-2021 08:22	20	22.2	16	22.7	20	23.0
04-11-2021 08:23	21	22.2	16	22.7	20	22.9
04-11-2021 08:24	20	22.2	16	22.7	20	22.9
04-11-2021 08:25	20	22.2	15	22.7	20	22.9
04-11-2021 08:26	19	22.2	15	22.7	20	22.9
04-11-2021 08:27	21	22.3	15	22.7	20	22.9
04-11-2021 08:28	20	22.3	15	22.8	20	22.9
04-11-2021 08:29	20	22.3	15	22.8	20	22.9
04-11-2021 08:30	21	22.3	16	22.8	21	23.0
04-11-2021 08:31	20	22.3	16	22.8	20	23.0
04-11-2021 08:32	20	22.3	16	22.8	20	23.0
04-11-2021 08:33	20	22.4	15	22.8	20	23.0
04-11-2021 08:34	20	22.4	15	22.8	21	23.0
04-11-2021 08:35	20	22.4	16	22.9	21	23.0
04-11-2021 08:36	20	22.4	15	22.9	20	23.0
04-11-2021 08:37	20	22.4	16	22.9	19	23.0
04-11-2021 08:38	20	22.4	15	22.9	20	23.0
04-11-2021 08:39	20	22.4	16	22.9	20	23.0
04-11-2021 08:40	20	22.4	16	22.9	20	23.0
04-11-2021 08:41	21	22.4	15	22.9	20	23.0
04-11-2021 08:42	20	22.4	16	22.9	20	23.0
04-11-2021 08:43	20	22.4	16	22.9	21	23.0
04-11-2021 08:44	20	22.5	16	22.9	20	23.0
04-11-2021 08:45	21	22.5	16	22.9	20	23.0
04-11-2021 08:46	20	22.5	16	22.9	19	23.0
04-11-2021 08:47	19	22.5	15	22.9	20	23.0
04-11-2021 08:48	18	22.5	15	22.9	20	23.0



# Environmental Monitoring System

## DATA REPORT

### STERILE EXIT CHANGE ROOMS (L3)

Date Time	STERILE PASSAGE (L3) wrt EXIT ROOM-1 (L3)	STERILE EXIT ROOM-1 (L3)	ASEPTIC EXIT ROOM-1 (L3) wrt EXIT ROOM-2 (L3)	STERILE EXIT ROOM-2 (L3)	ASEPTIC EXIT ROOM-2 (L3) wrt EXIT ROOM-3 (L3)	STERILE EXIT ROOM-3 (L3)
Date Time	DP Pa	°C TEMP	DP Pa	°C TEMP	DP Pa	°C TEMP
04-11-2021 08:49	21	22.5	15	23.0	20	23.1
04-11-2021 08:50	20	22.5	16	23.0	20	23.0
04-11-2021 08:51	20	22.5	15	23.0	20	23.0
04-11-2021 08:52	21	22.5	16	23.0	20	23.1
04-11-2021 08:53	20	22.5	15	23.0	20	23.1
04-11-2021 08:54	21	22.5	16	23.0	20	23.1
04-11-2021 08:55	20	22.5	16	23.0	20	23.1
04-11-2021 08:56	20	22.6	16	23.0	20	23.1
04-11-2021 08:57	20	22.6	15	23.0	20	23.1
04-11-2021 08:58	20	22.6	15	23.0	20	23.1
04-11-2021 08:59	20	22.6	16	23.0	20	23.1
04-11-2021 09:00	20	22.6	15	23.0	21	23.1
04-11-2021 09:01	21	22.6	16	23.0	21	23.1
04-11-2021 09:02	19	22.6	16	23.0	20	23.1
04-11-2021 09:03	20	22.6	15	23.0	20	23.1
04-11-2021 09:04	21	22.6	16	23.0	21	23.1
04-11-2021 09:05	20	22.6	15	23.0	20	23.1
04-11-2021 09:06	20	22.6	16	23.0	21	23.1
04-11-2021 09:07	20	22.6	15	23.0	20	23.1
04-11-2021 09:08	20	22.6	15	23.0	20	23.1
04-11-2021 09:09	21	22.6	15	23.0	20	23.1
04-11-2021 09:10	21	22.6	16	23.0	21	23.1
04-11-2021 09:11	20	22.6	16	23.0	21	23.1
04-11-2021 09:12	21	22.6	16	23.0	21	23.1
04-11-2021 09:13	20	22.5	16	23.0	20	23.1
04-11-2021 09:14	21	22.5	16	23.0	21	23.1
04-11-2021 09:15	20	22.6	15	23.0	20	23.1
04-11-2021 09:16	19	22.5	16	23.0	19	23.1



# Environmental Monitoring System

## DATA REPORT

### STERILE EXIT CHANGE ROOMS (L3)

Date Time	STERILE PASSAGE (L3) wrt EXIT ROOM-1 (L3)	STERILE EXIT ROOM-1 (L3)	ASEPTIC EXIT ROOM-1 (L3) wrt EXIT ROOM-2 (L3)	STERILE EXIT ROOM-2 (L3)	ASEPTIC EXIT ROOM-2 (L3) wrt EXIT ROOM-3 (L3)	STERILE EXIT ROOM-3 (L3)
Date Time	DP Pa	°C TEMP	DP Pa	°C TEMP	DP Pa	°C TEMP
04-11-2021 09:17	21	22.5	16	22.9	20	23.1
04-11-2021 09:18	20	22.5	17	22.9	20	23.1
04-11-2021 09:19	21	22.5	16	22.9	21	23.1
04-11-2021 09:20	20	22.4	16	22.9	20	23.1
04-11-2021 09:21	20	22.4	16	22.9	21	23.1
04-11-2021 09:22	19	22.4	16	22.8	21	23.1
04-11-2021 09:23	21	22.3	16	22.8	20	23.1
04-11-2021 09:24	21	22.3	16	22.8	21	23.1
04-11-2021 09:25	20	22.3	16	22.8	20	23.0
04-11-2021 09:26	20	22.3	16	22.8	20	23.0
04-11-2021 09:27	20	22.3	16	22.7	20	23.0
04-11-2021 09:28	20	22.2	16	22.7	20	23.0
04-11-2021 09:29	20	22.2	16	22.7	21	23.0
04-11-2021 09:30	21	22.2	16	22.7	20	23.0
04-11-2021 09:31	20	22.2	16	22.6	20	22.9
04-11-2021 09:32	22	22.2	18	22.6	20	22.9
04-11-2021 09:33	20	22.1	16	22.6	21	22.9
04-11-2021 09:34	20	22.1	16	22.6	20	22.9
04-11-2021 09:35	21	22.1	16	22.6	21	22.9
04-11-2021 09:36	21	22.1	16	22.6	20	22.9
04-11-2021 09:37	20	22.1	16	22.6	20	22.9
04-11-2021 09:38	20	22.1	15	22.6	21	22.9
04-11-2021 09:39	20	22.1	16	22.6	21	22.9
04-11-2021 09:40	19	22.1	15	22.6	21	22.9
04-11-2021 09:41	21	22.1	16	22.6	21	22.9
04-11-2021 09:42	22	22.1	16	22.6	21	22.9
04-11-2021 09:43	20	22.1	16	22.6	21	22.9
04-11-2021 09:44	18	22.1	16	22.6	20	22.9



# Environmental Monitoring System

## DATA REPORT

### STERILE EXIT CHANGE ROOMS (L3)

Date Time	STERILE PASSAGE (L3) wrt EXIT ROOM-1 (L3)	STERILE EXIT ROOM-1 (L3)	ASEPTIC EXIT ROOM-1 (L3) wrt EXIT ROOM-2 (L3)	STERILE EXIT ROOM-2 (L3)	ASEPTIC EXIT ROOM-2 (L3) wrt EXIT ROOM-3 (L3)	STERILE EXIT ROOM-3 (L3)
Date Time	DP Pa	°C TEMP	DP Pa	°C TEMP	DP Pa	°C TEMP
04-11-2021 09:45	23	22.1	17	22.6	21	22.9
04-11-2021 09:46	20	22.1	16	22.6	20	22.9
04-11-2021 09:47	20	22.1	15	22.6	20	22.9
04-11-2021 09:48	23	22.1	16	22.6	21	22.9
04-11-2021 09:49	21	22.2	15	22.6	21	22.9
04-11-2021 09:50	20	22.2	15	22.7	20	22.9
04-11-2021 09:51	19	22.2	16	22.7	20	22.9
04-11-2021 09:52	24	22.2	16	22.7	20	22.9
04-11-2021 09:53	20	22.2	16	22.7	20	22.9
04-11-2021 09:54	20	22.2	16	22.7	20	22.9
04-11-2021 09:55	20	22.2	15	22.7	20	22.9
04-11-2021 09:56	20	22.2	16	22.7	20	22.9
04-11-2021 09:57	0	22.3	23	22.8	24	22.9
04-11-2021 09:58	21	22.3	16	22.8	21	22.9
04-11-2021 09:59	21	22.3	16	22.8	22	22.9
04-11-2021 10:00	20	22.3	16	22.8	21	22.9
04-11-2021 10:01	21	22.3	16	22.8	20	22.9
04-11-2021 10:02	20	22.3	15	22.8	20	22.9
04-11-2021 10:03	19	22.3	15	22.8	20	23.0
04-11-2021 10:04	19	22.3	16	22.8	20	23.0
04-11-2021 10:05	20	22.4	16	22.9	20	23.0
04-11-2021 10:06	21	22.4	16	22.9	20	23.0
04-11-2021 10:07	20	22.4	15	22.9	20	23.0
04-11-2021 10:08	24	22.4	18	22.9	21	23.0
04-11-2021 10:09	20	22.4	16	22.9	20	23.0
04-11-2021 10:10	21	22.4	16	22.9	20	23.0
04-11-2021 10:11	20	22.4	15	22.9	20	23.0
04-11-2021 10:12	19	22.4	15	22.9	20	23.0



# Environmental Monitoring System

## DATA REPORT

### STERILE EXIT CHANGE ROOMS (L3)

Date Time	STERILE PASSAGE (L3) wrt EXIT ROOM-1 (L3)	STERILE EXIT ROOM-1 (L3)	ASEPTIC EXIT ROOM-1 (L3) wrt EXIT ROOM-2 (L3)	STERILE EXIT ROOM-2 (L3)	ASEPTIC EXIT ROOM-2 (L3) wrt EXIT ROOM-3 (L3)	STERILE EXIT ROOM-3 (L3)
Date Time	DP Pa	°C TEMP	DP Pa	°C TEMP	DP Pa	°C TEMP
04-11-2021 10:13	20	22.4	16	22.9	21	23.0
04-11-2021 10:14	20	22.4	16	22.9	20	23.0
04-11-2021 10:15	20	22.4	15	22.9	20	23.0
04-11-2021 10:16	21	22.5	15	22.9	20	23.0
04-11-2021 10:17	20	22.4	15	22.9	20	23.0
04-11-2021 10:18	20	22.5	16	22.9	20	23.0
04-11-2021 10:19	18	22.5	16	22.9	21	23.0
04-11-2021 10:20	20	22.5	16	22.9	20	23.0
04-11-2021 10:21	20	22.5	15	22.9	20	23.0
04-11-2021 10:22	21	22.5	17	23.0	21	23.0
04-11-2021 10:23	20	22.5	16	22.9	20	23.0
04-11-2021 10:24	20	22.5	15	22.9	20	23.0
04-11-2021 10:25	20	22.5	16	22.9	21	23.1
04-11-2021 10:26	18	22.4	15	22.9	20	23.0
04-11-2021 10:27	18	22.4	15	22.9	20	23.0
04-11-2021 10:28	19	22.4	15	22.9	20	23.0
04-11-2021 10:29	18	22.4	16	22.8	20	23.0
04-11-2021 10:30	20	22.4	16	22.8	21	23.0
04-11-2021 10:31	20	22.4	15	22.8	20	23.0
04-11-2021 10:32	19	22.4	16	22.8	21	23.0
04-11-2021 10:33	21	22.3	16	22.8	20	23.0
04-11-2021 10:34	20	22.3	16	22.8	20	23.0
04-11-2021 10:35	21	22.3	15	22.8	20	23.0
04-11-2021 10:36	20	22.3	16	22.8	20	23.0
04-11-2021 10:37	18	22.3	16	22.8	20	23.0
04-11-2021 10:38	19	22.3	16	22.7	20	23.0
04-11-2021 10:39	6	22.3	10	22.7	25	23.0
04-11-2021 10:40	21	22.3	15	22.7	20	23.0



# Environmental Monitoring System

## DATA REPORT

### STERILE EXIT CHANGE ROOMS (L3)

Date Time	STERILE PASSAGE (L3) wrt EXIT ROOM-1 (L3)	STERILE EXIT ROOM-1 (L3)	ASEPTIC EXIT ROOM-1 (L3) wrt EXIT ROOM-2 (L3)	STERILE EXIT ROOM-2 (L3)	ASEPTIC EXIT ROOM-2 (L3) wrt EXIT ROOM-3 (L3)	STERILE EXIT ROOM-3 (L3)
Date Time	DP Pa	°C TEMP	DP Pa	°C TEMP	DP Pa	°C TEMP
04-11-2021 10:41	20	22.3	16	22.7	23	23.0
04-11-2021 10:42	20	22.2	16	22.7	22	23.0
04-11-2021 10:43	23	22.2	16	22.7	22	22.9
04-11-2021 10:44	20	22.2	16	22.7	21	22.9
04-11-2021 10:45	21	22.2	16	22.7	21	22.9
04-11-2021 10:46	20	22.1	16	22.7	21	22.9
04-11-2021 10:47	21	22.2	17	22.7	22	22.9
04-11-2021 10:48	20	22.1	16	22.7	21	22.9
04-11-2021 10:49	20	22.1	15	22.6	21	22.9
04-11-2021 10:50	21	22.1	16	22.6	21	22.9
04-11-2021 10:51	21	22.1	16	22.6	21	22.9
04-11-2021 10:52	21	22.1	17	22.6	20	22.9
04-11-2021 10:53	20	22.0	16	22.6	21	22.8
04-11-2021 10:54	20	22.0	17	22.6	21	22.8
04-11-2021 10:55	21	22.0	16	22.5	21	22.8
04-11-2021 10:56	20	22.0	16	22.5	22	22.8
04-11-2021 10:57	21	22.0	16	22.5	21	22.8
04-11-2021 10:58	21	22.0	18	22.5	21	22.8
04-11-2021 10:59	21	22.0	16	22.5	20	22.8
04-11-2021 11:00	21	22.0	16	22.5	21	22.8
04-11-2021 11:01	22	22.0	16	22.5	21	22.8
04-11-2021 11:02	20	22.0	16	22.5	21	22.8
04-11-2021 11:03	21	22.0	16	22.5	21	22.8
04-11-2021 11:04	20	22.1	16	22.6	21	22.8
04-11-2021 11:05	20	22.1	16	22.6	21	22.8
04-11-2021 11:06	19	22.1	16	22.6	21	22.8
04-11-2021 11:07	21	22.1	16	22.6	20	22.8
04-11-2021 11:08	22	22.1	17	22.6	22	22.8





# Environmental Monitoring System

## DATA REPORT

### STERILE EXIT CHANGE ROOMS (L3)

Date Time	STERILE PASSAGE (L3) wrt EXIT ROOM-1 (L3)	STERILE EXIT ROOM-1 (L3)	ASEPTIC EXIT ROOM-1 (L3) wrt EXIT ROOM-2 (L3)	STERILE EXIT ROOM-2 (L3)	ASEPTIC EXIT ROOM-2 (L3) wrt EXIT ROOM-3 (L3)	STERILE EXIT ROOM-3 (L3)
Date Time	DP Pa	°C TEMP	DP Pa	°C TEMP	DP Pa	°C TEMP
04-11-2021 11:09	21	22.1	16	22.6	21	22.8
04-11-2021 11:10	21	22.1	17	22.6	21	22.8
04-11-2021 11:11	22	22.2	17	22.6	21	22.8
04-11-2021 11:12	21	22.2	17	22.7	21	22.8
04-11-2021 11:13	21	22.2	16	22.7	22	22.8
04-11-2021 11:14	22	22.2	17	22.7	21	22.8
04-11-2021 11:15	22	22.2	17	22.7	22	22.8
04-11-2021 11:16	22	22.2	16	22.7	22	22.8
04-11-2021 11:17	21	22.3	17	22.7	21	22.9
04-11-2021 11:18	22	22.3	16	22.8	22	22.9
04-11-2021 11:19	21	22.3	16	22.8	21	22.9
04-11-2021 11:20	21	22.3	17	22.8	20	22.9
04-11-2021 11:21	21	22.3	18	22.8	22	22.9
04-11-2021 11:22	22	22.3	17	22.8	21	22.9
04-11-2021 11:23	22	22.3	16	22.8	21	22.9
04-11-2021 11:24	21	22.4	18	22.9	22	22.9
04-11-2021 11:25	22	22.4	17	22.9	22	22.9
04-11-2021 11:26	21	22.4	18	22.9	21	22.9
04-11-2021 11:27	21	22.4	18	22.9	22	22.9
04-11-2021 11:28	22	22.5	17	22.9	21	22.9
04-11-2021 11:29	23	22.5	17	22.9	21	22.9
04-11-2021 11:30	21	22.5	16	22.9	21	23.0
04-11-2021 11:31	21	22.5	17	23.0	20	23.0
04-11-2021 11:32	21	22.5	17	23.0	21	23.0
04-11-2021 11:33	21	22.5	17	23.0	22	23.0
04-11-2021 11:34	21	22.5	16	23.0	21	23.0
04-11-2021 11:35	23	22.5	16	23.0	21	23.0
04-11-2021 11:36	23	22.5	17	23.0	21	23.0



# Environmental Monitoring System

## DATA REPORT

### STERILE EXIT CHANGE ROOMS (L3)

Date Time	STERILE PASSAGE (L3) wrt EXIT ROOM-1 (L3)	STERILE EXIT ROOM-1 (L3)	ASEPTIC EXIT ROOM-1 (L3) wrt EXIT ROOM-2 (L3)	STERILE EXIT ROOM-2 (L3)	ASEPTIC EXIT ROOM-2 (L3) wrt EXIT ROOM-3 (L3)	STERILE EXIT ROOM-3 (L3)
Date Time	DP Pa	°C TEMP	DP Pa	°C TEMP	DP Pa	°C TEMP
04-11-2021 11:37	22	22.5	17	23.0	22	23.0
04-11-2021 11:38	21	22.5	17	23.0	22	23.0
04-11-2021 11:39	21	22.5	17	23.0	22	23.0
04-11-2021 11:40	23	22.5	18	23.0	21	23.0
04-11-2021 11:41	21	22.5	17	23.0	21	23.0
04-11-2021 11:42	21	22.5	16	23.0	21	23.0
04-11-2021 11:43	23	22.5	20	22.9	25	23.0
04-11-2021 11:44	23	22.5	20	22.9	25	23.0
04-11-2021 11:45	20	22.5	16	22.9	22	23.0
04-11-2021 11:46	20	22.4	16	22.9	21	23.0
04-11-2021 11:47	21	22.4	17	22.9	20	23.0
04-11-2021 11:48	23	22.3	18	22.8	23	23.0
04-11-2021 11:49	22	22.3	16	22.8	21	23.0
04-11-2021 11:50	21	22.3	18	22.8	22	23.0
04-11-2021 11:51	25	22.3	18	22.8	23	23.0
04-11-2021 11:52	23	22.2	18	22.7	21	23.0
04-11-2021 11:53	21	22.2	16	22.7	22	22.9
04-11-2021 11:54	21	22.2	16	22.7	21	22.9
04-11-2021 11:55	21	22.2	16	22.7	21	22.9
04-11-2021 11:56	20	22.1	16	22.6	20	22.9
04-11-2021 11:57	22	22.1	17	22.6	21	22.9
04-11-2021 11:58	20	22.1	16	22.6	21	22.9
04-11-2021 11:59	21	22.1	16	22.6	21	22.9
04-11-2021 12:00	20	22.1	16	22.6	21	22.9
04-11-2021 12:01	20	22.1	16	22.6	21	22.9
04-11-2021 12:02	20	22.0	16	22.6	20	22.8
04-11-2021 12:03	20	22.0	16	22.5	21	22.8
04-11-2021 12:04	20	22.0	17	22.5	22	22.8



# Environmental Monitoring System

## DATA REPORT

### STERILE EXIT CHANGE ROOMS (L3)

Date Time	STERILE PASSAGE (L3) wrt EXIT ROOM-1 (L3)	STERILE EXIT ROOM-1 (L3)	ASEPTIC EXIT ROOM-1 (L3) wrt EXIT ROOM-2 (L3)	STERILE EXIT ROOM-2 (L3)	ASEPTIC EXIT ROOM-2 (L3) wrt EXIT ROOM-3 (L3)	STERILE EXIT ROOM-3 (L3)
Date Time	DP Pa	°C TEMP	DP Pa	°C TEMP	DP Pa	°C TEMP
04-11-2021 12:05	21	22.0	16	22.5	21	22.8
04-11-2021 12:06	21	22.0	16	22.5	21	22.8
04-11-2021 12:07	20	22.0	16	22.5	21	22.8
04-11-2021 12:08	20	22.1	16	22.5	21	22.8
04-11-2021 12:09	21	22.0	16	22.5	20	22.8
04-11-2021 12:10	21	22.0	16	22.5	21	22.8
04-11-2021 12:11	21	22.1	16	22.6	21	22.8
04-11-2021 12:12	21	22.0	16	22.6	20	22.8
04-11-2021 12:13	20	22.1	16	22.6	21	22.8
04-11-2021 12:14	19	22.1	16	22.6	20	22.8
04-11-2021 12:15	20	22.1	16	22.6	21	22.8
04-11-2021 12:16	20	22.1	16	22.6	21	22.8
04-11-2021 12:17	20	22.1	16	22.6	21	22.8
04-11-2021 12:18	20	22.1	16	22.6	21	22.8
04-11-2021 12:19	21	22.1	16	22.7	21	22.8
04-11-2021 12:20	33	22.1	13	22.7	11	22.8
04-11-2021 12:21	20	22.1	16	22.7	21	22.9
04-11-2021 12:22	20	22.2	16	22.7	21	22.9
04-11-2021 12:23	20	22.2	16	22.7	21	22.9
04-11-2021 12:24	20	22.2	16	22.7	21	23.0
04-11-2021 12:25	20	22.2	16	22.8	20	23.0
04-11-2021 12:26	21	22.2	17	22.8	21	23.0
04-11-2021 12:27	19	22.2	16	22.8	21	23.0
04-11-2021 12:28	21	22.3	16	22.8	21	23.0
04-11-2021 12:29	20	22.3	15	22.8	20	23.0
04-11-2021 12:30	21	22.3	17	22.8	22	23.0
04-11-2021 12:31	20	22.3	16	22.8	21	23.0
04-11-2021 12:32	21	22.3	16	22.8	21	23.0



# Environmental Monitoring System

## DATA REPORT

### STERILE EXIT CHANGE ROOMS (L3)

Date Time	STERILE PASSAGE (L3) wrt EXIT ROOM-1 (L3)	STERILE EXIT ROOM-1 (L3)	ASEPTIC EXIT ROOM-1 (L3) wrt EXIT ROOM-2 (L3)	STERILE EXIT ROOM-2 (L3)	ASEPTIC EXIT ROOM-2 (L3) wrt EXIT ROOM-3 (L3)	STERILE EXIT ROOM-3 (L3)
Date Time	DP Pa	°C TEMP	DP Pa	°C TEMP	DP Pa	°C TEMP
04-11-2021 12:33	20	22.4	16	22.8	21	23.0
04-11-2021 12:34	21	22.4	16	22.9	21	23.0
04-11-2021 12:35	20	22.4	16	22.9	21	23.0
04-11-2021 12:36	20	22.4	15	22.9	20	23.0
04-11-2021 12:37	20	22.4	16	22.9	21	23.0
04-11-2021 12:38	21	22.4	16	22.9	21	23.0
04-11-2021 12:39	20	22.4	16	22.9	21	23.0
04-11-2021 12:40	20	22.4	16	22.9	21	23.0
04-11-2021 12:41	21	22.4	16	22.9	21	23.0
04-11-2021 12:42	21	22.4	15	22.9	20	23.0
04-11-2021 12:43	24	22.4	16	22.9	21	23.0
04-11-2021 12:44	22	22.4	16	22.9	20	23.0
04-11-2021 12:45	21	22.4	16	22.9	22	23.0
04-11-2021 12:46	21	22.3	16	22.8	21	23.0
04-11-2021 12:47	21	22.4	16	22.8	21	23.0
04-11-2021 12:48	21	22.3	16	22.8	21	23.0
04-11-2021 12:49	22	22.3	16	22.8	22	23.0
04-11-2021 12:50	21	22.3	16	22.8	20	23.0
04-11-2021 12:51	20	22.3	16	22.8	22	23.0
04-11-2021 12:52	21	22.2	16	22.7	21	23.0
04-11-2021 12:53	20	22.2	16	22.7	21	23.0
04-11-2021 12:54	20	22.2	16	22.7	21	22.9
04-11-2021 12:55	20	22.2	16	22.7	20	23.0
04-11-2021 12:56	20	22.2	16	22.7	21	23.0
04-11-2021 12:57	20	22.1	16	22.6	21	22.9
04-11-2021 12:58	20	22.1	16	22.6	21	22.9
04-11-2021 12:59	20	22.1	16	22.6	20	22.9
04-11-2021 13:00	21	22.1	16	22.6	21	22.9



# Environmental Monitoring System

## DATA REPORT

### STERILE EXIT CHANGE ROOMS (L3)

Date Time	STERILE PASSAGE (L3) wrt EXIT ROOM-1 (L3)	STERILE EXIT ROOM-1 (L3)	ASEPTIC EXIT ROOM-1 (L3) wrt EXIT ROOM-2 (L3)	STERILE EXIT ROOM-2 (L3)	ASEPTIC EXIT ROOM-2 (L3) wrt EXIT ROOM-3 (L3)	STERILE EXIT ROOM-3 (L3)
Date Time	DP Pa	°C TEMP	DP Pa	°C TEMP	DP Pa	°C TEMP
04-11-2021 13:01	20	22.1	17	22.6	21	22.9
04-11-2021 13:02	21	22.1	16	22.6	20	22.9
04-11-2021 13:03	20	22.1	16	22.5	21	22.9
04-11-2021 13:04	21	22.1	16	22.5	20	22.8
04-11-2021 13:05	20	22.0	16	22.5	21	22.8
04-11-2021 13:06	20	22.0	16	22.5	21	22.8
04-11-2021 13:07	20	22.0	16	22.5	21	22.8
04-11-2021 13:08	21	22.0	16	22.5	20	22.8
04-11-2021 13:09	20	22.0	15	22.5	21	22.8
04-11-2021 13:10	21	22.0	16	22.5	20	22.8
04-11-2021 13:11	20	22.0	15	22.5	21	22.8
04-11-2021 13:12	21	22.0	16	22.5	21	22.8
04-11-2021 13:13	20	22.0	16	22.5	21	22.8
04-11-2021 13:14	20	22.0	16	22.5	21	22.8
04-11-2021 13:15	21	22.0	15	22.6	21	22.8
04-11-2021 13:16	21	22.1	16	22.6	21	22.8
04-11-2021 13:17	19	22.1	16	22.6	21	22.8
04-11-2021 13:18	20	22.1	16	22.6	22	22.8
04-11-2021 13:19	20	22.1	16	22.6	21	22.8
04-11-2021 13:20	20	22.1	16	22.6	21	22.8
04-11-2021 13:21	20	22.1	15	22.6	21	22.8
04-11-2021 13:22	20	22.1	16	22.7	21	22.8
04-11-2021 13:23	21	22.1	16	22.7	21	22.8
04-11-2021 13:24	21	22.2	15	22.7	20	22.8
04-11-2021 13:25	21	22.2	17	22.7	21	22.9
04-11-2021 13:26	21	22.2	16	22.7	21	22.9
04-11-2021 13:27	21	22.2	11	22.7	18	22.9
04-11-2021 13:28	21	22.2	16	22.7	21	22.9



# Environmental Monitoring System

## DATA REPORT

### STERILE EXIT CHANGE ROOMS (L3)

Date Time	STERILE PASSAGE (L3) wrt EXIT ROOM-1 (L3)	STERILE EXIT ROOM-1 (L3)	ASEPTIC EXIT ROOM-1 (L3) wrt EXIT ROOM-2 (L3)	STERILE EXIT ROOM-2 (L3)	ASEPTIC EXIT ROOM-2 (L3) wrt EXIT ROOM-3 (L3)	STERILE EXIT ROOM-3 (L3)
Date Time	DP Pa	°C TEMP	DP Pa	°C TEMP	DP Pa	°C TEMP
04-11-2021 13:29	20	22.2	16	22.8	21	22.9
04-11-2021 13:30	21	22.2	15	22.8	20	22.9
04-11-2021 13:31	20	22.2	16	22.8	20	22.9
04-11-2021 13:32	21	22.3	16	22.8	21	22.9
04-11-2021 13:33	20	22.3	16	22.8	21	22.9
04-11-2021 13:34	20	22.3	16	22.8	21	22.9
04-11-2021 13:35	21	22.3	15	22.8	19	23.0
04-11-2021 13:36	21	22.3	16	22.9	21	23.0
04-11-2021 13:37	20	22.3	16	22.9	21	22.9
04-11-2021 13:38	21	22.3	16	22.9	21	23.0
04-11-2021 13:39	21	22.3	16	22.9	22	23.0
04-11-2021 13:40	20	22.4	16	22.9	20	23.0
04-11-2021 13:41	20	22.3	16	22.9	21	23.0
04-11-2021 13:42	20	22.3	15	22.9	20	23.0
04-11-2021 13:43	20	22.3	16	22.9	21	23.0
04-11-2021 13:44	21	22.4	16	22.9	21	23.0
04-11-2021 13:45	23	22.3	19	22.9	24	23.0
04-11-2021 13:46	23	22.3	18	22.9	23	23.0
04-11-2021 13:47	22	22.4	17	22.9	22	23.0
04-11-2021 13:48	20	22.3	17	22.9	23	23.0
04-11-2021 13:49	20	22.3	17	22.8	21	23.0
04-11-2021 13:50	21	22.3	17	22.8	23	23.0
04-11-2021 13:51	20	22.2	18	22.8	23	23.0
04-11-2021 13:52	23	22.2	19	22.8	24	23.0
04-11-2021 13:53	24	22.2	19	22.8	24	23.0
04-11-2021 13:54	23	22.2	19	22.8	25	23.0
04-11-2021 13:55	23	22.2	19	22.7	24	23.0
04-11-2021 13:56	21	22.2	18	22.7	23	23.0



# Environmental Monitoring System

## DATA REPORT

### STERILE EXIT CHANGE ROOMS (L3)

Date Time	STERILE PASSAGE (L3) wrt EXIT ROOM-1 (L3)	STERILE EXIT ROOM-1 (L3)	ASEPTIC EXIT ROOM-1 (L3) wrt EXIT ROOM-2 (L3)	STERILE EXIT ROOM-2 (L3)	ASEPTIC EXIT ROOM-2 (L3) wrt EXIT ROOM-3 (L3)	STERILE EXIT ROOM-3 (L3)
Date Time	DP Pa	°C TEMP	DP Pa	°C TEMP	DP Pa	°C TEMP
04-11-2021 13:57	24	22.1	19	22.7	24	23.0
04-11-2021 13:58	21	22.1	16	22.7	22	22.9
04-11-2021 13:59	21	22.1	17	22.6	23	22.9
04-11-2021 14:00	21	22.1	17	22.6	21	22.9
04-11-2021 14:01	21	22.0	17	22.6	22	22.9
04-11-2021 14:02	20	22.0	16	22.5	21	22.9
04-11-2021 14:03	21	22.0	16	22.5	21	22.9
04-11-2021 14:04	20	21.9	16	22.5	21	22.9
04-11-2021 14:05	20	21.9	16	22.5	21	22.9
04-11-2021 14:06	21	21.9	16	22.4	21	22.9
04-11-2021 14:07	20	21.9	16	22.4	21	22.8
04-11-2021 14:08	20	21.9	16	22.4	22	22.8
04-11-2021 14:09	21	21.9	17	22.4	21	22.8
04-11-2021 14:10	24	21.9	18	22.4	22	22.8
04-11-2021 14:11	20	21.9	16	22.4	21	22.8
04-11-2021 14:12	20	21.8	16	22.4	21	22.8
04-11-2021 14:13	21	21.8	16	22.4	21	22.8
04-11-2021 14:14	20	21.8	16	22.4	21	22.8
04-11-2021 14:15	21	21.8	16	22.4	21	22.8
04-11-2021 14:16	22	21.8	17	22.4	22	22.8
04-11-2021 14:17	23	21.8	18	22.4	21	22.8
04-11-2021 14:18	23	21.8	17	22.4	21	22.7
04-11-2021 14:19	20	21.8	17	22.4	21	22.7
04-11-2021 14:20	25	21.8	18	22.4	21	22.7
04-11-2021 14:21	20	21.8	16	22.4	21	22.7
04-11-2021 14:22	20	21.8	16	22.4	21	22.7
04-11-2021 14:23	20	21.9	14	22.4	20	22.7
04-11-2021 14:24	19	21.8	16	22.4	20	22.7



# Environmental Monitoring System

## DATA REPORT

### STERILE EXIT CHANGE ROOMS (L3)

Date Time	STERILE PASSAGE (L3) wrt EXIT ROOM-1 (L3)	STERILE EXIT ROOM-1 (L3)	ASEPTIC EXIT ROOM-1 (L3) wrt EXIT ROOM-2 (L3)	STERILE EXIT ROOM-2 (L3)	ASEPTIC EXIT ROOM-2 (L3) wrt EXIT ROOM-3 (L3)	STERILE EXIT ROOM-3 (L3)
Date Time	DP Pa	°C TEMP	DP Pa	°C TEMP	DP Pa	°C TEMP
04-11-2021 14:25	23	21.9	16	22.4	22	22.7
04-11-2021 14:26	21	21.9	15	22.4	21	22.7
04-11-2021 14:27	21	21.9	16	22.4	21	22.7
04-11-2021 14:28	20	21.9	16	22.4	21	22.7
04-11-2021 14:29	20	21.9	17	22.4	21	22.8
04-11-2021 14:30	20	21.9	16	22.5	21	22.7
04-11-2021 14:31	20	22.0	16	22.5	21	22.7
04-11-2021 14:32	20	22.0	16	22.5	20	22.8
04-11-2021 14:33	20	22.0	15	22.5	20	22.8
04-11-2021 14:34	20	22.0	16	22.5	22	22.8
04-11-2021 14:35	20	22.0	16	22.5	21	22.8
04-11-2021 14:36	21	22.1	16	22.6	21	22.8
04-11-2021 14:37	20	22.1	16	22.6	21	22.8
04-11-2021 14:38	21	22.1	16	22.6	21	22.8
04-11-2021 14:39	21	22.1	13	22.6	17	22.8
04-11-2021 14:40	22	22.1	19	22.6	23	22.8
04-11-2021 14:41	24	22.1	19	22.6	24	22.8
04-11-2021 14:42	21	22.2	18	22.7	23	22.8
04-11-2021 14:43	18	22.2	15	22.7	21	22.8
04-11-2021 14:44	28	22.2	18	22.7	22	22.9
04-11-2021 14:45	24	22.2	18	22.7	22	22.9
04-11-2021 14:46	23	22.3	19	22.7	25	22.9
04-11-2021 14:47	22	22.3	18	22.8	24	22.9
04-11-2021 14:48	20	22.3	18	22.8	22	22.9
04-11-2021 14:49	21	22.3	16	22.8	21	22.9
04-11-2021 14:50	21	22.3	17	22.8	21	22.9
04-11-2021 14:51	21	22.3	17	22.8	21	22.9
04-11-2021 14:52	21	22.4	16	22.8	23	22.9





# Environmental Monitoring System

## DATA REPORT

### STERILE EXIT CHANGE ROOMS (L3)

Date Time	STERILE PASSAGE (L3) wrt EXIT ROOM-1 (L3)	STERILE EXIT ROOM-1 (L3)	ASEPTIC EXIT ROOM-1 (L3) wrt EXIT ROOM-2 (L3)	STERILE EXIT ROOM-2 (L3)	ASEPTIC EXIT ROOM-2 (L3) wrt EXIT ROOM-3 (L3)	STERILE EXIT ROOM-3 (L3)
Date Time	DP Pa	°C TEMP	DP Pa	°C TEMP	DP Pa	°C TEMP
04-11-2021 14:53	21	22.4	17	22.9	21	22.9
04-11-2021 14:54	21	22.4	17	22.9	22	23.0
04-11-2021 14:55	21	22.4	17	22.9	23	23.0
04-11-2021 14:56	21	22.4	17	22.9	21	23.0
04-11-2021 14:57	20	22.4	17	22.9	23	23.0
04-11-2021 14:58	22	22.4	17	22.9	23	23.0
04-11-2021 14:59	21	22.4	17	22.9	22	23.0
04-11-2021 15:00	22	22.4	17	22.9	22	23.0
04-11-2021 15:01	21	22.4	16	22.9	22	23.0
04-11-2021 15:02	21	22.4	18	22.9	22	23.0
04-11-2021 15:03	21	22.3	18	22.9	21	23.0
04-11-2021 15:04	20	22.3	17	22.8	22	23.0
04-11-2021 15:05	20	22.3	17	22.8	23	23.0
04-11-2021 15:06	20	22.3	16	22.8	22	23.0
04-11-2021 15:07	21	22.3	17	22.8	21	23.0
04-11-2021 15:08	21	22.3	16	22.8	23	23.0
04-11-2021 15:09	21	22.2	18	22.8	22	23.0
04-11-2021 15:10	20	22.2	17	22.7	22	23.0
04-11-2021 15:11	21	22.2	17	22.7	22	23.0
04-11-2021 15:12	20	22.2	17	22.7	22	23.0
04-11-2021 15:13	21	22.1	17	22.7	22	23.0
04-11-2021 15:14	21	22.1	17	22.7	22	23.0
04-11-2021 15:15	21	22.1	17	22.6	22	23.0
04-11-2021 15:16	21	22.1	18	22.6	23	23.0
04-11-2021 15:17	21	22.1	17	22.6	23	22.9
04-11-2021 15:18	20	22.1	17	22.6	23	22.9
04-11-2021 15:19	21	22.1	17	22.6	23	22.9
04-11-2021 15:20	21	22.1	18	22.6	21	22.9



# Environmental Monitoring System

## DATA REPORT

### STERILE EXIT CHANGE ROOMS (L3)

Date Time	STERILE PASSAGE (L3) wrt EXIT ROOM-1 (L3)	STERILE EXIT ROOM-1 (L3)	ASEPTIC EXIT ROOM-1 (L3) wrt EXIT ROOM-2 (L3)	STERILE EXIT ROOM-2 (L3)	ASEPTIC EXIT ROOM-2 (L3) wrt EXIT ROOM-3 (L3)	STERILE EXIT ROOM-3 (L3)
Date Time	DP Pa	°C TEMP	DP Pa	°C TEMP	DP Pa	°C TEMP
04-11-2021 15:21	21	22.1	18	22.6	22	22.9
04-11-2021 15:22	21	22.1	16	22.6	22	22.9
04-11-2021 15:23	20	22.1	18	22.6	22	22.9
04-11-2021 15:24	21	22.0	18	22.6	22	22.9
04-11-2021 15:25	21	22.0	17	22.5	22	22.9
04-11-2021 15:26	21	22.0	17	22.5	21	22.9
04-11-2021 15:27	21	22.0	17	22.5	22	22.9
04-11-2021 15:28	22	22.0	17	22.5	23	22.9
04-11-2021 15:29	21	22.1	16	22.5	23	22.9
04-11-2021 15:30	20	22.1	16	22.5	23	22.9
04-11-2021 15:31	22	22.1	17	22.5	23	22.9
04-11-2021 15:32	20	22.1	16	22.5	22	22.9
04-11-2021 15:33	21	22.1	18	22.6	21	22.9
04-11-2021 15:34	21	22.1	17	22.6	21	22.9
04-11-2021 15:35	21	22.1	17	22.6	22	22.9
04-11-2021 15:36	20	22.1	18	22.6	23	22.9
04-11-2021 15:37	21	22.1	17	22.6	23	22.9
04-11-2021 15:38	21	22.1	16	22.6	23	22.9
04-11-2021 15:39	21	22.1	17	22.6	23	22.9
04-11-2021 15:40	21	22.1	16	22.6	21	22.9
04-11-2021 15:41	22	22.2	17	22.6	23	22.9
04-11-2021 15:42	20	22.1	17	22.6	23	22.9
04-11-2021 15:43	21	22.2	16	22.7	23	22.9
04-11-2021 15:44	21	22.2	18	22.7	23	22.9
04-11-2021 15:45	21	22.2	18	22.7	23	22.9
04-11-2021 15:46	21	22.2	17	22.7	23	22.9
04-11-2021 15:47	21	22.2	18	22.7	22	22.9
04-11-2021 15:48	21	22.2	16	22.7	21	22.9



# Environmental Monitoring System

## DATA REPORT

### STERILE EXIT CHANGE ROOMS (L3)

Date Time	STERILE PASSAGE (L3) wrt EXIT ROOM-1 (L3)	STERILE EXIT ROOM-1 (L3)	ASEPTIC EXIT ROOM-1 (L3) wrt EXIT ROOM-2 (L3)	STERILE EXIT ROOM-2 (L3)	ASEPTIC EXIT ROOM-2 (L3) wrt EXIT ROOM-3 (L3)	STERILE EXIT ROOM-3 (L3)
Date Time	DP Pa	°C TEMP	DP Pa	°C TEMP	DP Pa	°C TEMP
04-11-2021 15:49	21	22.2	18	22.7	23	22.9
04-11-2021 15:50	20	22.2	17	22.7	23	22.9
04-11-2021 15:51	21	22.2	18	22.7	22	22.9
04-11-2021 15:52	20	22.2	17	22.7	22	22.9
04-11-2021 15:53	21	22.3	18	22.7	22	22.9
04-11-2021 15:54	21	22.3	17	22.8	23	22.9
04-11-2021 15:55	21	22.3	17	22.8	21	22.9
04-11-2021 15:56	20	22.3	17	22.8	23	22.9
04-11-2021 15:57	21	22.3	18	22.8	23	22.9
04-11-2021 15:58	21	22.3	17	22.8	23	23.0
04-11-2021 15:59	21	22.3	17	22.8	23	23.0
04-11-2021 16:00	22	22.3	16	22.8	23	23.0
04-11-2021 16:01	21	22.3	17	22.8	23	23.0
04-11-2021 16:02	23	22.3	17	22.8	23	23.0
04-11-2021 16:03	20	22.3	17	22.8	23	23.0
04-11-2021 16:04	21	22.3	16	22.8	22	23.0
04-11-2021 16:05	21	22.3	17	22.8	23	23.0
04-11-2021 16:06	21	22.4	17	22.8	23	23.0
04-11-2021 16:07	21	22.4	17	22.8	23	23.0
04-11-2021 16:08	20	22.3	17	22.8	21	23.0
04-11-2021 16:09	20	22.4	17	22.8	22	23.0
04-11-2021 16:10	21	22.4	16	22.8	23	23.0
04-11-2021 16:11	21	22.4	17	22.9	23	23.0
04-11-2021 16:12	21	22.4	17	22.9	22	23.0
04-11-2021 16:13	21	22.4	16	22.9	23	23.0
04-11-2021 16:14	21	22.4	18	22.9	23	23.0
04-11-2021 16:15	21	22.4	16	22.9	22	23.0
04-11-2021 16:16	21	22.4	17	22.9	23	23.0



# Environmental Monitoring System

## DATA REPORT

### STERILE EXIT CHANGE ROOMS (L3)

Date Time	STERILE PASSAGE (L3) wrt EXIT ROOM-1 (L3)	STERILE EXIT ROOM-1 (L3)	ASEPTIC EXIT ROOM-1 (L3) wrt EXIT ROOM-2 (L3)	STERILE EXIT ROOM-2 (L3)	ASEPTIC EXIT ROOM-2 (L3) wrt EXIT ROOM-3 (L3)	STERILE EXIT ROOM-3 (L3)
Date Time	DP Pa	°C TEMP	DP Pa	°C TEMP	DP Pa	°C TEMP
04-11-2021 16:17	21	22.4	17	22.9	23	23.0
04-11-2021 16:18	21	22.4	17	22.9	23	23.0
04-11-2021 16:19	21	22.4	17	22.9	22	23.0
04-11-2021 16:20	20	22.4	17	22.9	23	23.0
04-11-2021 16:21	21	22.4	18	22.9	23	23.0
04-11-2021 16:22	21	22.4	16	22.9	23	23.0
04-11-2021 16:23	21	22.5	17	22.9	22	23.0
04-11-2021 16:24	21	22.4	17	22.9	23	23.0
04-11-2021 16:25	21	22.5	17	22.9	23	23.0
04-11-2021 16:26	21	22.5	17	22.9	23	23.0
04-11-2021 16:27	20	22.5	17	22.9	22	23.0
04-11-2021 16:28	21	22.5	18	22.9	23	23.1
04-11-2021 16:29	21	22.5	17	23.0	23	23.1
04-11-2021 16:30	21	22.4	17	23.0	23	23.1
04-11-2021 16:31	21	22.4	17	23.0	23	23.1
04-11-2021 16:32	21	22.5	18	23.0	22	23.1
04-11-2021 16:33	21	22.5	17	23.0	21	23.1
04-11-2021 16:34	21	22.5	18	23.0	22	23.1
04-11-2021 16:35	21	22.5	17	23.0	23	23.1
04-11-2021 16:36	21	22.5	16	23.0	23	23.1
04-11-2021 16:37	21	22.5	18	23.0	23	23.1
04-11-2021 16:38	20	22.5	17	22.9	22	23.1
04-11-2021 16:39	20	22.5	17	22.9	23	23.1
04-11-2021 16:40	20	22.5	17	22.9	23	23.1
04-11-2021 16:41	21	22.4	17	22.9	23	23.1
04-11-2021 16:42	22	22.4	17	22.9	23	23.1
04-11-2021 16:43	20	22.4	18	22.9	23	23.1
04-11-2021 16:44	21	22.4	17	22.9	23	23.1



# Environmental Monitoring System

## DATA REPORT

### STERILE EXIT CHANGE ROOMS (L3)

Date Time	STERILE PASSAGE (L3) wrt EXIT ROOM-1 (L3)	STERILE EXIT ROOM-1 (L3)	ASEPTIC EXIT ROOM-1 (L3) wrt EXIT ROOM-2 (L3)	STERILE EXIT ROOM-2 (L3)	ASEPTIC EXIT ROOM-2 (L3) wrt EXIT ROOM-3 (L3)	STERILE EXIT ROOM-3 (L3)
Date Time	DP Pa	°C TEMP	DP Pa	°C TEMP	DP Pa	°C TEMP
04-11-2021 16:45	20	22.4	17	22.9	23	23.1
04-11-2021 16:46	21	22.3	18	22.8	22	23.1
04-11-2021 16:47	21	22.4	17	22.8	22	23.1
04-11-2021 16:48	21	22.3	17	22.8	22	23.1
04-11-2021 16:49	21	22.3	18	22.8	23	23.0
04-11-2021 16:50	21	22.3	18	22.8	23	23.1
04-11-2021 16:51	21	22.3	18	22.8	22	23.0
04-11-2021 16:52	21	22.3	17	22.8	23	23.0
04-11-2021 16:53	22	22.2	17	22.8	23	23.0
04-11-2021 16:54	21	22.2	18	22.8	23	23.0
04-11-2021 16:55	21	22.2	17	22.8	23	23.0
04-11-2021 16:56	21	22.2	17	22.8	22	23.0
04-11-2021 16:57	21	22.2	17	22.8	21	23.0
04-11-2021 16:58	20	22.3	16	22.8	22	23.0
04-11-2021 16:59	20	22.2	17	22.8	23	23.0
04-11-2021 17:00	21	22.3	16	22.8	22	23.0
04-11-2021 17:01	21	22.3	18	22.8	22	23.0
04-11-2021 17:02	21	22.3	18	22.8	23	23.0
04-11-2021 17:03	21	22.3	17	22.7	21	23.0
04-11-2021 17:04	20	22.3	16	22.7	23	23.0
04-11-2021 17:05	21	22.3	17	22.7	23	23.0
04-11-2021 17:06	21	22.3	18	22.7	23	23.0
04-11-2021 17:07	21	22.3	17	22.7	22	23.0
04-11-2021 17:08	21	22.3	18	22.7	22	23.0
04-11-2021 17:09	22	22.3	17	22.7	23	23.0
04-11-2021 17:10	21	22.3	18	22.7	21	23.0
04-11-2021 17:11	21	22.3	16	22.7	21	23.0
04-11-2021 17:12	20	22.3	18	22.7	22	23.0



# Environmental Monitoring System

## DATA REPORT

### STERILE EXIT CHANGE ROOMS (L3)

Date Time	STERILE PASSAGE (L3) wrt EXIT ROOM-1 (L3)	STERILE EXIT ROOM-1 (L3)	ASEPTIC EXIT ROOM-1 (L3) wrt EXIT ROOM-2 (L3)	STERILE EXIT ROOM-2 (L3)	ASEPTIC EXIT ROOM-2 (L3) wrt EXIT ROOM-3 (L3)	STERILE EXIT ROOM-3 (L3)
Date Time	DP Pa	°C TEMP	DP Pa	°C TEMP	DP Pa	°C TEMP
04-11-2021 17:13	21	22.3	17	22.7	23	23.0
04-11-2021 17:14	21	22.2	17	22.7	22	23.0
04-11-2021 17:15	21	22.2	18	22.7	23	23.0
04-11-2021 17:16	20	22.3	16	22.7	23	23.0
04-11-2021 17:17	20	22.3	17	22.7	21	23.0
04-11-2021 17:18	21	22.3	16	22.7	23	22.9
04-11-2021 17:19	21	22.3	17	22.8	21	23.0
04-11-2021 17:20	20	22.3	17	22.7	22	22.9
04-11-2021 17:21	21	22.3	17	22.8	21	22.9
04-11-2021 17:22	21	22.3	17	22.7	21	23.0
04-11-2021 17:23	21	22.3	17	22.7	21	22.9
04-11-2021 17:24	21	22.3	17	22.7	23	22.9
04-11-2021 17:25	21	22.2	18	22.8	22	23.0
04-11-2021 17:26	21	22.2	18	22.7	23	23.0
04-11-2021 17:27	21	22.3	16	22.7	21	22.9
04-11-2021 17:28	20	22.3	18	22.7	22	23.0
04-11-2021 17:29	21	22.2	17	22.8	23	22.9
04-11-2021 17:30	21	22.3	17	22.7	23	22.9
04-11-2021 17:31	21	22.3	17	22.7	23	22.9
04-11-2021 17:32	21	22.3	17	22.7	23	23.0
04-11-2021 17:33	21	22.3	18	22.7	23	22.9
04-11-2021 17:34	21	22.3	17	22.7	21	22.9
04-11-2021 17:35	21	22.3	18	22.7	23	23.0
04-11-2021 17:36	21	22.2	17	22.7	21	22.9
04-11-2021 17:37	21	22.3	17	22.7	22	22.9
04-11-2021 17:38	21	22.3	17	22.8	21	23.0
04-11-2021 17:39	21	22.3	18	22.8	24	23.0
04-11-2021 17:40	20	22.3	17	22.8	23	23.0



## Environmental Monitoring System

### DATA REPORT

#### STERILE EXIT CHANGE ROOMS (L3)

Date Time	STERILE PASSAGE (L3) wrt EXIT ROOM-1 (L3)	STERILE EXIT ROOM-1 (L3)	ASEPTIC EXIT ROOM-1 (L3) wrt EXIT ROOM-2 (L3)	STERILE EXIT ROOM-2 (L3)	ASEPTIC EXIT ROOM-2 (L3) wrt EXIT ROOM-3 (L3)	STERILE EXIT ROOM-3 (L3)
Date Time	DP Pa	°C TEMP	DP Pa	°C TEMP	DP Pa	°C TEMP
04-11-2021 17:41	21	22.3	18	22.8	23	22.9
04-11-2021 17:42	21	22.3	16	22.8	21	23.0
04-11-2021 17:43	21	22.3	17	22.8	22	23.0
04-11-2021 17:44	20	22.3	17	22.8	23	23.0
04-11-2021 17:45	21	22.3	17	22.8	23	23.0
04-11-2021 17:46	21	22.3	17	22.8	22	22.9
04-11-2021 17:47	21	22.3	18	22.8	23	22.9
04-11-2021 17:48	20	22.3	17	22.8	22	23.0
04-11-2021 17:49	21	22.3	17	22.8	22	23.0
04-11-2021 17:50	22	22.3	17	22.8	21	22.9
04-11-2021 17:51	21	22.3	17	22.8	23	23.0
04-11-2021 17:52	20	22.3	16	22.8	23	23.0
04-11-2021 17:53	21	22.3	16	22.8	22	23.0
04-11-2021 17:54	21	22.3	17	22.8	22	23.0
04-11-2021 17:55	21	22.3	16	22.8	22	23.0
04-11-2021 17:56	21	22.4	18	22.8	22	23.0
04-11-2021 17:57	21	22.4	17	22.8	23	23.0
04-11-2021 17:58	20	22.4	17	22.8	22	23.0
04-11-2021 17:59	21	22.4	17	22.8	22	23.0
04-11-2021 18:00	21	22.4	17	22.8	22	23.0
04-11-2021 18:01	20	22.4	17	22.8	23	23.0
04-11-2021 18:02	21	22.4	16	22.8	21	23.0
04-11-2021 18:03	20	22.4	17	22.8	23	23.0
04-11-2021 18:04	21	22.4	18	22.9	23	23.0
04-11-2021 18:05	20	22.4	16	22.9	21	23.0
04-11-2021 18:06	20	22.4	16	22.9	22	23.0
04-11-2021 18:07	21	22.4	17	22.9	23	23.0
04-11-2021 18:08	20	22.4	17	22.9	21	23.0



# Environmental Monitoring System

## DATA REPORT

### STERILE EXIT CHANGE ROOMS (L3)

Date Time	STERILE PASSAGE (L3) wrt EXIT ROOM-1 (L3)	STERILE EXIT ROOM-1 (L3)	ASEPTIC EXIT ROOM-1 (L3) wrt EXIT ROOM-2 (L3)	STERILE EXIT ROOM-2 (L3)	ASEPTIC EXIT ROOM-2 (L3) wrt EXIT ROOM-3 (L3)	STERILE EXIT ROOM-3 (L3)
Date Time	DP Pa	°C TEMP	DP Pa	°C TEMP	DP Pa	°C TEMP
04-11-2021 18:09	21	22.4	17	22.9	23	23.0
04-11-2021 18:10	22	22.4	17	22.9	22	23.0
04-11-2021 18:11	21	22.4	17	22.9	22	23.0
04-11-2021 18:12	21	22.4	18	22.9	23	23.0
04-11-2021 18:13	21	22.4	16	22.9	22	23.0
04-11-2021 18:14	22	22.4	17	22.9	23	23.0
04-11-2021 18:15	20	22.4	18	22.9	23	23.0
04-11-2021 18:16	22	22.4	17	22.9	23	23.0
04-11-2021 18:17	20	22.4	17	22.9	21	23.0
04-11-2021 18:18	20	22.4	17	22.9	22	23.0
04-11-2021 18:19	21	22.4	17	22.9	22	23.1
04-11-2021 18:20	21	22.5	17	22.9	23	23.0
04-11-2021 18:21	21	22.5	17	22.9	22	23.0
04-11-2021 18:22	20	22.4	16	22.9	23	23.0
04-11-2021 18:23	21	22.4	17	22.9	23	23.0
04-11-2021 18:24	21	22.4	17	22.9	23	23.0
04-11-2021 18:25	22	22.4	17	22.9	21	23.0
04-11-2021 18:26	20	22.4	18	22.9	22	23.0
04-11-2021 18:27	21	22.4	17	22.9	22	23.0
04-11-2021 18:28	22	22.4	18	22.9	21	23.0
04-11-2021 18:29	20	22.4	17	22.9	23	23.0
04-11-2021 18:30	22	22.4	18	22.9	23	23.1
04-11-2021 18:31	21	22.4	17	22.9	23	23.1
04-11-2021 18:32	20	22.4	17	22.9	23	23.0
04-11-2021 18:33	21	22.4	18	22.8	22	23.0
04-11-2021 18:34	21	22.4	18	22.8	22	23.0
04-11-2021 18:35	21	22.4	17	22.8	23	23.0
04-11-2021 18:36	21	22.4	16	22.8	22	23.0





# Environmental Monitoring System

## DATA REPORT

### STERILE EXIT CHANGE ROOMS (L3)

Date Time	STERILE PASSAGE (L3) wrt EXIT ROOM-1 (L3)	STERILE EXIT ROOM-1 (L3)	ASEPTIC EXIT ROOM-1 (L3) wrt EXIT ROOM-2 (L3)	STERILE EXIT ROOM-2 (L3)	ASEPTIC EXIT ROOM-2 (L3) wrt EXIT ROOM-3 (L3)	STERILE EXIT ROOM-3 (L3)
Date Time	DP Pa	°C TEMP	DP Pa	°C TEMP	DP Pa	°C TEMP
04-11-2021 18:37	20	22.4	17	22.8	21	23.0
04-11-2021 18:38	21	22.3	16	22.8	23	23.0
04-11-2021 18:39	21	22.3	17	22.8	22	23.0
04-11-2021 18:40	21	22.3	16	22.8	22	23.0
04-11-2021 18:41	21	22.3	17	22.7	22	23.0
04-11-2021 18:42	21	22.2	18	22.7	23	23.0
04-11-2021 18:43	21	22.2	17	22.7	23	23.0
04-11-2021 18:44	21	22.2	18	22.7	23	23.0
04-11-2021 18:45	21	22.2	17	22.7	21	23.0
04-11-2021 18:46	21	22.2	16	22.7	22	23.0
04-11-2021 18:47	20	22.2	17	22.7	21	23.0
04-11-2021 18:48	21	22.2	16	22.7	23	22.9
04-11-2021 18:49	20	22.2	17	22.7	23	22.9
04-11-2021 18:50	22	22.2	17	22.7	23	23.0
04-11-2021 18:51	21	22.2	18	22.7	23	23.0
04-11-2021 18:52	20	22.2	17	22.7	23	23.0
04-11-2021 18:53	21	22.2	17	22.7	22	23.0
04-11-2021 18:54	20	22.3	18	22.8	21	23.0
04-11-2021 18:55	20	22.3	18	22.8	22	23.0
04-11-2021 18:56	21	22.3	17	22.8	23	23.0
04-11-2021 18:57	21	22.4	17	22.8	22	23.0
04-11-2021 18:58	21	22.4	17	22.8	22	23.0
04-11-2021 18:59	21	22.4	17	22.8	22	23.0
04-11-2021 19:00	21	22.4	17	22.9	23	23.0
04-11-2021 19:01	20	22.4	17	22.9	23	23.0
04-11-2021 19:02	20	22.4	17	22.9	21	23.0
04-11-2021 19:03	21	22.4	18	22.9	22	23.0
04-11-2021 19:04	21	22.4	17	22.9	23	23.0



# Environmental Monitoring System

## DATA REPORT

### STERILE EXIT CHANGE ROOMS (L3)

Date Time	STERILE PASSAGE (L3) wrt EXIT ROOM-1 (L3)	STERILE EXIT ROOM-1 (L3)	ASEPTIC EXIT ROOM-1 (L3) wrt EXIT ROOM-2 (L3)	STERILE EXIT ROOM-2 (L3)	ASEPTIC EXIT ROOM-2 (L3) wrt EXIT ROOM-3 (L3)	STERILE EXIT ROOM-3 (L3)
Date Time	DP Pa	°C TEMP	DP Pa	°C TEMP	DP Pa	°C TEMP
04-11-2021 19:05	20	22.4	18	22.9	22	23.0
04-11-2021 19:06	20	22.4	17	22.9	22	23.0
04-11-2021 19:07	21	22.5	17	22.9	22	23.0
04-11-2021 19:08	20	22.5	17	23.0	23	23.0
04-11-2021 19:09	20	22.5	17	23.0	22	23.0
04-11-2021 19:10	21	22.5	17	23.0	21	23.1
04-11-2021 19:11	21	22.5	16	23.0	22	23.1
04-11-2021 19:12	21	22.6	18	23.0	23	23.1
04-11-2021 19:13	20	22.5	17	23.0	22	23.1
04-11-2021 19:14	20	22.6	16	23.0	23	23.1
04-11-2021 19:15	20	22.6	16	23.0	22	23.1
04-11-2021 19:16	21	22.6	17	23.0	21	23.1
04-11-2021 19:17	21	22.6	17	23.0	23	23.1
04-11-2021 19:18	21	22.6	17	23.0	23	23.1
04-11-2021 19:19	21	22.6	17	23.0	23	23.1
04-11-2021 19:20	21	22.6	17	23.0	23	23.1
04-11-2021 19:21	21	22.6	17	23.0	22	23.1
04-11-2021 19:22	21	22.6	17	23.0	23	23.1
04-11-2021 19:23	21	22.6	17	23.0	22	23.1
04-11-2021 19:24	20	22.6	16	23.0	22	23.1
04-11-2021 19:25	21	22.6	18	23.0	22	23.1
04-11-2021 19:26	21	22.6	17	23.0	22	23.1
04-11-2021 19:27	20	22.6	16	23.0	22	23.1
04-11-2021 19:28	21	22.5	17	23.0	21	23.1
04-11-2021 19:29	21	22.5	18	23.0	23	23.1
04-11-2021 19:30	21	22.5	17	23.0	23	23.1
04-11-2021 19:31	21	22.5	17	23.0	22	23.1
04-11-2021 19:32	20	22.5	18	23.0	23	23.1



# Environmental Monitoring System

## DATA REPORT

### STERILE EXIT CHANGE ROOMS (L3)

Date Time	STERILE PASSAGE (L3) wrt EXIT ROOM-1 (L3)	STERILE EXIT ROOM-1 (L3)	ASEPTIC EXIT ROOM-1 (L3) wrt EXIT ROOM-2 (L3)	STERILE EXIT ROOM-2 (L3)	ASEPTIC EXIT ROOM-2 (L3) wrt EXIT ROOM-3 (L3)	STERILE EXIT ROOM-3 (L3)
Date Time	DP Pa	°C TEMP	DP Pa	°C TEMP	DP Pa	°C TEMP
04-11-2021 19:33	21	22.5	17	22.9	23	23.1
04-11-2021 19:34	21	22.5	17	22.9	22	23.1
04-11-2021 19:35	20	22.5	17	22.9	22	23.1
04-11-2021 19:36	22	22.5	18	22.9	23	23.1
04-11-2021 19:37	22	22.5	18	22.9	23	23.1
04-11-2021 19:38	21	22.5	17	22.9	22	23.1
04-11-2021 19:39	20	22.4	17	22.9	21	23.1
04-11-2021 19:40	20	22.4	16	22.9	23	23.1
04-11-2021 19:41	22	22.4	18	22.9	23	23.1
04-11-2021 19:42	20	22.4	17	22.9	22	23.1
04-11-2021 19:43	22	22.4	17	22.8	22	23.1
04-11-2021 19:44	20	22.4	17	22.9	23	23.1
04-11-2021 19:45	22	22.4	17	22.8	22	23.1
04-11-2021 19:46	21	22.4	17	22.8	22	23.1
04-11-2021 19:47	21	22.4	19	22.8	25	23.1
04-11-2021 19:48	21	22.4	17	22.8	22	23.1
04-11-2021 19:49	21	22.4	17	22.8	22	23.1
04-11-2021 19:50	20	22.4	15	22.8	21	23.1
04-11-2021 19:51	20	22.3	15	22.8	20	23.1
04-11-2021 19:52	20	22.4	16	22.8	20	23.0
04-11-2021 19:53	20	22.4	16	22.8	21	23.0
04-11-2021 19:54	19	22.4	16	22.8	21	23.1
04-11-2021 19:55	20	22.4	15	22.8	20	23.0
04-11-2021 19:56	20	22.4	15	22.8	20	23.0
04-11-2021 19:57	20	22.4	16	22.8	21	23.0
04-11-2021 19:58	20	22.4	15	22.8	20	23.0
04-11-2021 19:59	20	22.3	15	22.8	21	23.0
04-11-2021 20:00	21	22.3	15	22.8	21	23.0



# Environmental Monitoring System

## DATA REPORT

### STERILE EXIT CHANGE ROOMS (L3)

Date Time	STERILE PASSAGE (L3) wrt EXIT ROOM-1 (L3)	STERILE EXIT ROOM-1 (L3)	ASEPTIC EXIT ROOM-1 (L3) wrt EXIT ROOM-2 (L3)	STERILE EXIT ROOM-2 (L3)	ASEPTIC EXIT ROOM-2 (L3) wrt EXIT ROOM-3 (L3)	STERILE EXIT ROOM-3 (L3)
Date Time	DP Pa	°C TEMP	DP Pa	°C TEMP	DP Pa	°C TEMP
04-11-2021 20:01	20	22.4	16	22.8	21	23.0
04-11-2021 20:02	20	22.4	16	22.8	21	23.0
04-11-2021 20:03	20	22.4	16	22.8	21	23.0
04-11-2021 20:04	20	22.4	15	22.8	20	23.0
04-11-2021 20:05	22	22.4	17	22.8	21	23.0
04-11-2021 20:06	21	22.4	16	22.8	21	23.0
04-11-2021 20:07	21	22.4	17	22.8	21	23.0
04-11-2021 20:08	20	22.4	16	22.8	21	23.0
04-11-2021 20:09	19	22.3	16	22.8	21	23.0
04-11-2021 20:10	20	22.3	16	22.8	21	23.0
04-11-2021 20:11	21	22.4	17	22.8	21	23.0
04-11-2021 20:12	20	22.4	15	22.8	20	23.0
04-11-2021 20:13	20	22.4	16	22.8	20	23.0
04-11-2021 20:14	20	22.4	16	22.8	20	23.0
04-11-2021 20:15	20	22.3	15	22.8	21	23.0
04-11-2021 20:16	21	22.3	16	22.8	20	23.0
04-11-2021 20:17	20	22.3	16	22.8	21	23.0
04-11-2021 20:18	21	22.4	16	22.8	21	23.0
04-11-2021 20:19	20	22.4	16	22.8	21	23.0
04-11-2021 20:20	20	22.3	16	22.8	21	23.0
04-11-2021 20:21	21	22.3	16	22.8	20	23.0
04-11-2021 20:22	20	22.3	16	22.8	21	23.0
04-11-2021 20:23	20	22.3	16	22.8	21	23.0
04-11-2021 20:24	20	22.3	15	22.8	21	23.0
04-11-2021 20:25	20	22.3	15	22.8	21	23.0
04-11-2021 20:26	20	22.3	15	22.8	21	23.0
04-11-2021 20:27	21	22.3	16	22.8	20	23.0
04-11-2021 20:28	20	22.3	15	22.8	21	23.0



# Environmental Monitoring System

## DATA REPORT

### STERILE EXIT CHANGE ROOMS (L3)

Date Time	STERILE PASSAGE (L3) wrt EXIT ROOM-1 (L3)	STERILE EXIT ROOM-1 (L3)	ASEPTIC EXIT ROOM-1 (L3) wrt EXIT ROOM-2 (L3)	STERILE EXIT ROOM-2 (L3)	ASEPTIC EXIT ROOM-2 (L3) wrt EXIT ROOM-3 (L3)	STERILE EXIT ROOM-3 (L3)
Date Time	DP Pa	°C TEMP	DP Pa	°C TEMP	DP Pa	°C TEMP
04-11-2021 20:29	20	22.3	16	22.8	21	23.0
04-11-2021 20:30	19	22.3	16	22.8	21	23.0
04-11-2021 20:31	20	22.3	16	22.7	21	23.0
04-11-2021 20:32	21	22.3	15	22.8	20	23.0
04-11-2021 20:33	20	22.3	15	22.8	21	23.0
04-11-2021 20:34	20	22.3	15	22.8	21	23.0
04-11-2021 20:35	20	22.3	16	22.8	20	23.0
04-11-2021 20:36	20	22.3	17	22.8	20	23.0
04-11-2021 20:37	20	22.3	16	22.8	20	23.0
04-11-2021 20:38	20	22.3	16	22.8	21	23.0
04-11-2021 20:39	21	22.3	16	22.8	20	23.0
04-11-2021 20:40	19	22.3	16	22.8	20	23.0
04-11-2021 20:41	19	22.3	15	22.8	21	23.0
04-11-2021 20:42	20	22.3	16	22.8	21	23.0
04-11-2021 20:43	19	22.3	16	22.8	20	23.0
04-11-2021 20:44	20	22.3	16	22.8	21	23.0
04-11-2021 20:45	21	22.4	16	22.8	20	23.0
04-11-2021 20:46	20	22.3	16	22.8	21	23.0
04-11-2021 20:47	20	22.4	16	22.8	21	23.0
04-11-2021 20:48	21	22.4	16	22.8	20	23.0
04-11-2021 20:49	20	22.4	16	22.8	21	23.0
04-11-2021 20:50	20	22.3	16	22.8	20	23.0
04-11-2021 20:51	20	22.3	16	22.8	20	23.0
04-11-2021 20:52	20	22.3	15	22.8	20	23.0
04-11-2021 20:53	20	22.3	16	22.8	20	23.0
04-11-2021 20:54	21	22.3	16	22.8	20	23.0
04-11-2021 20:55	20	22.3	15	22.8	22	23.0
04-11-2021 20:56	20	22.3	16	22.7	20	23.0



# Environmental Monitoring System

## DATA REPORT

### STERILE EXIT CHANGE ROOMS (L3)

Date Time	STERILE PASSAGE (L3) wrt EXIT ROOM-1 (L3)	STERILE EXIT ROOM-1 (L3)	ASEPTIC EXIT ROOM-1 (L3) wrt EXIT ROOM-2 (L3)	STERILE EXIT ROOM-2 (L3)	ASEPTIC EXIT ROOM-2 (L3) wrt EXIT ROOM-3 (L3)	STERILE EXIT ROOM-3 (L3)
Date Time	DP Pa	°C TEMP	DP Pa	°C TEMP	DP Pa	°C TEMP
04-11-2021 20:57	21	22.3	16	22.7	20	23.0
04-11-2021 20:58	20	22.3	16	22.7	21	23.0
04-11-2021 20:59	21	22.3	15	22.7	21	23.0
04-11-2021 21:00	21	22.3	16	22.7	21	22.9
04-11-2021 21:01	21	22.3	16	22.7	21	22.9
04-11-2021 21:02	21	22.2	15	22.7	20	22.9
04-11-2021 21:03	20	22.2	16	22.7	21	22.9
04-11-2021 21:04	20	22.2	15	22.7	21	22.9
04-11-2021 21:05	21	22.2	16	22.6	21	22.9
04-11-2021 21:06	21	22.2	16	22.6	21	22.9
04-11-2021 21:07	20	22.2	16	22.6	21	22.9
04-11-2021 21:08	20	22.2	16	22.6	21	22.9
04-11-2021 21:09	21	22.1	15	22.6	20	22.9
04-11-2021 21:10	20	22.2	15	22.6	21	22.9
04-11-2021 21:11	21	22.1	16	22.6	21	22.9
04-11-2021 21:12	21	22.1	16	22.6	21	22.9
04-11-2021 21:13	21	22.1	15	22.6	21	22.9
04-11-2021 21:14	20	22.1	16	22.6	20	22.9
04-11-2021 21:15	20	22.1	16	22.6	20	22.9
04-11-2021 21:16	22	22.1	15	22.6	21	22.9
04-11-2021 21:17	19	22.1	16	22.6	21	22.9
04-11-2021 21:18	21	22.1	15	22.7	21	22.9
04-11-2021 21:19	21	22.2	16	22.7	21	22.9
04-11-2021 21:20	20	22.2	16	22.7	20	22.9
04-11-2021 21:21	21	22.2	15	22.7	21	22.9
04-11-2021 21:22	20	22.2	16	22.7	21	22.9
04-11-2021 21:23	18	22.2	16	22.7	20	22.9
04-11-2021 21:24	21	22.2	17	22.7	20	22.9



# Environmental Monitoring System

## DATA REPORT

### STERILE EXIT CHANGE ROOMS (L3)

Date Time	STERILE PASSAGE (L3) wrt EXIT ROOM-1 (L3)	STERILE EXIT ROOM-1 (L3)	ASEPTIC EXIT ROOM-1 (L3) wrt EXIT ROOM-2 (L3)	STERILE EXIT ROOM-2 (L3)	ASEPTIC EXIT ROOM-2 (L3) wrt EXIT ROOM-3 (L3)	STERILE EXIT ROOM-3 (L3)
Date Time	DP Pa	°C TEMP	DP Pa	°C TEMP	DP Pa	°C TEMP
04-11-2021 21:25	20	22.2	17	22.7	21	22.9
04-11-2021 21:26	21	22.2	16	22.7	21	22.9
04-11-2021 21:27	21	22.3	15	22.7	21	22.9
04-11-2021 21:28	21	22.2	16	22.7	20	22.9
04-11-2021 21:29	20	22.3	16	22.8	21	22.9
04-11-2021 21:30	21	22.3	16	22.8	21	22.9
04-11-2021 21:31	21	22.4	16	22.8	20	22.9
04-11-2021 21:32	21	22.4	16	22.8	21	23.0
04-11-2021 21:33	20	22.4	16	22.8	21	23.0
04-11-2021 21:34	21	22.4	16	22.8	21	23.0
04-11-2021 21:35	21	22.4	16	22.8	21	23.0
04-11-2021 21:36	20	22.4	15	22.8	21	23.0
04-11-2021 21:37	20	22.4	16	22.8	21	23.0
04-11-2021 21:38	21	22.4	16	22.8	20	23.0
04-11-2021 21:39	20	22.4	16	22.8	21	23.0
04-11-2021 21:40	21	22.4	17	22.8	21	23.0
04-11-2021 21:41	20	22.4	16	22.8	20	23.0
04-11-2021 21:42	21	22.4	16	22.8	20	23.0
04-11-2021 21:43	20	22.4	16	22.8	20	23.0
04-11-2021 21:44	20	22.4	16	22.8	21	23.0
04-11-2021 21:45	21	22.4	16	22.9	21	23.0
04-11-2021 21:46	20	22.4	16	22.9	21	23.0
04-11-2021 21:47	20	22.4	17	22.9	21	23.0
04-11-2021 21:48	21	22.4	16	22.9	20	23.0
04-11-2021 21:49	20	22.4	17	22.9	20	23.0
04-11-2021 21:50	20	22.4	16	22.9	21	23.0
04-11-2021 21:51	20	22.5	16	22.9	21	23.0
04-11-2021 21:52	21	22.5	16	22.9	21	23.0



# Environmental Monitoring System

## DATA REPORT

### STERILE EXIT CHANGE ROOMS (L3)

Date Time	STERILE PASSAGE (L3) wrt EXIT ROOM-1 (L3)	STERILE EXIT ROOM-1 (L3)	ASEPTIC EXIT ROOM-1 (L3) wrt EXIT ROOM-2 (L3)	STERILE EXIT ROOM-2 (L3)	ASEPTIC EXIT ROOM-2 (L3) wrt EXIT ROOM-3 (L3)	STERILE EXIT ROOM-3 (L3)
Date Time	DP Pa	°C TEMP	DP Pa	°C TEMP	DP Pa	°C TEMP
04-11-2021 21:53	21	22.5	16	23.0	21	23.1
04-11-2021 21:54	21	22.5	16	23.0	20	23.1
04-11-2021 21:55	21	22.5	16	23.0	21	23.1
04-11-2021 21:56	20	22.5	15	23.0	21	23.1
04-11-2021 21:57	20	22.6	16	23.0	21	23.1
04-11-2021 21:58	20	22.6	16	23.1	21	23.1
04-11-2021 21:59	20	22.6	16	23.1	20	23.1
04-11-2021 22:00	20	22.6	16	23.1	21	23.2
04-11-2021 22:01	20	22.6	16	23.1	21	23.2
04-11-2021 22:02	20	22.7	16	23.1	20	23.2
04-11-2021 22:03	21	22.7	16	23.1	21	23.2
04-11-2021 22:04	20	22.7	16	23.2	21	23.2
04-11-2021 22:05	20	22.7	16	23.2	21	23.2
04-11-2021 22:06	21	22.7	17	23.2	21	23.3
04-11-2021 22:07	21	22.8	15	23.2	20	23.3
04-11-2021 22:08	22	22.8	16	23.2	21	23.3
04-11-2021 22:09	20	22.8	16	23.3	20	23.3
04-11-2021 22:10	20	22.8	16	23.3	21	23.4
04-11-2021 22:11	20	22.8	16	23.3	21	23.4
04-11-2021 22:12	20	22.8	16	23.3	20	23.4
04-11-2021 22:13	20	22.8	16	23.3	20	23.4
04-11-2021 22:14	20	22.8	15	23.3	21	23.4
04-11-2021 22:15	21	22.9	15	23.3	20	23.4
04-11-2021 22:16	20	22.8	16	23.3	20	23.4
04-11-2021 22:17	20	22.9	16	23.3	20	23.4
04-11-2021 22:18	21	22.8	16	23.3	21	23.4
04-11-2021 22:19	20	22.8	16	23.3	21	23.4
04-11-2021 22:20	20	22.9	16	23.3	21	23.4





# Environmental Monitoring System

## DATA REPORT

### STERILE EXIT CHANGE ROOMS (L3)

Date Time	STERILE PASSAGE (L3) wrt EXIT ROOM-1 (L3)	STERILE EXIT ROOM-1 (L3)	ASEPTIC EXIT ROOM-1 (L3) wrt EXIT ROOM-2 (L3)	STERILE EXIT ROOM-2 (L3)	ASEPTIC EXIT ROOM-2 (L3) wrt EXIT ROOM-3 (L3)	STERILE EXIT ROOM-3 (L3)
Date Time	DP Pa	°C TEMP	DP Pa	°C TEMP	DP Pa	°C TEMP
04-11-2021 22:21	21	22.9	16	23.3	22	23.4
04-11-2021 22:22	21	22.8	16	23.3	20	23.4
04-11-2021 22:23	20	22.8	15	23.3	21	23.4
04-11-2021 22:24	21	22.8	16	23.3	21	23.4
04-11-2021 22:25	20	22.8	16	23.3	21	23.4
04-11-2021 22:26	22	22.8	16	23.2	21	23.4
04-11-2021 22:27	21	22.8	16	23.2	21	23.4
04-11-2021 22:28	21	22.8	16	23.2	21	23.4
04-11-2021 22:29	21	22.8	16	23.2	21	23.4
04-11-2021 22:30	20	22.8	15	23.2	20	23.4
04-11-2021 22:31	20	22.8	16	23.2	21	23.4
04-11-2021 22:32	21	22.8	16	23.2	21	23.4
04-11-2021 22:33	20	22.7	16	23.2	21	23.4
04-11-2021 22:34	20	22.7	16	23.2	21	23.4
04-11-2021 22:35	21	22.7	16	23.2	22	23.4
04-11-2021 22:36	21	22.7	16	23.2	21	23.3
04-11-2021 22:37	20	22.7	16	23.2	21	23.3
04-11-2021 22:38	21	22.7	16	23.2	20	23.3
04-11-2021 22:39	21	22.7	17	23.1	20	23.3
04-11-2021 22:40	20	22.6	16	23.2	21	23.3
04-11-2021 22:41	22	22.7	16	23.1	21	23.3
04-11-2021 22:42	20	22.7	16	23.1	21	23.4
04-11-2021 22:43	21	22.7	15	23.1	20	23.3
04-11-2021 22:44	20	22.7	16	23.1	22	23.3
04-11-2021 22:45	21	22.7	15	23.1	21	23.3
04-11-2021 22:46	21	22.7	16	23.1	20	23.3
04-11-2021 22:47	20	22.7	15	23.1	20	23.3
04-11-2021 22:48	20	22.6	15	23.1	19	23.3



# Environmental Monitoring System

## DATA REPORT

### STERILE EXIT CHANGE ROOMS (L3)

Date Time	STERILE PASSAGE (L3) wrt EXIT ROOM-1 (L3)	STERILE EXIT ROOM-1 (L3)	ASEPTIC EXIT ROOM-1 (L3) wrt EXIT ROOM-2 (L3)	STERILE EXIT ROOM-2 (L3)	ASEPTIC EXIT ROOM-2 (L3) wrt EXIT ROOM-3 (L3)	STERILE EXIT ROOM-3 (L3)
Date Time	DP Pa	°C TEMP	DP Pa	°C TEMP	DP Pa	°C TEMP
04-11-2021 22:49	21	22.7	15	23.1	20	23.3
04-11-2021 22:50	20	22.6	15	23.1	20	23.3
04-11-2021 22:51	20	22.6	15	23.1	20	23.3
04-11-2021 22:52	20	22.6	15	23.1	20	23.3
04-11-2021 22:53	20	22.6	15	23.1	20	23.3
04-11-2021 22:54	20	22.7	16	23.1	20	23.3
04-11-2021 22:55	20	22.7	15	23.1	20	23.3
04-11-2021 22:56	20	22.6	15	23.1	20	23.3
04-11-2021 22:57	19	22.7	15	23.1	20	23.3
04-11-2021 22:58	21	22.6	15	23.1	20	23.3
04-11-2021 22:59	20	22.7	15	23.1	20	23.3
04-11-2021 23:00	20	22.7	16	23.1	20	23.3
04-11-2021 23:01	22	22.7	15	23.1	21	23.3
04-11-2021 23:02	20	22.7	15	23.1	20	23.3
04-11-2021 23:03	21	22.7	15	23.1	21	23.3
04-11-2021 23:04	21	22.7	16	23.1	19	23.3
04-11-2021 23:05	20	22.6	16	23.1	20	23.3
04-11-2021 23:06	20	22.6	15	23.1	20	23.3
04-11-2021 23:07	20	22.6	15	23.1	20	23.3
04-11-2021 23:08	20	22.6	15	23.1	20	23.3
04-11-2021 23:09	20	22.6	15	23.1	20	23.3
04-11-2021 23:10	21	22.6	15	23.1	20	23.3
04-11-2021 23:11	20	22.6	15	23.1	20	23.3
04-11-2021 23:12	21	22.6	13	23.1	19	23.3
04-11-2021 23:13	20	22.6	15	23.0	20	23.3
04-11-2021 23:14	19	22.6	15	23.0	20	23.3
04-11-2021 23:15	21	22.6	15	23.0	20	23.3
04-11-2021 23:16	20	22.6	15	23.0	20	23.3



# Environmental Monitoring System

## DATA REPORT

### STERILE EXIT CHANGE ROOMS (L3)

Date Time	STERILE PASSAGE (L3) wrt EXIT ROOM-1 (L3)	STERILE EXIT ROOM-1 (L3)	ASEPTIC EXIT ROOM-1 (L3) wrt EXIT ROOM-2 (L3)	STERILE EXIT ROOM-2 (L3)	ASEPTIC EXIT ROOM-2 (L3) wrt EXIT ROOM-3 (L3)	STERILE EXIT ROOM-3 (L3)
Date Time	DP Pa	°C TEMP	DP Pa	°C TEMP	DP Pa	°C TEMP
04-11-2021 23:17	20	22.6	16	23.0	20	23.3
04-11-2021 23:18	19	22.6	15	23.0	20	23.3
04-11-2021 23:19	20	22.6	16	23.0	20	23.2
04-11-2021 23:20	20	22.6	15	23.0	21	23.2
04-11-2021 23:21	20	22.5	15	23.0	20	23.2
04-11-2021 23:22	20	22.5	15	23.0	20	23.2
04-11-2021 23:23	21	22.5	15	23.0	21	23.2
04-11-2021 23:24	20	22.5	15	23.0	19	23.2
04-11-2021 23:25	21	22.5	15	23.0	19	23.2
04-11-2021 23:26	20	22.5	15	23.0	20	23.2
04-11-2021 23:27	21	22.5	15	23.0	20	23.2
04-11-2021 23:28	19	22.5	16	23.0	20	23.2
04-11-2021 23:29	20	22.5	15	23.0	20	23.2
04-11-2021 23:30	20	22.5	15	23.0	20	23.2
04-11-2021 23:31	20	22.5	15	23.0	20	23.2
04-11-2021 23:32	20	22.5	15	23.0	21	23.2
04-11-2021 23:33	20	22.5	14	23.0	20	23.2
04-11-2021 23:34	20	22.5	15	23.0	20	23.2
04-11-2021 23:35	24	22.6	16	23.0	21	23.2
04-11-2021 23:36	21	22.6	15	23.1	20	23.2
04-11-2021 23:37	20	22.6	15	23.1	21	23.2
04-11-2021 23:38	20	22.6	15	23.1	20	23.2
04-11-2021 23:39	21	22.7	15	23.1	20	23.2
04-11-2021 23:40	20	22.7	15	23.1	20	23.2
04-11-2021 23:41	20	22.7	15	23.2	20	23.3
04-11-2021 23:42	20	22.7	15	23.2	20	23.3
04-11-2021 23:43	21	22.7	15	23.2	20	23.3
04-11-2021 23:44	20	22.8	15	23.2	20	23.3



# Environmental Monitoring System

## DATA REPORT

### STERILE EXIT CHANGE ROOMS (L3)

Date Time	STERILE PASSAGE (L3) wrt EXIT ROOM-1 (L3)	STERILE EXIT ROOM-1 (L3)	ASEPTIC EXIT ROOM-1 (L3) wrt EXIT ROOM-2 (L3)	STERILE EXIT ROOM-2 (L3)	ASEPTIC EXIT ROOM-2 (L3) wrt EXIT ROOM-3 (L3)	STERILE EXIT ROOM-3 (L3)
Date Time	DP Pa	°C TEMP	DP Pa	°C TEMP	DP Pa	°C TEMP
04-11-2021 23:45	20	22.8	16	23.2	20	23.3
04-11-2021 23:46	19	22.8	16	23.2	20	23.3
04-11-2021 23:47	20	22.8	15	23.3	20	23.3
04-11-2021 23:48	20	22.8	15	23.3	20	23.3
04-11-2021 23:49	19	22.8	15	23.3	20	23.3
04-11-2021 23:50	20	22.8	15	23.3	20	23.3
04-11-2021 23:51	20	22.8	16	23.3	20	23.3
04-11-2021 23:52	20	22.8	15	23.3	20	23.4
04-11-2021 23:53	20	22.8	15	23.3	19	23.4
04-11-2021 23:54	21	22.9	16	23.3	20	23.4
04-11-2021 23:55	20	22.9	15	23.4	20	23.4
04-11-2021 23:56	20	22.9	15	23.4	20	23.4
04-11-2021 23:57	20	22.9	15	23.4	20	23.4
04-11-2021 23:58	19	22.9	15	23.4	20	23.4
04-11-2021 23:59	20	22.9	16	23.4	20	23.4
05-11-2021 00:00	20	22.9	15	23.4	20	23.4
Min Value	****	****	****	****	****	****
Max Value	****	****	****	****	****	****

End Of Report : From 04/11/2021 00:00:00 To 05/11/2021 00:00:00

ACTIVITY	NAME	SIGNATURE AND DATE
REVIEWED BY USER		
REVIEWED BY QA		