



Environmental Monitoring System

fdfddfdfdffff

DATA REPORT

STERILE EXIT CHANGE ROOMS (L4)

Date Time	STERILE PASSAGE (L4) wrt EXIT ROOM-1 (L4)	STERILE EXIT ROOM-1 (L4)	ASEPTIC EXIT ROOM-1 (L4) wrt EXIT ROOM-2 (L4)	STERILE EXIT ROOM-2 (L4)	ASEPTIC EXIT ROOM-2 (L4) wrt EXIT ROOM-3 (L4)	STERILE EXIT ROOM-3 (L4)
Date Time	DP Pa	°C TEMP	DP Pa	°C TEMP	DP Pa	°C TEMP
Alarm Low Limit	252	253.00	254	255.00	256	257.00
Set Value						
Alarm High Limit	379	380.00	381	382.00	383	384.00
24-05-2022 11:37	16	21.98	22	23.16	25	21.81
24-05-2022 12:07	19	21.96	27	23.11	30	21.87
24-05-2022 12:37	9	21.89	23	22.97	25	21.93
24-05-2022 13:07	11	21.91	27	22.95	21	21.89
24-05-2022 13:37	12	21.72	21	22.82	25	21.71
24-05-2022 14:07	8	21.81	21	22.80	25	21.65
24-05-2022 14:37	9	21.85	21	22.79	26	21.62
24-05-2022 15:07	9	21.88	21	22.76	27	21.58
24-05-2022 15:37	10	21.79	26	22.51	21	21.55
24-05-2022 16:07	9	21.83	21	22.62	25	21.45
24-05-2022 16:37	7	21.92	22	22.63	25	21.38
24-05-2022 17:07	7	22.11	21	22.74	23	21.53
24-05-2022 17:37	9	22.08	21	22.75	27	21.53
24-05-2022 18:07	9	22.13	24	22.78	27	21.54
24-05-2022 18:37	8	22.07	24	22.79	28	21.51
Min Value	9999	9999.00	9999	9999.00	9999	9999.00
Max Value	-9999	-9999.00	-9999	-9999.00	-9999	-9999.00

End Of Report : From 24/05/2022 11:37:33 To 25/05/2022 11:37:33

ACTIVITY	NAME	SIGNATURE AND DATE
REVIEWED BY USER		



Environmental Monitoring System

fdfddfdfdfdfff

DATA REPORT

STERILE EXIT CHANGE ROOMS (L4)

Date Time	STERILE PASSAGE (L4) wrt EXIT ROOM-1 (L4)	STERILE EXIT ROOM-1 (L4)	ASEPTIC EXIT ROOM-1 (L4) wrt EXIT ROOM-2 (L4)	STERILE EXIT ROOM-2 (L4)	ASEPTIC EXIT ROOM-2 (L4) wrt EXIT ROOM-3 (L4)	STERILE EXIT ROOM-3 (L4)
Date Time	DP Pa	°C TEMP	DP Pa	°C TEMP	DP Pa	°C TEMP

REVIEWED BY QA