



SOMERSET THERAPEUTICS LIMITED

DATA REPORT - SVP1 AND AMPOULE LINE EMS

WASHING AND STERILIZATION AREA

Date Time	Temperature	RH	Diffrential Pressure	Diffrential Pressure	Diffrential Pressure
DD-MM-YYYY HH:MM:SS	Washing and Sterilization Area (NMT 30°C)	Washing and Sterilization Area (NMT 80%)	Washing and Sterilization Area w.r.t Unit Preparation Room (NLT 6 Pa)	Washing and Sterilization Area w.r.t Ampoule Decartoning Room (NLT 12 Pa)	Washing and Sterilization Area w.r.t Injectable main corridor (NLT 12 Pa)
10-07-2022 12:09:00	17.6	77.6	49	22	46
10-07-2022 12:39:00	17.3	78.7	50	0	0
10-07-2022 13:09:00	17.5	81.9	50	0	0
10-07-2022 13:39:00	17.6	79.6	51	0	0
10-07-2022 14:09:00	17.5	79.6	51	1	0
10-07-2022 14:39:00	17.6	79.2	51	0	0
10-07-2022 15:09:00	19	78.5	0	0	0
10-07-2022 15:39:00	20.7	75.1	0	0	0
10-07-2022 16:09:00	21	75	0	0	0
10-07-2022 16:39:00	20.9	93.7	0	0	0
10-07-2022 17:09:00	21.8	96.7	0	0	0
10-07-2022 17:39:00	21.8	94.6	0	0	0
10-07-2022 18:09:00	21.7	94.2	0	0	0
10-07-2022 18:39:00	21.5	86.7	46	21	43
10-07-2022 19:09:00	18.9	77.6	46	21	44
10-07-2022 19:39:00	17.9	76.8	46	21	45
10-07-2022 20:09:00	17.7	77.5	48	21	41
10-07-2022 20:39:00	17.7	78.7	48	23	44
10-07-2022 21:09:00	17.9	77.5	47	21	45
10-07-2022 21:39:00	18	78.7	47	20	44
10-07-2022 22:09:00	18	78.2	45	19	42
10-07-2022 22:39:00	17.7	76.7	43	20	42
10-07-2022 23:09:00	17.6	76.6	46	18	43
10-07-2022 23:39:00	18.3	75.7	47	20	38

ACTIVITY	NAME	SIGNATURE AND DATE
REVIEWED BY USER		
REVIEWED BY QA		



SOMERSET THERAPEUTICS LIMITED

DATA REPORT - SVP1 AND AMPOULE LINE EMS

WASHING AND STERILIZATION AREA

Date Time	Temperature	RH	Diffrential Pressure	Diffrential Pressure	Diffrential Pressure
DD-MM-YYYY HH:MM:SS	Washing and Sterilization Area (NMT 30°C)	Washing and Sterilization Area (NMT 80%)	Washing and Sterilization Area w.r.t Unit Preparation Room (NLT 6 Pa)	Washing and Sterilization Area w.r.t Ampoule Decartoning Room (NLT 12 Pa)	Washing and Sterilization Area w.r.t Injectable main corridor (NLT 12 Pa)
11-07-2022 01:09:00	17.6	76.4	47	12	22
11-07-2022 01:39:00	17.3	77.2	47	20	41
11-07-2022 02:09:00	17.2	77	47	20	41
11-07-2022 02:39:00	17.2	76.8	47	20	39
11-07-2022 03:09:00	17.3	76.7	47	19	39
11-07-2022 03:39:00	17.4	76.7	44	18	38
11-07-2022 04:09:00	18	77.3	46	19	37
11-07-2022 04:39:00	17.7	76.1	46	19	38
11-07-2022 05:09:00	17.5	76	47	19	39
11-07-2022 05:39:00	17.4	76.4	46	19	39
11-07-2022 06:09:00	17.6	75.3	46	20	42
11-07-2022 06:39:00	17.8	78.2	48	18	42
11-07-2022 07:09:00	17.9	77.6	46	20	41
11-07-2022 07:39:00	17.9	77.6	45	20	42
11-07-2022 08:09:00	17.6	77.5	46	19	41
11-07-2022 08:39:00	17.6	78.7	47	17	33
11-07-2022 09:09:00	17.7	81.5	46	20	42
11-07-2022 09:39:00	17.8	80.4	46	19	40
11-07-2022 10:09:00	17.8	80.9	46	19	39
11-07-2022 10:39:00	18	78.6	46	17	37
11-07-2022 11:09:00	18.2	77.2	47	17	35
Min Value	17.2	75	0	0	0
Max Value	21.8	96.7	51	23	46

ACTIVITY	NAME	SIGNATURE AND DATE
REVIEWED BY USER		
REVIEWED BY QA		



SOMERSET THERAPEUTICS LIMITED

DATA REPORT - SVP1 AND AMPOULE LINE EMS

WASHING AND STERILIZATION AREA

Date Time	Temperature	RH	Diffrential Pressure	Diffrential Pressure	Diffrential Pressure
DD-MM-YYYY HH:MM:SS	Washing and Sterilization Area (NMT 30°C)	Washing and Sterilization Area (NMT 80%)	Washing and Sterilization Area w.r.t Unit Preparation Room (NLT 6 Pa)	Washing and Sterilization Area w.r.t Ampoule Decartoning Room (NLT 12 Pa)	Washing and Sterilization Area w.r.t Injectable main corridor (NLT 12 Pa)

ACTIVITY	NAME	SIGNATURE AND DATE
REVIEWED BY USER		
REVIEWED BY QA		