



SOMERSET THERAPEUTICS LIMITED

DATA REPORT - SVP1 AND AMPOULE LINE EMS

VIAL TUNNEL FILLING

Date Time	Temperature	RH	Diffrential Pressure	Diffrential Pressure	Diffrential Pressure
DD-MM-YYYY HH:MM:SS	Vial Tunnel Filling (NMT 25°C)	Vial Tunnel Filling (NMT 65%)	Vial Tunnel Filling w.r.t Sterile corridor (NLT 6 Pa)	Vial Tunnel Filling w.r.t Vial tunnel Washing (NLT 12 Pa)	Vial Tunnel Filling w.r.t Vial tunnel Sealing (NLT 12 Pa)
12-07-2022 15:00:00	21	66.6	1	115	134
12-07-2022 15:01:00	21	65.7	1	123	137
12-07-2022 15:02:00	21	66.9	0	121	136
12-07-2022 15:03:00	21	67.5	0	122	135
12-07-2022 15:04:00	21	65.9	1	123	135
12-07-2022 15:05:00	21	65.6	1	123	135
12-07-2022 15:06:00	21	67.8	0	126	136
12-07-2022 15:07:00	21	67.2	0	121	135
12-07-2022 15:08:00	21	65.6	0	119	49.2
12-07-2022 15:09:00	21	67.2	0	121	49.4
12-07-2022 15:10:00	21	68.2	4	118	132
12-07-2022 15:11:00	21	66.4	5	123	79
12-07-2022 15:12:00	21	66.2	10	90	86
12-07-2022 15:13:00	21	68.2	15	75	90
12-07-2022 15:14:00	21	68.1	15	77	91
12-07-2022 15:15:00	21	66	16	78	90
12-07-2022 15:16:00	21	66.4	16	78	90
12-07-2022 15:17:00	21	68.8	17	77	91
12-07-2022 15:18:00	21	67.7	14	75	89
12-07-2022 15:19:00	21	66.3	14	77	90
12-07-2022 15:20:00	21	67.3	15	76	91
12-07-2022 15:21:00	21	68.4	15	76	93
12-07-2022 15:22:00	21	66.9	14	75	93
12-07-2022 15:23:00	21	65.9	15	78	96

ACTIVITY	NAME	SIGNATURE AND DATE
REVIEWED BY USER		
REVIEWED BY QA		



SOMERSET THERAPEUTICS LIMITED

DATA REPORT - SVP1 AND AMPOULE LINE EMS

VIAL TUNNEL FILLING

Date Time	Temperature	RH	Diffrential Pressure	Diffrential Pressure	Diffrential Pressure
DD-MM-YYYY HH:MM:SS	Vial Tunnel Filling (NMT 25°C)	Vial Tunnel Filling (NMT 65%)	Vial Tunnel Filling w.r.t Sterile corridor (NLT 6 Pa)	Vial Tunnel Filling w.r.t Vial tunnel Washing (NLT 12 Pa)	Vial Tunnel Filling w.r.t Vial tunnel Sealing (NLT 12 Pa)
12-07-2022 15:24:00	21	67	17	76	91
12-07-2022 15:25:00	21	68.6	17	79	80
12-07-2022 15:26:00	21	67.2	12	79	82
12-07-2022 15:27:00	21	66.3	15	84	85
12-07-2022 15:28:00	21	67.1	17	79	84
12-07-2022 15:29:00	21	69	17	79	83
12-07-2022 15:30:00	21	68.1	12	75	75
Min Value	21	65.6	0	75	49.2
Max Value	21	69	17	126	137

End Of Report : From 12-07-2022 15:00:00 To 12-07-2022 15:30:00

ACTIVITY	NAME	SIGNATURE AND DATE
REVIEWED BY USER		
REVIEWED BY QA		