

SOMERSET THERAPEUTICS LIMITED

Ampoule Washing Area

${\bf Excursion Test Report}$

| Date Time | ems_svp1_amp_trh_03_rh | ems_svp1_amp_trh_03_temp | ems_svp1_amp_dp_15_dp |
|----------------------|------------------------|--------------------------|-----------------------|
| Excursion Low Limit | 5 | 6 | 3 |
| Excursion High Limit | 82 | 82 | 82 |
| 10-06-2022 12:05:00 | 69.8 | 19.4 | 83 |
| 11-06-2022 02:50:00 | 69.4 | 19 | 83 |
| 11-06-2022 04:05:00 | 69.4 | 18.8 | 84 |
| 11-06-2022 10:50:00 | 70.3 | 18.9 | 83 |

End Of Report: From 10-06-2022 11:50:55 To 11-06-2022 11:50:55

| ACTIVITY | NAME | SIGNATURE AND DATE |
|------------------|------|--------------------|
| REVIEWED BY USER | | |
| REVIEWED BY QA | | |