



Contractor's Material and Test Certificate for Underground Piping

PROCEDURE

Upon completion of work, inspection and tests shall be made by the contractor's representative and witnessed by an owner's representative. All defects shall be corrected and system left in service before contractor's personnel finally leave the job...

Property name Samson Warner Date 5/11/1975

Property address Occaecat iste commod

Plans

Accepted by approving authorities (names) Maxime fugiat eos

Address Eu rerum ab autem cu

Installation conforms to accepted plans

☒ Yes ☐ No

Equipment used is approved

☒ Yes ☐ No

If no, state deviations Velit eos ut debiti

Instructions

Has person in charge of fire equipment been instructed as to location of control valves and care and maintenance of this new equipment?

☒ Yes ☐ No

If no, explain

Quia distinctio Eu

Have copies of appropriate instructions and care and maintenance charts been left on premises?

☒ Yes ☐ No

If no, explain

Sit quisquam dignis

Location

Supplies buildings Dara Gardner

Underground pipes and joints

Pipe types and class Et distinctio Culpa

Type joint Voluptatem quo cons

Pipe conforms to Minus quae sed standard
sed e

☒ Yes ☐ No

Fittings conform to Similique sed standard
soluta

☒ Yes ☐ No

If no, explain Ullam dolores fugiat

Joints needing anchorage clamped, strapped, or blocked in accordance with
Nobis blanditiis quo standard

☒ Yes ☐ No

If no, explain Sit ea et rerum volu

Test description

Flushing: Flow the required rate until water is clear as indicated by no collection of foreign material in burlap bags at outlets such as hydrants and blow-offs. Flush in accordance with the requirements of 6.10.2.1.3.

Hydrostatic: All piping and attached appurtenances subjected to system working pressure shall be hydrostatically tested at 200 psi (13.8 bar) or 50 psi (3.4 bar) in excess of the system working pressure, whichever is greater, and shall maintain that pressure ± 5 psi (0.34 bar) for 2 hours.

Hydrostatic Testing Allowance: Where additional water is added to the system to maintain the test pressures required by 6.10.2.2.1, the amount of water shall be measured and shall not exceed the limits of the following equation (for metric equation, see 6.10.2.2.6):

$L =$

$SD\sqrt{P}$

148,000

L = testing allowance (makeup water), in gallons per hour

S = length of pipe tested, in feet

D = nominal diameter of the pipe, in inches

P = average test pressure during the hydrostatic test, in pounds per square inch (gauge)

Contractor's Material and Test Certificate for Underground Piping (continued)

Flushing tests	New underground piping flushed according to <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
	Excepture in recusan standard by (company)	
	If no, explain Ut et omnis commodi	
	How flushing flow was obtained	Through what type opening
	<input type="radio"/> Public water	<input type="radio"/> Hydrant butt
	<input type="radio"/> Tank or reservoir	<input type="radio"/> Open pipe
	<input checked="" type="radio"/> Fire pump	
	Lead-ins flushed according to <input type="checkbox"/> Yes <input type="checkbox"/> No	
	standard by (company)	
	If no, explain	
	How flushing flow was obtained	Through what type opening
	<input type="radio"/> Public water	<input type="radio"/> Y connection to flange and spigot
	<input type="radio"/> Tank or reservoir	<input type="radio"/> Open pipe
	<input type="radio"/> Fire pump	