

■ BIDPILOT AI — ELECTRICAL & EMERGENCY POWER BID PACKAGE

PROJECT: METRO CITY MEDICAL CENTER EXPANSION

Drawing Sheet: E-401 | Discipline: Electrical (CSI Division 26) | Addendum: Addendum #1 Revision

■■ VISION DIFF DETECTED CHANGE: Emergency Standby Diesel Generator Fuel Feed Piping Scope Add (+\$42,000 Cost Impact). Spec Sect

1. STANDBY POWER & SWITCHGEAR SCHEDULE

Tag ID	Equipment Description	Rating / Voltage	Fuel / Feed Type	CSI Code	PCO Status
GEN-1	Standby Diesel Generator #1	1,500 kW / 480V 3Ø	Dual-Wall Diesel Piping	26 32 13	Promoted PCO #04
GEN-2	Standby Diesel Generator #2	1,500 kW / 480V 3Ø	Dual-Wall Diesel Piping	26 32 13	Promoted PCO #04
ATS-1	Automatic Transfer Switch - Life Safety	2000A 4-Pole 480V	Bypass Isolation	26 36 23	Approved
MDS-1	Main Distribution Switchboard	4000A 480V 65kAIC	Copper Busbars (AA-8000)	26 24 13	Approved
PANEL-EM1	Emergency Critical Branch Panel	400A 208Y/120V	100% Solid Copper Wire	26 24 16	Approved

2. ELECTRICAL SPECIFICATION CITATIONS & MANDATES

- **Spec Section 26 05 19:** All branch circuits #10 AWG and smaller must use 100% solid copper conductors with THHN/THWN-2 90°C insulation.
- **Spec Section 26 24 13:** Main service entrance switchboards must have minimum 65kAIC short-circuit withstand rating and ground fault protection.
- **Spec Section 26 32 13:** Emergency generator exhaust must route through dual-chamber critical-grade silencers with seismic spring isolators.