DIRECTORATE OF FIRE & EMERGENCY SERVICES

STATE DISASTER MANAGEMENT & FIRE SAFETY ACADEMY

DIVISIONAL FIRE HEADQUARTERS, BHOPAL REGION

NO OBJECTION CERTIFICATE FOR FIRE SAFETY & LIFE HAZARD CLEARANCE

NOC Certificate Number: FS-NOC-2021-9920-ALT | **Dispatch No:** FSD/BPL/2025/1104
Date of Statutory Inspection: 08th April 2025 | **Date of Issuance:** 15th April 2025

Fire Safety Inspection Parameter	Certified Official Compliance Details
Institution Name & Campus:	Bhartiya Institute of Technology & Science Campus Address: Khajuri Kalan, Huzur, Bhopal - 462022
Issuing Authority:	**Chief Fire Officer (CFO), Bhopal Municipal Corporation**
Building Occupancy Classification:	Group B - Educational Building (College Campus)
Maximum Building Height:	**14.50 Meters** (G+3 Floors Laboratory & Academic Wing)
Installed Fire Protection Systems:	Wet Riser System, Yard Hydrants, ABC Type Extinguishers, Automatic Smoke Detectors, 50,000L Underground Static Water Tank, 10,000L Terrace Tank, Diesel Booster Pump (2280 LPM).
Emergency Exit & Staircase Width:	Two separate fire-escape staircases, minimum width 2.0 meters each, unobstructed corridor clearance.
Certificate Validity Period:	Valid from 15-04-2025 until **31st March 2027** *(Altered font metric / overlay)*
Statutory NBC 2016 Compliance:	**Suspected Digital Stamp Replacement / Splice**

STATUTORY CONDITIONS OF NOC:

1. All active fire fighting equipment must be maintained in operative condition at all times.
2. Mandatory mock fire drill and evacuation rehearsal must be executed every 6 months.
3. Any unauthorized structural alteration or vertical expansion without prior approval shall invalidate this certificate.
4. Application for renewal must be submitted 60 days prior to the expiration date.

[OFFICIAL FIRE SERVICE SEAL]
CHIEF FIRE OFFICER
EMERGENCY SERVICES
BHOPAL REGIONAL COMMAND

Chief Fire Officer (CFO)
Fire & Emergency Services
Municipal Corporation Bhopal
Official Clearance Code: **BPL-FIRE-SAFE-2027**