


Partial Discharge Report

Report Name
Date and Time 2025-10-13 14:58:32
Site Name
Site Location
Performed By
Phone
Email

Statistics
Total Images 1
Corona 1

**Partial Discharge Info**




Max. Level	15.4 dB
Discharge Level	Severe
Selected Frequency	19.9 ~ 49.9 kHz
Range	
Distance	16.0 m

Discharge Type

Corona	99%
Particle	0%
Surface	0%
Floating	0%

Image Information

Created	2025-10-12 12:50:26
File Name	HM20251012125026.pd
Device Model	AI76
Device Serial No.	EA2404668

PRPD**Signal****FFT****Text Note**