BrightFlow Plumbing Pty Ltd
Licensed plumbers | QBCC 000000 | 24/7 emergency

Tax Invoice INV-30981

Customer	Daniel Morrison, 14 Wattle Grove, Carindale QLD 4152
Attendance	12 October 2026, 8:25am - 9:40am
Job type	Emergency call-out

Findings: Braided flexible hose (cold supply, kitchen mixer) ruptured at the crimp ferrule. The hose was a 2019 install. Failure was sudden; no sign of prior slow leakage, staining or corrosion at the cabinet base before the event. Water mains had been isolated by owner.

Work completed: Replaced both hot and cold flexi hoses with stainless braided hoses, pressure-tested, checked under-sink for further leaks. Failed hose bagged and left with owner.

Recommendation: Resulting water damage to cabinetry and flooring should be assessed by a builder.

Description	Qty	Amount
Emergency call-out (business hours)	1	$180.00
Labour	1.25 hr	$165.00
Flexi hose 450mm stainless (x2)	2	$75.00

Total incl. GST	$420.00
Status	PAID - card, 12/10/2026