Quotation Q-2210 - Water damage repairs

Client	Daniel & Priya Morrison
Site	14 Wattle Grove, Carindale QLD 4152
Inspection date	14 October 2026
Valid	30 days

Inspection confirms water damage consistent with a single sudden escape of water from the kitchen sink supply. Moisture readings in the subfloor have returned to normal after drying. Cabinet carcasses (particleboard) at the sink and two adjoining base units have swollen and delaminated beyond repair. Approx. 14 m2 of 130mm spotted gum boards are cupped.

Scope item	Amount (AUD)
Remove and dispose damaged sink base + 2 base units	$620.00
Supply and install 3 matching base units (2-pac, colour matched)	$3,180.00
Remove/refit stone benchtop and reconnect sink and plumbing	$1,050.00
Replace 14 m2 spotted gum boards, sand and coat kitchen/dining (blend)	$3,240.00
Total incl. GST	$8,090.00