Direction "from"

Key	Value	Meaning
illumination	0 ... 1530 [lx], step 6	Illumination (linear)
motionDetected	false	PIR off
	true	PIR on
occupancyButton	pressed	Button pressed
	released	Button released
supplyVoltage	0 ... 5.1 [V], step 0.02	Supply voltage (linear)
temperature	-30 ... 50 [°C], step 0.314	Temperature (linear)