Ip representation:A5-09-0D

IP KEY	Valid range	Step size	Unit	IP Meaning
humidity	0...200	0.50	%	Measurement of Relative Humidity in %values 201...255 = invalid data
TVOC	0...200	0.50	%	relative VOC signal (index) 0 = clean air (calibration ambient) 200 = maximum polluted air values 201..255 = invalid data
temperature	0...250	0.20	C	Measurement of Temperature in linear values 251..255 = invalid data
CMF-T	0			Temperature out of Comfort Zone
	1			Temperature in Comfort Zone
CMF-rh	0			humidity out of Comfort Zone
	1			humidity in Comfort Zone
unused	1			always = 1
LrnBit	0			Teach-in telegram
	1			Data Telegram
IAQ	0			excellent Air Quality TVOC = 0...10%
	1			Good Air Quality, TVOC = 10,5....20%
	2			lightly polluted air, TVOC = 20,5....30%
	3			moderately polluted air, TVOC = 30,5...40%
	4			heavily polluted air; TVOC = 40,5...50%
	5			severely polluted air; TVOC = 50,5...70%
	6			extremely polluted air; TVOC > 70%
	7			invalid air quality