Direction "from"

Key	Value	Meaning
accelerationStatus	heartbeat	Heartbeat
	threshold1	Threshold 1 exceeded
	threshold2	Threshold 2 exceeded
accelerationX	-2.5 ... 2.5 [g], step 0.005	Acceleration X (linear)
	accelerationErrorX	Error
	overrange	Out of Range positive (>2.5g)
	underrange	Out of Range negative (<-2.5g)
accelerationY	-2.5 ... 2.5 [g], step 0.005	Acceleration Y (linear)
	accelerationErrorY	Error
	overrange	Out of Range positive (>2.5g)
	underrange	Out of Range negative (<-2.5g)
accelerationZ	-2.5 ... 2.5 [g], step 0.005	Acceleration Z (linear)
	accelerationErrorZ	Error
	overrange	Out of Range positive (>2.5g)
	underrange	Out of Range negative (<-2.5g)
humidity	0 ... 100 [%], step 0.5	Rel. Humidity (linear)
	humidityError	Error
illumination	0 ... 100000 [lx], step 1	Illumination (linear)
	illuminationError	Error
temperature	-40 ... 60 [°C], step 0.1	Temperature (linear)
	overrange	Out of Range positive (>60°)
	temperatureError	Error
	underrange	Out of Range negative (<-40°)