Ip representation:D2-14-53

IP KEY	Valid range	Step size	Unit	IP Meaning
Leak Detection	0			No leak detected
	1			Leak detected
	2			Leak sensor error
Past Leak Detection	0			No leak detected
	1			Leak detected

Ip representation:D2-14-54

IP KEY	Valid range	Step size	Unit	IP Meaning
Leak Detection	0			No leak detected
	1			Leak detected
	2			Leak sensor error
Past Leak Detection	0			No leak detected
	1			Leak detected
temperature	0...500	0.10	°C	Measurement of Temperature in linear
	511			Error
humidity	0...200	0.50	%	Rel. Humidity linear)
	254			Supported + Invalid
	255			notSupported