## Ip representation:D2-14-59

| IP KEY | Valid range | Step size | Unit | IP Meaning |
|---|---|---|---|---|
| Humidity | 0...200 | 0.50 | % | Measurement of Relative Humidity |
| | 255 | | | Sensor not present |
| Temperature | 0...800 | 0.10 | °C | Measurement of Temperature |
| | 1023 | | | Sensor not present |
| Particulate Matter 10um | 0...510 | 1 | ug/m3 | Measurement PM10 |
| | 511 | | | Sensor not present |
| Particulate Matter 2.5um | 0...510 | 1 | ug/m3 | Measurement PM2.5 |
| | 511 | | | Sensor not present |
| Particulate Matter 1um | 0...510 | 1 | ug/m3 | Measurement PM1 |
| | 511 | | | Sensor not present |
| HCHO | 0...2000 | 1 | ppb | Measurement HCHO |
| | 2047 | | | Sensor not present |
| TVOC | 0...65000 | 1 | ppb | Measurement of TVOC |
| | 65535 | | | Sensor not present |
| CO2 | 0...10000 | 1 | ppm | Measurement of CO2 |
| | 16383 | | | Sensor not present |