Ip representation:D2-14-5E

IP KEY	Valid range	Step size	Unit	IP Meaning
PPFD	0...1000000	0.01	umol/ m^2/s	Photosynthetic photon flux density
	1048574			Sensor Error
	1048575			Sensor Not Present
Barometer	0...650	1	hPa	Barometer linear
	1022			Sensor Error
	1023			Sensor Not Present
temperature	0...1000	0.10	C	Air Temperature
	1022			Sensor Error
	1023			Sensor Not Present
Co2	0...250	10	ppm	CO2 linear
	254			Sensor Error
	255			Sensor Not Present
humidity	0...100	1	%	Measurement of Relative Humidity in
	126			Sensor Error
	127			Sensor Not Present
VPD	0...100	1	hPa	Vapor Pressure Deficit
	126			Sensor Error
	127			Sensor Not Present