Ip representation:D2-34-10

IP KEY	Valid range	Step size	Unit	IP Meaning
channel	0...29	1	Ch	channel address
	30			All channels supported by the device
commandId	8			Temperature Controller Status Query
temperature	0...400	0.10	C	Current room temperature
	510			Not available
	511			Unknown
Setpoint	0...400	0.10	C	Currently active Setpoint
	510			Not available
	511			Unknown
Operation Mode	0			Off (deactivated)
	1			Temperature(s) unknown (Emergency mode)
	4			Normal operation
	15			Not available
HeatingCircuitState	0			Heating circuit off
	1			Heating circuit on
Temperature	0...400	0.10	C	Current room Temperature
	510			Not available
	511			Do not change
ChannelState	0			Channel disabled
	1			Channel enabled
ChannelNumbers	1...30	1		Number of channels of device
Heatingmode	0			cooling
	1			heating
Error	0			No error
	1			General error
	2			Actuating drive error
	15			Not available