สร้าง | BUILD TH Construction Check Sheet	KEY POINT CHECK SHEET · 9 key points **Reinforcement Works (Columns, Beams, Slabs)**	SHEET NO. DATE

Project ..... Area .....

Contractor ..... Drawing no. .....

No.	ITEMS TO BE CHECKED	CHECK · ACCEPTANCE	C	NC	REMARKS
1	**Mill certificate and marking on the bars**	• Grade [ ] as drawing • product standard mark present	☐	☐	
2	**Bar surface: no pitting rust, oil, mud or old mortar**	• New bars, no cracks • clean, free of oil, soil, mud and flaking rust (DPT 1103-64 cl. 5.1) • light surface rust acceptable	☐	☐	
3	**Size and number of main bars at every location**	As drawing	☐	☐	
4	**Spacing of links or mesh, including closer spacing near supports**	As drawing	☐	☐	
5	**Lap position and lap length; no lap where the drawing forbids**	• As drawing • if not stated: round bars 40 diameters (hooked) • deformed SD30 30, SD40 36, SD50 45 diameters • adjacent splices staggered about 1.00 m (DPT 1103-64 cl. 5.5.3 and 5.5.4.1)	☐	☐	
6	**Extra bars: column head, bent-up bars, around openings, dowels**	Complete per detail drawings	☐	☐	
7	**Concrete cover: size and spacing of spacers or chairs for top bars**	• As drawing • if not stated (not exposed): slabs and walls 20 mm, beams 30 mm, columns 35 mm • exposed to earth or weather 50/40 mm (DPT 1101-64 Table 13) • spacers not more than [ ] m apart	☐	☐	
8	**Bars and forms clean; temporary walkways not resting on bars**	Clean	☐	☐	
9	**Photos of all reinforcement with location label and date before approval**	Complete photo set	☐	☐	

C = Complies · NC = Not complying · Fill the blanks in the criteria from the drawings and the job specification before checking · For each NC item, take a photo and notify the contractor in writing · References: DPT 1103-64 Standard for Reinforcing Steel Works · TIS 24-2559 Steel Bars for Reinforced Concrete: Deformed Bars (the full list is in the professional edition)

By signing, each party and every inspector confirms that they have checked and accepted the criteria, the requirements and the inspection results recorded in this document by their own independent judgement and intent. This agreement binds only the parties who sign.

Inspected by	**Contractor, acknowledged**
Company	Company .....
Signature	Signature .....
Name	Name .....
Position	Position .....
Date	Date .....

What the professional edition BTH-F03-P adds

- All 22 items in 3 work stages
- 7 hold points (H)
- 2 languages on one sheet
- Tables for measured values
- Defect list and re-check
- Photo log for each item
- Sign-off by 3 parties, ready to attach to a payment claim

Professional edition and other sheets: https://srangbuild.github.io/srang-build/sheets.html

This standard document is a framework to help manage and record basic information only. It is not an engineering certification or specific legal advice. The choice of requirements and the approval of work are the direct responsibility of the parties and the licensed professional who supervises the project. · Free to share without changes