สร้าง | BUILD TH Construction Check Sheet	KEY POINT CHECK SHEET · 11 key points **Ceiling and Drywall Partition**	SHEET NO. DATE

Project ..... Area .....

Contractor ..... Drawing no. .....

No.	ITEMS TO BE CHECKED	CHECK · ACCEPTANCE	C	NC	REMARKS
1	**Ceiling and partition drawings, ceiling level, positions of access panels, luminaires and air outlets**	• Approved issue • match the site	☐	☐	
2	**Ceiling level and level line around the room**	As drawing [ ] m from finished floor	☐	☐	
3	**Spacing and fixing of hangers to the structure**	• Not more than [ ] m • fixed to the structure, not to pipes or cable trays	☐	☐	
4	**Spacing of main and cross framing**	Not more than [ ] cm per the maker's manual and drawing	☐	☐	
5	**Partition framing: stud spacing, fixing of top and bottom tracks**	• Spacing [ ] cm • firmly fixed • plumb	☐	☐	
6	**Services above the ceiling and in partitions inspected and tested (electrical, plumbing, air conditioning)**	All inspection records passed	☐	☐	
7	**Thermal or acoustic insulation**	• Type and thickness as drawing • full cover • no gap	☐	☐	
8	**Screw spacing; screw heads set just below the surface, paper not broken**	Not more than [ ] cm	☐	☐	
9	**Joint treatment: tape, full number of coats, sanded smooth**	• Per the maker's manual • tape line not visible	☐	☐	
10	**Ceiling flatness and level; partition plumb and flatness**	Deviation not more than [ ] mm in [ ] m	☐	☐	
11	**Cracks, joints and screw heads checked with raking light before painting**	No joint or screw head visible	☐	☐	

C = Complies · NC = Not complying · Fill the blanks in the criteria from the drawings and the job specification before checking · For each NC item, take a photo and notify the contractor in writing · References: TIS 219-2552 Gypsum Plasterboards (the full list is in the professional edition)

By signing, each party and every inspector confirms that they have checked and accepted the criteria, the requirements and the inspection results recorded in this document by their own independent judgement and intent. This agreement binds only the parties who sign.

Inspected by	**Contractor, acknowledged**
Company	Company .....
Signature	Signature .....
Name	Name .....
Position	Position .....
Date	Date .....

What the professional edition BTH-F13-P adds

- All 22 items in 5 work stages
- 4 hold points (H)
- 2 languages on one sheet
- Tables for measured values
- Defect list and re-check
- Photo log for each item
- Sign-off by 3 parties, ready to attach to a payment claim

Professional edition and other sheets: https://srangbuild.github.io/srang-build/sheets.html

This standard document is a framework to help manage and record basic information only. It is not an engineering certification or specific legal advice. The choice of requirements and the approval of work are the direct responsibility of the parties and the licensed professional who supervises the project. · Free to share without changes