สร้าง | BUILD TH Construction Check Sheet	KEY POINT CHECK SHEET · 12 key points **Doors, Windows, Aluminium and Glazing**	SHEET NO. DATE

Project ..... Area .....

Contractor ..... Drawing no. .....

Glass in locations at risk of impact or falling must be the type that the drawings and the law require. Follow the project drawings and specification.

No.	ITEMS TO BE CHECKED	CHECK · ACCEPTANCE	C	NC	REMARKS
1	**Door and window shop drawings: sizes, opening direction, glass type and hardware**	Approved issue	☐	☐	
2	**Glass type and thickness at each location (safety, laminated, insulating)**	• As drawing • glass carries the mark of its type	☐	☐	
3	**Opening size, plumb, square and sill level before installation**	Deviation not more than ☐ mm	☐	☐	
4	**Stiffener columns and lintels around the opening**	Provided as drawing	☐	☐	
5	**Frame fixing: anchor type and spacing**	• Spacing not more than ☐ cm • firmly fixed	☐	☐	
6	**Frame plumb, square and level; diagonals measured**	Diagonals differ by not more than ☐ mm	☐	☐	
7	**Gap filling around the frame and external sealant**	• Fully filled • sealant continuous	☐	☐	
8	**Sashes open and close smoothly, no binding, no drop; even gap around the sash**	Gap ☐ mm	☐	☐	
9	**Locks, handles, hinges, rollers, catches and anti-drop devices**	Every set works	☐	☐	
10	**Large or full-height glass carries visibility markings as required by the drawing**	Provided as drawing	☐	☐	
11	**Water spray test around frames and joints**	• Spray for ☐ min • no water inside	☐	☐	
12	**Sealant checked after curing, inside and outside**	Smooth, continuous, no crack, no gap	☐	☐	

C = Complies · NC = Not complying · Fill the blanks in the criteria from the drawings and the job specification before checking · For each NC item, take a photo and notify the contractor in writing · References: Drawings and specification Door and window details, specification and manufacturer's instructions (the full list is in the professional edition)

By signing, each party and every inspector confirms that they have checked and accepted the criteria, the requirements and the inspection results recorded in this document by their own independent judgement and intent. This agreement binds only the parties who sign.

Inspected by	**Contractor, acknowledged**
Company	Company .....
Signature	Signature .....
Name	Name .....
Position	Position .....
Date	Date .....

What the professional edition BTH-F15-P adds

- All 21 items in 4 work stages
- 3 hold points (H)
- 2 languages on one sheet
- Tables for measured values
- Defect list and re-check
- Photo log for each item
- Sign-off by 3 parties, ready to attach to a payment claim

Professional edition and other sheets: https://srangbuild.github.io/srang-build/sheets.html

This standard document is a framework to help manage and record basic information only. It is not an engineering certification or specific legal advice. The choice of requirements and the approval of work are the direct responsibility of the parties and the licensed professional who supervises the project. · Free to share without changes