

HILLSIDE TOWER - BLOCK C

Job No. PRJ-4471 SUBMITTAL REGISTER - SHEET 1 OF 2
Transmittal ref: TR-2026-0148 Issued: 09-Aug-2026

REF	ITEM	DESCRIPTION	DISCIPLINE	LOCATION	REV	STATUS
SUB-0001	GT-12	Grout Termination Unit, 50mm	Structural	Zone A	Rev C 31-Jul-2026	APPROVED
SUB-0002	GT-12	Grout Termination Unit, 50mm	Structural	Zone B	REV-C 31/07/2026	APPROVED
SUB-0003	VLV-22	Isolation Valve, DN50 PN16	Mechanical	Zone B	Rev. C 2026-07-28	APPROVED
SUB-0004	AHU-04	Air Handling Unit, 4000 CFM	Mechanical	Zone C	D 28-Jul-2026	APPROVED
SUB-0005	PNL-08	Distribution Panel, 400A	Electrical	Zone C	Rev B 09-Aug-2026	PENDING
SUB-0006	DMP-15	Fire Damper, 600x400	Mechanical	-	Rev A 12-Jul-2026	APPROVED
SUB-0007	VLV-22	Isolation Valve, DN50 PN16	Mechanical	Zone D	Rev C 28-Jul-2026	APPROVED
SUB-0008	GT-I2	Grout Termination Unit, 50mm	Structural	Zone D	Rev C 31-Jul-2026	APPROVED

NOTES / TRANSMITTAL REMARKS

- SUB-0013 (GT-12 Rev B, Zone A) is SUPERSEDED BY SUB-0001 Rev C dated 31-Jul-2026.
Rev B units are not to be installed in Zone A. Any already fitted to be removed.
- SUB-0005 remains PENDING consultant approval. Do not release for installation.
- SUB-0006 zone allocation to be confirmed by the mechanical coordinator.
- Issued for construction unless marked otherwise above.