

HILLSIDE TOWER - BLOCK C

Job No. PRJ-4471 SUBMITTAL REGISTER - SHEET 2 OF 2
Transmittal ref: TR-2026-0149 Issued: 10-Aug-2026

REF	ITEM	DESCRIPTION	DISCIPLINE	LOCATION	REV	STATUS
SUB-0011	AHU-04	Air Handling Unit, 4000 CFM	Mechanical	Zone A	Rev D 28-Jul-2026	APPROVED
SUB-0012	AHU-04	Air Handling Unit, 4000 CFM	Mechanical	Zone B	Rev D 28-Jul-2026	APPROVED
SUB-0013	GT-12	Grout Termination Unit, 50mm	Structural	Zone A	Rev B 04-Jun-2026	APPROVED
SUB-0014	PNL-08	Distribution Panel, 400A	Electrical	Zone D	Rev C 01-Aug-2026	APPROVED
SUB-0015	DMP-15	Fire Damper, 600x400	Mechanical	Zone C	Rev B 22-Jul-2026	REJECTED

NOTES / TRANSMITTAL REMARKS

- SUB-0015 REJECTED - damper rating does not meet the 90 minute requirement.
Resubmission required. Nothing to be installed against this reference.
- AHU-04 Rev D supersedes Rev C across all zones.