

Specification Modbus TCP Controller Series 400

Baud rate	Tcp Port	502
Parity	DHCP	
Stop bit	Hostname	
Modbus address	Protokoll	Modbus TCP

Data point	ParaID	SubID	Modbus adress	READ	WRITE	Min	Max	Comment
			dezimal					
Active actual value	2000	0	100	x		-	-	[° C], in tenths of a degree
Temperature Charge zone	2000	1	101	x		-	-	[° C], in tenths of a degree
Temperature cooling zone	2000	2	102	x		-	-	[° C], in tenths of a degree
Temperature zone 1	2000	3	103	x		-	-	[° C], in tenths of a degree
Temperature zone 2	2000	4	104	x		-	-	[° C], in tenths of a degree
Temperature zone 3	2000	5	105	x		-	-	[° C], in tenths of a degree
Temperature zone 4	2000	6	106	x		-	-	[° C], in tenths of a degree
Temperature Docu zone 1	2000	7	107	x		-	-	[° C], in tenths of a degree
Temperature Docu zone 2	2000	8	108	x		-	-	[° C], in tenths of a degree
Temperature Docu zone 3	2000	9	109	x		-	-	[° C], in tenths of a degree
Temperature Docu zone 4	2000	10	110	x		-	-	[° C], in tenths of a degree
Set value program	2001	0	111	x		-	-	[° C], in tenths of a degree
reserve	2001	1	112	x		-	-	[° C], in tenths of a degree
Set value charge	2001	2	113	x		-	-	[° C], in tenths of a degree
Set valu cooling thermocouple	2001	3	114	x		-	-	[° C], in tenths of a degree
Set value zone 1	2001	4	115	x		-	-	[° C], in tenths of a degree
Set value zone 2	2001	5	116	x		-	-	[° C], in tenths of a degree
Set value zone 3	2001	6	117	x		-	-	[° C], in tenths of a degree
Set value zone 4	2001	7	118	x		-	-	[° C], in tenths of a degree
Power Master	2002	0	119	x		-	-	[%], in tenths of a percent
Power cooling	2002	1	120	x		-	-	[%], in tenths of a percent
Power zone 1	2002	2	121	x		-	-	[%], in tenths of a percent
Power zone 2	2002	3	122	x		-	-	[%], in tenths of a percent
Power zone 3	2002	4	123	x		-	-	[%], in tenths of a percent
Power zone 4	2002	5	124	x		-	-	[%], in tenths of a percent
Status	411	0	125	x		-	-	0=Off,1=Wait,2=Run,3=Pause,4=End,6=Error
Program no	2003	0	126	x		-	-	-
Segment no	2004	0	127	x		-	-	-
Remaining time	415	0	128+129	x		-	-	32Bit, 125=Low Word,126=High Word
Extra relais	414	0	130	x		-	-	Bit field
Alarm 1 Status	860	0	131	x		-	-	-
Alarm 2 Status	860	1	132	x		-	-	-
Warnings	161	0	133+134	x		-	-	Bit field,32Bit, 130=Low Word,131=High Word
Actual error	170	0	135	x		-	-	-
Controller Type	257	0	136	x		-	-	0=B400,1=B410,2=C440,3=C450,4=P470,5=P48C
Maximum Temperature	600	0	137	x		-	-	[° C]
Serial no	2005	0-9	138-147	x		-	-	ASCII string
Controller command	428	0	148		x	1	3	1=Start,2=Stop,3=Pause
Programm no. command	425	0	149		x	0	50	-
Segment jump command	426	0	150		x	-40	40	-

Warnings		
Bit	Wert	Beschreibung
0	1	Gardient error
1	2	No control parameters
2	4	TC charge defect
3	8	TC cooling defect
4	16	TC Docu defect
5	32	Resart after power failure
6	64	Alarm 1 band alarm
7	128	Alarm 1 min
8	256	Alarm 1 max
9	512	Alarm 2 band alarm
10	1024	Alarm 2 min
11	2048	Alarm 2 max
12	4096	Alarm 1 E1
13	8192	Alarm 1 E2
14	16384	Alarm 2 E1
15	32768	Alarm 2 E2
16	65536	No USB plugged
17	131072	Import error+

Current error		
Display	ID+Sub-ID	
257	01-01	
258	01-02	
513	02-01	
514	02-02	
515	02-03	
516	02-04	
517	02-05	
518	02-06	
519	02-07	
769	03-01	
770	03-02	
771	03-03	
772	03-04	
773	03-05	
774	03-06	
1025	04-01	
1026	04-02	
1027	04-03	
1028	04-04	
1029	04-05	