

CERTIFICATE OF ELECTRICAL COMPLIANCE

AS/NZS 3000:2018 Wiring Rules

Certificate No: EC-2024-8945

Issue Date: 25 September 2024

Property: 123 Sunset Boulevard, Sydney NSW 2000

Owner: John & Mary Smith

Builder: ABC Construction Pty Ltd

ELECTRICAL WORK COMPLETED:

Complete electrical installation for new two-storey dwelling including:

- Main switchboard with RCD protection
- Power circuits (20x), Lighting circuits (12x)
- Power points (45x), Light switches (28x), Light fittings (32x)
- Hardwired smoke alarms interconnected (6x)
- Hot water system connection, Oven/cooktop circuits

TEST RESULTS:

Test	Result	Standard
Insulation Resistance	>100 MΩ	>1 MΩ
Earth Continuity	<0.5 Ω	<1 Ω
RCD Trip Time (30mA)	18ms	<300ms
Polarity	Correct	Correct

DECLARATION:

I certify that the electrical installation work detailed above has been carried out in accordance with AS/NZS 3000:2018 and is safe to connect and use.

Licensed Electrician: David Patterson

License Number: EL-123456

Company: Bright Spark Electrical Pty Ltd

Signature: _D. Patterson_

Date: 25 September 2024