

PLUMBING COMPLIANCE CERTIFICATE

AS/NZS 3500 Plumbing and Drainage Standards

Certificate No: PC-2024-7823

Issue Date: 28 September 2024

Property: 123 Sunset Boulevard, Sydney NSW 2000

Owner: John & Mary Smith

PLUMBING WORK COMPLETED:

Complete plumbing installation including:

- Cold water supply system (copper & PEX)
- Hot water system - 315L electric storage
- Sanitary drainage (100mm & 150mm PVC)
- Stormwater drainage connected to Council system
- Fixtures: 3x toilets, 3x basins, 2x showers, 1x bath, 1x kitchen sink
- Backflow prevention devices installed

PRESSURE TEST RESULTS:

Cold water system: Tested 24 hours @ 1500kPa - PASS

Hot water system: Tested 24 hours @ 1000kPa - PASS

Drainage system: Water test all fixtures - PASS

CERTIFICATION:

I certify that the plumbing work detailed above complies with AS/NZS 3500 and has been installed in a safe and workmanlike manner.

Licensed Plumber: Robert Chen

License Number: PL-234567

Company: John's Plumbing Services Pty Ltd

Signature: _R. Chen_

Date: 28 September 2024