SUB-DIVISION WATER TESTING LABORATORY
RWS&S SUB-DIVISION, CHAMPUA

At/PO –Champua, Dist-Kendujhargada
Odisha, Pin: 758041
Email: labrwsschchampua@gmail.com

DRINKING WATER ANALYSIS REPORT

Lab Ref. No. 05/2026

Dated 07.09.2026

To

The Principal
Kalinga Model Residential School, Kulam
At- Kulam, PO - Deojhar, Dist Keonjhar, Odisha 758038
Sample Receive Date -02.09.2026

Test Result

Test started on-02.09.2026			Test completed on-05.09.2026		
				Requirements IS:10500:2012	
Sl. No.	Name of the Parameters	Unit	Results obtained	Acceptable Limit	Permissible Limit in absence of alternate source
1	Temperature	°C	26.1	-------	-------
2	pH		6.88	6.50-8.50	No relaxation
3	Turbidity	NTU	0.16	1.00	5.00
4	TDS	mg/l	283	500	2000
5	Chloride	mg/l	16	250	1000
6	T.Alkalinity as CaCO3	mg/l	220	200	600
7	T.Hardness as CaCO3	mg/l	284	200	600
8	Calcium (as Ca)	mg/l	8.02	75	200
9	Magnesium (as Mg)	mg/l	64.15	30	100
10	Fluoride	mg/l	0.14	1.0	1.5
11	Iron	mg/l	0.12	0.30	1.0
12	Elect. Conductivity	uScm	435.4	1000	1000
13	Total Coliform	MPN/100 ml	0	0	0
14	E. Coli	MPN/100 ml	0	0	0

Note: As per above parameters tested water is potable

Information on Test Report:

Results relates only to sample received in the Laboratory.

07/09/2026

Lab Chemist
Sub-Divisional Water Testing Laboratory
RWS&S Sub-Division, Champua

---------- End of Report----------