

## NTPC FGD Operations Guide

Flue Gas Desulfurization (FGD) removes sulfur dioxide from exhaust gases of fossil-fuel power plants.

NTPC uses wet limestone FGD systems at several coal-based stations.

Key operating parameters:

- Limestone slurry concentration: 15-20 percent
- pH range in absorber: 5.2 to 6.0
- Gypsum purity target: above 90 percent

Routine checks include slurry density monitoring, mist eliminator inspection, and pump vibration analysis.

Operators must log absorber inlet and outlet SO<sub>2</sub> readings every shift.

Emergency shutdown is required if absorber pH drops below 4.5 or if slurry recirculation pumps fail.

Contact the plant control room immediately for any FGD trip event.