Δ

Table 6A

Maximum number of 600 V thermoset insulated conductors without a jacket, Types R90, RW75, RW90, and RPV90, of one size in trade sizes of conduit or tubing

[See Rule 12-910 5) and Appendix B.]

| Conductor stze, AWG or kcmil | Size of condult or tubing | | | | | | | | | | | | | |
|------------------------------------|---------------------------|----|----|----|----|----|-----|-----|-----|-----|-----|-----|-----|-----|
| | 16 | 21 | 27 | 35 | 41 | 53 | 63 | 78 | 91 | 103 | 116 | 129 | 155 | 200 |
| 14 | 5 | 11 | 21 | 33 | 49 | 89 | 132 | 200 | 200 | 200 | 200 | 200 | 200 | 200 |
| 12 | 3 | 9 | 16 | 26 | 37 | 68 | 101 | 155 | 200 | 200 | 200 | 200 | 200 | 200 |
| 10 | 2 | 6 | 12 | 19 | 27 | 50 | 75 | 114 | 156 | 200 | 200 | 200 | 200 | 200 |
| 8 | 1 | 3 | 6 | 10 | 15 | 28 | 41 | 63 | 87 | 111 | 144 | 176 | 200 | 200 |
| 6 | 1 | 2 | 5 | 7 | 11 | 20 | 31 | 47 | 64 | 82 | 107 | 131 | 185 | 200 |
| 4 | 1 | 1 | 3 | 5 | 8 | 15 | 22 | 34 | 46 | 60 | 77 | 94 | 134 | 200 |
| 3 | 0 | 1 | 3 | 4 | 7 | 12 | 19 | 29 | 39 | 50 | 65 | 80 | 113 | 200 |
| 2 | 0 | 1 | 2 | 4 | 5 | 10 | 15 | 24 | 33 | 42 | 55 | 67 | 95 | 169 |
| 1 | 0 | 1 | 1 | 3 | 4 | 8 | 11 | 18 | 24 | 31 | 41 | 50 | 71 | 126 |
| 1/0 | 0 | 1 | 1 | 1 | 3 | 6 | 9 | 15 | 20 | 26 | 34 | 42 | 59 | 105 |
| 2/0 | 0 | 0 | 1 | 1 | 3 | 5 | 8 | 12 | 17 | 22 | 28 | 35 | 49 | 88 |
| 3/0 | 0 | 0 | 1 | 1 | 1 | 4 | 6 | 10 | 14 | 18 | 23 | 29 | 41 | 73 |
| 4/0 | 0 | 0 | 1 | 1 | 1 | 3 | 5 | 8 | 11 | 15 | 19 | 24 | 34 | 60 |
| 250 | 0 | 0 | 1 | 1 | 1 | 3 | 4 | 7 | 9 | 12 | 16 | 19 | 27 | 49 |
| 300 | 0 | 0 | 0 | 1 | 1 | 2 | 4 | 6 | 8 | 10 | 13 | 17 | 24 | 42 |
| 350 | 0 | 0 | 0 | 1 | 1 | 1 | 3 | 5 | 7 | 9 | 12 | 15 | 21 | 37 |
| 400 | 0 | 0 | 0 | 1 | 1 | 1 | 3 | 4 | 6 | 8 | 10 | 13 | 18 | 33 |
| 450 | 0 | 0 | 0 | 0 | 1 | 1 | 2 | 4 | 5 | 7 | 9 | 12 | 17 | 30 |
| 500 | 0 | 0 | 0 | 0 | 1 | 1 | 2 | 3 | 5 | 6 | 9 | 11 | 15 | 27 |