

INSULATION CERTIFICATE



This form must be filled out and posted to comply with building code requirements.
Meets IRC Sections N1101.3, N1101.41, and N1101.8 requirements.

The following spray polyurethane foam product(s) has/have been installed:

- ☒ THERMA-LOK | 500EZ ☐ THERMA-LOK | 500MAX ☐ THERMA-SHIELD | 2000
☐ THERMA-SHIELD | 2002 ☐ THERMA-SHIELD | 2003

Consult International Building Code, Chapter 26-Plastic and International Residential Code (IRC) R314 Foam Plastics for specific requirements. The spray polyurethane foam insulation system(s) has/have been installed in accordance with manufacturer's processing guidelines to provide a thermal resistance of the following:

Area Insulated	Aged R-Value	Thickness*
Attic Area 1144 sqft	R- 30 At	8.25 inches
Sloped Ceilings	R- At	inches
Walls (Location):	R- At	inches
Walls (Location):	R- At	inches
Floors (over an unheated crawl space)	R- At	inches
Crawl Space Perimeter	R- At	inches
Basement Exterior Walls	R- At	inches
Other (Location):	R- At	inches

A list of limitations for the space including the following: Entry to the space is only to service utilities and no storage is permitted. The hatch shall remain closed at all times except for when servicing of utilities is required. No locks or latches that would prevent the hatch from opening freely may be added at the hatch. FIRE SAFETY WARNING: If hot work (welding/cutting) is required to be performed, all necessary procedures, precautions and limitations must be observed in accordance with OSHA 1926, Subpart J, Standard 1926.352 requirements for hot work performed in vicinity of combustible materials. Notification that the space has been designed and constructed/installed as an unvented attic assembly; introduction of any penetrations to the exterior or alterations to the insulation shall be designed by a registered design professional. The design of the change shall be submitted to the local code official for approval, as required by the local jurisdiction. Unvented attics shall conform with IBC Section 1202.3 or IRC Section R806.5. The insulation may be left exposed to the attic without a prescriptive ignition barrier or an intumescent coating. For items penetrating the roof deck or walls, such as skylight wells or vents, the annular space must be covered with a minimum of 3 inches of insulation.

*Nominal thicknesses are representative of field, spray-applied foam material

Jobsite Address: 3316 W Nassau Street Tampa, FL, 33607

Date of Insulation: 11/12/2025

Building Contractor:

Insulation Contractor: Adonys Rodriguez

Insulation Contractor Phone: 786-423-8752

Installed By: Adonys Rodriguez

INSULATION CERTIFICATE - DO NOT REMOVE
Please Post Near Electrical Panel