



**GOVERNMENT OF TELANGANA**  
**FIRE, DISASTER RESPONSE, EMERGENCY & CIVIL DEFENCE DEPARTMENT**



|  |   |
|--|---|
| From<br>The District fire officer,<br><br>Rangareddy District. | To,<br>Appala Naidu Nalla,<br>Sri Sathya Sai Grammar High School Temple Hills Colony,<br>ChevellaRR District, |
|--|---|

Ack. No. **572480002025** Dated: **14/05/2025**

|      |   |
|------|---|
| Sir, |   |
| Sub: | Telangana Fire, Disaster Response,<br>Emergency & Civil Defence Department<br>—Rangareddy District. Renewal of No<br>Objection Certificate for Occupancy to the<br>Non Multi storeyed Building of <b>Sri<br/>Sathya Sai Grammar High School, Sy<br/>no 34/2 Chevella Village and mandal /-<br/>Chevella/Chevella/Rangareddy , –</b><br>Regarding. |



|      |  |
|------|--|
| Ref: | 1. Acknowledgement No <b>572480002025</b><br>2. This Office NOC for Occupancy Ack/RC No. <b>429/ADFO-RR2012</b><br>dt. <b>14/05/2025</b><br>3. Non Multi storeyed Building Inspection Committee Report,.<br>Ack. No. <b>572480002025</b> , dt. <b>14/05/2025</b> |
|------|--|

\*\*\*\*\*


- 1) The Non Multi storeyed Building Inspection committee, vide reference cited (3) has inspected the Non Multi storeyed Building of **Sri Sathya Sai Grammar High School, Sy no 34/2 Chevella Village and mandal /- Chevella/Chevella/Rangareddy**
- 2) The above said building was issued was issued No Objection certificate vide reference cited (2) for Non Multi storeyed Building with **1 Ground, 1 Floors**, with a height of **7.40** Meters for **EDUCATIONAL B-1 Schools up to senior secondary level** Occupancy .
- 3) Now the Builder/Authorized person has requested to issue Renewal of No Objection Certificate for Occupancy to the Non Multi storeyed Building with **1 Ground, 1 Floors**, with a height of **7.40** Meters for **EDUCATIONAL B-1 Schools up to senior secondary level** Occupancy

4) Open Spaces: The builder provided the following open spaces all around the building.

| Sl.No    | Side                            | Open spaces as per Noc occupancy | Open spaces provided now |
|----------|---------------------------------|----------------------------------|--------------------------|
| a 1      | North                           | 6.00                             | 6.00                     |
| 2        | South                           | 6.00                             | 6.00                     |
| 3        | East                            | 6.00                             | 6.00                     |
| 4        | West                            | 6.00                             | 7.35                     |
| b Sl. No | Gate Width As per Occupancy NOC | as per Noc occupancy             | provided now             |
| 1        | Entry gate width                | 6.00                             | 6                        |
| 2        | Entry Gate Head Clearance       | 5.00                             | 5                        |
| 3        | Exit Gate Width                 | 6.00                             | 6                        |
| 4        | Exit Gate Head Clearance        | 5.00                             | 5.00                     |

5) Travel Distance

| Sl. No. | Item / Description  | as per Noc occupancy | provided now |
|---------|---|----------------------|--------------|
| 1       | Farthest point ( Most Remote Point) With in a storey or a mezzanine floor to the door to an Exit.                                       | 27.00                | 27.00        |
| 2       | The Dead end of the corridor length in exit access. ( 6 mtrs for Educational, Institutional and Assembly, 15mtrs for other Occupancies) | 3.00                 | 3.00         |



**GOVERNMENT OF TELANGANA**  
**FIRE, DISASTER RESPONSE, EMERGENCY & CIVIL DEFENCE DEPARTMENT**



6) Stair Cases (As per Occupancy NOC) :

| Sl.no. | Type of staircases  | Total width | No of staircases | Floors from | Floors to |
|--------|---------------------|-------------|------------------|-------------|-----------|
| 1      | Internal staircases | 1.30        | 4                | Ground      | 1st Floor |

7) Means of Escape Floor Wise Details :

| Sl.no | Floor type   | Buil-up Area in Sq.Mtrs | Type of Occupancy                                       | Occupant Load | Means of escape required as per Occupancy NOC | Means escape available now |
|-------|--------------|-------------------------|---|---------------|---|----------------------------|
| 1     | Ground       | 2184.00                 | EDUCATIONAL B-1<br>Schools up to senior secondary level | 520.00        | 5.20  | 5.20                       |
| 2     | 1st Floor    | 2098.00                 | EDUCATIONAL B-1<br>Schools up to senior secondary level | 520.00        | 5.20  | 5.20                       |
|       | <b>Total</b> | <b>4282.00</b>          |   |               |   |                            |

8) Fire Shaft as per Occupancy NOC:

9) Floor Wise details of Fire Fighting Installations:

| Sl.no | Floor Details | Fire Extinguisher | Hose Reel | Automatic Sprinklers System | Manually Operated Electronic Fire Alarm System | Automatic detection and alarm system |
|-------|---------------|-------------------|-----------|-----------------------------|--|--------------------------------------|
| 1     | Ground        | 11.00             | 3.00      | 0.00                        | 0.00   | 0.00                                 |
| 2     | 1st Floor     | 11.00             | 3.00      | 0.00                        | 0.00   | 0.00                                 |

10) Fire Fighting Installations As per Occupancy NOC :

| Fire Fighting System. | Required As per Occupancy NOC | Provided |
|-----------------------|-------------------------------|----------|
| Fire Extinguishers    | 22                            | 22       |

11). The Non Multi storeyed Building Inspection Committee have reported that the Management has provided the Fire Safety Measures and there are no deficiencies.

12. **Remarks :**

All fire and life safety provisions are met and as per the recommendations of the inspection committee the application is approved.

13) In view of the above and as per recommendations of the Non Multi storeyed building inspection Committee, the Renewal of No Objection Certificate for occupancy is issued to Non Multi storeyed Building with **Sri Sathya Sai Grammar High School, Sy no 34/2 Chevella Village and mandal /-Chevella/Chevella/Rangareddy** with a height of **7.40 Meters** for **EDUCATIONAL B-1 Schools up to senior secondary level** Occupancy subject to the following conditions

| Sl No | Builder and Management Body  | Occupant  | Management Body and fire and security personnel   |
|-------|--|---|---|
| 1     | -a) All the fire protection arrangements shall be maintained in good condition as seen during inspection.<br>-b) Do's and Don'ts in case of fire shall be prominently displayed in entire building | All the escape/exit routes shall not be kept locked/blocked or encroached | All the occupants must know the correct method of operation of the fire fighting systems installed. |
| 2     | Any loss of life or property due to non-functioning of fire safety measures and  | All occupants shall be trained to operate the fire safety                 | Mock drills should be conducted once in 3 months for initial two years. Thereafter, once            |




**GOVERNMENT OF TELANGANA**  
**FIRE, DISASTER RESPONSE, EMERGENCY & CIVIL DEFENCE DEPARTMENT**



|   |   |  |   |
|---|---|--|---|
|   | other installations shall be the responsibility of the management.  | equipment during emergency.  | in every 6 months.  |
| 3 | Addition / alteration, if any in the building may be verified by building authority.                      | Mock drills should be conducted once in 3 months for initial two years. Thereafter, once in every 6 months.        | All security personnel shall be trained to operate the fire safety equipment during emergency and guiding the occupants in safe evacuation. Call the fire Brigade by dialing 101. |
| 4 | This No objection Certificate for occupancy is valid for Five year from the date of issue of this letter. | Raise the alarm if the fire cannot be controlled, evacuate the area completely at once from the nearest safe exit. | Attack the fire using available fire equipment only if you feel capable of controlling it. If not, take all steps to isolate the area by closing doors and windows.               |

This Renewal of No Objection Certificate for Occupancy is valid for Five years from the date of issue of this letter. It is the responsibility of the builder to apply for renewal NOC, duly remitting the user charges as per G.O. Ms. No. 71, Home (Prison – A) Department, dated 01-04-2010, two months before expiry of this No Objection Certificate.

  
 Signed By : Mr. Shaik Khaja Karimulla  
 Designation : District Fire Officer , Ranga Reddy  
 Date : 14-05-2025  
 Rangareddy District.

Copies to:  
 i) The Management  
 ii) Non Multi storeyed Building Inspection Committee  
 iii) Copy submitted to Regional Fire officer  
 iv) Copy submitted to DG fire services

**"THIS IS COMPUTER GENERATED DOCUMENT AND DO NOT REQUIRE ANY STAMP OR SIGNATURE"**