

Code citations (values and references only)

These are the code rows the customer supplies; the product page checks the ones that are product facts and marks the rest as depending on the installation.

Ref	Source	Requirement (paraphrased)	Value	Applies to
C-1	NFPA 10 (2022), Table 6.2.1.1	Light (low) hazard occupancy: minimum rated single extinguisher; maximum travel distance	2-A; 75 ft	Extinguisher rating (product fact)
C-2	NFPA 10 (2022), Chapter 5 (Class C hazards)	Extinguishers for fires involving energized electrical equipment carry a Class C rating	C	Extinguisher rating (product fact)
C-3	NFPA 10 (2022), 6.1.3.8.1	Extinguishers with gross weight $\leq$ 40 lb: top of extinguisher not more than 5 ft above the floor	60 in	Installation, not a product fact
C-4	2010 ADA Standards, 307.2	Objects with leading edges between 27 in and 80 in above the floor protrude no more than 4 in into the circulation path	4 in, given installed height and location	Installation context; the schedule calls for recessed cabinets where wall depth allows

Hazard classification for C-1 (light hazard) is the customer's determination for the data hall and support rooms. The governing edition and the authority having jurisdiction decide applicability; the page reports how the product compares with the row as supplied.