

Sheet A-601 — Fire Extinguisher Schedule (excerpt)

Project: · Level 1 · Issue:

Tag	Item	Rating (min)	Qty	Unit	Locations	Mounting
FE-1	Clean-agent portable fire extinguisher per Section 10 44 00, 2.3	2-A:10-B:C	6	EA	E101, E102 (electrical); 1M1 (MDF); 1I1, 1I2 (IDF); data hall entry	In FEC-1
FEC-1	Fire-protection cabinet per Section 10 44 00, 2.2, recessed where wall depth allows, otherwise semirecessed	—	6	EA	At each FE-1	Recessed / semirecessed

Notes: 1. Verify final locations with the life-safety plan, sheet LS-101. 2. Mount so the top of the extinguisher is not more than 60 in above finished floor. 3. Quantities on this sheet govern over any count implied elsewhere.