

## Code citations used in the demo (values and references only)

Prepared for the Westgate Data Center demo. These are the code rows the customer supplies; the product page checks the ones that are product facts and marks the rest as depending on the installation.

| Ref | Source                                      | Requirement (paraphrased)                                                                                               | Value                                     | Applies to                                                                             |
|-----|---------------------------------------------|-------------------------------------------------------------------------------------------------------------------------|-------------------------------------------|----------------------------------------------------------------------------------------|
| C-1 | NFPA 10 (2022), Table 6.2.1.1               | Light (low) hazard occupancy: minimum rated single extinguisher; maximum travel distance                                | 2-A; 75 ft                                | Extinguisher rating (product fact)                                                     |
| C-2 | NFPA 10 (2022), Chapter 5 (Class C hazards) | Extinguishers for fires involving energized electrical equipment carry a Class C rating                                 | C                                         | Extinguisher rating (product fact)                                                     |
| C-3 | NFPA 10 (2022), 6.1.3.8.1                   | Extinguishers with gross weight $\leq$ 40 lb: top of extinguisher not more than 5 ft above the floor                    | 60 in                                     | Installation, not a product fact                                                       |
| C-4 | 2010 ADA Standards, 307.2                   | Objects with leading edges between 27 in and 80 in above the floor protrude no more than 4 in into the circulation path | 4 in, given installed height and location | Installation context; the schedule calls for recessed cabinets where wall depth allows |

Hazard classification for C-1 (light hazard) is the customer's determination for the data hall and support rooms. The governing edition and the authority having jurisdiction decide applicability; the page reports how the product compares with the row as supplied.